



RETROFIT OF CO₂ CAPTURE TO NATURAL GAS COMBINED CYCLE POWER PLANTS

**Report Number 2005/1
January 2005**

*This document has been prepared for the Executive Committee of the Programme.
It is not a publication of the Operating Agent, International Energy Agency or its Secretariat.*



RETROFIT OF CO₂ CAPTURE TO NATURAL GAS COMBINED CYCLE POWER PLANTS

Background to the Study

The main application of CO₂ capture in the long term is expected to be at new power plants. This has been the main focus of the IEA Greenhouse Gas R&D Programme's studies on CO₂ capture. However, there are various reasons why retrofitting CO₂ capture to existing power plants may be worth considering in some circumstances, for example:

- Power plants have long lives, 40 years or more in many cases. It may be cheaper to retrofit capture to an existing power plant rather than prematurely retire it and build a new power plant with capture.
- Utilities often prefer to extend the lives of existing plants rather than build new ones to minimise permitting problems and make use of existing fuel supply and electricity transmission infrastructure.
- Opportunities may arise to use captured CO₂, e.g. for enhanced oil recovery, in places where there is no need for new power generating capacity.

Most of the power plants currently being built in developed countries are natural gas fired combined cycle plants. Such plants could potentially be good candidates for CO₂ capture retrofit because they are relatively new and have high thermal efficiencies. This study assesses the feasibility and costs of retrofitting CO₂ capture to modern natural gas combined cycle plants. The study was carried out by Jacobs Consultancy Netherland B.V.

Study Description

The study is based on a 785 MW_e natural gas fired combined cycle plant, which includes 2 GE 9FA gas turbines. Similar gas turbines are produced by the other main turbine manufacturers. Five CO₂ capture retrofit options based on existing technology are assessed:

- Post combustion capture of CO₂
- Pre-combustion reforming of natural gas and capture of CO₂ at the power plant site
- Pre-combustion reforming of natural gas and capture of CO₂ at a remote site
- Gasification of coal and pre-combustion capture of CO₂ at the power plant site
- Gasification of coal and pre-combustion capture of CO₂ at a remote site

A preliminary assessment was carried out to select the technologies for use in the plants with CO₂ capture. The post combustion capture plant is based on a mono-ethanolamine (MEA) scrubbing process. The natural gas pre-combustion capture plants are based on air-blown auto-thermal reforming, followed by shift conversion and an amine scrubbing CO₂ separation unit. The coal gasification plants are based on the ChevronTexaco (now GE) slurry feed, oxygen-blown entrained-flow gasifier with water quench of the product gas. The gasifiers are followed by shift conversion and a Selexol physical solvent scrubbing unit for separation of H₂S, which is converted to sulphur, and CO₂. Post combustion capture was not considered for the gasification plants because it was assumed that it would be less expensive to capture CO₂ from the high pressure/high CO₂ concentration fuel gas than from the low pressure/low CO₂ concentration gas turbine flue gas

In the remote site cases, fuel processing and CO₂ capture is carried out at a plant that is 40 km from the power plant and hydrogen-rich fuel gas is transported by pipeline. Remote capture could be necessary if



there is insufficient plot area or other constraints at the power plant. Post combustion capture at a remote site is not feasible because a large volume of flue gas would have to be transported between the sites.

The study was carried out using IEA GHG's standard assessment criteria. The main criteria are:

- Netherlands coastal plant location
- Australian bituminous coal
- Natural gas price \$3/GJ, LHV basis (equivalent to \$2.7/GJ HHV basis)
- Coal price \$1.5/GJ, LHV basis (equivalent to \$1.43/GJ HHV basis)
- 10% discount rate (constant money values)
- 25 year overall operating life

It was assumed that CO₂ capture would be retrofitted after 10 years operation of the combined cycle plant. Sensitivities to the year in which the retrofit takes place (± 5 years) were assessed. It was also assumed that the whole plant, including the capture equipment would have zero value at the end of the 25 year operating period. In some cases it may be possible to replace or refurbish the power plant, to obtain a longer operating life for the capture equipment. However, gas turbines that are commercially available in future may not have the same flowrates as existing turbines, so it may be difficult to re-use capture units that are closely matched to the size of existing turbines. It may be easier to re-use capture units that are not closely linked to the power plant and which could be used to supply low-carbon content fuels to plants of any size.

Retrofitting CO₂ capture normally results in a reduction in net power output. In some cases a utility may need to maintain a constant net power output, so installation of additional generating capacity to maintain the net power output was assessed in sensitivity cases.

Results and Discussion

Thermal efficiency

Thermal efficiencies of the plants with and without CO₂ capture retrofit are shown in figure 1, along with the efficiency reductions due to the retrofit.




Figure 1: Thermal efficiencies

Post combustion capture has the lowest efficiency reduction due to capture. The highest efficiency reduction is for the coal based retrofits.

Capital cost

The capital costs of plants before and after retrofit are shown in figure 2. The costs are broken down into the costs of the original natural gas combined cycle (NGCC) plant and the costs of the retrofit. The cost of the original NGCC, in terms of \$/kW of net power output, increases after retrofit because the overall net power output decreases, as shown later in figure 7. The capital costs of local natural gas based retrofits (post combustion and pre combustion) are broadly similar to the original costs of the NGCC power plant. The costs of remote plant and coal-based retrofits are substantially higher than the original costs of the NGCC.




Figure 2: Capital costs

Cost of electricity generation

A power plant operator would be able to recover the cost of retrofitting CO₂ capture either by an increase in the electricity price or by a credit for the quantity of CO₂ emissions avoided, e.g. through a carbon trading scheme. The total cost of electricity generation after retrofit, assuming no carbon credits, and the increase in the cost due to the retrofit are shown in figure 3.

Figure 3 shows that the lowest cost capture retrofit option is post combustion amine scrubbing. For the natural gas and coal prices used in this study (3 and 1.5 \$/GJ respectively), coal-based pre-combustion capture retrofit is slightly more expensive than natural gas pre-combustion retrofit. For pre-combustion capture, retrofit of a capture plant at a remote site is about 0.8c/kWh more expensive than retrofit at the power plant site, assuming there are no special difficulties with on-site retrofit.




Figure 3: Electricity generation cost after capture retrofit

Fuel prices are different in different locations and they can fluctuate greatly over time. Sensitivities to fuel prices are shown in figure 4. A plant retrofitted with coal-based pre-combustion capture, using coal at \$1.5/GJ, would generate electricity at the same cost as a plant retrofitted with natural gas pre-combustion capture, if the gas price was 3.2-3.4 \$/GJ. For the coal-based retrofit to compete with post-combustion capture retrofit, the natural gas price would have to be \$4.2/GJ. In some places, for example the US, natural gas prices were higher than this at the time this report was written and coal prices were lower than \$1.5/GJ. Coal prices also tend to be more stable than gas prices and supplies may be more secure. Retrofit of coal gasification with CO₂ capture may therefore be competitive with natural gas-based capture retrofit in some places. However, as explained below, CO₂ emissions from coal-based plants tend to be higher, so emissions credits would be lower.




Figure 4: Sensitivity to fuel prices

The costs in this study exclude CO₂ transport and storage. As an illustration, a cost of \$10/t of CO₂ transported and stored would correspond to about 0.4 c/kWh for a gas fired plant and 0.8 c/kWh for a coal fired plant.

Cost of CO₂ emissions avoidance

Figure 5 shows the CO₂ emissions from the plants with and without capture and the quantities of CO₂ emissions avoided. The quantities of CO₂ emissions avoided are calculated by comparing the emissions of the natural gas fired plant without capture and the emissions of the plants after retrofit of capture. The quantities of emissions avoided are less than the quantities captured because extra CO₂ is produced to provide the energy required by the capture processes. In the case of the coal gasification retrofits, the quantity of CO₂ captured is much greater than the emissions avoided because of the change to a more carbon-intensive fuel. All of the retrofits are based on the same percentage CO₂ capture. The CO₂ emissions from the coal-based plants are greater than from the natural gas-fuelled plants because coal is a more carbon intensive fuel and the thermal efficiencies of the coal-based plants are lower.




Figure 5: CO₂ emissions

The cost of CO₂ emissions avoidance, i.e. the CO₂ credit that would be required to enable a retrofitted plant to generate electricity at the same overall cost as the original plant without CO₂ capture, is shown in figure 6. Figure 6 also shows the sensitivity to the timing of retrofit. The base case assumption in this study is that CO₂ capture is retrofitted 10 years after the start of operation of the power plant and the sensitivity to retrofitting 5 or 15 years after start of operation is shown.




Figure 6: Cost of avoiding CO₂ emissions and the sensitivity to the power plant age when retrofitted

Effect on net power output

Retrofitting CO₂ capture reduces the net power output of an existing combined cycle plant, as shown in figure 7.




Figure 7: Net power outputs

The fuel feed rate to the plant with post-combustion capture is the same as to the plant without capture. The reduction in power output is therefore directly proportional to the reduction in thermal efficiency, shown in figure 1. In the plants with pre-combustion capture the fuel (natural gas or coal) feed rates depend on the fuel gas requirement of the gas turbine and the energy losses in the fuel processing stages upstream of the gas turbine. The fuel feed rates are higher than in the plant without capture and consequently the reduction in net power output is less than the reduction in thermal efficiency.

In some circumstances a power plant operator may want to maintain its net power output. This could be achieved by installing additional combined cycle generating capacity at each plant that is retrofitted but this extra capacity would be less efficient and more expensive than the original generating plant. Maintaining a constant net power output in this way would reduce the overall efficiency of power generation by between



zero and 2 percentage points and increase the cost of CO₂ emissions avoided by between zero and 5 \$/t of CO₂.

Barriers to retrofit

In general, standard combined cycle power plants are not designed for the future possibility of major modifications. This study identifies possible barriers to retrofitting CO₂ capture to existing combined cycle plants and possible ways to minimise them during the original plant design phase, i.e. making the plants “capture ready”.

The CO₂ capture retrofit plants require a considerable plot space. The approximate plot spaces are:

- | | |
|--|----------|
| - Post combustion capture | 250x150m |
| - Natural gas pre-combustion capture | 175x150m |
| - Coal gasification pre-combustion capture | 475x375m |

Significant additional plot space is also required during construction. If there insufficient area available at the combined cycle plant, a pre-combustion capture plant could be installed at a remote site but, as shown by figure 2, this increases costs.

Space available within the combined cycle plant for tie-in of large diameter steam and fuel gas pipes may be a constraint in some cases. Other possible site constraints include the need to provide additional cooling and demineralised water, coal supply and storage infrastructure in coal fired cases, and accessibility for delivery of large plant items. Obtaining permits for major modifications to the power plant or construction of a remote capture plant and its fuel gas pipeline could be a barrier in some circumstances.

Gas turbine performance will differ significantly when firing a low-LHV fuel gas from pre-combustion capture plant, which will also lead to changed process conditions in the steam cycle. As no design is exactly the same, it will be necessary to determine possible problems for each installation that is retrofitted. Retrofit of CO₂ capture could also affect plant operating flexibility, such as the ability to operate efficiently at part load.

Many of the potential barriers to retrofit could be overcome in the design phase of a new combined cycle power plant. This would lead to minor extra costs but the cost savings at the retrofit stage could be substantial, for example if the need to build a remote capture plant is avoided.

As a sensitivity case, the study briefly assessed retrofit of a capture-ready coal gasification plant, which could be operated efficiently without capture. This option may be attractive in locations where fuel switching from natural gas to coal is economically attractive now but there is no requirement yet to capture CO₂.

Comparison with IEA GHG studies on CO₂ capture in new power plants

Retrofitting CO₂ capture to an existing power plant is inevitably more costly than including it in a new plant. Reasons for this include:

- The capture equipment has a shorter operating life in a retrofit than in a new plant.
- The efficiency is usually lower because of less energy integration between the power plant and capture unit.
- The power plant has to operate at non-optimum conditions.
- Some equipment in the power plant becomes redundant or has to be modified.
- The existing power plant has to be shut down for a period of time during the retrofit.
- Separate utility systems, such as cooling water supply, have to be installed for the capture unit, resulting in less economies of scale.



IEA GHG has recently published cost and performance data for post combustion CO₂ capture in new power plants, on the same basis as this study¹. The cost of post combustion capture in a new natural gas combined cycle plant was estimated to be \$37-41/tonne of CO₂ emissions avoided, compared to \$73/tonne in the corresponding retrofit case in this study. This higher cost for retrofit is partly due to the reasons given above but a further reason is the different sources of cost data in the new and retrofit plant studies. This retrofit study is based on information provided to Jacobs by UOP, for a conventional MEA scrubbing process. IEA GHG's study on new plants was based on data provided by Fluor and MHI are for their improved scrubbing processes (Econamine FG+SM and KS-1), which have much lower steam consumptions for solvent regeneration. The efficiency penalty for post combustion capture in this study is 11.3 percentage points but the penalty is 8.2 and 6.0 percentage points in Fluor and MHI's studies. The specific capital cost penalty for CO₂ capture in this retrofit study is approximately twice as great as in IEA GHG's new plant study. The data provided by UOP is conservatively based on eight parallel CO₂ absorbers, compared to 3 and 2 in Fluor's and MHI's studies. The resulting economies of scale account for a significant proportion of the cost difference. Despite the conservative data used for post combustion capture in Jacobs' study, post combustion capture is still the lowest cost retrofit option. Use of Fluor's or MHI's processes would not have affected this conclusion.

IEA GHG has also published a study on CO₂ capture in new IGCC plants², which was carried out by Foster Wheeler. The cost and performance data for gasification plants based on Chevron Texaco gasification in that study are broadly consistent with those in Jacobs' study. The thermal efficiency and capital cost are both lower in Foster Wheeler's study but the differences are not great enough to affect the conclusions of this study.

Expert Group Comments

The draft study report was sent to expert reviewers for comment. The main comments related to fuel prices. US reviewers pointed out that the gas price used in the study is low compared to current US prices. They also pointed out that one of the options considered in the study, conversion to coal gasification, would only be attractive if gas prices were much higher than the base case price used in the study. These and other comments from the reviewers are taken into account in the final version of the study report or in this study overview.

Major Conclusions

Retrofitting CO₂ capture to natural gas combined cycle plants would increase the cost of electricity by about 2-3c/kWh, corresponding to about 70-90 \$/tonne of CO₂ emissions avoided.

Post combustion capture is the lowest cost capture retrofit option.

Remote fuel processing and CO₂ capture plants could provide low-carbon fuel gas to a combined cycle plant but the cost would be about 0.8c/kWh higher than for on-site CO₂ capture retrofit.

There are several potential barriers to retrofit of CO₂ capture to existing combined cycle power plants but most of them could be overcome if the possibility of retrofit was taken into account when the power plant was designed.

¹ Improvement in power generation with post-combustion capture of CO₂, IEA GHG report PH4/33, Nov. 2004.

² Potential for improvement in gasification combined cycle power generation with CO₂ capture, IEA GHG report PH4/19, May 2003



Retrofitting a coal gasification plant with CO₂ capture could be an attractive option in some countries where gas costs are high and coal costs are low. Capture-ready gasification plants could be built if there is currently no requirement to capture CO₂.

Recommendations

No further work on retrofit of CO₂ capture to natural gas combined cycle plants is recommended at this time.

Work by others on retrofit of CO₂ capture to coal fired power plants, involving upgrading to ultra-supercritical boilers, should be monitored and compared to the results of IEA GHG's studies.

International Energy Agency
Greenhouse Gas Programme

**Retrofit of CO₂ Capture to
Natural Gas Combined Cycle
Power Plants**

Project No. : 64114-00
Document No. : 6411400-2300-P06-001
Revision : D
Revision description: Final
Prepared by : J. IJzenbrandt/S.J. Ribberink
Checked by : M. van Kooten
Approved by : E. Goudappel

Issue date : 10 August 2004

Submitted by:
Jacobs Consultancy Nederland B.V.
Plesmanlaan 100, 2332 CB Leiden
P.O. Box 141, 2300 AC Leiden
The Netherlands
Tel +31.71.582.7111 Fax +31.71.582.7050

A Subsidiary of Jacobs Engineering Group Inc.

Trade register: Rijnland 28092274

C:\Documents and Settings\JvanLoon\Local Settings\Temporary Internet Files\OLK8D\64114-00-2300-P06-001-D_cdfrom.doc

TABLE OF CONTENTS

1. MANAGEMENT SUMMARY 6

2. INTRODUCTION..... 11

3. DESIGN BASIS 14

3.1 REFERENCE PLANT..... 14

3.2 FEEDSTOCK 14

3.2.1 Natural Gas..... 14

3.2.2 Coal 15

3.3 PRODUCTS PRE COMBUSTION CAPTURE PLANT..... 15

3.3.1 Carbon Dioxide 15

3.3.2 Fuel Gas 16

3.3.3 Fuel Gas Diluent 16

3.4 ENVIRONMENTAL CONSTRAINTS 16

3.4.1 Gaseous Emissions 16

3.4.2 Liquid Effluent 16

3.4.3 Solid Effluent..... 16

3.5 ADDITIONAL CAPACITY, AVAILABILITY AND SPARES 17

3.5.1 Additional Capacity 17

3.5.2 Availability 17

3.5.3 Spares Philosophy 17

3.6 SITE INFORMATION 17

3.6.1 Location 17

3.6.2 Meteorological/ Site Data 17

3.7 UTILITIES 17

3.7.1 Open Circuit Sea Water Cooling 17

3.7.2 Fresh Water Cooling Small Coolers and Machinery 18

3.7.3 Plant Water 18

3.7.4 Electricity..... 18

3.8 BATTERY LIMITS DEFINITION 19

3.8.1 Reference Case 19

3.8.2 Case 1 Post-combustion Capture..... 19

3.8.3 Case 2-1 - Natural Gas Pre-combustion Capture (Local) 20

3.8.4	Case 2-2 - Natural Gas Pre Combustion Capture (Remote).....	21
3.8.5	Case 3-1 - Coal based Pre-combustion Capture (Local)	21
3.8.6	Case 3-2 - Coal based Pre-combustion Capture (Remote)	22
4.	TECHNOLOGY SELECTION CO ₂ CAPTURE	24
4.1	CASE 1 – POST-COMBUSTION CAPTURE.....	24
4.2	CASE 2 – PRE-COMBUSTION CAPTURE FROM NATURAL GAS.....	25
4.2.1	Reforming	26
4.2.2	Varying Steam to Carbon Ratio in the Autothermal Reformer.....	27
4.2.3	CO Shift system	28
4.2.4	CO ₂ removal Section.....	28
4.2.5	Fuel Gas Conditioning.....	30
4.3	CASE 3 – PRE-COMBUSTION CAPTURE FROM COAL	31
4.3.1	Gasification	32
4.3.2	Shift System.....	35
4.3.3	Acid Gas Removal	37
4.3.4	Sulphur recovery	38
4.3.5	Fuel Gas Conditioning.....	38
5.	PROCESS DESCRIPTIONS AND PERFORMANCES	40
5.1	REFERENCE CASE: STANDARD COMBINED CYCLE POWER PLANT.....	40
5.1.1	CCPP Description	40
5.2	CASE 1: POST COMBUSTION CO ₂ CAPTURE.....	45
5.2.1	CCPP Description	45
5.2.2	CCPP Performance.....	46
5.2.3	Capture Plant Description	47
5.2.4	Capture Plant Performance	49
5.2.5	Overall Plant Balance.....	49
5.3	CASE 2-1: PRE COMBUSTION CO ₂ CAPTURE BY LOCAL H ₂ PRODUCTION FROM NATURAL GAS.....	51
5.3.1	Capture Plant Description	51
5.3.2	Capture Plant Performance	54
5.3.3	CCPP Description	55
5.3.4	CCPP Performance.....	56
5.3.5	Overall Plant Performance	57

5.4	CASE 2-2: PRE COMBUSTION CO ₂ CAPTURE BY REMOTE H ₂ PRODUCTION FROM NATURAL GAS	58
5.4.1	Capture Plant Description	58
5.4.2	Capture Plant Performance	60
5.4.3	CCPP Description	60
5.4.4	CCPP Performance.....	61
5.4.5	Overall Plant Performance	62
5.5	CASE 3-1: PRE COMBUSTION CO ₂ CAPTURE BY LOCAL H ₂ PRODUCTION FROM COAL.....	64
5.5.1	Capture Plant Description	64
5.5.2	Capture Plant Performance	69
5.5.3	CCPP Description	69
5.5.4	CCPP Performance.....	70
5.5.5	Case 3-1 Overall Plant Balance	71
5.6	CASE 3-2: PRE COMBUSTION CO ₂ CAPTURE BY REMOTE H ₂ PRODUCTION FROM COAL.....	72
5.6.1	Capture Plant Description	72
5.6.2	Capture Plant Performance	74
5.6.3	CCPP Description	74
5.6.4	CCPP Performance.....	75
5.6.5	Overall Plant Balance.....	76
5.7	OVERALL RESULTS AND CONCLUSIONS.....	76
6.	CAPITAL EXPENDITURE.....	78
6.1	INTRODUCTION.....	78
6.2	CAPITAL EXPENDITURE	80
7.	ECONOMIC ANALYSIS	81
7.1	INTRODUCTION.....	81
7.2	CASH FLOW CALCULATIONS.....	81
7.2.1	Background.....	81
7.2.2	Starting points	82
7.3	RESULTS	84
7.4	CALCULATION OF CO ₂ COST	84
7.5	RESULTS SENSITIVITY ANALYSIS.....	85
7.5.1	Fuel price sensitivity	85

7.5.2	Discount rate sensitivity.....	86
7.5.3	Retrofit year sensitivity	87
8.	RETROFITTING ISSUES.....	88
8.1	BARRIERS TO RETROFIT	88
8.2	DESIGN FOR FUTURE RETROFIT.....	91
8.2.1	Avoiding potential barriers.....	91
8.2.2	Potential process integration	93
8.3	OVERALL AVAILABILITY	95
8.3.1	Availability rating	95
8.3.2	Case 1 Post combustion CO ₂ capture	96
8.3.3	Case 2 Pre combustion CO ₂ capture by syngas production from natural gas	96
8.3.4	Case 3 Pre combustion CO ₂ capture by syngas production from coal	97
8.3.5	Availability during start-up	97
9.	CONCLUSIONS.....	98

APPENDICES:

1. CCGT simplified process scheme and mass balance
2. Fuel/CO₂ capture plants simplified process schemes and mass balances
3. Plot lay-outs
4. Fuel/CO₂ capture plants equipment lists
5. Fuel/CO₂ capture plants power consumption/production and utility usage
6. Fuel/CO₂ capture plants capital cost estimates
7. Cash flow calculations
8. Task 1 – Same Output Retrofit
9. Task 3 – Pre-Implementation Retrofit

Distribution:

External: IEA: Mr. J. Davison

Internal: KOMI, JOC, R. Delaney, CEF

1. MANAGEMENT SUMMARY

This report describes the results of a study conducted to evaluate several options for retrofitting an existing natural gas fired Combined Cycle Power Plant (CCPP) to a CCPP with a CO₂ capture plant.

This retrofit is set to take place after 10 years of operating the power plant as a standard CCPP.

The CO₂ capture options evaluated are:

- Post combustion CO₂ capture based on amine scrubbing of the CCPP's flue gases (case 1).
- Pre combustion CO₂ capture based natural gas as a fuel. This is done by reforming of natural gas in both a local (at the power plant site) case (case 2.1) and a remote (at 40 km distance) case (case 2.2).
- Pre combustion CO₂ capture based coal as a fuel. This is done by gasification of coal in both a local (at the power plant site) case (case 3.1) and a remote (at 40 km distance) case (case 3.2).

These options are visualized in following figure.




Figure 1.1 - Cases Studied

As part of the report a separate chapter (chapter 4) is dedicated to technology selection aspects for several process steps in a CO₂ capture Combined Cycle Power Plant. The technologies described and selected in this chapter are the basis for the five CO₂ capture cases as described in chapter 5.

For all cases considered, following characteristics have been established:

- Performance
- Avoided CO₂ emission
- Capital investment
- Operation & maintenance costs

Using the IEA economic model, modified for evaluation of retrofit options, following results have been obtained:

- Electricity production costs
- Cost of avoided CO₂

The results of these evaluations are summarized below:

	Ref.	Case 1	Case 2.1	Case 2.2	Case 3.1	Case 3.2
Additional ¹⁾ capital expenditure for CO ₂ capture plant (mln. USD)	---	395	569	750	962	1194
Net power production (MWe)	785	626	694	667	751	775
Overall efficiency (%)	55.9	44.6	41.5	39.9	35.4	33.6
Spec. total investment (USD/MWe)	529	1294	1419	1746	1833	2077
Electricity costs (USD/MWh)	30.0	52.4	58.6	67.1	61.9	69.1
CO ₂ emission (ton/MWh)	0.373	0.067	0.072	0.075	0.130	0.140
Avoided CO ₂ (ton/MWh)	---	0.306	0.301	0.299	0.243	0.233
Avoided CO ₂ (% of ref.)	---	82.1	80.6	80.0	65.2	62.5
Cost of avoided CO ₂ (USD/ton CO ₂)	---	73.2	95.1	124.3	131.4	168.1

Notes:

¹⁾ On top of capital expenditure for reference plant: 415 mln. USD

From the study it becomes clear that a retrofit of CO₂ capture to a natural gas fired CCCP requires a significant cost of investment and results also in a significant reduction of the overall electric efficiency. The post combustion CO₂ capture option is strongly preferred from a performance and financial point of view compared to the natural gas reforming and the coal gasification based pre combustion CO₂ capture plants.

The post combustion option shows the smallest but still significant efficiency reduction in combination with the lowest capital expenditures and the best specific CO₂ emission.

The main disadvantage of the post combustion option is the requirement of installing the plant almost next to the existing CCCP because of the large atmospheric flue gas flow. As the plant requires also a large plot space, this could be a problem for retrofitting.

Other conclusions are:

- All options comply with the CO₂ capture efficiency of 85%.
- The remote pre combustion options require a higher cost of investment and have a lower efficiency due to transportation of the fuel gas.
- The overall power generation availability of the retrofitted plant is “identical” to the reference CCCP.

Taking this as a basis, sensitivity analyses have been made for:

- Fuel price : +100% and –50%
- Discount rate : 5% (instead of 10%)
- Year of retrofit : 5 years and 15 years after start of CCPP (instead of 10 years)
- Sensitivity analyses on fuel price show a different behaviour of the cost of avoided CO₂ for the coal-based plants compared to the natural gas fuelled plants. An increase of the fuel price results in an increase in the cost of avoided CO₂ for the natural gas fuelled plants and a decrease of cost for the coal fuelled plants. In case of a fuel price reduction the opposite occurs. Sensitivity analysis on discount rate show, as expected, a reduction of the costs of avoided CO₂ for all cases considered with a reduced discount rate.
- Sensitivity analyses on the year of retrofit show as expected that when the retrofit is executed at a later time, the cost of avoided CO₂ increase.
- The post combustion option remains the best option from a financial point of view for all sensitivities considered.

Additionally one chapter (chapter 8) is dedicated to issues related to future retrofitting, which can be anticipated for in the design stage of the original Combined Cycle Power Plant.

Indications are given for:

- Plot space requirements of the various retrofit options. They range from 175x150 to 475x375 m.
- Additional required cooling water capacities. These additional capacities range from 21,000 to 83,000 m³/h.
- Additional required space for 12" to 36" additional fuel gas line to the gas turbine when retrofitting.
- Additional required space for 36" LP steam line from the CCPP steam turbine to the CO₂ capture plant in the local cases.

In this chapter some notes on availability and the effect on CO₂ capture of failure of some process units are also given. In all cases, provided that the CCPP is allowed to operate temporarily without capturing 85% CO₂, the availability is not affected by installing a capture plant.

Furthermore some capex reduction options and performance improvement potential have been identified.

Additional Tasks

Two additional tasks were carried out by Jacobs as a supplement to the study:

Task 1 – Same Output Retrofit

In all cases, the action of retrofitting the CCPP to capture 85% of the CO₂, results in a reduction in net generation capacity. However, some operators may be contracted to retain the original plant output.

In order to achieve this it is necessary in most cases to install supplementary combined cycle power plant either with additional flue gas scrubbing capacity or fuelled from an enlarged capture plant.

The results of these evaluations are summarised below:

Additional Power Requirements	Ref.	1	2-1	2-2	3-1	3-2	
Total Overall Plant Net Power Output	784.8	625.9	693.7	667.4	751.2	774.6	MWe
Additional Power Required	-	158.9	91.1	117.4	33.6	10.2	MWe
Additional Combined Cycle Gas Turbine Type	-	GE9EA	GE6FA	GE9EA	GE6B	-	
Revised Overall Plant Net Power Output	784.8	780.2	786.9	805.4	793.9	784.0	MWe
Revised Overall Plant Net Electrical Efficiency	55.9	43.8	40.6	37.9	34.2	33.6	%

The study demonstrates that the reference case output can be closely matched with CO₂ capture using additional gas turbines.

In all cases the overall efficiency is reduced. This is because the additional gas turbines are all less efficient than the GE 9FA used in the CCPP. This increases specific CO₂ emissions and the increase in capacity increases overall CO₂ emissions.

In all cases the total capital costs are increased, but in the specific capital cost differ marginally compared to the results of the original study.

Additional Capital Expenditures	Ref.	1	2-1	2-2	3-1	3-2	
Additional Capital Costs ¹	-	584	712	978	1045	1210	Million US \$
Specific Total Investment	529	1280	1432	1729	1839	2073	US \$/MWe
Costs of Avoided CO ₂	-	74.3	98.2	128.9	136.9	167.5	US \$/ton

Notes

1. On top of capital expenditure for reference plant of 415 million US \$
2. Calculated with electricity at 30.0 US \$/MWh

Task 3 _ Pre-implementation Retrofit

A major problem facing an intended new power plant investor is the choice between a plant design that cannot capture CO₂ and one that can only operate with CO₂ capture. With the former, he will face penalties under any carbon tax levy for which his only recourse is to pay. The latter choice will give him an uncompetitive plant for today that produces by-product CO₂ to no benefit.

An option is to design a fuel plant which is CO₂ capture ready based on the designs for Cases 3-1 and 3-2, renamed Cases 3-3 and 3-4 respectively. These designs could be operated to advantage without CO₂ capture. The fuel gas diluent of nitrogen and water vapour, both of which are energy intensive to use, could be replaced simply by leaving the CO₂ in the fuel gas. Here it acts as the diluent and is eventually discharged up the stacks of the CCPP and Power Block.

The results of these calculations are summarised below.

Plant Performance Output	Ref.	3-3	3-4	
Combined Cycle Power Plant Net Electrical Output	784.8	846.6	820.8	MWe
Overall Plant Net Power Output	784.8	973.6	932.6	MWe
Total Plant Fuel Consumption (LHV)	1404.6	2388.7	2390.7	MWth
Overall Plant Net Electrical Efficiency	55.9	40.8	39.1	%

The economic results are shown in the table below.

Additional Capital Expenditure	Ref.	3-3	3-4	
Additional Capital Costs ¹	-	949	1102	Million US \$
Specific Total Investment	529	1401	1627	US \$/MWe
Costs of Electricity	30.3	44.4	49.8	US \$/MWh

Notes

1. On top of capital expenditure for reference plant of 415 million USD

A fuel plant can be built which is CO₂ capture ready and used to refuel an existing gas turbine at similar efficiencies and costs to a traditional IGCC without the ability to capture CO₂. The prices for natural gas and coal as used in the study means that the cost of electricity produced by such a plant is not competitive with electricity produced from natural gas in a combined cycle. However, there are some parts of the world, most notably North America where the price differential between coal (or petroleum coke) and natural gas would mean that refuelling a natural gas combined cycle with syngas are commercially attractive.

2. INTRODUCTION

The International Energy Agency Greenhouse Gas R&D Programme (IEA GHG) was established in 1991 to evaluate technologies that could be used to avoid emissions of greenhouse gas emissions, particularly from the use of fossil fuels. IEA GHG is an international organisation, supported by sixteen countries worldwide, the European Commission and several industrial organisations. From this perspective IEA GHG selected Jacobs Consultancy to study the feasibility and costs of retrofitting CO₂ capture to modern natural gas combined cycle power plants. Jacobs Consultancy is part of the internationally operating Jacobs Engineering Group, with extensive experience in retrofitting, power plant technology/projects and fuel reforming.

Fossil Fuel fired power stations are responsible for a large part of the worlds CO₂ emissions. Decreasing their emissions is an important step in decreasing the total CO₂ emission caused by human activity. Increasing their efficiency helps because less fuel is consumed for the same amount of electricity produced, but major efficiency improvements are difficult to obtain in today's modern installations. A different approach is to avoid the CO₂ being emitted by capturing it before it is emitted to the atmosphere.

Most of the power stations currently being built in developed countries are natural gas fired Combined Cycle Power Plants (CCPP). These plants could potentially be good candidates for CO₂ capture retrofit because they are relatively new and have high thermal efficiencies. This study will assess the feasibility and costs of different options for retrofitting CO₂ capture to modern natural gas combined cycle plants.

In this study two main concepts with a different approach are distinguished. The first concept is post-combustion CO₂ capture, where the flue gasses from a natural gas fired power plant are being led through a CO₂ scrubber, which removes the CO₂ from the flue gas.

The other concept is pre-combustion CO₂ capture. This comprises the reforming and treating of standard fuels to a fuel without carbon contents. When these synthesis fuels are combusted, no CO₂ is emitted to the atmosphere and therefore no flue gas cleaning is needed.

This study will describe and discuss the different techniques that are available for these concepts. The most promising techniques are compared to a standard power plant without CO₂ capture, to evaluate the consequences when CO₂ capture is applied. Hereto one reference case and several CO₂ capture cases are defined:

- Reference: Standard 800 MWe Combined Cycle Power Plant
- Case 1: Post Combustion CO₂ Capture
- Case 2: Pre Combustion CO₂ Capture: Reforming natural gas
- Case 3: Pre Combustion CO₂ Capture: Gasifying Coal

In addition to this, cases 2 and 3 are divided into two subcases: a local case and a remote case. The difference between those cases is that in the local case the power plant is supplied with syngas from the Fuel/CO₂ Capture Plant, which is on or near the power plant site. In the remote case, the Fuel/CO₂ Capture Plant is located at a 40 km distance from the power plant.




Figure 2.1 - Cases Studied

Retrofitting a CCGT to CO₂ capture requires modifications to be performed to the existing installation, as well as completely new installations to be installed. For some cases these measures will be alike, while major differences between the cases also appear. The study gives a description of these modifications and add-on installations that are needed for each individual case.

Performance calculations for the different cases are executed to compare the different options with respect to the technical performance. This includes mass and heat balance calculations with dedicated computer software, which give an exact view on the total plant performance.

Cost estimates of investment costs for retrofitting a standard power plant to a plant with CO₂ capture are based on vendor data as well as in-house information from Jacobs Engineering.

Together with the performance calculations, the cost estimates for retrofitting give the basis of the economic analysis, in which the different cases are compared with respect to economic feasibility.

Several barriers exist to retrofitting an existing power plant. These can be economical and/or technical barriers, which are often created because in the design phase of the

power plant, no special attention is paid to the possibility of future adjustments or expansion. When a plant is designed for future retrofit and these barriers are defined beforehand, they can be avoided which makes retrofitting less difficult, less costly and less time-consuming.

The study will define the possible barriers to retrofit an existing installation and indicate how, when designing a new power plant, a future retrofit to CO₂ capture can be taken into account. Furthermore the possibilities for process integration of the Capture Plant and the power plant are considered.

The report is built up as follows. Chapter 3 contains the basis of design, which incorporates all general starting points and assumptions. In Chapter 4 the technology selection for the CO₂ capture cases is substantiated. The process descriptions for the Fuel/CO₂ capture and power plant configurations can be found in Chapter 5, together with the technical performances for each case. Chapter 6 contains the capital cost and owners cost calculations, and is followed by Chapter 7 with the economic analysis. Chapter 8 describes the barriers that can arise when an existing plant is retrofitted to CO₂ capture and assesses the possibilities to avoid these barriers by designing for future retrofit. Overall conclusions can be found in Chapter 9.

3. DESIGN BASIS

The design basis gives the starting points and assumptions for the study, which are not specific for one case. If, for a specific reason it is decided to deviate from these starting points, it will be mentioned in the case description of individual cases in Chapter 5.

3.1 REFERENCE PLANT

The reference plant comprises two trains of GE Frame 9FA gas turbines each fitted with a triple pressure, reheat, heat recovery steam generator in combined cycle with a condensing seawater cooled steam turbine. The total plant produces approximately 800 MWe.

3.2 FEEDSTOCK

There are two types of feedstock; natural gas and coal. The feedstock data depicted below is provided by IEA.

3.2.1 Natural Gas

The gas specification is based on a pipeline quality gas from the southern part of the Norwegian offshore reserves.

Component	Volume %
Methane	83.9
Ethane	9.2
Propane	3.3
Butane +	1.4
CO ₂	1.8
Nitrogen	0.4

Sulphur (as H ₂ S)	:	4 mg/Nm ³
LHV	:	46.9 MJ/kg
Delivery Pressure	:	40 barg
Delivery Temperature	:	10°C

3.2.2 Coal

The coal specification is based on an open-cut coal from Eastern Australia.

Proximate Analysis	Weight %
coal (dry, ash-free)	78.3
ash	12.2
moisture	9.5
Ultimate Analysis	Weight %
Carbon	82.5
Hydrogen	5.6
Nitrogen	1.8
Chlorine	0.0
Sulphur	1.1
Oxygen	9.0
Ash Composition	Weight %
Silica as SiO ₂	50.0
Aluminium as Al ₂ O ₃	30.0
Iron as Fe ₂ O ₃	9.7
Titanium as Ti ₂ O ₃	2.0
Calcium as CaO	3.9
Magnesium as MgO	0.4
Sodium as Na ₂ O	0.1
Potassium as K ₂ O	0.1
Phosphorus as P ₂ O ₅	1.7
Sulphate as SO ₃	1.7
Gross Calorific Value (kJ/kg)	27060
Net Calorific Value (kJ/kg)	25870
Ash Fusion Point (reducing Atmosphere)	1350°C

3.3 PRODUCTS PRE COMBUSTION CAPTURE PLANT

The CO₂ capture plant for the pre combustion capture cases delivers its products at conditions described in this paragraph.

3.3.1 Carbon Dioxide

The captured carbon dioxide is dried and delivered to the battery limits at 110 bar(g) and 40 °C. The CO₂ is sulphur free and suitable for use in Enhanced Oil Recovery (EOR).

3.3.2 Fuel Gas

The fuel gas for the gas turbines in the pre-combustion capture cases is delivered to the gas turbine at a minimum of 25 bar(g).

3.3.3 Fuel Gas Diluent

Fuel gas diluent delivered to the gas turbines in the pre combustion capture cases at which the diluent is delivered separately from the fuel gas is delivered at a pressure of at least 24 bar(g).

3.4 ENVIRONMENTAL CONSTRAINTS

3.4.1 Gaseous Emissions

The gaseous emissions are in general compliance with the large Combustion Plant Directive (2001/80/EC), current requirements for maximum permitted emission levels for power stations in the EU with a capacity in excess of 500 MW_{th}.

Approximately 85% of the carbon in the primary fuel gas is captured as CO₂ in all cases. In the natural gas fuelled cases, Case 1, Case 2-1 and Case 2-2, the primary fuel gas is natural gas. In the coal gasification cases, Case 3-1 and Case 3-2, the primary fuel gas is the raw synthesis gas from the gasifier high temperature cooling system.

3.4.2 Liquid Effluent

Most liquid discharge is treated to a sufficient standard so that it can be discharged into UK inland waterway.

A minimal amount of liquid effluent may be sent to a controlled landfill.

3.4.3 Solid Effluent

Most solid effluents are treated to a sufficient standard so that they can be sold e.g. sulphur or solid slag.

Some solid effluent is sent to specialist contractors for recovery e.g. spent catalysts and absorbents

The proportion of solid waste sent to controlled landfill is minimised.

3.5 ADDITIONAL CAPACITY, AVAILABILITY AND SPARES

3.5.1 Additional Capacity

There is no additional power generation capacity installed in the existing combined cycle power plant to replace that used to capture or compress the CO₂.

3.5.2 Availability

The overall availability of the power station on the primary fuel after retrofit is minimal 90%.

3.5.3 Spares Philosophy

All rotating equipment, except steam and gas turbines and generators, are spared on a "plus one" basis, i.e. one 100% pump has a 100% spare; two 50% pumps have one 50% spare. Certain other pieces of equipment such as sulphur treatment plants, solids handling units and gasification units may also be spared to maintain the overall availability after retrofit of 90%.

3.6 SITE INFORMATION

3.6.1 Location

The Power Station is located in North East Netherlands, close to the North Sea. For the remote pre combustion CO₂ capture cases 2-2 and 2-3, the capture plants are located 40 km from the power station and also close to the North Sea.

3.6.2 Meteorological/ Site Data

For all cases including remote pre combustion CO₂ capture, the following conditions apply:

Elevation	2m above mean sea level
Barometric Pressure	1.013 bara – Design
Ambient Temperature	9 °C
Relative Humidity	60 %

3.7 UTILITIES

The utilities required at the battery limit of the unit including the required conditions are described in this paragraph.

3.7.1 Open Circuit Sea Water Cooling

Seawater is circulated once through major coolers and condensers and discharged directly back to the sea. A secondary closed water system is used for smaller coolers and machinery.

Supply: Temperature	12 °C
Pressure	1.6 barg
Design class	ANSI 150 lb Rating
Material	As for return
Return: Temperature	19 °C
Pressure	0.5 barg
Design class	ANSI 150 lb Rating
Material	Cement Lined Carbon Steel 300 NB and larger Epoxy lined /carbon Steel 250 NB and smaller

3.7.2 Fresh Water Cooling Small Coolers and Machinery

Supply: Temperature	22 °C
Pressure	3.9 barg
Design class	ANSI 150 lb Rating
Material	Carbon Steel
Return: Temperature	37 °C
Pressure	3.0 barg
Design class	ANSI 150 lb Rating
Material	Galvanised Carbon Steel

Note: the use of this utility is minimised.

3.7.3 Plant Water

Pressure	2.7 barg
Temperature	30 °C
Design class	ANSI 150 lb Rating
Material	Galvanised Carbon Steel

3.7.4 Electricity

Voltage	110 kV
Frequency	50 Hz

3.8 BATTERY LIMITS DEFINITION

3.8.1 Reference Case

The battery limits for the existing reference plant are given in the following table.

Commodity	Battery Limits
Import:	
Natural gas	Natural gas inlet flange
Fresh water	Pipe flange
Sea water	Sea water intake
Export:	
Electricity	Primary transformer terminals
Waste water	Pipe flange
Sea water	Sea water discharge

ISBL Scope

CCPP: Combined Cycle Power Plant:

- Primary transformers and switchgear
- Seawater intake and discharge structure and pumps
- Demineralised water treatment plant

Ancillaries Excluded from Scope

- Connections to the electricity grid system

3.8.2 Case 1 Post-combustion Capture

In addition to the battery limits for the existing reference plant given in 3.8.1, the new plant battery limits are as in shown in the table below.

Commodity	Battery Limits
Import:	
Flue gases	HRSG flue gas outlet flange
Low pressure steam	HRSG LP steam line
Fresh water	Pipe flange
Electricity	110 kV cable (from existing plant)
Sea water	Sea water intake
Export:	
CO ₂	CO ₂ export pipe flange
Waste water	Pipe flange
Sea water	Sea water discharge
Condensate	Condensate system

ISBL Scope

Existing CCPP:

- Combined Cycle Power Plant (for modifications only)
- Primary transformers and switchgear (for modifications only)

New Capture Plant:

- Flue gas scrubbing unit
- CO₂ compressor and dryer
- Utilities - including primary and secondary cooling water, demineralised and waste water treatment plant, firewater, instrument air, roads and buildings.

Ancillaries Excluded from Scope

- Connections to the electricity grid system

3.8.3 Case 2-1 - Natural Gas Pre-combustion Capture (Local)

In addition to the battery limits for the existing reference plant given in 3.8.1, the new plant battery limits are as in shown in the table below.

Commodity	Battery Limits
Import:	
Natural gas	Natural gas inlet flange
Fresh water	Pipe flange
Electricity	110 kV cable (from existing plant)
Sea water	Sea water intake
Export:	
Fuel gas	Import flange on CCPP
CO ₂	CO ₂ export pipe flange
Waste water	Pipe flange
Sea water	Sea water discharge

ISBL Scope

Existing CCPP:

- Combined Cycle Power Plant (for modifications only)
- Primary transformers and switchgear (for modifications only)

New Capture Plant:

- Fuel gas production plant
- CO₂ compressor and dryer
- Utilities - including primary and secondary cooling water, demineralised and waste water treatment plant, firewater, instrument air, flare system, roads and buildings.

Ancillaries Excluded from Scope

- Connections to the electricity grid system

3.8.4 Case 2-2 - Natural Gas Pre Combustion Capture (Remote)

In addition to the battery limits for the existing reference plant given in 3.8.1, the new plant battery limits are as in shown in the table below.

Commodity	Battery Limits
Import:	
Natural gas	Natural gas inlet flange
Fresh water	Pipe flange
Electricity	110 kV cable (from grid)
Sea water	Sea water intake
Export:	
Fuel gas	Inlet flange at existing CCPP
CO ₂	CO ₂ export pipe flange
Waste water	Pipe flange
Sea water	Sea water discharge

ISBL Scope

Existing CCPP:

- Combined Cycle Power Plant (for modifications only)
- Demineralised Water Treatment Plant (extension)

New Capture Plant

- Fuel gas production plant
- Sea water intake and discharge structures
- Fuel gas pipeline
- CO₂ compressor and dryer
- Utilities - including primary and secondary cooling water, demineralised and waste water treatment plant, firewater, instrument air, flare system, roads and buildings.

Ancillaries Excluded from Scope

- Connections to the electricity grid system

3.8.5 Case 3-1 - Coal based Pre-combustion Capture (Local)

In addition to the battery limits for the existing reference plant given in 3.8.1, the new plant battery limits are as in shown in the table below.

Commodity	Battery Limits
Import:	
Coal	Coal storage pile
Fresh water	Pipe flange
Electricity	110 kV cable (from existing plant)
Sea water	Sea water intake
Export:	
Fuel gas	Import flange on CCGT
CO ₂	CO ₂ export pipe flange
Waste water	Pipe flange
Sea water	Sea water discharge

ISBL Scope

Existing CCGT:

- Combined Cycle Power Plant (for modifications only)
- Primary transformers and switchgear (for modifications only)

New Capture Plant

- Fuel gas production plant
- Sea water intake and discharge structures
- Coal reclaimer, conveyors, grinding and slurring plant
- Black water treatment plant
- Fuel gas pipeline
- CO₂ compressor and dryer
- Utilities - including primary and secondary cooling water, demineralised and wastewater treatment plant, firewater, instrument air, flare system, back-up fuel tank, roads and buildings.

Ancillaries Excluded from Scope

- Connections to the electricity grid system
- Coal delivery system

3.8.6 Case 3-2 - Coal based Pre-combustion Capture (Remote)

In addition to the battery limits for the existing reference plant given in 3.8.1, the new plant battery limits are as in shown in the table below.

Commodity	Battery Limits
Import:	
Coal	Coal storage pile
Fresh water	Pipe flange
Electricity	110 kV cable (from grid)
Sea water	Sea water intake
Back-up fuel	Inlet flange
Export:	
Fuel gas	Inlet flange at existing CCGP
CO ₂	CO ₂ export pipe flange
Waste water	Pipe flange
Sea water	Sea water discharge

ISBL Scope

Existing CCGP:

- Combined Cycle Power Plant (for modifications only)
- Primary transformers and switchgear (for modifications only)
- Demineralised Water Treatment Plant (extension)

New Capture Plant

- Fuel gas production plant
- Sea water intake and discharge structures
- Coal reclaimers, conveyors, grinding and slurring plant
- Black water treatment plant
- Fuel gas pipeline
- CO₂ compressor and dryer
- Utilities - including primary and secondary cooling water, demineralised and wastewater treatment plant, firewater, instrument air, flare system, back-up fuel tank, roads and buildings.

Ancillaries Excluded from Scope

- Connections to the electricity grid system
- Coal delivery system

4. TECHNOLOGY SELECTION CO₂ CAPTURE

4.1 CASE 1 – POST-COMBUSTION CAPTURE

In Case 1, CO₂ capture is effected by installing a scrubbing unit to absorb the carbon dioxide from the gas turbine flue gases. The absorbent solution is regenerated by heating and the CO₂ is compressed, dried and exported from the Capture Plant.

There are two generic types of solvents for CO₂; chemical solvents such as amines, and physical solvents such as poly-glycols. These are usually used as a solution in water. Both of these solvent types were developed for refinery and petrochemical applications where the process streams are at elevated pressure and in reducing atmospheres. With flue gas scrubbing, the process stream is necessarily at atmospheric pressure and in an oxidising environment.

The CO₂ partial pressure in gas turbine exhaust is especially low because large volumes of un-combusted air are used to cool combustion flames, moderation air is used to control the TIT (Turbine Inlet Temperature), and air is also used to cool stator and rotor blades. The typical CO₂ content of gas turbine exhaust is 3-4% by volume, which compares starkly with a typical figure of 10-15% for fired boilers

This means that absorption is weak and large volumes of solvent are required. The low partial pressure of CO₂ in the flue gas also means that solution regeneration by simple pressure reduction, or flash, is not possible. Therefore regeneration has to be achieved by stripping the rich solvent with steam. The steam is usually generated by simply boiling part of the water component in the solution. The large volumes of solution and the absence of any advantage from pressure flash mean that heating (regenerator reboiler) load is very high.

The problem of an environment that is oxidising, rather than reducing, for which the solvents were developed, is rapid degradation of the solvent. The oxidation products tend to form a solid sludge, which is filtered from the solution, and the system is “topped up “ with fresh solvent on a regular basis.

The low partial pressure of the CO₂ means that chemical solvents such as amines are preferred rather than physical solvents. These have a stronger affinity for the CO₂ and therefore less solvent is required. Because of the oxidising nature of the oxygen rich flue gas, simple amines such as MEA are chosen rather than the more active and expensive amines such as MDEA.

Therefore Case 1 comprises the CCGT fuelled with natural gas followed by flue gas scrubbing with an MEA solution. The solution is regenerated in a reboiled stripping column with the heat provided by low-pressure steam taken from the steam cycle of the CCGT.

4.2 CASE 2 – PRE-COMBUSTION CAPTURE FROM NATURAL GAS

In Case 2, capture is effected by removing the carbon before combustion, also in the form of carbon dioxide, but generated this time through a two stage chemical process of converting the natural gas to a mixture of hydrogen and carbon dioxide.

Such pre-combustion capture of CO₂ requires that the natural gas is converted to CO₂ and hydrogen in the Capture Plant before hydrogen rich fuel gas is fed to the CCPP.

The Capture Plant first converts natural gas to synthesis gas (or syngas), which is a mixture of carbon monoxide and hydrogen. The carbon monoxide in the syngas is then converted to carbon dioxide and more hydrogen in a series of shift reactors and then a liquid solvent is used to remove the CO₂ to produce the hydrogen rich fuel gas. For NO_x control, the fuel gas is saturated with water.

There are two basic technologies, which can be used to convert natural gas into synthesis gas, plus two basic CO₂ removal technologies. Each of these has a variety of implementation options and several possible methods of NO_x control.

Figure 4.1 shows a simplified decision tree for the choice of technology for the pre-combustion capture of CO₂ from natural gas. It should be noted that for the remote case steam injection is applied rather than water saturation.




Figure 4.1 - Technology Selection case 2

4.2.1 Reforming

The chemical conversion of natural gas into mainly hydrogen and oxides of carbon is generally carried out through catalytic reaction with steam (steam reforming) or a mixture of steam and oxygen (auto-thermal reforming).


Steam Reforming

Steam reforming is the reaction of natural gas with steam over a catalyst at elevated temperature and pressure according to the reactions below:

Steam Reforming



Water Gas Shift




The reactions are endothermic and better conversion is achieved at high temperatures. The reactor is therefore configured as a series of tubes filled with catalyst inside a fired heater. The process conditions are typically 25 bar(g) and 850°C and are limited by the metallurgy of the reactor tubes. The heater is fired with either more natural gas, or in the case of a carbon capture plant, some of the carbon-free fuel gas.

The efficient conversion of the natural gas to syngas is crucial, as any unconverted carbon-containing methane left in the syngas cannot be captured as CO₂. The methane slip is inversely proportional to the partial pressure of the reactant steam and therefore a high steam to natural gas ratio is used. A further advantage is that conversion of the CO produced in the reformer to CO₂ in the shift reactor is also facilitated by the presence of large amounts of steam. A disadvantage is that the large amount of steam increases the sensible heat load in the reformer which in turn increases the fuel required by the fired heater and lowers the overall efficiency of the plant to less than 70% including auxiliary power.


Auto Thermal Reforming

Auto-thermal reforming is the reaction of natural gas with oxygen and steam over a catalyst at elevated temperature and pressure according to the reactions below:


Total Oxidation of Higher Hydrocarbons




Total Oxidation of Methane



Steam Reforming of methane



Water Gas Shift



The high temperature of the reactor, typically 1050 °C ensures that equation (3) is driven to the right, minimising the methane content of the reformed gas. This means that the amount of steam used is lower than for steam only reforming, and the exit syngas is rich in CO. The overall efficiency of the total plant including auxiliary power is just under 78%.

The capital cost of autothermal reforming is similar to steam reforming but it is significantly more efficient. Therefore autothermal reforming is chosen for the study.

The simplest way of providing oxygen for the ATR is to use air. This has the advantage of adding nitrogen to dilute the hydrogen fuel gas at the same time. The efficiency of the process is also improved by utilizing the heat from the discharge of the air compressor.

The disadvantage is that the nitrogen so introduced increases the volumetric and mass flow of the gas through the ATR, which requires more oxygen to be consumed to heat up the additional nitrogen.

The alternative is to use oxygen from an ASU. The advantages are that:

1. No nitrogen diluent is present in the ATR feed and therefore less oxygen is consumed than in the air blown case.
2. No nitrogen is present in the syngas and therefore the downstream equipment; shift, syngas cooling and acid gas removal sections are smaller and less expensive.

The disadvantage is that the ASU cost far exceeds that of the air compressor and more power is required to drive the ASU and compress the oxygen and nitrogen than is required by the air compressor alone.

Therefore as the additional capital cost of the ASU exceeds the cost savings in the downstream equipment and the parasitic power demand of the ASU is higher than that of the air compressor, an air blown ATR is chosen.

4.2.2 Varying Steam to Carbon Ratio in the Autothermal Reformer

A variety of steam to carbon ratios were considered. It was found that as the steam to carbon ratio was reduced, overall conversion of the natural gas decreased but the overall thermal efficiency increased. The overall capital cost of the different configurations did not vary much, but with steam to carbon ratios of less than 1.25, catalyst life is reduced by 20%. The increase in efficiency more than compensates for the increased catalyst costs and therefore unit costs decrease with decreasing steam to carbon ratio. The limiting factor is then the related reduction in conversion of

hydrocarbon to CO₂. At a steam to carbon ratio of 1.0, the overall carbon capture is just over 85%. Therefore a steam to carbon ratio of 1.0 is selected.

4.2.3 CO Shift system

In order to achieve the specified 85% capture of carbon, the CO in the reformed gas has to be converted to CO₂. Studies have shown that there is sufficient surplus steam from the reforming process to achieve this in a combination of a High Temperature (HT) and a Low Temperature (LT) catalytic shift reactor.

4.2.4 CO₂ removal Section

There are many commercial methods used for the removal of CO₂ from process gas streams. These include using solvents, pressure swing adsorption, temperature swing adsorption, cryogenic separation and membrane separation. For the bulk removal of CO₂ from high pressure process streams, pressure swing adsorption, temperature swing adsorption, cryogenic separation or membrane separation are not considered to be feasible and all large scale commercial applications use solvents.

There are two generic types of solvents for CO₂, chemical solvents such as amines and physical solvents such as poly-glycols. These are usually used as a solution in water. The CO₂ is absorbed from the syngas in an absorber column and regenerated either by simple pressure flash or by stripping with steam. The steam is usually generated by simply boiling part of the water component in the solution.

Solvent Selection

The advantage of chemical solvents over physical solvents is that they have a strong affinity for the CO₂ and therefore much less solvent is required. This means that process equipment, such as absorber and stripper columns, pumps and pipework is smaller. The strong affinity for CO₂ is also useful for removing CO₂ from process streams at low to moderate partial pressures. However, the stronger affinity for CO₂ also means that the regeneration energy requirement is larger.

For pre-combustion capture of CO₂ from natural gas, the partial pressure of CO₂ is less than 5 bar(a). Under these conditions, an amine-based system is selected as the reduced capital costs outweigh the slightly reduced efficiency when compared with physical solvents.

Process Configuration

There are several possible configurations of the amine CO₂ removal unit. Because of the low partial pressure of CO₂ in the product gas, the rich amine solution cannot be regenerated by simple pressure flash alone. Therefore some of the amine has to be regenerated using a steam stripper in order to become lean enough to absorb sufficient CO₂ from the syngas.

It is possible to have either a single or a two-stage CO₂ absorber.

In the two-stage absorber, the bulk (over 70%) of the CO₂ is removed in the lower section and the solution is partially regenerated by pressure flash. The partially regenerated (or semi-lean) amine solution is then returned to the top of the lower section of the absorber. The remainder of the CO₂ is removed in the upper section of the absorber by washing with lean amine solution which has a much lower residual CO₂ content because it has been regenerated with steam in a stripper column. The much lower CO₂ content of the lean amine means that it can absorb, on a tonne for tonne basis, much more CO₂ than the semi-lean solution.

Thus, if more lean solution is circulated, the duty of the semi-lean solution circuit is reduced. This reduces the pumping duty and the size of the absorber. However the size of the stripper column and the reboiler duty is correspondingly increased.

The logical extension is to have a single stage absorber and circulate only lean solution, thus removing the semi-lean solution system all together. The single stage CO₂ absorber is smaller in diameter and overall height than a two-stage absorber, and the pumping duty is reduced by over 60%. The disadvantage is that the diameter of the stripper column increases by over 60%, and the reboiler duty by over 170%. This additional heat requirement, of 50 MW_{th}, would have a significant impact on the overall plant efficiency.

The two-stage absorber option is therefore selected.

4.2.5 Fuel Gas Conditioning

At the exit of the CO₂ absorber, the fuel gas contains 42% H₂ plus 39% N₂, together with small amounts of CO₂, CO, CH₄ and Ar. This gas has a high adiabatic flame temperature and, if fed directly to a gas turbine, would generate unacceptable levels of NO_x. The flame temperature can be reduced and controlled either by the addition of nitrogen or water vapour.

Selection of Diluent

As the Auto Thermal Reformer (ATR) is blown with air, there is no Air Separation Unit (ASU); therefore a dedicated proprietary nitrogen generator would have to be used to provide nitrogen. This would consume electricity to drive the generator and compress the nitrogen, and require an expensive new unit operation. Water vapour addition is more cost effective and is therefore selected.

Water Vapour Addition

Water vapour can be added to the fuel gas either by direct steam addition, or by using a saturator. A saturator consists of a packed column, which directly contacts the fuel gas with hot water. Surplus water from the bottom of the column plus make-up water is pumped through a series of heat exchangers where it is reheated and returned to the top of the column. There is a small blow-down stream.

Alternatively, steam can be injected directly into the combustion chamber of the gas turbine. This steam can be taken either from the Capture Plant steam system or from the HRSG of the CCPP.

Water saturation is more capital intensive than direct steam addition because more process equipment is required, namely the saturator column, pumps and heat exchangers, however it is more efficient because it can use low grade heat from the Capture Plant which may otherwise be rejected to the cooling system. Direct steam addition is less efficient because the steam added is medium pressure, superheated steam which could otherwise be used to generate more electricity in the steam cycle.

When the Capture Plant is located close to the CCPP (Case 2-1), low-grade heat is available; therefore water saturation is selected because it is more efficient.

When the Capture Plant is remote from the CCPP (Case 2-2), there is no unused low-grade heat available, and because it is unfeasible to transmit low-grade heat over large distances, direct steam addition from the CCPP steam cycle is therefore selected.

4.3 CASE 3 – PRE-COMBUSTION CAPTURE FROM COAL

In Case 3, capture is again effected by removing the carbon in the form of carbon dioxide before combustion following a similar process route to the natural gas cases. However, this time, the first of the two stage chemical process of converting coal to a mixture of hydrogen and carbon dioxide consists of a gasifier rather than a reformer.

In essence, the Capture Plant converts the coal to synthesis gas (or syngas), which is a mixture of carbon monoxide and hydrogen. The carbon monoxide in the syngas is then converted to carbon dioxide and more hydrogen in a shift reactor. The sulphur containing gases and CO₂ are removed with a solvent, and nitrogen and / or water added to the fuel gas for NO_x control.

There are several gasification technologies a number of possible shift systems, two basic CO₂ removal technologies, each with implementation options, and two forms of NO_x control.

Figure 4.2 shows a simplified decision tree for the choice of technology for the pre-combustion capture of CO₂ from coal.




Figure 4.2 - Technology Selection case 3

4.3.1 Gasification

Oxidant

The oxygen required for the partial oxidation or gasification of the coal can be supplied either as air or as oxygen separated from air. Using air has the double advantage of not requiring the capital investment of an ASU and directly adds nitrogen to the fuel gas, which then acts as a diluent for NO_x control (see section 3.5 Fuel Gas Conditioning). The disadvantages of using air are that it is inefficient and expensive.

The capital costs of a gasification based capture plant are proportional to the volume flow through the plant. This includes the gasifier, cooling train, shift reactors and acid gas removal. Lower flowrates, mean lower capital costs.

Air contains less than 21% oxygen by volume. Therefore, to provide the quantity of oxygen required for gasification using air requires a volume flow of air nearly five times

more than the corresponding flow of pure oxygen. All the nitrogen associated with the oxygen in the air will pass through the plant, raising the capital cost substantially. The use of pre-separated oxygen rather than air keeps the volume throughput at a minimum and hence the capital cost at a minimum. This reduction in cost more than outweighs the cost of an Air Separation Unit (ASU).

Using oxygen rather than air is also more efficient. If air is used, all of the nitrogen present in air has to be heated to the gasification temperature, in excess of 1400°C. The source of energy for this is oxidation of the coal. Therefore more coal has to be oxidised, and more air used, than if pure oxygen alone were used. The sensible heat in the nitrogen is recovered in the cooling systems, but that enthalpy is lost from the fuel gas and the overall process becomes less efficient.

Oxygen is therefore selected as the oxidant.

Many optimisation studies have been carried out on the effect of oxygen purity on gasification based fuel gas plants. The general conclusion is that an oxygen purity of 95 vol% is the most cost effective.

The oxygen purity selected is therefore 95 vol%.

Operating Pressure

The Capture Plant gasifier can operate at a range of pressures from 35 bar(g), sufficient to deliver fuel gas to a local CCPP without further compression, up to 63 bar(g), which is the highest operating pressure yet used in a commercial coal fed gasifier.

The efficiency of a gasification based Capture Plant increases with pressure for three reasons:

1. More power can be generated through an expander, letting the syngas down from gasification pressure to gas turbine feed pressure, than is used in compressing the oxidant above gas turbine feed pressure.
2. Higher operating pressures increase the temperature at which surplus steam in the syngas will condense and hence aid efficient heat recovery.
3. More CO₂ can be recovered by pressure flash and less reboil is required.

The capital cost of a gasification based capture plant is proportional to the volume flow through the plant. This includes the gasifier, cooling train, shift reactor and acid gas removal. Higher operating pressures mean lower capital costs despite the design requirement for thicker vessel walls.

The selected operating pressure is therefore 63 bar(g) - the highest commercially proven operating pressure to date.

Gasifier Selection

There are two basic gasifier types for the continuous gasification of coal to syngas:

- Entrained Flow
- Fixed Bed

Entrained Flow

Entrained flow gasifiers are fed with pulverised feedstock entrained in either water as a slurry, or in a dense phase flow under pressure with nitrogen. Main examples are ChevronTexaco and ConocoPhillips (formerly Global Energy E-Gas) – both are slurry fed; Future Energy (formerly Noell) – both slurry and dense phase flow fed; and Shell – dense phase flow fed only.

The temperature in the gasification chamber is sufficient to melt the ash. The ash becomes an inert slag or “frit” and over 95% of the carbon and hydrocarbons in the coal are converted to carbon oxides and hydrogen. Water is an important moderating reactant and in the case of the dry feed gasifiers, is added as steam.

Sulphur in the coal is converted to H₂S with a little COS, and the other compounds reduced to their elements. Hydrocarbons in the exit gases are less than 1% and limited to methane.

Fixed Bed

Fixed bed gasifiers are gravity fed with lump feedstock through a lock hopper system at the top of the gasifier. The oxidant and steam moderator are injected at the bottom where most of the carbon in the coal is gasified to carbon oxides and hydrogen. As the feedstock moves down the bed, it is gradually heated by the hot gases rising from the bottom of the gasifier. The feedstock is pyrolysed, driving off the volatile hydrocarbons and sulphur compounds before they reach the bottom of the gasifier. Therefore the hydrocarbon content of the exit gases can be up to 25%, containing a large proportion of heavy hydrocarbons including tar, phenol and cresols. The sulphur is also present in complex compounds.


As fixed bed gasifiers do not convert sufficient carbon in the feedstock to carbon oxides, to be able to capture 85% of the carbon as CO₂, entrained flow gasifiers are selected.

High Temperature Cooling

Raw syngas exits an entrained flow gasifier at very high temperatures (> 1000°C) and is cooled by either raising high pressure steam in a specially designed boiler, or by being quenched in a water bath.

In the Capture Plant, the carbon monoxide in the raw syngas is converted to carbon dioxide (see section 4.2.3 CO Shift system for more details) ready for capture in a shift reactor according to the equation:

Water Gas Shift



This is an equilibrium (reversible) reaction and to encourage conversion of CO, the mole fraction of the steam should be as high as possible.

The mole fraction of steam in the raw syngas from an entrained flow gasifier is low, typically 5-10%, depending on the feedstock and gasifier type. Therefore much more steam has to be added to effect the conversion of the CO to CO₂.

If a high pressure boiler is fitted to cool the raw syngas from the gasifier, then the generated steam can be directly injected into the syngas upstream of the shift reactor. This steam is "clean" i.e. it is produced from high quality demineralised water (demin water) and does not contain sulphur or other contaminants. Therefore it can be used in a sweet shift reactor as well as a sour shift reactor, (see section 4.3.2 Shift System for more details). The disadvantage is that direct steam injection consumes large volumes of demin water and the make-up plant has to be sized for this duty.

An alternative is to fit a direct water quench to the outlet of the gasifier. The enthalpy in the raw syngas exiting the gasifier generates steam intimately mixed with the syngas and ready for the shift reaction. The advantage of water quenched gasifiers for shifted schemes over gasifiers fitted with boilers is that the quench is a small and simple, relatively low temperature, low cost vessel. Whereas high temperature "dirty" (the hot raw syngas contains all the ash and sulphur in the feedstock) waste heat boilers are large, complex and therefore expensive.

A previous IEA GHG study¹ in which various options have been evaluated, has shown that for Integrated Gasification Combined Cycle (IGCC) plant, the lowest cost electricity is produced by designs which use water quench gasifiers. This is because the lower efficiency of the water quench design is outweighed by the lower capital cost. As the Capture Plant and the CCPP together are in effect an IGCC, it is logical that the same economic drivers apply.

Hence for this application, especially where the addition of a large quantity of steam is required for shifting of the syngas, a quench cooled gasifier is selected.


Gasifier Technology

An oxygen blown, entrained flow gasifier, operating at a pressure of 63 bar(g) and fitted with a quench cooler, is therefore selected. There is only one commercial gasification technology, which satisfies all of these requirements, and that is the ChevronTexaco (CVX) gasifier.

4.3.2 Shift System

The shift system catalytically converts CO to CO₂ with co-product hydrogen according to the equation:

Water Gas Shift




¹ "Potential for Improvement in Gasification Combined Cycle Power Generation with CO₂ Capture" IEA GHG 2003

The shift catalyst can either be sulphur tolerant, and is then termed a “sour” shift catalyst, or it is poisoned by sulphur in which case it is known as a sweet shift catalyst.

Sweet shift catalysts can be used only with feed gases which contain very low levels of sulphur compounds, typically less than 2 ppm. The syngas from a coal gasifier contain typically 0.5% H₂S which would very quickly poison a sweet shift catalyst. Therefore sweet shift catalysts have to be installed downstream of a sulphur removal unit.


Commercial sulphur removal technologies are highly active towards H₂S, but have difficulty in removing COS from the 100 ppm present in the raw syngas down to below 2 ppm required by the sweet shift catalyst. Therefore COS hydrolysis is required upstream of the sulphur removal unit. COS hydrolysis catalyst promotes the COS hydrolysis reaction:




To use a sweet shift system, the Capture Plant therefore comprises, gasification unit and high temperature cooling, COS hydrolysis reactor, low temperature cooling, sulphur removal, reheating, steam injection or water saturation, sweet shift reactors, cooling and CO₂ removal.

The alternative is to use a sour shift catalyst which promotes the water gas shift reaction, COS hydrolysis reaction and the HCN hydrolysis reaction:


Water Gas Shift



COS Hydrolysis



HCN Hydrolysis



The conversion of COS to H₂S occurs simultaneously with the conversion of CO to CO₂ and the level of COS in the shifted syngas is low enough to use commercial sulphur removal technologies.

Therefore, using a sour shift system, the Capture Plant comprises, gasification unit and high temperature cooling with saturation of raw syngas, sour shift reactor, low temperature cooling, sulphur and CO₂ removal in the same unit.

The flow schemes used in this study contain a desaturator which greatly increases the mole fraction of steam at the inlet to a sour shift reactor such that greater than 85% carbon capture can be achieved using a single bed of sour shift catalyst.

As a previous IEA study (1) has shown, the advantage of using a sour shift catalyst system is that it is simpler and lower capital cost than a sweet shift system. A sour shift system requires only one cooling train and one acid gas removal unit compared to the two cooling trains, a heating train and water saturation system, and two acid gas removal units required by a sweet shift system.

Therefore, a single bed sour shift system is selected

4.3.3 Acid Gas Removal

In a gasification based Capture Plant there are two acid gas species to be removed, sulphur compounds and CO₂. Sulphur compounds exiting an entrained flow gasifier are mainly H₂S with a small amount of COS. Other sulphur compounds are negligible.

The two generic types of solvents for CO₂ removal are chemical solvents such as amines, and physical solvents such as poly-glycols. Both are normally used as a solution in water. The CO₂ is absorbed from the syngas in an absorber column and regenerated either by simple pressure flash or by stripping with steam. The steam is usually generated by simply boiling part of the water component in the solution.

Neither amines nor poly-glycols have strong affinity to COS. If COS is present in the feed to the acid gas removal unit, significant amounts of sulphur will “slip” through the unit and sulphur emission limits exceeded. COS can be hydrolysed to H₂S either over a sour shift catalyst or in a dedicated COS hydrolysis reactor see section 4.2.3 CO Shift system for more details.

Solvent Selection

The advantages of chemical solvents over physical solvents is that they have a strong affinity for H₂S and CO₂ and therefore much less solvent is required. This means that process equipment, such as absorber and stripper columns, pumps and pipework is smaller. However the stronger affinity also means that the regeneration energy is also larger.

The advantage of physical solvents over chemical solvents is that for CO₂ absorption at high pressure, the solvent can be regenerated using simple pressure flash. Also, most of the CO₂ is recovered at 5 bar(g), greatly reducing the CO₂ compressor power and costs. Thermal stripping is still required to recover the more strongly absorbed H₂S from the solvent, but the regeneration energy is much less than that required by physical solvents.

For pre-combustion capture from gasified coal, the partial pressure of CO₂ is about 20 bar(a). Under these conditions, a poly-glycol (trade name Selexol) based system is selected as the lower energy demand, both for regeneration and CO₂ compression, outweighs the increased capital costs when compared with chemical solvents.

Process Configuration

To avoid corrosion in the CO₂ export pipeline, the regenerated CO₂ needs to be free of H₂S. To avoid overloading the sulphur recovery plant, the H₂S in the feed to the

sulphur plant needs to be kept high. i.e. the unit needs to recover the H₂S and the CO₂ from the solvent in two separate steams.

This is carried out by absorbing the sulphur compounds first and then absorbing the CO₂.

Because of the low partial pressures of H₂S and CO₂ in the fuel gas after CO₂ capture, the rich Selexol solution cannot be regenerated by simple pressure flash alone. Therefore some of the Selexol has to be regenerated using a steam stripper in order to become lean enough to absorb sufficient H₂S and CO₂ from the syngas.

The acid gas removal system developed by UOP consists of separate H₂S and CO₂ absorber columns, a third column to concentrate the H₂S in the rich liquor and a steam stripper column to regenerate the Selexol.

4.3.4 Sulphur recovery

There are a variety of sulphur recovery technologies commercially available.

Because oxygen is available at low cost from the ASU, an oxygen blown Claus unit is selected for sulphur recovery. The tail gas from the Claus unit is compressed and returned to the inlet of the H₂S absorber column and the water effluent is returned to the de-saturator.

There are no normal sulphur emissions to atmosphere other than through the gas turbine exhaust.

4.3.5 Fuel Gas Conditioning

At the exit of the CO₂ absorber, the fuel gas contains 75% H₂ plus 16% N₂, together with small amounts of CO₂, CO, CH₄ and Ar. This gas has a high adiabatic flame temperature and, if fed directly to a gas turbine, would generate unacceptable levels of NO_x. The flame temperature can be reduced and controlled either by the addition of nitrogen or water vapour.

Selection of Diluent

There is a large flow of waste nitrogen available from the ASU, which is normally vented to atmosphere. This can be compressed and added to the fuel gas as a convenient inert diluent for both pre-capture coal cases.

Water vapour can be added to the fuel gas either by direct steam addition, or by using a saturator. A saturator consists of a packed column, which directly contacts the fuel gas with hot water. Surplus water from the bottom of the column plus make-up water is pumped through a series of heat exchangers where it is reheated and then returned to the top of the column. There is a small blow-down stream.

Alternatively, steam can be injected directly into the combustion chamber of the gas turbine. The steam is either taken from the Capture Plant steam system or from the HRSG of the CCGT.

Studies carried out by Jacobs have shown that for IGCC plants, where the low grade heat can be used efficiently, the cost of electricity production using water injection or saturation (including water purchase and purification) is higher than for schemes using nitrogen dilution. The flowschemes used in this report all include a desaturator which upgrades all of the low-grade heat so that it can be used to generate low pressure steam.

Therefore for Case 3-1, nitrogen is selected as the diluent when the capture plant is local to the CCPP.

In Case 3-1 where the Capture Plant is located local to the CCPP, the nitrogen can be injected directly into the combustion cans of the gas turbine. As the combustor cans are at a lower pressure than the fuel delivery system, the diluent nitrogen can be delivered at a lower pressure than the fuel gas thus saving on parasitic compressor power.

In Case 3-2, where the Capture Plant is remote from the CCPP, the diluent nitrogen is compressed to the full fuel gas pressure, which can be up to 60 bar(g), for pipelining purposes.

5. PROCESS DESCRIPTIONS AND PERFORMANCES

This chapter contains the process descriptions for the considered cases. The configurations for the different capture plants are discussed, together with the modifications that are needed to the CCGT. The first paragraph describes the reference case, which contains a standard CCGT fired on natural gas. The power plant configurations for the other cases are all based on this reference case but modifications are required. These modifications are assessed as well.

The technical performances of the different cases are described and compared on a basis of electrical efficiency and CO₂ emission.

Reference is made to appendix 1 for CCGT simplified process scheme and mass balance. Reference is made to appendix 2 for simplified process schemes and mass balances of Fuel/CO₂ capture plants. Reference is made to appendix 3 for plot layouts of all plants. Reference is made to appendix 4 for equipment lists of Fuel/CO₂ capture plants. Reference is made to appendix 5 for overview of power consumption/production and utility usage in all designs for Fuel/CO₂ capture plants.

5.1 REFERENCE CASE: STANDARD COMBINED CYCLE POWER PLANT

This paragraph describes the process design and performance of the reference case, which consists of a standard combined cycle power plant, including the most significant design parameters for the major equipment and systems. This case represents the reference plant without CO₂ capture, to which the other (retrofitted) cases are compared.

5.1.1 CCGT Description

The study is based on an 800 MWe power plant, consisting of two identical trains of natural gas fired, standard combined cycle units. Each of the two combined cycle trains comprises:

- One gas turbine
- One triple pressure, non fired, natural circulation Heat Recovery Steam Generator (HRSG) with reheat section
- One steam turbine with HP, IP and LP-condensing sections

The gas turbine and steam turbine for each unit are connected to a common hydrogen cooled generator. (i.e. single shaft configuration)

The overall plant design, including the selected components, has been based on state of the art proven technology.

A GE Frame 9FA gas turbine (approximately 260 MW_e), with a dry low NO_x combustion system has been selected as a typical representative proven design gas turbine in the power range considered.

Type	GE PG9351(FA)
ISO Base Rating	255.6 MWe
Heat rate	9759 kJ/kWh
Pressure ratio	15.4
Mass flow	623.7 kg/s
Exhaust Temperature	609 °C

Table 5.1 - GE Frame 9FA Gas Turbine Performance Data

This gas turbine can be considered as the current proven state of the art within its power range. Alternative gas turbines within this power range are (ISO base rating between brackets):

- Alstom GT26 (263.0 MWe)
- Siemens V94.3A (265.9 MWe)
- Mitsubishi M701F (270.3 MWe)

It shall be noted that the required modifications to these gas turbines when fired on low LHV fuel gas will differ for each type of gas turbine. With other words, the modifications as described in this report for the General Electric 9FA gas turbine should not be considered to be representative for gas turbines from other manufacturers.

For evaluation purposes the following starting points are used:

- Fuel: natural gas (Reference is made to paragraph 3.2.1)
- Ambient conditions as described in paragraph 3.6.2
- Gas turbine base load operation
- No degradation
- No fouling
- Other starting points:

Inlet pressure drop	10 mbar
Exhaust pressure drop	30 mbar

Table 5.2 - Reference Case Starting Points

The HRSG of the standard power plant is a non-fired triple pressure natural circulation boiler with single reheat. As the installation is considered to be a base load operating power plant the design is optimized with respect to the overall efficiency of the system. The higher overall efficiency will consequently result in a reduction of the fuel gas consumption and CO₂ emission compared to a non-optimised installation.

In the simplified process diagram of the standard design (see appendix 1) only major components are presented. Additional facilities, which are required for operation of the plant over the complete operating range such as de-superheating equipment, closed cooling water system and instrument air, etcetera are not shown. The HRSG supplies steam at the following pressures and temperatures:

	Pressure	Temperature
HP: High pressure	120 bara	560 °C
IP: Intermediate pressure	27 bara	560 °C
LP: Low pressure	4.6 bara	300 °C

Table 5.2 - HRSG Pressure/Temperature Levels

In order to achieve the given steam conditions the HRSG process design is according to *Table 5.3*.

High pressure superheater	Steam temperature	560 °C
Medium pressure superheater/ reheater	Steam temperature	560 °C
Medium pressure superheater	Steam temperature	300 °C
Low pressure superheater	Steam temperature	300 °C
High pressure economizer	Degrees of subcooling	3 °C
Medium pressure economizer	Degrees of subcooling	3 °C
Low pressure economizer	Degrees of subcooling	3 °C
Water preheater	Exit temperature	90 °C
Evaporator (low, medium and high pressure)	Pinch delta temperature	8 °C

Table 5.3 - HRSG process design

The condenser pressure is 0.04 bar. This is the saturation pressure at 29°C. This temperature is based on the seawater temperature of 12°C, a maximum allowed temperature rise of 7°C and an approach temperature of 10°C.

The design of the condensate heating/deaerator system has been based on a maximum deaerating efficiency in combination with a maximum thermal efficiency. Therefore the deaerator system will operate at a pressure of 1.2 bar; 105°C with a condensate feed water temperature of 90°C (The feed water temperature shall be approximately 15 °C below the deaerator temperature to ensure a high deaerator efficiency). LP steam will be used for deaeration and heating of the condensate.

The condensate from the condenser will be heated from 29°C to 90°C by means of a closed water loop, which is using the flue gas heat from the stack to preheat the condensate. Direct heating the condensate with flue gas is not preferred because the condensate entry temperature is below the dew point of the flue gas.

List of remaining starting points:

- For calculation of the auxiliary power consumption all the pumps used have an overall efficiency of 75%.
- The generator efficiency is 98.3%
- Blow down and deaerator vent is set at 0%
- Minor steam losses, such as the ejector steam and gland steam are neglected.

The steam turbine is split up in the following sections:

- A HP section, which is supplied with steam from the HP superheater
- A MP section, which is supplied with a mixture of steam from the MP superheater and steam from the HP turbine which is reheated in the reheat section
- A LP section, which is supplied with a mixture of steam from the LP superheater and steam from the MP turbine section

The steam turbine has the following characteristics:

Section	isentropic efficiency	Inlet pressure	Inlet temperature	Outlet pressure	Outlet temperature
High pressure	87.0%	120 bara	560 °C	27.4 bara	346 °C
Intermediate pressure	88.5%	27 bara	560 °C	4.6 bara	320 °C
Low pressure	90.0%	4.6 bara	318 °C	0.04 bara	29 °C

Table 5.4 - Steam Turbine Data

An additional loss of 1% of the steam turbine shaft power output is used to take account for the shaft and other losses.

CCPP Performance

The resulting energy balance for the standard power plant firing natural gas is shown in *Table 5.5*:

Power Plant Energy Balance		
Gas Turbine Energy Input		1404.6 MWth
	Fuel Consumption LHV	1404.9 MWth
	Fuel Sensible Heat Input (Tref. 15 °C)	-0.3 MWth
	Total Gas Turbine Energy Input	1404.6 MWth
Gas Turbines		525.9 MW
	GT Gross power	554.4 MW
	GT losses	-28.6 MW
	Net GT output	525.9 MW
Steam Turbines		282.8 MW
	ST Shaft power	285.7 MW
	ST losses	-2.9 MW
	Net ST output	282.8 MW
Generator losses		-14.0 MW
Balance of Plant losses		-9.8 MWe
	Boiler feed water pumps	-2.8 MWe
	Cooling water pumps	-6.0 MWe
	Condensate pumps	-0.2 MWe
	Remaining losses (0.1%)	-0.8 MWe
	BOP losses	-9.8 MWe
Total Plant net power		784.8 MWe
Net electrical efficiency		55.9 %

Table 5.5 - Reference Case Power Plant Energy Balance

* Remaining losses are assumed to be 0.1% of the plant gross power output. These losses comprise small power consumers like the closed cooling water system pumps, instrument air compressor, HVAC, etc.

5.2 CASE 1: POST COMBUSTION CO₂ CAPTURE

The first case comprises post combustion CO₂ capture, which is effected by using direct scrubbing of the flue gas with a proprietary amine solution. This is a so-called “end of pipe” method, as the capture plant is located downstream of the power plant and CO₂ is removed from the flue gas of the CCPP, see *Figure 5.1*.




Figure 5.1 - Case 1 Scheme

5.2.1 CCPP Description

This case does not require significant modifications to the equipment of the reference power plant. The CO₂ capture installation will be a strictly add-on plant, only to consume energy from the power plant required for the flue gas scrubbing. All assumptions, starting points and equipment data concerning the power plant are equal to the reference case.

Main process modifications to the reference CCPP are:

- Tie-in to LP steam system to supply LP steam from the power plant to the reboiler section(s)
- Tie-in to the condensate system(s) to receive the cooled condensate from the reboiler section(s)
- Tie-in to the stack of the HRSG's in order to discharge the fluegas to the CO₂ capture plant.

For overall availability reasons it may be preferred to install switch over dampers which allow for base load operation with and without CO₂ capture.

Each CCPP unit is equipped with a scrubbing unit, which removes the CO₂ from the flue gasses. This scrubbing unit is located downstream of the Heat Recovery Steam Generator, before the flue gasses leave the stack. Paragraph 5.2.3 describes the complete CO₂ capture installation in detail.

The capture installation needs a significant amount of heat for its internal process. This heat is supplied in the form of superheated low pressure steam from the CCPP

steam cycle, which is extracted upstream of the condensing LP steam turbine section. A direct consequence is that the condensing LP steam turbine section will be operated at low load, with about 10% of the design steam flow through the section.

The capture unit returns 100% of the extracted steam as sub-cooled condensate, which is cooled to 30 °C in seawater cooled heat exchangers and mixed with the condensate flow from the CCPP main condenser.

The condensate flow from the condensing steam turbine section to the condenser decreases because of this extracted steam. The main condenser duty is therefore significantly lower in comparison to the design case, and the cooling water flow is decreased to 60% of the flow in the reference case. It is required to discharge the condensate heat to the surface water, as there are no low-grade heat consumers available.

The scrubber unit will introduce an additional pressure drop at the flue gas side. If no action is taken this would result in exceeding allowable pressure limits for the HRSG and gas turbine ducting. To anticipate this an induced draft flue gas fan is introduced to overcome the extra exit pressure loss. This will introduce an additional auxiliary power consumer in the capture unit. It should be noted that installation of the induced draft fan prevents loss of performance of the gas turbine due to increased backpressure of the HRSG.

5.2.2 CCPP Performance

Table 5.6 shows the energy balance for the CCPP in case 1. The energy input and gas turbine output are unchanged compared to the reference case. This is expected, as the process conditions for the gas turbine have not changed.

However, the steam turbine power output decreased considerably, which is due to the LP steam extraction. The condensing steam turbine section is almost bypassed, and this causes the output to fall from 283 MWe in the reference case to 157 MWe.

As a result, the CCPP electrical efficiency decreased to 47.3%.

Power Plant Energy Balance			
Gas Turbine Energy Input		1404.6 MWth	
	Fuel Consumption LHV		1404.9 MWth
	Fuel Sensible Heat Input (Tref. 15 °C)		-0.3 MWth
	Total Gas Turbine Energy Input		1404.6 MWth
Gas Turbine		525.9 MW	
	GT Gross power		554.4 MW
	GT losses		-28.6 MW
	Net GT output		525.9 MW
Steam Turbine		157.1 MW	
	ST Shaft power		158.7 MW
	ST losses		-1.6 MW
	Net ST output		157.1 MW
Generator losses		-11.5 MW	
Balance of Plant losses		-7.1 MWe	
	Boiler feed water pumps		-2.8 MWe
	Cooling water pumps		-3.6 MWe
	Condensate pumps		0.0 MWe
	Remaining losses (0.1%)		-0.7 MWe
	BOP losses		-7.1 MWe
Total Plant net power		664.3 MWe	
Net electrical efficiency		47.3 %	
Steam supply to CO ₂ capture plant(@ 4.6 bar, 318°C)		309.6 t/hr	

Table 5.6 - Case 1 Power Plant Energy Balance

5.2.3 Capture Plant Description

The Capture Plant captures CO₂ after combustion from the exhaust gas from the CCPP. The exhaust gas from the CCPP is first cooled in a water quench where most of the steam in the flue gas is condensed. The cooled exhaust gas is fed to the CO₂ absorber where CO₂ is scrubbed from the exhaust gas by an amine solution. The CO₂ lean flue gas is then vented. The rich amine solution is regenerated by thermal stripping, and the captured carbon dioxide is compressed and dried for export.

Quench

The gas turbine exhaust leaving the HRSG is both too hot, (typically 100°C) and it contains too much steam to be fed directly to the CO₂ absorber. The quench column both cools the exhaust stream to near ambient and condenses most of the steam.

The quench column is a large packed tower in which a large amount of water which cascades down the packing. The gas turbine exhaust flows up the quench column and is cooled by direct contact cooling. A significant volume of circulating water is required to contact the exhaust gas to remove the sensible and latent heat.

The water from the bottom of the quench column is cooled against sea water in the quench water cooler and returned to the top of the quench column. The excess water,

condensed from the gas turbine exhaust gas, is purged and sent to waste water treatment.

The cooled gas turbine exhaust leaves the top of the quench column at 38°C and is then blown to the CO₂ absorber column by the absorber feed fan.

Acid Gas Removal

Carbon dioxide is removed from the cooled gas turbine exhaust by scrubbing with MEA. The carbon dioxide is absorbed into the amine solution, which is then regenerated in a stripping column where the carbon dioxide is stripped from the amine solution with steam. The performance data for the stripper unit was obtained from vendor data for this study.

The flue gas is blown from the absorber feed fan to the bottom of the absorber column. It flows up the packed column against a down flowing aqueous solution of MEA. The solution is "lean" in carbon dioxide content and enters the column at 34° C. The carbon dioxide is absorbed from the gas turbine exhaust, making a 'rich' solution, which leaves the bottom of the absorber column.

The gas turbine exhaust, after having any droplets of MEA washed out of it in a demin water wash section at the top of the column, leaves at 42°C, lean in carbon dioxide.

The absorbed carbon dioxide is stripped from the rich solution in the stripper column. The rich solution is pumped from the bottom of the absorber column and is then heated to 107°C in the rich/ lean exchanger. The hot rich solution passes to the top of the stripping column and flows down against an upflow of steam that desorbs the carbon dioxide from the solution. The steam is generated in the stripper reboiler from the water in the amine solution. Heat for the stripper reboiler is supplied by low pressure steam from the CCGT HRSG.

The carbon dioxide, together with some steam, exits the top of the column at 112°C and passes to the stripper condenser where it is cooled to 70°C, condensing most of the steam. The remaining vapour flows into the stripper trim condenser where it is cooled to 22°C against sea water. Condensate is collected after each condenser in knock out drums and is then pumped by the stripper reflux pump back to the top of the stripping column.

The MEA solution leaves the bottom of the stripping column at 125°C, lean in carbon dioxide, and passes through the rich / lean exchanger. It is then pumped by the lean amine pump through the lean amine air cooler and then the lean amine trim cooler where it is cooled to 38°C against sea water. Finally the lean amine is returned to the top of the absorber column.

CO₂ Compression and Drying

The CO₂ removed in the acid gas removal unit is compressed to 22 bar(g), dried using a molecular sieve and compressed again to 110 bar(g) for export. The molecular sieve is regenerated using hot process water from the gas treatment section in a "no loss" configuration, which recycles the regeneration off gas back to the CO₂ compressor.

The CO₂ compressor is an 8-stage integral gear machine with full intercooling after stages 1 to 5, partial intercooling after stage 6 and no intercooling after stage 7.

Cooling Water

Seawater, from a new intake, is circulated once through major coolers and condensers and then discharged directly back to the sea. A secondary fresh water system is used for smaller coolers and machinery.

Water Treatment

The water treatment plant treats the quench water purge and produces demin water make-up for the acid gas removal unit.

A small quantity of sludge is produced for disposal offsite.

5.2.4 Capture Plant Performance

Table 5.7 shows the performance of the capture plant in case 1. There is no fuel input in this case, neither there is syngas output. The capture plant does require an amount of electricity for the process, next to the steam import from the CCPP (which is not shown in the table).

A detailed breakdown of the power producers and consumers within the capture plant can be found in Appendix 5.

The CO₂ capture efficiency is calculated by taking the actual CO₂ emission, compensate for the CO₂ in the inlet air to the gas turbine, and divide this by the maximum CO₂ emission from burning the original fuel (before reforming).

CO₂ Capture Plant Energy Balance	
Capture Plant Fuel Energy Input (LHV)	- MWth
Capture Plant Syngas Output (LHV + Heat)	- MWth
CO ₂ Capture Plant Auxiliary Power Consumption	-38.5 MWe
CO ₂ Capture Plant Power Production	- MWe
Capture Plant Net Power Output	-38.5 MWe
CO ₂ Capture Efficiency	85.7 %

Table 5.7 - Case 1 Energy Balance Capture Plant

5.2.5 Overall Plant Balance

The energy balance for the post combustion CO₂ capture power plant is shown in Table 5.8. The net power production decreased in comparison with the reference case. This is caused by the decreased production in the CCPP because of steam extraction to the capture plant and by the electrical power consumption in the capture plant.

Total Overall Plant Energy Balance	
Total Overall Plant Energy Input (LHV)	1404.6 MWth
Combined Cycle Power Plant Net Electrical Output	664.3 MWe
CO ₂ Capture Plant Auxiliary Power Consumption	-38.5 MWe
CO ₂ Capture Plant Power Production	0.0 MWe
Total Overall Plant Net Power Output	625.9 MWe
Net Overall Plant Electrical Efficiency	44.6 %

Table 5.8 - Case 1 Overall Plant Energy Balance

5.3 CASE 2-1: PRE COMBUSTION CO₂ CAPTURE BY LOCAL H₂ PRODUCTION FROM NATURAL GAS

In case 2-1, capture is effected by removing the carbon from natural gas fuel before combustion. This carbon removal is done in the CO₂ Capture Plant, after which the carbon-free syngas is fed to the gas turbine. This syngas has a significantly lower heating value compared with natural gas. Firing this fuel will require modifications to the gas turbines.

The Capture Plant is located at or near the power plant plot and therefore this case is a “local” case, in contrast to case 2-2, at which the Capture Plant is located at 40 km distance from the CCPP (remote case).

The capture plant is located upstream of the CCPP, see *Figure 5.2*.




Figure 5.2 - Case 2-1 Scheme

5.3.1 Capture Plant Description

This section is to be read in conjunction with the process block diagram for case 2-1 and the mass balance for case 2-1, P03-2101.

The Capture Plant converts a feed of natural gas to a fuel gas mixture of hydrogen and nitrogen. First the gas is led through a desulphurisation section in which the H₂S in the natural gas is captured by using a bed of ZnO. After desulphurisation the Capture Plant consists of a reforming stage, where a mixture of natural gas with steam and air is converted to synthesis gas, or syngas, which is a mixture of H₂, CO, CO₂ and N₂. The reformer is followed by two stages of shift reaction, where the carbon monoxide and residual steam are converted to hydrogen and carbon dioxide. The reaction stages are followed by the removal of CO₂ from the shifted syngas, using a chemical solvent, and delivery of the fuel gas to battery limits. The CO₂ is regenerated from the solvent and compressed for delivery to battery limits for subsequent disposal. The resulting hydrogen rich syngas is saturated with water to control NO_x formation during combustion in the gas turbines.


The Capture Plant recovers waste heat from the high temperature sections of the process by generating high-pressure superheated steam. Some of this steam is used in the process and the remainder is used to generate electricity, which is used within the plant. For the remaining electricity demand, additional electricity is imported from the external grid.

Auto-Thermal Reformer


Natural gas is first pre-heated to 380°C and passed through a desulphurisation reactor where all of the sulphur components are converted to H₂S, which is then absorbed. The reforming and shift catalysts can easily be poisoned by sulphur and therefore only a very low level (less than 1 ppm) can be tolerated.

The gas is then mixed with process steam, sufficient to give a steam to carbon ratio of 1.0, heated further and passed to an air-blown auto-thermal reformer (ATR). In the ATR, the natural gas is sub-stoichiometrically combusted with air. It is then passed over a high temperature reforming catalyst, which promotes the formation of synthesis gas according to the following reactions:


Partial Oxidation of Higher Hydrocarbons




Partial Oxidation of Methane



Steam Reforming of Methane



Water Gas Shift



The high temperature of partial oxidation maximises reforming of the gas and minimises its methane content.

High Temperature Cooling

The syngas stream leaves the ATR at 950°C, and it is cooled by raising and superheating high pressure steam and by preheating the feed stream to the ATR.

CO Shift

The syngas from the ATR contains 14 mol%(dry) CO which must be converted to CO₂ in order to facilitate the removal of carbon. This conversion is carried out in two shift

reactors, namely the high-temperature and the low-temperature (HT shift and LT shift). The shift reaction is exothermic and the heat of reaction is recovered after the HT shift reactor by raising more HP steam and by preheating the boiler feed water.

Cooling and Condensation

The enthalpy of the syngas exiting the LT Shift provides heat for the saturator, heating of the fuel gas product and preheating of demineralised water feed to the deaerator. The gas stream is finally cooled to 50°C in an air cooler and fed to the CO₂ absorber in the acid gas removal unit. The condensate is separated from the syngas and the dissolved gases are stripped out in the steam system.

Acid Gas Removal

The CO₂ absorber is a two-stage counter-current column where the CO₂ rich syngas is contacted first with a “semi-lean” solution of MDEA solvent, then with a “lean” solution to absorb the carbon dioxide, leaving the hydrogen/nitrogen fuel gas.

The CO₂-rich stream leaving the bottom of the absorber is regenerated by depressurisation in three stages. In the first stage the liquid stream passes to the HP flash column where the pressure is reduced from about 30 bar(g) to about 5.5 bar(g), allowing CO₂ gas to flash off. The liquor then passes to the LP flash column, which operates at about 0.2 bar(g), where further flashing takes place and some stripping as the liquid passes through a packed bed counter-current with the vapour stream from the final stage. At the bottom of this column the liquid is sufficiently “lean” to be recycled to the absorber as “semi-lean” solvent.

Approximately 85% of the liquid from the LP flash column is recycled to the absorber, while the remaining 15% passes to the third stage of regeneration. This stage is a reboiled stripper column, where the liquid is contacted with steam in a packed bed. The steam is generated by boiling some of the water present in the MDEA solution. The liquor from the bottom of the column is sufficiently low in CO₂ to be recycled to the absorber as “lean” solution. The vapour overhead from the stripper column passes through the LP flash column, as described above, and is cooled in the LP flash column condenser. The off-gas from the condenser passes to the CO₂ compressor.

CO₂ Compression

The CO₂ removed in the acid gas removal unit is compressed to 22 bar(g), dried using a molecular sieve and compressed again to 110 bar(g) for export. The molecular sieve is regenerated using hot process water from the gas treatment section in a “no loss” configuration, which recycles the regeneration off gas back to the CO₂ compressor.

Gas Conditioning

Carbon dioxide free syngas from the top of the CO₂ absorber is heated and passed to a saturator to raise the water content, which together with the nitrogen present, are sufficient to control NO_x formation in the gas turbine combustor to 25 ppmvd. It is then superheated to 230°C against circulating demineralised water, before being sent to the local combined cycle power plant at 27.5 bar(g).

Steam System

Superheated steam is generated at 122 bar(g) by heat recovery from the ATR product gas stream. The outlet steam from the first stage, at 37 bar(g), is reheated by heat exchange with the ATR product gas stream. Part of this steam is used to strip the process condensate of the dissolved gases and the whole stream is fed to the ATR as process steam. The remainder of the 37 bar(g) superheated steam passes to the second stage of the turbine. Pass out steam is taken from the second stage of the turbine and condensed at 2.5 bar(g) to provide reboil for the stripper column in the acid gas removal unit. The remainder of the steam passes to the condensing stage of the turbine.

Condensate from the final stage of the turbine passes to a deaerator for eventual recycle to the HP boiler. Process condensate separated from the syngas during cooling is also recycled after passing through a stripping column to remove dissolved process gases. A make-up stream of demineralised water is fed to the deaerator to replace the process steam consumed in the reformer.

Power Block

The superheated steam raised in the high temperature cooling is fed to a 3-stage condensing steam turbine in the power block. The power generated is used for onsite consumption.

Cooling Water

Seawater, taken from a dedicated intake, is circulated once through the major coolers and condensers and discharged directly back to the sea through a dedicated discharge system. A secondary fresh water system is used for smaller coolers and machinery.

5.3.2 Capture Plant Performance

Table 5.9 shows the performance of the capture plant. The fuel input in MW is given, based on the LHV value of the feedstock. The fuel output is presented in MW, which is based on LHV of the produced syngas plus the sensible heat of the syngas. This is important in the local cases as the fuel is heated to around 230 °C, which gives a significant part of the heat input to the gas turbine.

Furthermore the net electricity consumption is presented, which exists from the consumed electricity for all power consumers minus the electricity production from the power block of the capture plant.

A detailed breakdown of the power producers and consumers within the capture plant can be found in Appendix 5.

The CO₂ capture efficiency is calculated by taking the actual CO₂ emission, compensate for the CO₂ in the inlet air to the gas turbine, and divide this by the maximum CO₂ emission from burning the original fuel (before reforming).

CO₂ Capture Plant Energy Balance	
Capture Plant Fuel Energy Input (LHV)	1672.4 MWth
Capture Plant Syngas Output (LHV + Heat)	1417.3 MWth
CO ₂ Capture Plant Auxiliary Power Consumption	-158.9 MWe
CO ₂ Capture Plant Power Production	43.0 MWe
Capture Plant Net Power Output	-115.9 MWe
CO ₂ Capture Efficiency	85.6 %

Table 5.9 - Case 2-1 Capture Plant Energy Balance

5.3.3 CCPP Description

The overall process flow scheme of the power plant is not modified with respect to the reference power plant. However modifications are required to the gas turbines to enable the firing of a fuel with a significantly lower heating value. The different fuel also has a large impact on the gas turbine control and the process parameters of the power plant.

Main process modifications to the reference CCPP are:

- Replacement of gas turbine Dry Low NO_x(DLN) combustion system by a conventional dual fuel(natural gas and syngas) system provided with steam injection for NO_x abatement.
- Tie-in in MP steam system for steam supply to the gas turbine steam injection system. A steam injection system is needed in all cases, to limit NO_x emissions when the unit is operated on the back-up fuel (natural gas).
- Demin water plant capacity to be enlarged for steam injection or additional demin water plant needed.

Because of the high hydrogen content in the fuel it is not possible to use a DLN combustion system. This means that the DLN combustors need to be removed and replaced by conventional combustors. To keep the NO_x emissions within the limit of 25 ppmv (dry @15%O₂), it is necessary to prepare the fuel composition with diluents, e.g. by adding N₂ or by applying steam injection. Both methods decrease the flame temperature and limit the thermal NO_x formation.

When feeding the gas turbine with the same fuel input as in the natural gas application, the fuel mass flow into the gas turbine increases significantly when firing low LHV fuel. In order to keep the compression ratio of the gas turbine at design level in order to avoid potential compressor surge, the expander inlet flow should be kept at design level as well. This is realised by decreasing the inlet air flow. This is achieved by controlling the Inlet Guide Vanes (IGV's), which can be partly shut to decrease the air intake.

The consequence of decreasing the inlet flow to the GT compressor by IGV control is a decrease in the amount of compressor work. The turbine still receives the same flow as in the design case, because of the increased fuel flow. These effects result in an increase in the overall gas turbine power output.

Information from GE showed that the maximum net electrical power output of their frame 9 gas turbine is limited to 286 MWe (design value = +/- 260 MWe). Therefore it is necessary to lower the combustor exit temperature in order to control the power output.

To increase the efficiency of the power plant it can be feasible to apply fuel preheating when the gas turbine is fired on natural gas. Fuel preheating increases the sensible heat input to the combustion chamber and reduces the amount of fuel energy needed (and therefore the fuel consumption). The heat for fuel heating is usually taken from the steam cycle, which will cost some electrical power (as this is not available for expansion in the steam turbine). The overall effect on net electrical efficiency is however positive.

When the gas turbine is fired on a low-LHV fuel, the positive effect of fuel heating increases significantly. This is the consequence of the much higher fuel flow to the combustion chamber. Fuel preheating should therefore be applied with these kinds of fuels.

The fuel is delivered from the fuel processing plant already at a temperature of 230 °C. The fuel is not preheated to a higher temperature, and this should be considered as an option for optimization.

5.3.4 CCGP Performance

Table 5.10 below shows the gas turbine parameters fired on the low-LHV syngas in comparison to the gas turbine parameters when fired on natural gas.

Case	Reference Case	Case 2-1
Fuel LHV	46,855 kJ/kg	7,476 kJ/kg
Fuel Flow / Temperature	15.0 kg/s / 10 °C	89.7 kg/s / 230 °C
Steam Injection Flow / Temperature	-	-
Air Inlet Flow	618 kg/s	535 kg/s
Combustor Exit Temperature	1352 °C	1270 °C
Exhaust flow / Temperature	633 kg/s / 608 °C	625 kg/s / 565 °C
Net Power Output	258.8 MW	286.0 MW
Net Electric Efficiency (LHV)	36.8 %	42.6 %

Table 5.10 - Case 2-1: Gas Turbine performance

The table shows that the net electric power output of the gas turbine increases to 286 MWe, which is an increase of almost 11%. This 286 MWe is the maximum net power output for this gas turbine, according to information provided by General Electric. The exhaust gas flow rates are similar but due to the lower Combustor Exit Temperature the exhaust gas temperature has decreased to 565 °C. This means that the HRSG section will work at different flue gas conditions. The low-LHV fuel will influence the performance of the steam cycle. Off-design calculations show that the HRSG and steam turbine can operate properly at the given conditions without modifications.

The following table shows the overall energy balance for the combined cycle power plant.

Power Plant Energy Balance		
Gas Turbine Energy Input		1417.3 MWth
	Fuel Consumption LHV	1341.6 MWth
	Fuel Sensible Heat Input (Tref. 15 °C)	75.7 MWth
	Total Gas Turbine Energy Input	1417.3 MWth
Gas Turbine		581.2 MW
	GT Gross power	609.7 MW
	GT losses	-28.6 MW
	Net GT output	581.2 MW
Steam Turbine		252.0 MW
	ST Shaft power	254.5 MW
	ST losses	-2.5 MW
	Net ST output	252.0 MW
Generator losses		-14.2 MW
Balance of Plant losses		-9.3 MWe
	Boiler feed water pumps	-2.6 MWe
	Cooling water pumps	-5.7 MWe
	Condensate pumps	-0.2 MWe
	Remaining losses (0.1%)	-0.8 MWe
	BOP losses	-9.3 MWe
Total Plant net power		809.6 MWe
Net electrical efficiency		57.1 %

Table 5.11 - Case 2-1 Energy Balance Power Plant

The mass and heat balance for the most important streams are shown in Appendix 1.

5.3.5 Overall Plant Performance

The overall energy balance for the combined CO₂ capture plant and CCPP is shown in Table 5.12, which combines the results from Table 5.9 and Table 5.11.

Total Overall Plant Energy Balance	
Total Overall Plant Energy Input (LHV)	1672.4 MWth
Combined Cycle Power Plant Net Electrical Output	809.6 MWe
CO ₂ Capture Plant Auxiliary Power Consumption	-158.9 MWe
CO ₂ Capture Plant Power Production	43.0 MWe
Total Overall Plant Net Power Output	693.7 MWe
Net Overall Plant Electrical Efficiency	41.5 %

Table 5.12 - Case 2-1 Overall Plant Energy Balance

5.4 CASE 2-2: PRE COMBUSTION CO₂ CAPTURE BY REMOTE H₂ PRODUCTION FROM NATURAL GAS

Case 2-2 is similar to case 2-1, except for the fact that the fuel processing plant is located at 40 km distance from the power plant plot. The syngas is transported through pipelines from the fuel plant to the power plant, see *Figure 5.3*.




Figure 5.3 - Case 2-2 Scheme

5.4.1 Capture Plant Description

This section is to be read in conjunction with the process block diagram for case 2-2 and the mass balance for case 2-2 P03-2201.

The Capture Plant converts natural gas to synthesis gas (or syngas), which is a mixture of carbon monoxide and hydrogen. The carbon monoxide in the syngas is then converted to carbon dioxide and more hydrogen in a series of catalytic reactors. The CO₂ is removed by an absorbent solution and the resultant hydrogen rich syngas is compressed, dried and exported from the site at ambient temperature for piping to the CCPP. NO_x formation on combustion in the CCPP is controlled by direct injection of steam taken from the CCPP steam cycle. The captured CO₂ is dried and compressed before being exported from the Capture Plant site.

Most of the process steps are equal to the process steps in case 2-1 and will not be repeated. The items that are different are described here.

Auto Thermal Reformer

Reference is made to paragraph 5.3.1.

High Temperature Cooling

Reference is made to paragraph 5.3.1.

CO Shift

Reference is made to paragraph 5.3.1.

Cooling and Condensation

Reference is made to paragraph 5.3.1.

Acid Gas Removal

Reference is made to paragraph 5.3.1.

CO₂ Compression

Reference is made to paragraph 5.3.1.

Gas Conditioning

Carbon dioxide free syngas from the top of the CO₂ absorber in the AGR is dried and compressed to 39 bar(g) in order to transfer the fuel to the remote combined cycle power plant.

In the CCGT steam is added to the fuel gas for NO_x control and then the combined fuel gas stream is heated using steam to 230°C before being fed to the gas turbine combustors.

Steam System

Reference is made to paragraph 5.3.1.

Power Block

Reference is made to paragraph 5.3.1.

Cooling Water

Seawater, from a new intake, is circulated once through major coolers and condensers and discharged directly back to the sea. A secondary fresh water system is used for smaller coolers and machinery.

Fuel Gas Pipeline

The 40 km pipeline for the transportation of fuel gas between the Capture Plant and the CCGT site is made of carbon steel. No special metallurgy is required, as the fuel gas is dried before transportation. The line size is 36 " and the fuel gas inlet and outlet pressures are respectively 39.0 barg and 30.6 barg.

5.4.2 Capture Plant Performance

Table 5.13 shows the performance of the capture plant in case 2-2. In comparison with the performance of the capture plant of case 2-1, which is shown in Table 5.9, a few differences can be recognised.

The syngas output in MW is lower, while the feedstock input in MW is approximately the same. This can be explained by the fact that however the syngas mass flows are similar, in case 2-2 the syngas leaves the fuel plant at low temperature, i.e. the sensible heat content is almost zero. The fuel preheating in this case takes place in the CCPP, and will cause a loss in power production there. Because the fuel is not preheated in the capture plant, more heat is available for power production in the power block, and this results in a higher capture plant power production in comparison to case 2-1.

The power consumption has increased, which is a direct consequence of the need for compressing the syngas, so that it can be transported through the 40 km pipeline to the CCPP plot. A detailed breakdown of the power producers and consumers within the capture plant can be found in Appendix 5.

The CO₂ capture efficiency is calculated by taking the actual CO₂ emission, compensate for the CO₂ in the inlet air to the gas turbine, and divide this by the maximum CO₂ emission from burning the original fuel (before reforming).

CO₂ Capture Plant Energy Balance	
Capture Plant Fuel Energy Input (LHV)	1671.0 MWth
Capture Plant Syngas Output (LHV + Heat)	1344.7 MWth
CO ₂ Capture Plant Auxiliary Power Consumption	-168.0 MWe
CO ₂ Capture Plant Power Production	71.1 MWe
Capture Plant Net Power Output	-96.9 MWe
CO ₂ Capture Efficiency	85.7 %

Table 5.13 - Case 2-2 Energy Balance Capture Plant

5.4.3 CCPP Description

The fuel is delivered at the power plant at a low temperature of 21.5 °C (compared to a temperature of 230 °C in the local case 2-1). This is due to the 40 km transportation distance between the two sites.

In paragraph 5.3.3 it was stated that preheating the fuel is a feasible option to increase the overall efficiency of the power plant. In this case the heat for the fuel preheating is supplied from the CCPP steam system.

Main process modifications to the reference CCPP are:

- Replacement of gas turbine Dry Low NO_x(DLN) combustion system by a conventional dual fuel(natural gas and syngas) system provided with steam injection for NO_x abatement.
- Tie-in in MP steam system for steam supply to the gas turbine steam injection system
- Pre-mix system for mixing syngas with MP steam

- Demin water plant capacity to be enlarged for steam injection or additional demin water plant needed

To avoid NO_x emissions above permitted levels it is necessary to add extra diluents to the fuel. It is possible to do this at the fuel processing plant, but this would mean that the extra diluent is transported together with the fuel over 40 km of pipeline. When the diluent is added at the power plant plot, the extra compression energy is avoided. At the power plant plot, steam is available as diluent. The steam is injected directly into the gas turbine combustion chamber, without premixing it with the fuel. In the combined cycle power plant in this study, IP steam of about 330 °C @ 27 bara is available for steam injection.

In this study the fuel is preheated until the temperature of the mixture of fuel and steam is about 230 °C. At this temperature no extra measures need to be taken to materials in the existing equipment. The temperature level can be subject to optimization, as this is not considered in this study.

5.4.4 CCPP Performance

Table 5.14 shows the gas turbine performance for case 2-2 in comparison to the reference case.

Case	Reference Case	Case 2-2
Fuel LHV	46,855 kJ/kg	8,622 kJ/kg
Fuel Flow / Temperature	15.0 kg/s / 10 °C	77.9 kg/s / 215 °C
Steam Injection Flow / Temperature	-	12.0 kg/s / 337 °C
Air Inlet Flow	618 kg/s	536 kg/s
Combustor Exit Temperature	1352 °C	1268 °C
Exhaust flow / Temperature	633 kg/s / 608 °C	626 kg/s / 564 °C
Net Power Output	258.8 MW	288.8 MW
Net Electric Efficiency (LHV)	36.8 %	42.6 %

Table 5.14 - Case 2-2 gas turbine performance

The following table shows the energy balance for the complete combined cycle power plant.

Power Plant Energy Balance			
Gas Turbine Energy Input		1344.7	MWth
	Fuel Consumption LHV	1343.0	MWth
	Fuel Sensible Heat Input (Tref. 15 °C)	1.8	MWth
	Total Gas Turbine Energy Input	1344.7	MWth
Gas Turbine		580.7	MW
	GT Gross power	609.3	MW
	GT losses	-28.6	MW
	Net GT output	580.7	MW
Steam Turbine		204.9	MW
	ST Shaft power	207.0	MW
	ST losses	-2.1	MW
	Net ST output	204.9	MW
Generator losses		-13.3	MW
Balance of Plant losses		-8.1	MWe
	Boiler feed water pumps	-2.4	MWe
	Cooling water pumps	-4.7	MWe
	Condensate pumps	-0.2	MWe
	Remaining losses (0.1%)	-0.8	MWe
	BOP losses	-8.1	MWe
Total Plant net power		764.3	MWe
Net electrical efficiency		56.8	%

Table 5.15 - Case 2-2 Energy Balance Power Plant

When *Table 5.15* is compared to the case 2-1 performance, the decreased steam turbine power generation attracts the attention. This is caused by the fact that steam is used to preheat the syngas fuel at the CCPP plot. This steam is extracted from the CCPP steam cycle and is no longer available for expansion in the LP steam turbine section. Therefore the power generation from the steam turbine is lower than in the local case. The amount of heat which is transferred to the fuel by preheating is equal to 58.2 MWth.

The mass and heat balance for the most important streams are shown in Appendix 2.

5.4.5 Overall Plant Performance

The overall energy balance for the combined CO₂ capture plant and power plant is shown in *Table 5.16*, which is a combination of *Table 5.13* and *Table 5.15*.

Total Overall Plant Energy Balance	
Total Overall Plant Energy Input (LHV)	1671.0 MWth
Combined Cycle Power Plant Net Electrical Output	764.3 MWe
CO ₂ Capture Plant Auxiliary Power Consumption	-168.0 MWe
CO ₂ Capture Plant Power Production	71.1 MWe
Total Overall Plant Net Power Output	667.4 MWe
Net Overall Plant Electrical Efficiency	39.9 %

Table 5.16 - Case 2-2 Overall Plant Energy Balance

5.5 CASE 3-1: PRE COMBUSTION CO₂ CAPTURE BY LOCAL H₂ PRODUCTION FROM COAL

In case 3-1, capture is effected by removing the carbon from the Coal feedstock before combustion. The Capture Plant converts the coal by partial oxidation (gasification) to synthesis gas (or syngas), which is a mixture of carbon monoxide and hydrogen. After capture of CO₂ the carbon-free syngas is fed to the gas turbine, see *Figure 5.4*. In case 3-1 the capture plant is located at or near the power plant plot, in comparison to case 3-2 where the capture plant is located at 40 km distance from the power plant.




Figure 5.4 - Case 3-1 Scheme

5.5.1 Capture Plant Description

The Capture Plant converts a feed of coal to a fuel gas mixture of hydrogen and nitrogen suitable for a gas turbine. The plant consists of a gasification stage where a mixture of coal and water is partially oxidised with oxygen from an air separation unit (ASU). The synthesis gas, or syngas, which is a mixture of H₂, CO, CO₂ and N₂ produced in the gasification unit, is fed to a CO shift reactor, where the carbon monoxide and residual steam are converted to H₂ and CO₂. The CO₂ and H₂S are removed from the shifted syngas, using a physical solvent, and then the pressure of the hydrogen rich fuel gas is reduced to gas turbine inlet pressure through an expander. The fuel gas is heated before and after the expander to increase the overall efficiency of the Capture Plant. The hydrogen rich fuel gas has nitrogen added to reduce NO_x formation during combustion in the gas turbines. Nitrogen from the ASU is compressed, heated and injected directly into the combustors of the CCPP for NO_x control.

The CO₂ is regenerated from the solvent, dried and compressed for delivery to battery limits for subsequent disposal. An H₂S rich gas stream is reacted with oxygen in a Claus Unit to form a solid sulphur product.

The waste heat from the Capture Plant is used to generate steam, which is superheated in the HRSG of a small gas turbine for generation of electric power for internal use. Additional electricity is imported from the grid.

This section is to be read in conjunction with the process block diagram for case 3-1 and the mass balance for case 3-1 P03-3101.

ASU

Oxygen for the gasification and Claus units is separated from air in a cryogenic air separation unit (ASU). The nitrogen is used to dilute the fuel gas for NO_x control. The ASU is operated at low pressure and all of the feed air is supplied by dedicated air compressors driven by electric motors.

The oxygen is pumped to high pressure as a cryogenic liquid to remove the requirement for an oxygen compressor and vaporised against a stream of condensing high pressure air within the ASU main heat exchanger. The gaseous oxygen, at a purity of 95 vol%, is preheated with low pressure steam before being fed to the gasifier at 79 bar(g).

A small side stream is taken off at low pressure for the burners in the Claus unit. The majority of the product nitrogen stream, which contains less than 10 ppm O₂, is compressed, and some is added to the fuel gas stream to reduce the hydrogen content with the majority injected directly into the combustors of the gas turbines for NO_x control. Some additional nitrogen is used in concentrating the H₂S in the Selexol unit, a small amount is used for purging and inerting, and the remainder is used internally within the ASU.

Coal Storage and Preparation

Coal is delivered to the site and stored in a stockpile normally sized for 3 days operation at full load. There is also an inactive coal storage pile sized for 30 days storage.

The coal is crushed and slurried with process water to 66 wt% and then pumped to one of a pair of day storage tanks. From the storage tank the slurry is pumped to 68 bar(g) and delivered to the gasifier.

Gasification

The coal slurry is gasified in a high pressure, top fired, ChevronTexaco gasifier fitted with a water quench. The temperature in the gasifier is sufficient to melt all the ash to slag. The coal is converted to synthesis gas, or syngas containing primarily H₂ and CO, together with some steam, CO₂, N₂, CH₄, and Ar. The sulphur in the coal is converted to H₂S with some COS; other sulphur containing compounds are not considered in this study. The chlorine in the coal is converted to HCl. Small amounts of HCN and NH₃ are also produced. A small amount of carbon remains as soot.

The syngas, slag and soot exit from the bottom of the gasifier and are passed at 63 bar(g) to a water quench for cooling. The solids are removed through a lock-hopper system at the bottom of the quench, and the syngas, now saturated with water vapour, leaves at the top of the quench chamber. To prevent the build-up of soluble


compounds, a blowdown stream, called black water, is taken from the quench, cooled in a cascade of flash drums at decreasing pressure and sent to the waste water treatment unit.

The saturated syngas is scrubbed with filtered process water, recycled from the bottom of the desaturator to remove particulates and then passed to the gas processing section. The scrubber water together with more process water is fed to the quench as make-up.


CO Shift

The scrubbed syngas is heated to above 290°C and passed to the sour shift reactor where most of the CO is converted to CO₂ over a catalyst according to the reaction:


Water Gas Shift



At the same time most of the COS is converted to H₂S and HCN to NH₃ according to the reactions:



and



The shift reaction is exothermic and the shifted syngas exits the reactor at above 430 °C.

Cooling and Condensation

The syngas from the outlet of the shift reactor is cooled initially by raising HP (135 bar(g)) steam. It is further cooled against the inlet stream to the shift reactor and then against demineralised water. Some of this water is used as BFW, and the remainder is circulated to the back of the plant to provide preheat to the expander and gas turbine. Final cooling and condensation is carried out in a desaturator.

The desaturator is a direct contact gas / liquid exchanger which consists of a packed or trayed column down which a liquid (water in this case) flows against a condensing gas steam passing upwards. The main effect is to preheat the condensate against the incoming hot gas.

Some of the hot water from the bottom of the desaturator is recycled to the quench / scrubber as make-up. The balance is used to raise LP steam, and to provide reboil duty for the sulphur removal unit before the majority is recycled back to the centre section of the desaturator. The remainder is then cooled by preheating incoming BFW. A small stream is fed to the coal preparation unit for coal slurring, and the remainder is used as a cold water recycle to the desaturator.

In this way, the syngas is cooled to below 40°C, without the use of cooling water, before being fed to the H₂S absorber in the AGR unit.

The HP and LP process steam is sent to the power block for superheating in the HRSG's before passing to the steam turbine.

Acid Gas Removal

The sulphur compounds and CO₂ are removed from the syngas in two stages. First, the sulphur compounds are removed in an H₂S absorber, and then syngas passes to a CO₂ absorber where the CO₂ is removed.

The CO₂ absorber is in two stages. Lean Selexol liquor from the stripper column is fed to the upper section of the CO₂ absorber and CO₂ is removed to the required specification. A much larger flow of "semi-lean" solution is fed to the lower section of the absorber to remove the bulk of the CO₂.

The Selexol stream from the bottom of this column, now rich in CO₂ is split into two streams. The majority of the flow is directed to a series of flash vessels operating at successively reducing pressure. The overhead vapour from the first vessel, which still contains considerable amounts of H₂, is recycled back to the inlet of the H₂S absorber using the flash gas compressor. The overhead from the remainder of the flash vessels is sent to the CO₂ compressor. The Selexol, which is now semi-lean in CO₂, is cooled and pumped back to the lower section of the CO₂ absorber.

The remainder of the CO₂ rich Selexol stream from the bottom of the CO₂ absorber is cooled and pumped to the top of the H₂S absorber where the sulphur compounds are absorbed. The Selexol from the bottom of the H₂S absorber, now rich in H₂S and containing about 25% of the inlet CO₂, is pumped to the H₂S concentrator column which operates at a slightly higher pressure than the H₂S absorber column via the rich / lean interchanger. The overhead from the H₂S concentrator is recycled directly to the inlet of the H₂S absorber. The liquor from the bottom of the H₂S concentrator is flashed down to low pressure to remove the remainder of the CO₂. The overhead vapour, which contains some H₂S, is recycled back to the inlet of the H₂S absorber using the flash gas compressor.

The Selexol is finally regenerated by steam stripping. The reboil duty for the stripper column is provided by hot process water from the gas treatment section. The overhead vapour from the stripper column, which contains 40% vol H₂S, is fed to the Claus unit where it is reacted with oxygen to form a solid sulphur product. The tail gas stream from the Claus reactor is compressed and recycled back to the inlet of the H₂S absorber.

Selexol plants often use refrigeration. This is avoided in this design by having a higher solvent flowrate than would be necessary with a design using refrigeration. This increases the capital costs of the absorber and stripper columns themselves but overall costs of the Selexol unit is lower because a refrigeration package is not required.

Gas Conditioning

Sulphur and carbon dioxide free syngas from the top of the CO₂ absorber in the AGR unit is heated by exchange with hot demineralised water, and then expanded to the gas turbine fuel supply pressure, in an expander to generate power. Nitrogen from the ASU is added to dilute the hydrogen fuel gas stream as per GE's specifications, it is then superheated to 230°C against circulating demineralised water. A separate nitrogen stream is compressed, and superheated to 230°C again against circulating demineralised water before being fed directly to the gas turbine combustor. The combined effect of the two nitrogen streams is sufficient to control the NO_x formation in the gas turbine to the required level.

Sulphur Recovery

The H₂S is converted to pure sulphur in an oxygen blown Claus unit. The tail gas is compressed and recycled to the inlet of the H₂S absorber removing any atmospheric sulphur emissions from the sulphur removal or recovery units. The sour water produced is pumped to the desaturator.

Power Block

The power block consists of a GE 6B gas turbine, modified for combustion of syngas, fitted with a modified HRSG. A new gas turbine is included to enable the steam from the gasification plant to be superheated without interfering with the existing HRSG. The steam produced in the capture plant of case 2 is superheated by the effluent gases from the ATR, and therefore no new gas turbine is required in that particular case. After superheating the steam passes to a condensing steam turbine. The exhaust from the steam turbine passes to a deaerator-condenser, which operates at a pressure of 40 mbar(a). The boiler feed water from the deaerator-condenser is pumped back to the gas treatment section.

The generators, transformers and switchgear for the power block are included in this section.

CO₂ Compression and Drying

The CO₂ removed in the acid gas removal unit is compressed to 22 bar(g), dried using a molecular sieve and compressed again to 110 bar(g) for export. The molecular sieve is regenerated using hot process water from the gas treatment section in a "no loss" configuration, which recycles the regeneration off gas back to the CO₂ compressor.

Cooling Water

Seawater, taken from a new intake, is circulated once through the major coolers and condensers and discharged directly back to the sea through a new discharge structure. A secondary fresh water system is used for smaller coolers and machinery.

Water Treatment

The feed water plant takes raw water and softens it to remove hard water anions. This is used as make-up water for the desaturator. A small stream is taken for the demin water plant.

The waste water plant takes black water from the quench blowdown and first filters it to remove soot, slag fines and other particulate matter. The filtered solids are recycled

back to the coal grinding plant to recover the unconverted carbon. The filtered water is then treated by means of pH control, coagulation and flocculation, and finally ion exchange to meet the required specification. A small quantity of sludge is produced for disposal offsite.

5.5.2 Capture Plant Performance

Table 5.17 shows the performance of the capture plant in case 3-1.

CO₂ Capture Plant Energy Balance	
Capture Plant Fuel Energy Input (LHV)	2121.2 MWth
Capture Plant Syngas Output (LHV + Heat)	1405.3 MWth
CO ₂ Capture Plant Auxiliary Power Consumption	-244.9 MWe
CO ₂ Capture Plant Power Production	190.1 MWe
Capture Plant Net Power Output	-54.8 MWe
CO ₂ Capture Efficiency	85.8 %

Table 5.17 - Case 3-1 Energy Balance Capture Plant

Compared to the capture plant performances in case 2, it becomes clear that the coal reforming process is more energy intensive than the natural gas reforming process. The power consumption increased significantly (245 MWe compared to 159 MWe in case 2-1), which is mostly due to the power consumption of the larger CO₂ compressor and the Nitrogen compressor.

The power generation in case 3-1 is also increased. This can be explained by the fact that the power block consists of a complete combined cycle power plant, which produces a significant amount of electricity. A detailed breakdown of the power producers and consumers within the capture plant can be found in Appendix 5.

The CO₂ capture efficiency is calculated by taking the actual CO₂ emission, compensate for the CO₂ in the inlet air to the gas turbine, and divide this by the maximum CO₂ emission from burning the original fuel (before reforming).

5.5.3 CCPP Description

The syngas, which is fed to the gas turbine combustion chamber, is a low-LHV fuel, and the gas turbine needs to be adjusted and controlled in the same way as with the previous pre combustion CO₂ capture cases.

The capture plant is located near the power plant plot and the syngas fuel is delivered at a temperature of 230 °C. For this study the fuel is not preheated to a higher temperature, which could lead to higher efficiencies. This should be considered as an option for optimization.

5.5.4 CCPP Performance

The table shows the gas turbine data for case 2-2 in comparison to the reference case.

Case	Reference Case	Case 3-1
Fuel LHV	46,855 kJ/kg	6,416 kJ/kg
Fuel Flow / Temperature	15.0 kg/s / 10 °C	103.7 kg/s / 230 °C
Steam Injection Flow / Temperature	-	-
Air Inlet Flow	618 kg/s	523 kg/s
Combustor Exit Temperature	1352 °C	1274.9 °C
Exhaust flow / Temperature	633 kg/s / 608 °C	627 kg/s / 565 °C
Net Power Output	258.8 MW	286.1 MW
Net Electric Efficiency (LHV)	36.8 %	43.0 %

Table 5.18 - Case 3-1 Gas Turbine Performance

Table 5.19 shows the energy balance for the combined cycle power plant.

Power Plant Energy Balance		
Gas Turbine Energy Input		1405.3 MWth
	Fuel Consumption LHV	1330.1 MWth
	Fuel Sensible Heat Input (Tref. 15 °C)	75.2 MWth
	Total Gas Turbine Energy Input	1405.3 MWth
Gas Turbine		581.4 MW
	GT Gross power	609.9 MW
	GT losses	-28.6 MW
	Net GT output	581.4 MW
Steam Turbine		248.0 MW
	ST Shaft power	250.5 MW
	ST losses	-2.5 MW
	Net ST output	248.0 MW
Generator losses		-14.2 MW
Balance of Plant losses		-9.2 MWe
	Boiler feed water pumps	-2.5 MWe
	Cooling water pumps	-5.7 MWe
	Condensate pumps	-0.2 MWe
	Remaining losses (0.1%)	-0.8 MWe
	BOP losses	-9.2 MWe
Total Plant net power		806.0 MWe
Net electrical efficiency		57.4 %

Table 5.19 - Case 3-1 Power Plant Energy Balance

5.5.5 Case 3-1 Overall Plant Balance

The overall energy balance for the combined CO₂ capture plant and power plant is shown in *Table 5.20*, which is composed of *Table 5.17* and *Table 5.19*.

Total Overall Plant Energy Balance	
Total Overall Plant Energy Input (LHV)	2121.2 MWth
Combined Cycle Power Plant Net Electrical Output	806.0 MWe
CO ₂ Capture Plant Auxiliary Power Consumption	-244.9 MWe
CO ₂ Capture Plant Power Production	190.1 MWe
Total Overall Plant Net Power Output	751.2 MWe
Net Overall Plant Electrical Efficiency	35.4 %

Table 5.20 - Case 3-1 Overall Plant Energy Balance

The table shows that the overall plant net electrical efficiency decreased significantly compared to the reference case.

5.6 CASE 3-2: PRE COMBUSTION CO₂ CAPTURE BY REMOTE H₂ PRODUCTION FROM COAL

In case 3-2, capture is effected by removing the carbon from Coal before combustion with the capture plant located at 40 km distance from the power plant, see *Figure 5.5*. The Capture Plant converts the coal by partial oxidation (gasification) to synthesis gas (or syngas), which is a mixture of carbon monoxide and hydrogen. The carbon-free syngas is fed to the gas turbine.




Figure 5.5 - Case 3-2 Scheme

5.6.1 Capture Plant Description

The Capture Plant converts a feed of coal to a fuel gas mixture of hydrogen and nitrogen suitable for refuelling a gas turbine. The plant consists of a gasification stage where a mixture of coal and water is partially oxidised with oxygen from an air separation unit (ASU). The synthesis gas, or syngas, which is a mixture of H₂, CO, CO₂ and N₂ produced in the gasification unit, is fed to a CO shift reactor, where the carbon monoxide and residual steam are converted to H₂ and CO₂. The CO₂ and H₂S are removed from the shifted syngas, using a physical solvent, and dried. Nitrogen from the ASU is compressed and added, to the hydrogen rich fuel gas for NO_x control. The CO₂ is regenerated from the solvent, dried and compressed for delivery to battery limits for subsequent disposal. An H₂S rich gas stream is reacted with oxygen in a Claus unit to form a solid sulphur product.

The waste heat from the Capture Plant is used to generate steam, which is superheated in the HRSG's of two small gas turbines and generate electric power for internal use.

This section is to be read in conjunction with the process block diagram for case 3-2 and the mass balance for case 3-2 P03-3201.

Most of the process steps are equal to the process steps in case 2-1 and will not be repeated. The items that are different are described here.

ASU

Reference is made to paragraph 5.5.1.

Coal Storage and Preparation

Reference is made to paragraph 5.5.1.

Gasification

Reference is made to paragraph 5.5.1.

CO Shift

Reference is made to paragraph 5.5.1.

Cooling and Condensation

Reference is made to paragraph 5.5.1.

Acid Gas Removal

Reference is made to paragraph 5.5.1.

Gas Conditioning

Sulphur and carbon dioxide free syngas from the top of the CO₂ absorber in the AGR is dried and diluted with compressed nitrogen from the ASU. The fuel gas is then transferred to the remote combined cycle power plant.

Sulphur Recovery

Reference is made to paragraph 5.5.1.

Power Block

The power block consists of two GE 6B gas turbines, modified for combustion of syngas, fitted with HRSG's. The HP and LP steam from the gas treatment section is superheated in the HRSG's and passes to a condensing steam turbine. The exhaust from the steam turbine passes to a de-aerator condenser, which operates at a pressure of 40 mbar(a). The boiler feed water from the deaerator-condenser is pumped back to the gas treatment section.

The generators, transformers and switchgear for the power block are included in this section.

CO₂ Compression and Drying

Reference is made to paragraph 5.5.1.

Cooling Water

Seawater, from a new intake, is circulated once through major coolers and condensers and discharged directly back to the sea. A secondary fresh water system is used for smaller coolers and machinery.

Water Treatment

Reference is made to paragraph 5.5.1.

5.6.2 Capture Plant Performance

Table 5.21 shows the performance of the capture plant in case 3-2.

CO₂ Capture Plant Energy Balance	
Capture Plant Fuel Energy Input (LHV)	2306.4 MWth
Capture Plant Syngas Output (LHV + Heat)	1344.3 MWth
CO ₂ Capture Plant Auxiliary Power Consumption	-269.1 MWe
CO ₂ Capture Plant Power Production	269.4 MWe
Capture Plant Net Power Output	0.4 MWe
CO ₂ Capture Efficiency	85.5 %

Table 5.21 - Case 3-2 Energy Balance Capture Plant

Compared to the local case 3-1 a higher power production can be distinguished. A larger power plant is installed in the power block of the capture plant and this increases the electricity that is produced. A detailed breakdown of the power producers and consumers within the capture plant can be found in Appendix 5.

The CO₂ capture efficiency is calculated by taking the actual CO₂ emission, compensate for the CO₂ in the inlet air to the gas turbine, and divide this by the maximum CO₂ emission from burning the original fuel (before reforming).

5.6.3 CCPP Description

The fuel is delivered at the power plant at a low temperature of 21.5 °C (compared to a temperature of 230 °C in the local case 3-1). This is due to the 40 km transportation distance between the two sites.

In paragraph 5.3.3 it was stated that preheating the fuel is a feasible option to increase the overall efficiency of the power plant. In this case the fuel is preheated by heat exchangers, which are fed with steam generated by the HRSG's in the power plant.

When fuel preheating is applied, steam injection is needed to limit the NO_x emissions below the permitted limit.

In this study the fuel is preheated until the temperature of the mixture of fuel and steam is about 230 °C. At this temperature no extra measures need to be taken to materials in the existing equipment. The temperature level can be subject to optimization, as this is not considered in this study.

5.6.4 CCPP Performance

The table shows the gas turbine data for case 3-2 in comparison to the reference case.

Case	Reference Case	Case 3-2
Fuel LHV	46,855 kJ/kg	7,480 kJ/kg
Fuel Flow / Temperature	15.0 kg/s / 10 °C	89.7 kg/s / 223 °C
Steam Injection Flow / Temperature	-	5.9 kg/s / 340.6 °C
Air Inlet Flow	618 kg/s	532 kg/s
Combustor Exit Temperature	1352 °C	1274.9 °C
Exhaust flow / Temperature	633 kg/s / 608 °C	627 kg/s / 567 °C
Net Power Output	258.8 MW	286.0 MW
Net Electric Efficiency (LHV)	36.8 %	42.6 %

Table 5.22 - Case 3.2 Gas Turbine Performance

Table 5.23 shows the energy balance for the complete combined cycle power plant.

Power Plant Energy Balance		
Gas Turbine Energy Input		1344.3 MWth
	Fuel Consumption LHV	1341.4 MWth
	Fuel Sensible Heat Input (Tref. 15 °C)	3.0 MWth
	Total Gas Turbine Energy Input	1344.3 MWth
Gas Turbine		581.1 MW
	GT Gross power	609.7 MW
	GT losses	-28.6 MW
	Net GT output	581.1 MW
Steam Turbine		215.0 MW
	ST Shaft power	217.1 MW
	ST losses	-2.2 MW
	Net ST output	215.0 MW
Generator losses		-13.5 MW
Balance of Plant losses		-8.3 MWe
	Boiler feed water pumps	-2.4 MWe
	Cooling water pumps	-5.0 MWe
	Condensate pumps	-0.2 MWe
	Remaining losses (0.1%)	-0.8 MWe
	BOP losses	-8.3 MWe
Total Plant net power		774.3 MWe
Net electrical efficiency		57.6 %

Table 5.23 - Case 3-2 Power Plant Energy Balance

The amount of heat added to the fuel by preheating is equal to 63.5 MWth.

5.6.5 Overall Plant Balance

Table 5.24 shows the overall energy balance for the combined CO₂ capture plant and CCGP. It is composed from Table 5.21 and Table 5.23.

Total Overall Plant Energy Balance	
Total Overall Plant Energy Input (LHV)	2306.4 MWth
Combined Cycle Power Plant Net Electrical Output	774.3 MWe
CO ₂ Capture Plant Auxiliary Power Consumption	-269.1 MWe
CO ₂ Capture Plant Power Production	269.4 MWe
Total Overall Plant Net Power Output	774.6 MWe
Net Overall Plant Electrical Efficiency	33.6 %

Table 5.24 - Case 3-2 Overall Plant Energy Balance

5.7 OVERALL RESULTS AND CONCLUSIONS

The performance results for the different cases are described in the following table for comparison.

Total Overall Plant Energy Balance	Ref.	1	2-1	2-2	3-1	3-2	
Total Overall Plant Energy Input (LHV)	1404.6	1404.6	1672.4	1671.0	2121.2	2306.4	MWth
Combined Cycle Power Plant Net Electrical Output	784.8	664.3	809.6	764.3	806.0	774.3	MWe
CO ₂ Capture Plant Auxiliary Power Consumption	0.0	-38.5	-158.9	-168.0	-244.9	-269.1	MWe
CO ₂ Capture Plant Power Production	0.0	0.0	43.0	71.1	190.1	269.4	MWe
Total Overall Plant Net Power Output	784.8	625.9	693.7	667.4	751.2	774.6	MWe
Net Overall Plant Electrical Efficiency	55.9	44.6	41.5	39.9	35.4	33.6	%

Table 5.25 - Comparison Overall Plant Energy Balances

Table 5.25 shows clearly that CO₂ Capture has significant impact on the power plant electrical efficiency. This is due to the high power consumption of the capture plant. The reference plant without CO₂ capture reaches an efficiency of 55.9% and in the case of pre combustion CO₂ capture by syngas production from coal (case 3-2), this efficiency decreased with more then 20%-points to 33.6%.

The post combustion CO₂ capture case has the best electrical efficiency compared to the CO₂ capture cases.

The table also shows that the CCGP electrical output is about 32 to 35 MWe lower in the remote cases in comparison to the local cases. This is caused by the steam bleed, which is needed for the preheating of the fuel in the remote cases. As this steam is used for the fuel preheating, it is no longer available for expansion in the steam turbine. This effect is partially compensated by the higher power production in the CO₂ Capture Plant. In the local cases the fuel is preheated in the capture plant, and in the remote cases the fuel is preheated with steam from the CCGP. Therefore in the remote case the capture plant has more steam available for power production. The

overall difference in efficiency between a local and its remote case (transport loss) is between 1.6 and 1.8%-points.

Because the different fuels have different CO₂ emissions and the different cases have different power generation efficiencies, it is interesting to look at the CO₂ emission per kWh electricity produced for each case. By adding a price tag to avoided CO₂ production, the premium on the electricity price can be calculated for the CO₂ capture power plant.

CO₂ emission per kWh electricity	Ref.	1	2-1	2-2	3-1	3-2	
Total Overall Plant Net Power Output	784.8	625.9	693.7	667.4	751.2	774.6	MWe
CO ₂ emission in kg/s	81.4	11.7	13.9	13.9	27.1	30.2	kg/s
CO₂ emission per kWh	373.3	67.0	72.3	74.8	129.9	140.1	g CO₂/kWh

Table 5.26 - CO₂ emission per kWh generated electricity

Table 5.26 shows an important conclusion, which should be taken into account when CO₂ capture rates are discussed. The CO₂ capture rate for all cases is at least 85%, when based on the amount of CO₂, which is avoided on a per kg fuel basis. However the CO₂ captured per kWh electricity produced is much lower. This is due to the decreased electrical efficiency of the CCPP with CO₂ capture, which implies that the specific fuel consumption per kWh electricity has increased. For the overall plant performance this is a more appropriate figure to compare cases, as it takes the additional energy consumption of the capture plant into account.

Table 5.27 results from Table 5.26 and shows the relative CO₂ emissions per kWh net electricity production compared to no CO₂ capture from the natural gas fired CCPP from the reference case.

CO₂ Capture	Ref.	1	2-1	2-2	3-1	3-2	
Relative CO₂ emission	100.0	17.9	19.4	20.0	34.8	37.5	%
Relative CO₂ Capture efficiency	0.0	82.1	80.6	80.0	65.2	62.5	%

Table 5.27 - CO₂ Capture

It is clear to see that the coal based pre combustion cases perform less efficiently compared to the gas based pre combustion cases. The efficiency of the local cases is better than the remote cases, which is expected, as the remote cases demand a high amount of compression power to transport the fuel gas over the 40 km distance and does not allow waste heat utilisation for fuel preheating in the pre combustion plant. Case 1, which is the post combustion case, has the best performance with respect to total electrical efficiency as well as CO₂ Capture efficiency per kWh electricity produced.

6. CAPITAL EXPENDITURE

6.1 INTRODUCTION

To evaluate the economic feasibility of retrofitting a standard natural gas fired power plant with post- or pre-combustion CO₂ capture it is required to have an overview of the capital and operational expenditures for all alternatives considered.

The capital cost figures of the 2 * 400 MW_e power plant and the post- and pre-combustion CO₂ capture plants have been based on the following general starting points:

- The processes to be assessed will be state-of-the art for construction in the year 2004.
- The plants will be assumed to be on the NE coast of the Netherlands, within 1 km of the sea (i.e. availability of seawater for cooling purposes and ship unloading facilities).
- A green field site with no special civil work implications will be assumed
- The plants will be built on a turnkey basis and are provided with all required (auxiliary) systems. The power plant and the capture plants both have dedicated auxiliary systems (i.e. minimum integration). Facilities and infrastructure required outside the plant limits, e.g. HV connection, fuel supply, transport and storage of CO₂, etc. are not included in the cost estimate.
- The CCPP and the capture plant will not be realized simultaneously. In case of a local capture plant it is assumed the new plant is located next to the existing power plant. In case of a remote capture plant a distance of 40 km between both sites is considered. The high pressure fuel gas line from the fuel plant to the power plant will be routed underground. The pipeline is assumed to be through agricultural land, with no passage through urban areas.
- All cost figures are presented in USD (exchange rate used: EUR/USD = 1.23).

Besides the general starting points also the following specific cost estimating approach will be applicable:

CCPP

The capital cost for the power plant will be based on actual cost figures from plants recently taken into operation and/or under construction. All costs with respect to the power plant will be presented as one total cost figure.

Capture Plant

The capital cost for the capture plant will be based on actual cost figures for the individual equipment with an installation factor per equipment. The individual equipment costs have been obtained by price calculation of the equipment based on the actual design information and price comparison with prices available of similar equipment, obtained from vendor data. The installation factors, used for cost estimating, are based on the experience of Jacobs with similar units/processes. All costs with respect to the capture plant are presented for the following main plant sections:

Case 1 Post combustion CO₂ capture

- Acid Gas Removal
- CO₂ Compression and drying
- Offsites and Utilities

Case 2.1 Pre combustion CO₂ capture by local H₂ production from natural gas

- Air Compression
- Reforming and HT Cooling
- Shift and LT Cooling
- Acid Gas Removal
- CO₂ Compression and drying
- Power Generation
- Offsites and Utilities

Case 2.2 Pre combustion CO₂ capture by remote H₂ production from natural gas

- Reference is made to case 2.1

Case 3.1 Pre combustion CO₂ capture by local H₂ production from coal

- Air Separation Unit
- Coal Receiving, grinding and slurry preparation
- Gasification unit
- Gas Treatment Package
- Acid Gas removal
- Product Gas Exports
- Power Generation (combined cycle unit)
- Offsites and Utilities

Case 3.2 Pre combustion CO₂ capture by remote H₂ production from coal

- Reference is made to case 3.1

Reference is made to appendix 4 for a summary list of the equipment (no design details) concerned per case.

Per plant section the split up for the following cost items is presented:

- Direct materials
- Construction
- Engineering and construction services

The individual cost for all individual systems/activities such as individual equipment, auxiliary systems, civil, electrical, instrumentation, etc. will not be presented. To present an accurate cost overview for all individual systems/activities a great effort is required as this is only possible with a detailed break down per system/activity. As a (detailed) break down will not contribute to the aim of this study the above mentioned estimating approach has been followed.

The overall accuracy of the overall cost estimates is in the range of $\pm 25\%$.

For determining the overall project cost the following additional charges are applicable:

- A cost of 7% of the installed plant cost (overnight construction) will be assumed to cover the owners cost (i.e. process/patent fees, fees for agents or consultants, legal and planning costs land purchase, surveys, general site preparation, etc.)
- A cost of 10% of the installed plant cost (overnight construction) will be assumed to cover project contingency.

6.2 CAPITAL EXPENDITURE

A summary of the capital expenditure (excluding interest during construction) and specific costs in USD per kWe of installed capacity for the reference power plant and the capture plants are presented in *Table 6.1* and *Table 6.2*.

			Reference
Capital Expenditures			CCPP
Overnight construction costs		M USD	354.7
Owners cost	7%	M USD	24.8
Contingency	10%	M USD	35.5
Total installed cost		M USD	415.0
Specific investment			USD/kWe 529

Table 6.1 - Capital Expenditure Reference case

		Case					
Additional Capital Expenditures		1	2-1	2-2	3-1	3-2	
Overnight construction costs	M USD	337.7	486.4	641.2	822.4	1,020.7	
Owners cost	7% M USD	23.6	34.0	44.9	57.6	71.4	
Contingency	10% M USD	33.8	48.6	64.1	82.2	102.1	
Total additional installed cost		M USD	395.1	569.1	750.3	962.2	1,194.2
Specific additional investment		USD/kWe	631	820	1,124	1,281	1,542

Table 6.2 - Additional Capital Expenditures Capture plants

Reference is made to appendix 6 for the split up of the capital cost estimate of the various cases.

7. ECONOMIC ANALYSIS

7.1 INTRODUCTION

An economic analysis will be executed to evaluate the economic performance of the CO₂ capture retrofitted combined cycle power plants against the reference power plant. The economic calculations will be based on the starting points as provided by IEA GHG.

The results will be expressed in power production cost and CO₂ emission avoidance cost.

Both values will be calculated for a Net Present Value (NPV) of zero (0) for the complete project 25 years after the initial start-up of the CCPP.

7.2 CASH FLOW CALCULATIONS

7.2.1 Background

Using cash flow calculations one can determine the real cost of electricity production and CO₂ avoidance. This paragraph shows the calculation method and the criteria used. As a result the cost of CO₂ avoidance for the different plant configurations is summarised. The cash flow calculations are executed with the IEA GHG economic assessment model applicable for assessment of levelled costs of generation in new power plants. As the original model is not suitable for the assessment of retrofits the spreadsheet has been modified in order to evaluate retrofitting.

The cash flow calculation shows the cash flows of a power plant throughout its lifetime and calculates the net present value of these cash flows. The net present value (NPV) is the value of a project today if all future cash flows (including investments) are discounted to today's value using a discount ratio.

The cash flows include the following items:

- Revenues
- Fossil Fuel costs
- Maintenance costs
- Labour costs
- Chemicals and consumables costs
- Insurance
- Capital expenditures
- Working capital
- De-commissioning costs

The cash flow is calculated for 2 years of construction of the reference natural gas fired CCPP followed by 25 years of operation. The production costs per kWh of electricity are calculated by setting the NPV of the power plant to zero. This can be

achieved by varying the kWh price until the revenues balance the costs over the whole lifetime of the power plant.

The calculated kWh price at which the NPV of the reference case is zero, is maintained for the calculations to the different cases. The CO₂ avoidance cost are varied until the NPV of each of the cases is zero.

For the retrofit cases it is assumed that the new capture plants are constructed while the CCPP is still in operation. The CCPP will only be taken out of operation to allow for making the required tie-ins with the new plant and realize the required internal modifications (e.g. replace gas turbine combustion system). The 25 years of operation evaluation criteria for the CCPP will not change. There is no residual value at the end of the lifetime of the CCPP.

Sensitivity analyses will be made to evaluate the economic performance of the various options when varying one parameter at the time.

Parameters to be varied are:

- Fuel price (-50%/+100%)
- Discount rate (5%)
- Year of retrofit (-5/+5 year)

7.2.2 Starting points

The yearly cash flow is calculated using the IEA GHG criteria.

Criteria that need further explanation are discussed below:

Discount rate and cost of capital

All cash flows will be discounted using a discount rate of 10%. These cash flows also include the debts made during the design, construction and commissioning.

Year of retrofit

The retrofitted CCPP will be commissioned/started-up 10 years after the initial start-up of the CCPP. Design and construction period of the capture plant starts 2 (natural gas fuelled plant) or 3 (coal fuelled plant) years earlier.

Escalation

In accordance with the IEA GHG criteria, no escalation has been included.

Commissioning

A 3-month commissioning period will be allowed for all types of plant. In effect this means that during the first year the load factor of the plant is reduced by 25%. The reference power plant will operate at a load factor of 90% during the first year; by adding a commissioning period of 3 months, the load factor will be reduced to 67.5%. When the retrofitted plant is started up the identical approach is applicable for natural gas fuelled plants. However for the coal fuelled plants a load factor of 60 % is applicable for the first year, which has to be corrected for the 3-month commissioning period, resulting in a load factor of 45%.

Load Factor

The natural gas fuelled power plant(s) will operate at a load factor of 90% during a normal year. The coal-fuelled power plant(s) will operate at a load factor of 85% during a normal year. The load factor affects the electricity production, consumption of all consumables, disposal of wastes and maintenance costs. It does not reduce the labour costs and insurance.

De-commissioning

The costs associated with shut down of the plant can be taken as a percentage of the capital investment. However, since these costs occur only once at the end of the lifetime of the (power) plant the discounted cash flow is reduced to a minimum. As a result the de-commissioning costs only comprise 0.1 to 0.2% of the kWh price and are insignificant and therefore neglected.

Maintenance

The Maintenance expenditures are 2% p.a. of the installed costs for the CCCP and the gas conversion and treatment plants. For "coal handling" plants, maintenance expenditures of 4% p.a. of the installed plant costs are used.

Contingencies

An allowance is made for estimating error and process unknowns / development. This allowance is set as a percentage of the overnight construction cost. A contingency factor of 10% covers most of the risks.

Labour

The labour cost for one operator is set to 75.000 USD/year. A percentage is added to the labour cost for indirect costs for supervision (20%) and administration + overhead (30%). The number of operators (5 shift) necessary for each plant is assumed to be:

- Ten (10) operators for the NG fired CC reference power plant
- Fifteen (15) operators, power plant operators included, for the post-combustion CO₂ capture option
- Twenty (20) operators, power plant operators included, for the local natural gas fuelled pre-combustion CO₂ capture options
- Twenty (20) operators, power plant operators excluded for the remote natural gas fuelled pre-combustion CO₂ capture options
- Twenty five (25) operators, power plant operators included, for the local coal fuelled pre-combustion CO₂ capture options
- Thirty (30) operators, power plant operators excluded for the remote coal fuelled pre-combustion CO₂ capture options

Consumables and Working Capital

The consumables consist of the following components:

- Chemicals for boiler water treatment
- Chemicals for waste water treatment
- Lubricants
- Potable water

- M(D)EA solution + additives
- Catalyst + internals
- Solexol solvent

Working capital for storage of consumables is assumed to be 30 days.

Fuel Price

The fuel price is set at 3.0 USD/GJ (LHV) for natural gas and 1.5 USD/GJ (LHV) for coal.

Waste Disposal

For hazardous waste disposal the following costs are used:

- Small quantities 250 €/ton
- Large quantities 150 €/ton

It is assumed that the gasifier slag produced in the coal cases is a product, which can be sold. For the economical analysis it is assumed that the profits equal the disposal costs.

7.3 RESULTS

The results from the cash flow calculations are presented in *Table 7.2*. Reference is made to appendix 7 to the detailed calculation results. The results are given for the reference natural gas fired CCPP and the various CO₂ capture retrofitted cases. *Table 7.1* shows the specific investments and electric efficiencies.

The total specific investment is defined as the overall investment of CCCP and fuel/CO₂ capture plant without inflation correction, divided by the net power output after the retrofit. The overall electric efficiency presented for the fuel/CO₂ capture plants is also applicable for the retrofitted situation. Up to the retrofit the overall electric efficiency of the reference CCCP is applicable.

		Total Specific Investment	Overall Electric Efficiency
		USD/kWe	%
CCPP	Reference power plant	529	55.9
Case 1		1294	44.6
Case 2.1		1419	41.5
Case 2.2		1746	39.9
Case 3.1		1833	35.4
Case 3.2		2077	33.6

Table 7.1 – Investments and Efficiencies

7.4 CALCULATION OF CO₂ COST

Costs per ton of avoided CO₂ resulting from decarbonisation are calculated by varying the CO₂ avoidance costs until the NPV of the case is zero, at an electricity price equal to the price at which the NPV of the reference power plant is zero.

Electricity production costs are calculated as described in section 7.2.1. Specific CO₂ emission is calculated by dividing the emitted amount of CO₂ per year accountable to the fuel (i.e. absolute CO₂ emission is corrected for the CO₂ in the combustion air) by the yearly net power production. Both figures assume 8760 yearly hours and the applicable load factor. The CO₂ emission avoidance cost is defined to be the value at which the NPV of the considered option is zero.

	Electricity Production Cost	Specific avoided CO ₂	Cost of avoided CO ₂
	USD/MWh	Ton CO ₂ /MWh	USD/Ton CO ₂
CCPP	29.97		
Case 1	29.97	0.306	73.24
Case 2.1	29.97	0.301	95.05
Case 2.2	29.97	0.299	124.33
Case 3.1	29.97	0.243	131.36
Case 3.2	29.97	0.233	168.13

Table 7.2 - CO₂ Emission Avoidance Cost

7.5 RESULTS SENSITIVITY ANALYSIS

The following parameters were altered in order to perform a sensitivity analysis:

- A. Fuel price – increase of 100%
- B. Fuel price – decrease of 50%
- C. Discount rate – decreased from 10% to 5%
- D. Year of retrofit – (5 years after start-up of CCPP in stead of 10 years)
- E. Year of retrofit – (15 years after start-up of CCPP in stead of 10 years)

Electricity production costs and costs of avoided CO₂ have been recalculated for all cases. The electricity production costs for the reference plant are recalculated using an altered fuel price or discount rate in the sensitivity analyses A, B and C. These recalculated electricity production costs for the reference cases are kept constant for the corresponding cases and the CO₂ avoidance costs are calculated by finding the appropriate value at which the NPV is zero for each separate case.

7.5.1 Fuel price sensitivity

The influence of fuel price levels on electricity production cost and cost of avoided CO₂ is shown in *Table 7.3* and *Table 7.4*. An increased price level of fuel results in increased electricity production cost, having a negative impact on the cost of avoided CO₂ production for 1 and 2 and a positive impact on case 3. The specific difference in fuel costs between natural gas and coal increases, which is beneficial for coal firing compared to natural gas firing.

The opposite is true for a fuel price *decrement*.

Sensitivity calculation Fuel Price +100%	Electricity production cost	Cost of avoided CO ₂	Change of avoided Cost of CO ₂
	USD/MWh	USD/Ton CO ₂	%
CCPP Ref.	49.31		
Case 1	76.65	89.27	21.9
Case 2.1	84.63	117.33	23.4
Case 2.2	94.14	150.17	20.8
Case 3.1	77.38	115.29	-12.2
Case 3.2	85.44	154.95	-7.8

Table 7.3 - Sensitivity analysis results A

Sensitivity calculation Fuel Price -50%	Electricity production cost	Cost of avoided CO ₂	Change of avoided Cost of CO ₂
	USD/MWh	USD/Ton CO ₂	%
CCPP Ref.	20.31		
Case 1	40.30	65.23	-10.9
Case 2.1	45.57	83.91	-11.7
Case 2.2	53.56	111.42	-10.4
Case 3.1	54.24	139.40	6.1
Case 3.2	61.07	174.72	3.9

Table 7.4 - Sensitivity analysis results B

7.5.2 Discount rate sensitivity

The influence of the discount rate on electricity production cost and cost of avoided CO₂ is shown in *Table 7.5*. As expected, lowering the discount rate has a positive impact on the electricity production cost as well as the costs of avoided CO₂ for all cases studied.

Sensitivity calculation Discount rate 5% (instead of 10%)	Electricity production cost	Cost of avoided CO ₂	Change of avoided Cost of CO ₂
	USD/MWh	USD/Ton CO ₂	%
CCPP Ref.	27.03		
Case 1	45.23	59.43	-18.9
Case 2.1	50.82	79.02	-16.9
Case 2.2	51.93	102.47	-17.6
Case 3.1	50.22	95.27	-27.5
Case 3.2	55.92	123.88	-26.3

Table 7.5 - Sensitivity analysis results C

7.5.3 Retrofit year sensitivity

The influence of the moment of retrofit on electricity production cost and cost of avoided CO₂ is shown in *Table 7.6* and *Table 7.7*. Earlier retrofit results in reduced costs of avoided CO₂ because more CO₂ is captured over the lifetime of the plant. The more years the power plant is operated in “capture mode” the more money it makes compared to the reference cases, which are retrofitted 10 years after startup. A five year earlier retrofit lowers cost of avoided CO₂ per ton with 6% to 10%, whereas a “delay” in retrofit increases the cost of avoided CO₂ per ton with 13% to 22%.

Sensitivity calculation Retrofit year - 5 (5 years from start up)	Electricity production cost	Cost of avoided CO ₂	Change of avoided Cost of CO ₂
	USD/MWh	USD/Ton CO ₂	%
CCPP Ref.	29.97		
Case 1	51.11	69.02	-5.8
Case 2.1	56.92	89.53	-5.8
Case 2.2	64.82	116.76	-6.1
Case 3.1	58.90	118.92	-9.5
Case 3.2	65.54	152.58	-9.3

Table 7.6 - Sensitivity analysis results D

Sensitivity calculation Retrofit year + 5 (15 years from start up)	Electricity production cost	Cost of avoided CO ₂	Change of avoided Cost of CO ₂
	USD/MWh	USD/Ton CO ₂	%
CCPP Ref.	29.97		
Case 1	55.32	82.77	13.0
Case 2.1	62.34	107.49	13.1
Case 2.2	72.18	141.42	13.7
Case 3.1	68.82	159.71	21.6
Case 3.2	77.43	203.56	21.1

Table 7.7 - Sensitivity analysis results E

8. RETROFITTING ISSUES

When a standard combined cycle power plant is retrofitted to a low CO₂ emission power plant, modifications to the installation are needed or new add-on installations are required. These modifications are often not foreseen at the design phase of the original power plant, and this can therefore create barriers to the retrofit, either technical or economical. This chapter identifies the possible barriers and describes how action taken during the design phase of a new power plant can be used to minimize barriers to a future retrofit and even optimize the overall plant configuration by allowing future integration of capture plant and power plant.

8.1 BARRIERS TO RETROFIT

In general a standard combined cycle power plant is not designed for the future possibility of major modifications due to retrofitting the plant. Especially for modern power plants, standardization and modularization are getting more and more important as manufacturers are trying to find ways to cut engineering and erection costs. This however also complicates a retrofit, as there is not much space left for expansion or adjustments to the installation. Furthermore current plants are optimized based on the original design parameters and a change to the process parameters or plant design often leads to a sub optimal design, which may not survive in a competitive market environment.

This paragraph aims to identify possible barriers to retrofitting existing combined cycle power plants to a power plant with CO₂ capture. The barriers are listed below:

Plot Space

A fuel processing plant as well a post combustion CO₂ capture unit (flue gas scrubber) requires a considerable amount of plot space. This plot space needs to be available in the near surroundings of the plot. When the plant is situated in a residential area or a heavily industrialised area this plot space is not always available.

Especially for a post combustion unit with large atmospheric flue gas flows, the capture unit needs to be installed literally next to the CCCP. It is not desirable to transport these large quantities of flue gas over even a short distance. From a technical point of view the resulting higher pressure loss will to a great extent affect the performance. From an economical point of view the costs for this large diameter piping are high.

In case of a fuel processing plant, the distance between the CCCP and fuel plant is less critical from a technical point of view. However, the longer the distance is, the higher the costs are for connecting the plants. Furthermore it shall be clear that the area classification for the fuel plant is an important issue in the plot location. Of course these remarks are a less critical issue in the remote cases, at which the choice for the location of the fuel plant is "open".

Also significant plot space is required for construction. This is an important item with respect to the overall construction cost and time schedule. With little construction space available, items need to be delivered as prefab installations as much as possible (no place to construct on-site) and planning of the activities becomes very important (no place to store materials/equipment).

Available Space within installation

The existing installation is designed to take up the least plot space as possible. When tie-ins are required, problems can arise with the available place within the installation itself.

For example, in the pre combustion case the fuel supply piping has to be replaced as fuel flows increase significantly. In the post combustion case additional LP steam piping of approximately 36 inch is needed for steam supply from the power plant to the capture plant.

Fitting the large diameter piping in the existing CCPP will create difficulties, as the installation is not designed for this extra piping. Depending on the actual situation, a certain amount of effort will be needed to enable the tie-inns and because of this costs will rise.

Accessibility

The delivery of large equipment can be a problem when the power plant is situated in an industrial surrounding. This is the case at both the post combustion as well as the pre combustion cases (except for the remote options). It might be necessary to deliver very large equipment blocks in parts and build the equipment on-site. This can influence the cost of retrofitting negatively and have great influence on the time schedule.

To illustrate this, the largest new equipment items for the different options are listed here:

- Case 1 CO₂ absorber: 9.7 m. diameter by 20 m. tan-tan
- Case 2-1 CO₂ absorber: 6.5 m. diameter by 39 m. tan-tan
- Case 2-2 CO₂ absorber: 6.5 m. diameter by 39 m. tan-tan
- Case 3-1 CO₂ absorber: 6.4 m. diameter by 31 m. tan-tan
- ASU main column: 5.3 m. diameter by 50 m. tan-tan
- Case 3-2 CO₂ absorber: 6.5 m. diameter by 31 m. tan-tan
- ASU main column: 5.5 m. diameter by 50 m. tan-tan

Changed process conditions

The gas turbine performance will differ significantly when fired on a low-LHV fuel, which is the case with pre combustion CO₂ capture. The standard power plant has been designed for firing on natural gas, and the changed gas turbine performance will lead to different process conditions in the installation. This can lead to technical problems that can be hard to overcome.

For instance the lower exhaust temperature of the gas turbine exhaust gas will lead to a lower steam temperature at the HP superheater outlet. This can create problems in the condensing section of the steam turbine, causing too high moisture content in the steam, which damages the last blade rows in the steam turbine condensing section.

For the post combustion case the added flue gas scrubber introduces an additional pressure loss at the flue gas side. Additional measures have to be taken to overcome and/or reduce this pressure loss. This kind of problems may even lead to the complete replacement of parts of the existing equipment, with equipment that is designed for the new process conditions.

Whether this kind of problems will occur, depends on the design of the installation. As no design is exactly the same, it will be necessary to determine possible problems for

each installation that is retrofitted. This applies not only to base load operation, but also to different part load situations, at several ambient conditions.

Demin Water Capacity

Injection of high quality steam is needed in case gas turbine DLN burners are replaced with conventional burners. Hence demin water plant capacity is to be enlarged for steam injection.

In case of a local CCGT and remote capture plant an additional demin water plant is needed, which requires extra plot space.

The demin water consumption for each case can be found in Appendix 5. These consumptions represent the water consumptions in normal operation. When the CCGT is fired on secondary fuel (i.e. natural gas), higher demin water consumption is applicable for all cases, as steam injection is needed to restrict NO_x emissions.

Cooling Water Capacity

The fuel processing plant will increase the cooling water demand and cooling water duty significantly. The CCGT cooling system will probably not be sufficient to meet this increase in demand and therefore a new system might be necessary. It will not be a problem to install new piping and cooling water pumps, as these are simply add-on installations. When the spare capacity of the cooling water intake and outlet is too low, the implications are greater. Increasing the capacity demands for extensive civil works and sufficient space may not be available for these expansions. In that case cooling tower systems may be required.

Operational flexibility

Inlet Guide Vane control is used to operate the gas turbine when fired on low-LHV fuels. These IGV's are normally used to enable more efficient part load operation of the CCGT. Using them at full load means that the part load efficiency will be affected in a negative way, as this control can no longer be used in its full extent for part load operation.

CCGT units are generally spoken very flexible with respect to the time required for start up and shut down. In the pre combustion case, a complete fuel plant is added, which complicates start up and shut down as this plant has to start/stop as well.

Permitting

In practice it is time consuming and expensive to get the needed permits for expansions or modifications to an installation. Retrofitting an existing CCGT means that the emissions to air and water change, the noise level can increase, more cooling duty is required, etcetera. This will probably lead to the need for new or adjusted permits. The time and effort, which is consumed when new permits are needed, should not be underestimated. This will especially apply to high-pressure fuel lines near urban areas.

Fuel storage and transport

In case of coal fired plants a large open space is needed for coal storage. Because the coal in store is subject to self-ignition, hence the storage spreads smoke and smell, it is preferred to keep the plant away from residential areas and safe zones.

High pressure fuel lines are needed to transport syngas in the case a Fuel/CO₂ capture plant is built remotely from the existing CCPP. Routing of the HP fuel lines is complex because of the line size of 30-36 inch and the probable interference with road crossings and areas with explosion safety demands, which do not allow an HP fuel line to cross.

8.2 DESIGN FOR FUTURE RETROFIT

In the previous paragraph the barriers were discussed, which could arise when an existing combined cycle power plant is to be retrofitted to a low CO₂ emission power plant. This paragraph discusses the options to design the plant in such a way that a future retrofit can be executed without major costs and technical difficulties, caused by these barriers, while still maintaining an optimal performance before and after retrofit. First step is to point out the possible barriers and try to remove them by implementing additional design requirements. Next to removing barriers for future retrofit, there are also possibilities for process integration between the fuel plant and the power plant. These can increase the economical feasibility of the project with a considerable amount.

Without being studied in detail, some indications are given to illustrate the impact that these issues may have.

8.2.1 Avoiding potential barriers

In paragraph 8.1 the barriers to retrofitting are discussed. When a CCPP is designed for future retrofit, these potential barriers should be avoided in the design phase. In this paragraph the possible solutions are mentioned to each of the above-mentioned barriers.

Plot Space

In the ideal situation of a completely new and empty site, the design should also include the additional required plot space for the fuel processing plant or the flue gas scrubber. The most ideal location for the installations with respect to the CCPP can be determined.

When the CCPP is placed in an area with little additional space available, the nearest possible free plot space should be determined and reserved. In this way no new building activities are deployed on that lot, until the final decision for retrofitting is made.

When post combustion CO₂ capture is decided, it is however necessary to reserve additional plot space at the CCPP plot. It is not desirable to transport the large flue gas volume over big distances.

In Appendix 3 the plot plans with sizes for the different installations can be found.

In addition to the required space for the installations themselves, attention should be paid to the space required for the construction activities. When space is available to store materials, tools and installation parts on site, the construction work can be done cheaper in comparison to an off-site construction area.

Reserving more plot space than strictly necessary for the CCPP plant only will result in higher project costs in the first phase, but will save expenses when retrofit is carried out.

Indications of plotspace needed for building the capture plants are:

Case 1: post combustion capture plant 250x150 m.

Case 2.1 and 2.2: gas reformed based pre combustion capture plant 175x150 m.

Case 3.1 and 3.2: coal gasification based pre combustion capture plant 475 x 375 m.

Available space in installation

When the CCPP is designed for future retrofit, the future tie-ins have to be defined and the space they require becomes an additional design requirement.

For the pre combustion capture case this implies that space has to be reserved for large diameter (12"-36" dependant on the option concerned) fuel feed pipes to the gas turbine. The same applies for the large diameter low pressure steam line (approx. 36") in the post combustion option. Also when the replacement of equipment components is foreseen, the design should anticipate the incorporation of the new (possibly larger) component, as well as enable the replacement work itself. For example it might be necessary to replace the existing HRSG superheater section, to adjust the CCPP to the new process conditions. Taking these issues into account will lead to minor extra costs, while the cost savings at the retrofit stage can be significant.

Typically stretching the HRSG with a few meters and allow for some spare room for the heat surfaces concerned allows for a modification.

Accessibility

The accessibility of the plot should be considered as a design requirement at the choice for the most appropriate site location. Usually this aspect will already be part of the selection process for a new CCPP, and extra attention should be paid to the accessibility for the big components of the pre and post combustion capture installations.

Changed process conditions

A new power plant will generally be designed to perform in an optimal way at one set of process conditions, belonging to one type of fuel, one average ambient condition, etcetera. An important option to facilitate retrofitting a CCPP is to design the plant with keeping in mind that process conditions change due to the retrofit.

At the pre combustion capture case the exhaust gas temperature decreases when the gas turbine is fired on low-LHV fuel gas. This implies that the high-pressure steam superheater cannot raise the steam temperature to the original design value, as the surface area is too small at these different flue gas conditions. This could cause technical problems and it may even be necessary to exchange the superheater with a new, larger one.

During the design phase it could be considered to install the larger superheater, which will be able to raise the steam temperature to the original design value. This superheater will then be equipped with an attemperator to cool down the steam temperature when the gas turbine is fired on normal LHV (natural) gas. Installing a larger superheater will be more expensive and reduce efficiency in the CCPP. However it improves efficiency and saves costs in retrofit.

For the post combustion case there is no remedy to undo the higher pressure loss due to the flue gas scrubber unit. An induced draft fan could be installed during retrofitting in the flue gas ducting to overcome this extra loss, but this will also increase the auxiliary power consumption (because of the power needed to drive the fan). Extra plot space for enabling the installation of this fan should be provided for.

Cooling water capacity

The cooling water intake and outlet stations should be designed to have sufficient capacity to take the increase in cooling water demand because of the fuel processing plant or the flue gas scrubber. The stations can be designed to facilitate for example extra cooling water pumps, without the need for installing these pumps right away. This will give flexibility to increase the cooling water capacity without having to perform large civil works for expansion.

The cooling water capacity for the various capture plants is:

- coal gasification based local pre combustion capture plant 83,000 m³/h.
- gas reformed based local pre combustion capture plant 21,000 m³/h.
- post combustion capture plant 46,000 m³/h.

The cooling water requirement of the CCPP for the different cases can be found in Appendix 1, stream 5. For the reference case the maximum cooling water load applies, which is approximately 27,000 m³/h.

Operational Flexibility

It is difficult to design for a higher level of operational flexibility when the gas turbines are fired on low-LHV gas. Process integration between the pre combustion capture plant and the CCPP could help, as will be discussed in the following paragraph.

Permitting

As permitting can be a real problem, it is advisable to start the requests for the required permits as early as possible. This could mean that the application for the permits needed for the situation after retrofit, could best be started together with the permits for the CCPP. This will decrease the change on surprises as well as it will avoid lost time when the decision for retrofitting is made.

Construction and Start-up

Planned down time of the CCPP can be minimised when additional facilities for making the tie-ins with the CCPP in operation (Hot-tapping) are allowed for during construction.

8.2.2 Potential process integration

In addition to trying to remove potential barriers to future retrofit, it can be rewarding to design the CCPP in such a way that process integration can be obtained between the CCPP and the post or pre combustion capture plants. This could lead to cost savings as well as performance improvements compared to not-integrated plants. This paragraph indicates the potential options for process integration.

Gas Turbine Compressor Bleed

The Capture Plant requires high-pressure air, which is supplied by a dedicated compressor. At the power plant however, the gas turbine compressor is partially bypassed by closing the IGV's, in order to retain the fuel gas flow through the gas turbine expander section.

Here process integration can be achieved by using the highly efficient gas turbine compressor section to supply (part of) the high-pressure air for the Capture Plant. This has multiple advantages:

- Gas turbine compressor sections are state of the art compressors, with highest efficiencies. The efficiency of the gas turbine compressor will usually be higher than the efficiency of the dedicated compressor.
- Investment costs will be lower as the dedicated compressor can be designed for a smaller airflow or smaller pressure ratio.
- The gas turbine compressor section will take the airflow it was designed for and at which its efficiency is highest. This contrary to the non-integration case at which IGV's are used to decrease the flow through the compressor.
- The CCGT part load efficiency is increased, as the IGV control is once again completely available to reduce the gas turbine load.

As the natural gas fuelled (local) pre combustion CO₂ capture plant is provided with high efficient air compressor units with minimum intercooling the potential efficiency increase by implementing gas turbine compressor bleed is marginal. However it will have a positive impact on the overall cost of investment because of the reduction of air compressor capacity required. An overall cost reduction of approx. 7% of the fuel/CO₂ capture plant is expected.

For the coal gasification based (local) pre combustion CO₂ capture plant also potential efficiency increase is expected because for the ASU highly intercooled compressor units are used. This configuration aims for the minimum compressor power required, but results in a high loss of thermal energy via the cooling water system which has a negative impact on the overall plant efficiency.

To achieve a bleed flow from the gas turbine compressor outlet, the gas turbine needs to be equipped with a special bleed system. This will probably be too expensive when an existing gas turbine without air bleed is retrofitted. However when the power plant is designed for retrofit, the gas turbine can be ordered with an air bleed system installed. Of course this process integration is only feasible in the local cases as it will not be efficient to bring the compressed air from the power plant through a 40 km pipeline to the Capture Plant.

Integral water-steam cycle

The pre combustion capture plant has a dedicated steam turbine to expand the steam generated in the process and produce electricity. This steam turbine is a relatively small turbine, with high investment costs and a relatively low efficiency (compared to large scale power plant steam turbines). The power plant has such a large steam turbine generator and therefore process integration can be achieved here by feeding the steam from the Capture Plant to the power plant steam turbine. This has the following advantages:

- Small steam turbines have higher specific investment cost, and it is usually less expensive to purchase a somewhat larger steam turbine for the power plant with an

increased capacity to be able to accept the additional Capture Plant steam production.

- The large steam turbine has a higher efficiency than the small turbine, so the steam expansion and electricity production is more efficient in the large turbine. Additional advantage is the need for only one cooling water system. The larger steam turbine will also come with a larger condenser, so there is no need for a dedicated condenser for the fuel plant.
- The integration will save valuable plot space.

However, as the steam generation in the fuel plant (approx 300-550 t/h) is rather significant compared to the CCCP steam production (approx. 2*350 t/h), this will highly effect the steam turbine design of the CCCP. It requires a more detailed study to assess the overall impact and potential.

Again this process integration option is only feasible in the local cases as it will not be efficient to transport high pressure steam over 40 km in the remote cases.

The same arguments as above can be used to plead for a combined instead of a dedicated demin water plant and closed cooling water system.

8.3 OVERALL AVAILABILITY

8.3.1 Availability rating

The overall availability of a plant is mainly dependent on the following issues:

- complexity of the installation and/or process
- project experiences with the type of installation concerned (i.e. references)
- design philosophy of the plant (i.e. redundancy of critical equipment, control and safeguarding systems, etc.).

In *Table 8.1* an overview of the availability rating for the various plants concerned for this study is presented:

	Complexity	References *	Design	Overall rating
Reference plant	++	++	++	++
Case 1	+	o	++	+
Case 2.1	o	o/-	++	o
Case 2.2	o	o/-	++	o
Case 3.1	--	o/-	++	-
Case 3.2	--	o/-	++	-

Table 8.1 - Availability Rating

* There are presently hardly any CO₂ capture plants realized but in case there are similar types of plants in operation this is also taken into account.

From the table it becomes clear that the expected overall availability for the retrofitted plants is lower than the expected availability for the reference plant. This is in principle an expected result, as the retrofitted plant comprises not only additional plant sections

(i.e. additional systems and equipment, which may fail and require maintenance) but also rather complex installations (especially the coal based plants).

However when evaluating the availability of power generation it is possible to obtain a similar availability for all plants by providing sufficient provisions to allow for independent operation of the CCPP. The required provisions for each case are presented below.

In all cases, the capture plant is designed to have an availability of at least 90%. This is achieved by installing spares in key services. For example, all pumps, the gasifiers and sulphur plants in cases 3-1 and 3-2, and the desulphurisation reactors in Cases 2-1 and 2-2 are spared.

In all cases, provided the CCPP is allowed to operate without capturing 85% of the carbon in the feed, then the installation of the Capture Plant does not affect the availability of the CCPP.

8.3.2 Case 1 Post combustion CO₂ capture

A bypass stack with (automatic) switch over facilities between the HRSG sections and the CO₂ capture plant shall be provided in order to discharge the flue gas to the atmosphere or to the CO₂ capture plant.

The effect of the failure of a single quench and acid gas removal train would mean that, provided that the exhaust gases could be vented, CO₂ capture would be reduced by 12.5%. It is unlikely that the additional exhaust gas could be routed through the remaining quench and acid gas removal units, as this would increase pressure drops by up to 70% and overload the absorber feed fan. Failure of multiple quench and acid gas removal trains would result in further reductions in CO₂ capture and increases in the steam turbine generator condenser requirements. Alternatively, the CCPP for the failed quench and acid gas removal train, could be turned down to 75% of capacity, removing the need for venting of exhaust gas.

The effect of failure of a CO₂ compressor and dryer unit would be to reduce the CO₂ capture by 50%. The exhaust gas from the HRSG could be routed to the existing stack and the CCPP operated as before the Capture Plant was installed.

8.3.3 Case 2 Pre combustion CO₂ capture by syngas production from natural gas

The Capture Plant has two trains of desulphurisation, auto-thermal reformer, high temperature cooling, shift, low temperature cooling, acid gas removal, CO₂ compressor and dryer, and gas conditioning. A failure of any one of these process units means that the capture plant train is shut down and the feed of low carbon fuel to one gas turbine is stopped.

Therefore the gas turbine shall be provided with a conventional dual fuel system capable of firing 100 % syngas as well as 100 % natural gas. Steam injection will be required for NO_x abatement during firing natural gas.

8.3.4 Case 3 Pre combustion CO₂ capture by syngas production from coal

The Capture Plant has two trains of coal slurring and grinding, gasification, shift, low temperature cooling, acid gas removal, CO₂ compressor and dryer, and gas conditioning. Failure of coal slurring and grinding, gasification, shift, low temperature cooling, acid gas removal, or gas conditioning results in shut down of one train of the Capture Plant and one gas turbine is running on natural gas in stead of syngas. A spare gasifier is foreseen in the design of the Capture Plant (5 * 25% gasifiers).

Therefore the gas turbine shall be provided with a conventional dual fuel system capable of firing 100 % syngas as well as 100 % natural gas. Steam injection will be required for NO_x abatement during firing natural gas.

If the CO₂ compressor and dryer, CO₂ export pipeline or CO₂ sink fails, then fuel gas can be supplied to the CCGT, which operates as normal, except that CO₂ is vented to atmosphere, rather than being captured.

8.3.5 Availability during start-up

It shall be clear that the provisions mentioned above are also strongly preferred or even required for start-up and shut down purposes and are therefore implemented anyhow and not lead to additional capital cost.

In the year of retrofit the CCGT availability may decrease because of the down time to allow for implementing modifications and tie-in activities. In case of a good preparation and a tight schedule it is considered possible to make all tie-ins and implement the required modifications within approximately 1 month. For case 1, post combustion CO₂ capture, it may even be possible to realize the project without additional down time when all tie-ins have been prepared in advance (i.e. during a planned outage of the CCGT). For the pre combustion CO₂ capture cases a complete new combustion system has to be installed. This system will normally not be installed in advance as it will have a negative impact on the power plant performance (steam injection required when firing natural gas).

In case the modifications are executed during a major overhaul period the impact on the plant availability will be negligible for all cases.

Also during the initial commissioning/operating period the availability will be lower due to the 'normal' issues, which always rise during the initial start-up of an installation. It is normal practice that the higher the complexity of the installation the longer it takes to reach the stable operating mode.

To minimize the CCGT plant availability reduction during the commissioning/start-up period it is preferred to have a postponed schedule for the second power train. Experiences gained during start up of the first train can be used when starting up the second train.

9. CONCLUSIONS

From the study it becomes clear that a retrofit of CO₂ capture to a natural gas fired CCCP requires a significant cost of investment and results also in a significant reduction of the overall electric efficiency. The post combustion CO₂ capture option is strongly preferred from a performance and financial point of view compared to the natural gas reforming and the coal gasification based pre combustion CO₂ capture plants.

The post combustion option shows the smallest but still significant efficiency reduction in combination with the lowest capital expenditures and the best specific CO₂ emission.

The main disadvantage of the post combustion option is the requirement of installing the plant almost next to the existing CCCP because of the large atmospheric flue gas flow. As the plant requires also a large plot space, this could be a problem for retrofitting.

The main data for all options studied are presented in table 9.1

		Ref.	1	2.1	2.2	3.1	3.2
Capital expenditure ^{*)}	MUSD	415	395	569	750	962	1194
Specific electricity cost ^{**)}	USD/MWh	30.0					
Cost of avoided CO ₂	USD/ton CO ₂	---	73.2	95.1	124.3	131.4	168.1
Overall efficiency	%	55.9	44.6	41.5	39.9	35.4	33.6
Fuel consumption (LHV)	MWth	1405	1405	1672	1671	2121	2306
Net power production	MWe	785	626	694	667	751	775
CO ₂ emission	kg/s	81.4	11.7	13.9	13.9	27.1	30.2
Specific CO ₂ emission	g/kWh	373	67	72	75	130	140
Relative CO ₂ emission	%	100	17.9	19.4	20.0	34.8	37.5
Relative CO ₂ capture efficiency ^{***)}	%	0	82.1	80.6	80.0	65.2	62.5

Table 9.1 – Overall performance comparison

Ref : Natural gas fired CCCP

1 : Post combustion CO₂ capture

2.1 : Pre combustion CO₂ capture (natural gas reforming, local)

2.2 : Pre combustion CO₂ capture (natural gas reforming, remote)

3.1 : Pre combustion CO₂ capture (coal gasification, local)

3.2 : Pre combustion CO₂ capture (coal gasification, remote)

^{*)} The capital expenditures for the fuel/CO₂ capture plant are excluding the cost of the reference CCCP.

^{**)} The specific electricity costs are calculated for the project with a Net Present Value (NPV) of 0.

^{***)} The absolute capture efficiency for all plants is approx. 85%. However, as retrofitting reduces the efficiency, the relative capture efficiency decreases.

Other conclusions are:

- All options comply with the CO₂ capture efficiency of 85%.
- The remote pre combustion options require a higher cost of investment and have a lower efficiency due to transportation of the fuel gas.
- The overall power generation availability of the retrofitted plant is “identical” to the reference CCCP.
- Sensitivity analyses on fuel price show a different behaviour of the cost of avoided CO₂ for the coal-based plants compared to the natural gas fuelled plants. An increase of the fuel price results in an increase in the cost of avoided CO₂ for the natural gas fuelled plants and a decrease of cost for the coal fuelled plants. In case of a fuel price reduction the opposite occurs. Sensitivity analysis on discount rate show, as expected, a reduction of the costs of avoided CO₂ for all cases considered with a reduced discount rate.
- Sensitivity analyses on the year of retrofit show as expected that when the retrofit is executed at a later time, the cost of avoided CO₂ increase.
- The post combustion option remains the best option from a financial point of view for all sensitivities considered.


APPENDICES

1. CCGT Simplified Process Scheme & Mass Balances
2. Fuel/CO₂ Capture Plants Simplified Process Schemes & Mass Balances
3. Plot Lay-outs
4. Fuel/CO₂ Capture Plants Equipment List
5. Fuel/CO₂ Capture Plants Power Consumption/Production & Utility Usage
6. Fuel/CO₂ Capture Plants Capital Cost Estimates
7. Cash Flow Calculations
8. Task 1 – Same Output Retrofit
9. Task 3 – Pre-Implementation Retrofit

Appendix 1

CCPP Simplified Process Scheme and Mass Balance

CCPP SCHEME



**Mass balance standard power plant
Reference Case**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A.	N.A.	N.A.	N.A.	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	618.2	15.0	633.2	633.2	7508.0	7508.0	96.9	96.9	99.2	10.7
Pressure	bar	1.0	40.0	1.0	1.0	2.0	1.0	8.0	8.0	1.2	5.0
Temperature	C	9	10	608	99	12	19	29	90	105	105
Enthalpy	kJ/kg	-6	-11	656	87	51	80	122	377	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.00	1.00	1.00	1.00
Flow	kg/sec	10.7	10.7	10.7	2.3	11.4	11.4	11.4	11.4	11.4	88.5
Pressure	bar	4.9	4.7	4.6	4.6	28.3	28.2	28.1	27.5	27.4	27.0
Temperature	C	148	150	300	318	105	140	227	229	300	560
Enthalpy	kJ/kg	624	2745	3066	3102	444	591	977	2802	3003	3593

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	0.93
Flow	kg/sec	88.5	96.9	77.1	77.1	77.1	77.1	77.1	77.1	77.1	96.9
Pressure	bar	4.6	4.6	122.3	122.2	122.1	122.0	121.0	120.0	27.4	0.04
Temperature	C	320	318	107	140	221	323	325	560	346	29
Enthalpy	kJ/kg	3107	3102	457	597	951	1480	2687	3505	3114	2384

		31
Quality		1.00
Flow	kg/sec	0.0
Pressure	bar	27.0
Temperature	C	560
Enthalpy	kJ/kg	3593

NO FUEL PREHEATING AT CCPP

**Mass balance standard power plant
Case 1 Post Combustion**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A.	N.A.	N.A.	N.A.	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	618.2	15.0	633.2	633.2	4496.6	4496.6	10.8	96.8	99.2	10.7
Pressure	bar	1.0	40.0	1.0	1.0	2.0	1.0	8.0	8.0	1.2	5.0
Temperature	C	9	10	608	99	12	14	15	90	105	105
Enthalpy	kJ/kg	-6	-11	656	87	51	57	64	376	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.00	1.00	1.00	1.00
Flow	kg/sec	10.7	10.7	10.7	2.3	11.4	11.4	11.4	11.4	11.4	88.5
Pressure	bar	4.9	4.7	4.6	4.6	28.3	28.2	28.1	27.5	27.4	27.0
Temperature	C	148	150	300	318	105	140	227	229	300	560
Enthalpy	kJ/kg	624	2745	3066	3102	444	591	977	2802	3003	3593

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	1.00
Flow	kg/sec	88.5	10.8	77.1	77.1	77.1	77.1	77.1	77.1	77.1	10.8
Pressure	bar	4.6	4.6	122.3	122.2	122.1	122.0	121.0	120.0	27.4	0.02
Temperature	C	320	318	107	140	221	323	325	560	346	18
Enthalpy	kJ/kg	3107	3102	457	597	951	1480	2687	3505	3114	2534

		31	32	33
Quality		1.00	1.00	0.00
Flow	kg/sec	0.0	86.0	86.0
Pressure	bar	27.0	4.6	8.0
Temperature	C	560	318	30
Enthalpy	kJ/kg	3593	3102	126

NO FUEL PREHEATING AT CCPP

**Mass balance standard power plant
Case 2-1, local H2, Nat Gas**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A	N.A	N.A	N.A	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	535.3	89.7	625.1	625.1	7204.1	7204.1	93.5	93.5	95.3	12.1
Pressure	bar	1.0	30.0	1.0	1.0	2.0	1.0	8.0	8.0	1.2	5.1
Temperature	C	9.0	230.0	565.1	101.8	12	19	29	93	105	105
Enthalpy	kJ/kg	-6	422	631	94	51	80	121	388	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.00	1.00	1.00	1.00
Flow	kg/sec	12.1	12.1	12.1	1.8	13.9	13.9	13.9	13.9	13.9	83.2
Pressure	bar	4.9	4.7	4.6	4.6	28.4	28.2	28.1	27.5	27.3	27.0
Temperature	C	149	150	305	306	105	140	230	229	291	531
Enthalpy	kJ/kg	628	2745	3076	3078	444	592	988	2802	2980	3528

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	0.92
Flow	kg/sec	83.2	93.5	69.3	69.3	69.3	69.3	69.3	69.3	69.3	93.5
Pressure	bar	4.6	4.6	122.1	122.1	122.0	121.9	120.9	120.1	27.3	0.04
Temperature	C	306	306	107	142	225	324	325	526	330	29
Enthalpy	kJ/kg	3077.9	3078	457	606	970	1489	2687	3419	3077	2371

		31
Quality		1.00
Flow	kg/sec	0.0
Pressure	bar	27.0
Temperature	C	530.9
Enthalpy	kJ/kg	3528

NO FUEL PREHEATING AT CCPP

**Mass balance standard power plant
Case 2-2, remote H2, Nat Gas**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A.	N.A.	N.A.	N.A.	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	536.2	77.9	626.1	626.1	6052.5	6052.5	73.2	85.2	86.4	8.3
Pressure	bar	1.0	25.0	1.0	1.0	2.0	1.0	3.0	3.0	1.2	4.9
Temperature	C	9	215	564	103	12	19	27	96	105	105
Enthalpy	kJ/kg	-6	385	630	95	48	75	115	400	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.00	1.00	1.00	1.00
Flow	kg/sec	8.3	8.3	8.3	1.2	11.4	11.4	11.4	15.5	11.4	66.1
Pressure	bar	4.9	4.7	4.6	4.6	28.1	28.0	27.9	27.3	27.2	27.0
Temperature	C	151	149	314	334	105	143	230	229	300	539
Enthalpy	kJ/kg	638	2744	3094	3136	444	605	998	2802	3004	3546

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	0.94
Flow	kg/sec	66.1	73.2	66.8	66.8	66.8	66.8	66.8	66.8	66.8	73.2
Pressure	bar	4.6	4.6	122.0	121.9	121.8	121.7	120.7	120.0	27.2	0.04
Temperature	C	337	334	107	144	228	326	325	539	343	27
Enthalpy	kJ/kg	3141	3136	457	615	982	1499	2688	3452	3107	2403

		31
Quality		1.00
Flow	kg/sec	12.0
Pressure	bar	27.2
Temperature	C	337
Enthalpy	kJ/kg	3092

3 stage fuel preheating with saturated steam

HP 9.5 kg/s
MP 4.1 kg/s
LP 4.8 kg/s

NOTE: taken from evaporators

**Mass balance standard power plant
Case 3-1, local H2, Coal**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A.	N.A.	N.A.	N.A.	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	523.2	103.7	626.9	626.9	7108.6	7108.6	92.1	92.1	93.9	11.9
Pressure	bar	1.0	25.9	1.0	1.0	2.0	1.0	8.0	8.0	1.2	5.0
Temperature	C	9	230	565	101	12	19	29	93	105	105
Enthalpy	kJ/kg	-6	363	620	91	51	80	121	389	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.00	1.00	1.00	1.00
Flow	kg/sec	11.9	11.9	11.9	1.7	13.6	13.6	13.6	13.6	13.6	82.0
Pressure	bar	4.9	4.7	4.6	4.6	28.4	28.2	28.1	27.5	27.3	27.0
Temperature	C	149	150	305	308	105	140	230	229	291	531
Enthalpy	kJ/kg	628	2745	3077	3081	444	592	988	2802	2981	3530

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	0.93
Flow	kg/sec	82.0	92.1	68.4	68.4	68.4	68.4	68.3	68.3	68.3	92.1
Pressure	bar	4.6	4.6	122.1	122.0	121.9	121.8	120.8	120.1	27.3	0.04
Temperature	C	308	308	107	142	225	324	325	528	333	29
Enthalpy	kJ/kg	3082	3081	457	606	970	1488	2687	3424	3083	2373

		31
Quality		1.00
Flow	kg/sec	0.0
Pressure	bar	27.0
Temperature	C	531
Enthalpy	kJ/kg	3530

NO FUEL PREHEATING AT CCPP

**Mass balance standard power plant
Case 3-2; remote H2, Coal**

		1	2	3	4	5	6	7	8	9	10
Quality		N.A.	N.A.	N.A.	N.A.	0.00	0.00	0.00	0.00	0.00	0.00
Flow	kg/sec	531.7	89.7	627.3	627.3	6417.0	6417.0	77.9	83.8	84.7	8.3
Pressure	bar	1.0	21.0	1.0	1.0	2.0	1.0	3.0	3.0	1.2	4.9
Temperature	C	9	223	567	103	12	19	28	98	105	105
Enthalpy	kJ/kg	-6	371	627	94	48	75	117	409	439	440

		11	12	13	14	15	16	17	18	19	20
Quality		0.00	1.00	1.00	1.00	0.00	0.00	0.01	1.00	1.00	1.00
Flow	kg/sec	8.3	8.3	8.3	1.0	11.2	11.2	11.2	15.6	11.2	70.5
Pressure	bar	4.9	4.7	4.6	4.6	28.1	28.0	28.0	27.4	27.3	27.0
Temperature	C	151	149	315	329	105	144	230	229	300	540
Enthalpy	kJ/kg	639	2744	3096	3125	444	606	999	2802	3005	3548

		21	22	23	24	25	26	27	28	29	30
Quality		1.00	1.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	0.94
Flow	kg/sec	70.5	77.9	65.2	65.2	65.2	65.2	65.2	65.2	65.2	77.9
Pressure	bar	4.6	4.6	121.9	121.9	121.8	121.7	120.7	120.0	27.3	0.04
Temperature	C	330	329	107	145	228	326	325	543	348	28
Enthalpy	kJ/kg	3128	3125	457	616	985	1500	2688	3460	3118	2397

		31
Quality		1.00
Flow	kg/sec	5.9
Pressure	bar	27.3
Temperature	C	341
Enthalpy	kJ/kg	3102

3 stage fuel preheating with saturated steam


HP 11.2 kg/s
MP 4.4 kg/s
LP 4.9 kg/s

NOTE: taken from evaporators


Appendix 2

Fuel/CO₂ Capture Plants Simplified Process Schemes and Mass Balances


Case 1




Case 2-1




Case 2-2



Case 3-1



Case 3-2



The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

STREAM NUMBER		1		2		3		4		5		6	
STREAM NAME		Feed Gas		Air		Desulphurised Feed Gas		Reformed Gas		Shifted Gas		Dry Shifted Gas	
COMPONENT	MVV	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)
Hydrogen	2.016	0.00	0.00	0.00	0.00	66.04	1.92	6960.91	35.28	9358.72	42.29	9358.71	42.30
Nitrogen	28.013	13.24	0.40	8623.06	78.09	74.71	2.17	8697.77	44.09	8697.77	39.31	8697.76	39.31
Carbon Monoxide	28.010	0.00	0.00	0.00	0.00	2.73	0.08	2784.02	14.11	386.22	1.75	386.22	1.75
Carbon Dioxide	44.010	59.60	1.80	3.36	0.03	60.33	1.75	1023.44	5.19	3421.26	15.46	3421.13	15.46
Methane	16.042	2778.02	83.90	0.00	0.00	2778.65	80.70	160.06	0.81	160.06	0.72	160.06	0.72
Ethane	30.069	304.62	9.20	0.00	0.00	304.62	8.85	0.00	0.00	0.00	0.00	0.00	0.00
Propane	44.096	109.27	3.30	0.00	0.00	109.27	3.17	0.00	0.00	0.00	0.00	0.00	0.00
Butane	58.122	46.36	1.40	0.00	0.00	46.36	1.35	0.00	0.00	0.00	0.00	0.00	0.00
Argon	39.948	0.00	0.00	102.67	0.93	0.57	0.02	103.23	0.52	103.23	0.47	103.23	0.47
Oxygen	31.999	0.00	0.00	2312.91	20.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen Sulphide	34.082	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Temperature	°C	10.0		9.0		379.9		950.0		263.3		50.0	
Pressure	bar(a)	41.0		Ambient		37.5		34.4		32.3		30.4	
Total Dry Molar Flow	(kmol/h)	3311.11	100.00	11042.00	100.00	3443.26	100.00	19729.44	100.00	22127.26	100.00	22127.11	100.00
Water (kmol/h)	18.015	0.00		77.77		0.28		3903.90		1506.09		92.87	
TOTAL WET	(kmol/h)	3311.11		11119.77		3443.55		23633.33		23633.35		22219.99	
Total Mass Flow (kg/h)		64200		321000		66200		458000		458000		432000	
Molecular Weight		19.40		28.89		19.23		19.37		19.37		19.45	
Notes : All flows are for a single stream		Issue:	0	Date	1	Date		Date		Date		Date	
		Description:	For Final Report		Temp & Press Added								
		Made By:	THLW	05-apr-04	NJE	16-jul-04							
		Checked:	SBJS	06-apr-04	SBJS	26-jul-04							
		Approved:	SBJS	06-apr-04	SBJS	26-jul-04							



JACOBS CONSULTANCY UK LTD
MATERIAL BALANCE

Document No.: **60-8389-00/P.03/2101/A4**

Project No.: 60-8389-00 Plant: Autothermal Ref.
 Client: IEA Location: NE Netherlands
 Case: 2-1

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

STREAM NUMBER		7		8		9		10				1	
STREAM NAME		CO2 Lean Fuel Gas		Compressed CO2		Conditioned Fuel Gas		Flue Gas					
COMPONENT	M/W	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)
Hydrogen	2.016	9257.52	49.97	35.15	1.01	9257.51	49.97	0.00	0.00				
Nitrogen	28.013	8615.27	46.51	21.02	0.61	8615.27	46.51	60371.02	85.56				
Carbon Monoxide	28.010	382.24	2.06	1.25	0.04	382.24	2.06	0.00	0.00				
Carbon Dioxide	44.010	101.97	0.55	3317.26	95.63	101.97	0.55	591.45	0.84				
Methane	16.042	88.83	0.48	70.60	2.04	88.83	0.48	0.00	0.00				
Ethane	30.069	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
Propane	44.096	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
Butane	58.122	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
Argon	39.948	79.26	0.43	23.40	0.67	79.26	0.43	697.73	0.99				
Oxygen	31.999	0.00	0.00	0.00	0.00	0.00	0.00	8896.61	12.61				
Hydrogen Sulphide	34.082	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
Temperature	°C	41.1		40.0		230.0		103.8					
Pressure	bara	30.0		111.0		28.7		Ambient					
Total Dry Molar Flow	(kmol/h)	18525.09	100.00	3468.69	100.00	18525.08	100.00	70556.80	100.00				
Water	(kmol/h)	18.015	39.86	0.00		2399.97		12276.32					
TOTAL WET	(kmol/h)	18564.96		3468.69		20925.05		82833.12					
Total Mass Flow (kg/h)		281000		149000		323000		2251000					
Molecular Weight		15.11		42.88		15.44		27.17					
Notes : All flows are for a single stream		Issue:	0	Date	1	Date		Date		Date		Date	
		Description:	For Final Report		Temp & Press Added								
		Made By:	THLW	05-apr-04	NJE	16-jul-04							
		Checked:	SBJS	06-apr-04	SBJS	26-jul-04							
		Approved:	SBJS	06-apr-04	SBJS	26-jul-04							

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

STREAM NUMBER		1		2		3		4		5		6	
STREAM NAME		Feed Gas		Air		Desulphurised Feed Gas		Reformed Gas		Shifted Gas		Dry Shifted Gas	
COMPONENT	MW	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)
Hydrogen	2.016	0.00	0.00	0.00	0.00	65.99	1.92	6985.31	35.32	9389.36	42.34	9389.35	42.34
Nitrogen	28.013	13.23	0.40	8646.79	78.09	74.64	2.17	8721.44	44.10	8721.44	39.32	8721.43	39.32
Carbon Monoxide	28.010	0.00	0.00	0.00	0.00	2.72	0.08	2796.01	14.14	391.96	1.77	391.96	1.77
Carbon Dioxide	44.010	59.55	1.80	3.37	0.03	60.28	1.75	1023.57	5.18	3427.63	15.45	3427.50	15.45
Methane	16.042	2775.71	83.90	0.00	0.00	2776.34	80.70	144.66	0.73	144.66	0.65	144.66	0.65
Ethane	30.069	304.37	9.20	0.00	0.00	304.37	8.85	0.00	0.00	0.00	0.00	0.00	0.00
Propane	44.096	109.18	3.30	0.00	0.00	109.18	3.17	0.00	0.00	0.00	0.00	0.00	0.00
Butane	58.122	46.32	1.40	0.00	0.00	46.32	1.35	0.00	0.00	0.00	0.00	0.00	0.00
Argon	39.948	0.00	0.00	102.95	0.93	0.56	0.02	103.52	0.52	103.52	0.47	103.52	0.47
Oxygen	31.999	0.00	0.00	2319.28	20.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen Sulphide	34.082	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Temperature	°C	10.0		9.0		379.9		950.0		263.3		50.0	
Pressure	bar(a)	41.0		Ambient		37.5		34.4		32.3		31.3	
Total Dry Molar Flow	(kmol/h)	3308.36	100.00	11072.39	100.00	3440.40	100.00	19774.50	100.00	22178.56	100.00	22178.41	100.00
Water	(kmol/h)	18.015	0.00	77.98		0.28		3901.28		1497.22		89.33	
TOTAL WET	(kmol/h)	3308.36		11150.37		3440.68		23675.77		23675.79		22267.74	
Total Mass Flow (kg/h)		64200		322000		66200		458000		459000		433000	
Molecular Weight		19.40		28.89		19.23		19.37		19.37		19.45	
Notes : All flows are for a single stream		Issue:	0	Date	1	Date		Date		Date		Date	
		Description:	For Final Report		Revised T & P								
		Made By:	THLW	05-apr-04	NJE	23-jul-04							
		Checked:	SBJS	28-apr-04	SBJS	26-jul-04							
		Approved:	SBJS	28-apr-04	SBJS	26-jul-04							



JACOBS CONSULTANCY UK LTD
MATERIAL BALANCE

Document No.: **60-8389-00/P.03/3201/A4**
 Project No.: 60-8389-00 Plant: Capture Plant
 Client: IEA GHG Location: NE Netherlands
 Case: 3-2 Coal fed GEM remote from CAPP

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

STREAM NUMBER		1		2		3		4		5		6	
STREAM NAME		Coal Feed		ASU Air Intake		Oxygen for Gasifier		Raw Syngas		Shifted Syngas		Cold Syngas	
COMPONENT	M/W	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)
Hydrogen	2.016	0.00	0.00	0.00	0.00	0.00	0.00	Confidential	11194.96	55.26	11186.68	55.41	
Nitrogen	28.013	0.00	0.00	15147.19	78.10	83.86	2.00		159.49	0.79	159.36	0.79	
Carbon Monoxide	28.010	0.00	0.00	0.00	0.00	0.00	0.00		917.18	4.53	916.54	4.54	
Carbon Dioxide	44.010	0.00	0.00	3.72	0.02	0.00	0.00		7800.36	38.50	7741.49	38.34	
Methane	16.042	0.00	0.00	0.00	0.00	0.00	0.00		15.49	0.08	15.45	0.08	
Argon	39.948	0.00	0.00	180.35	0.93	125.79	3.00		126.13	0.62	125.75	0.62	
Hydrogen Sulphide	34.082	0.00	0.00	0.00	0.00	0.00	0.00		45.84	0.23	43.88	0.22	
Carbonyl Sulphide	60.076	0.00	0.00	0.00	0.00	0.00	0.00		0.15	0.00	0.15	0.00	
Ammonia	17.031	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	
Oxygen	31.999	0.00	0.00	4064.59	20.96	3983.30	95.00		0.00	0.00	0.00	0.00	
Sulphur Dioxide	64.065	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	
Coal	(kg/hr)	148976.60											
Temperature	°C	ambient		ambient		149.0					440.0		27.1
Pressure	bara	ambient		ambient		79.9					60.7		59.2
Total Dry Molar Flow	(kmol/h)	0.00	0.00	19395.86	100.00	4192.95	100.00	0.00	0.00	20259.60	100.00	20189.30	100.00
Water	(kmol/h)	18.015	868.08	135.58		0.00		28128.08		22.38		0.00	
TOTAL WET	(kmol/h)	868.08		19531.43		4192.95		28128.08		20281.98		20189.30	
Total Mass Flow (kg/h)		165000		564000		135000		507000		403000		400000	
Molecular Weight		N/A		28.89		32.16		18.02		19.88		19.82	
Notes : All flows are for a single stream		Issue:	0	Date	1	Date	2	Date		Date		Date	
		Description:	For Final Report		CO2 stream added		Revised						
		Made By:	THLW	05-apr-04	THLW	05-mei-04	NJE	16-jul-04					
		Checked:	SBJS	28-apr-04	SBJS	05-mei-04	SBJS	22-jul-04					
		Approved:	SBJS	28-apr-04	SBJS	05-mei-04	SBJS	22-jul-04					



JACOBS CONSULTANCY UK LTD
MATERIAL BALANCE


Document No.: **60-8389-00/P.03/3201/A4**
 Project No.: 60-8389-00 Plant: Capture Plant
 Client: IEA GHG Location: NE Netherlands
 Case: 3-2 Coal fed GEM remote from CCPP

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

STREAM NUMBER		7		8		9		10		11		12	
STREAM NAME		CO2 for export		Sweet Syngas		H2S Rich Gas to Claus Unit		Dilution Nitrogen		Fuel Gas		Flue Gas	
COMPONENT	MW	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)	kmol/h	mol% (dry)
Hydrogen	2.016	150.46	1.98	11048.48	74.62	0.00	0.00	0.00	0.00	9095.22	46.01	0.00	0.00
Nitrogen	28.013	18.55	0.24	2396.69	16.19	64.00	35.36	9210.14	100.00	9554.86	48.33	60961.72	85.17
Carbon Monoxide	28.010	31.69	0.42	885.26	5.98	0.00	0.00	0.00	0.00	728.75	3.69	0.00	0.00
Carbon Dioxide	44.010	7402.87	97.30	338.23	2.28	71.12	39.29	0.00	0.00	278.44	1.41	1037.30	1.45
Methane	16.042	1.10	0.01	14.35	0.10	0.00	0.00	0.00	0.00	11.81	0.06	0.00	0.00
Argon	39.948	3.89	0.05	122.35	0.83	0.00	0.00	0.00	0.00	100.72	0.51	716.23	1.00
Hydrogen Sulphide	34.082	0.00	0.00	0.05	0.00	45.79	25.30	0.00	0.00	0.04	0.00	0.00	0.00
Carbonyl Sulphide	60.076	0.00	0.00	0.06	0.00	0.10	0.06	0.00	0.00	0.05	0.00	0.00	0.00
Ammonia	17.031	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Oxygen	31.999	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8858.18	12.38
Sulphur Dioxide	64.065	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00
Temperature	°C	40.0		33.2		70.0		22.0		27.0		103.0	
Pressure	bara	111.0		59.2		1.7		61.0		59.2		ambient	
Total Dry Molar Flow	(kmol/h)	7608.56	100.00	14805.47	100.00	181.01	100.00	9210.14	100.00	19769.89	100.00	71573.51	100.00
Water	(kmol/h)	18.015	0.00	17.84		19.14		0.00		0.00		10751.65	
TOTAL WET	(kmol/h)	7608.56		14823.31		200.15		9210.14		19769.89		82325.16	
Total Mass Flow (kg/h)		328000		135000		6830		258000		323000		2259000	
Molecular Weight		43.07		9.08		34.15		28.01		16.33		27.44	
Notes : All flows are for a single stream		Issue:	0	Date	1	Date	2	Date		Date		Date	
		Description:	For Final Report		CO2 stream added		Revised						
		Made By:	THLW	05-apr-04	THLW	05-mei-04	NJE	16-jul-04					
		Checked:	SBJS	28-apr-04	SBJS	05-mei-04	SBJS	22-jul-04					
		Approved:	SBJS	28-apr-04	SBJS	05-mei-04	SBJS	22-jul-04					

Appendix 3

Plot Lay-outs



GENERAL NOTES

REFERENCE DRAWINGS

EQUIPMENT LISTING

LEGEND

- HRSG - HEAT RECOVERY STEAM GENERATOR
- CCR - CENTRAL CONTROL ROOM
- DEMIN - DEMINERALIZED WATER TREATMENT PLANT
- B/HOUSE - BOILER HOUSE
- FW - FIREWATER STORAGE
- CWS - COOLING WATER SUPPLY
- CWR - COOLING WATER RETURN
- GRS - GAS RECEIVING STATION



--	--	--	--	--	--	--	--	--	--

A	05-05-2004	ORIGINAL ISSUE FOR STUDY	WEA	MR	KOM				
File	Date	Description	Made by	Checked by	Disc. by	Proj. Lead	Client		

This drawing is the property of Jacobs and/or Client and it is loaned with the restriction that the borrower undertakes that it shall not be reproduced, copied, loaned or otherwise disposed of (directly or indirectly) nor used for any purpose other than for which it is specifically provided.


Client/Project Name: **IEA GHG RETROFIT OF CO2 CAPTURE TO NATURAL GAS CCPP**

Title: **PRELIMINARY OVERALL PLANT LAY-OUT STANDARD COMBINED CYCLE POWER PLANT**

JE JACOBS Drawing Number: **64114-00-L-01-0001**

Drawn by	Date	Drawing Scale	Drawing Size	Sheet	of	Issues
WEA	05-2004	1:50	A1	1	1	A

Last saved as : P:\64114\WORK_FILES\CAD33_ZR1\Reports\Appendix\Appendix3\64114-00-L-01-0001 rev A.kcm1.dwg Date: 2004-05-10



GENERAL NOTES

REFERENCE DRAWINGS

EQUIPMENT LISTING

LEGEND

- HRSG -HEAT RECOVERY STEAM GENERATOR
- CCR -CENTRAL CONTROL ROOM
- DEMIN -DEMINEALIZED WATER TREATMENT PLANT
- B/HOUSE -BOILER HOUSE
- FW -FIREWATER STORAGE
- CWS -COOLING WATER SUPPLY
- CWR -COOLING WATER RETURN
- GRS -GAS RECEIVING STATION



No.	Date	Description	Drawn By	Checked By	Scale	Proj.	Client
A	05-05-2004	ORIGINAL ISSUE FOR STUDY	NEA	VR	KOMI		

This drawing is the property of Jacobs and/or Client and it is loaned with the restriction that the borrower undertakes that it shall not be reproduced, copied, issued or otherwise disposed of (directly or indirectly) nor used for any purpose other than for which it is specifically provided.


Client/Project Name: **IEA GHG RETROFIT OF CO2 CAPTURE TO NATURAL GAS CCPP**

Title: **PRELIMINARY OVERALL PLANT LAY-OUT CASE1 POST COMBUSTION CO2 CAPTURE**


JE JACOBS Drawing Number: **64114-00-L-01-0002**

Drawn by: NEA Date: 05-2004 Scale: 1:100 Sheet: 1 of 1 Issue: A


Last saved on: P:\P64114\COMMON_FILES\64114-00-L-01-0002 rev A.NOM.dwg Date: 2004-05-05 14:40 Version: AutoCAD 15.08



NOTES



A		B		C		D		E		F		G		H	
REV. NO.	DESCRIPTION	ISSUE	DATE	BY	CHK	DATE									
CLIENT DRAWING NO.		CLIENT APP.		DATE											
<p>THIS DRAWING AND ALL INFORMATION CONTAINED HEREIN ARE THE EXCLUSIVE PROPERTY OF JACOBS ENGINEERING AND ARE LOANED TO YOU BY THE COMPANY. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF JACOBS ENGINEERING. ACCEPTANCE OF THIS DRAWING SHALL BE CONSIDERED AS AN AGREEMENT TO THIS STATEMENT.</p>															
		<p>JACOBS ENGINEERING UK LTD PROJECT OFFICE- JACOBS HOUSE 427 LONDON ROAD READING BERKSHIRE RG4 9LJ</p>													
<p>A MEMBER OF THE JACOBS ENGINEERING GROUP, INC.</p>															
PLANT		CO2 CAPTURE PLANT													
CLIENT		EA GHG													
LOCATION		N.E. NETHERLANDS													
<p>PRELIMINARY PLANT LAYOUT CASE 2-1</p>															
DRAWING SCALE		ORIGINAL SHEET SIZE A1 - FRAME SIZE 840 x 594													
PROJECT NO.		60-8389.00		DRAWING NO.		0003		REV.		A					



NOTES

10m

NO.	REVISION	DATE	BY	CHKD.	APP.	SCALE

DATE: 08/09/09

SCALE: 1:1000

THIS DRAWING AND ALL ITS CONTENTS, INFORMATION, AND FINANCIAL DATA ARE THE PROPERTY OF JACOBS ENGINEERING AND IS HEREBY TO BE KEPT IN CONFIDENCE. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT FOR ANY OTHER PURPOSE. THE USER SHALL BE RESPONSIBLE FOR THE PROTECTION OF THIS INFORMATION. ANY UNAUTHORIZED DISCLOSURE OR REPRODUCTION OF THIS DRAWING WILL BE CONSIDERED AS AN INFRINGEMENT OF THE PATENT RIGHTS OF JACOBS ENGINEERING.

JE JACOBS ENGINEERING UK LTD
 PROJECT OFFICE:
 JACOBS HOUSE
 427 LONDON ROAD
 LEAMINGTON SPA CV34 6EL


A MEMBER OF THE JACOBS ENGINEERING GROUP, INC.

PLANT: CO2 CAPTURE PLANT
 CLIENT: IEA GHG
 LOCATION: N.E. NETHERLANDS

PRELIMINARY PLANT LAYOUT CASE 2-2

PLANNING SCALE: 1:1000 ORIGINAL SHEET SIZE A1 - FRAME SIZE 411 x 554

DATE: 08-03-09 0004



NOTES

NO.	REVISION	DATE	BY	CHKD	APP'D

CLIENT: [] PROJECT NO.: [] DATE: []

THIS DRAWING IS THE PROPERTY OF JACOBS ENGINEERING UK LTD AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF JACOBS ENGINEERING UK LTD. ANY UNAUTHORIZED USE OF THIS DRAWING WILL BE CONSIDERED AS AN INFRINGEMENT OF THE PATENT RIGHTS OF JACOBS ENGINEERING UK LTD.


JE JACOBS ENGINEERING UK LTD
 PROJECT OFFICE:
 JACOBS HOUSE
 457 LONDON ROAD
 READING
 RG4 9LJ

A MEMBER OF THE JACOBS ENGINEERING GROUP, INC.

PLANT: **CO2 CAPTURE PLANT**
 CLIENT: **SEA OIL**
 LOCATION: **NL, NETHERLANDS**

PRELIMINARY PLANT LAYOUT
CASE 3-1

SCALE: **1/50** ORIGINAL SHEET SIZE: A1 - FRAME SIZE: 841 x 594
 NO: **66-0309.00** REV: **0005** OF: **0**




NOTES

Blank area for project notes.

REV. NO.	REVISION DESCRIPTION	ISSUE DATE	BY	CHK	APP	DATE
A	FOR FINAL REPORT	15.03.14				

CLIENT NAME: []	CLIENT APP: []	DATE: []
------------------	-----------------	-----------

THIS DRAWING AND ALL CONTENTS, REPRESENTATIONS, AND INFORMATION ARE THE PROPERTY OF JACOBS ENGINEERING UK LTD. AND SHALL REMAIN THE PROPERTY OF JACOBS ENGINEERING UK LTD. IN ALL CIRCUMSTANCES. NO PART OF THIS DRAWING OR ANY INFORMATION CONTAINED HEREIN IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF JACOBS ENGINEERING UK LTD.



A MEMBER OF THE JACOBS ENGINEERING GROUP, INC.

PLANT: CO2 CAPTURE PLANT
 CLIENT: IEA GHG
 LOCATION: N.E. NETHERLANDS

PRELIMINARY PLANT LAYOUT
 CASE 3-2

SCALE: 1:1	ORIGINAL SHEET SIZE A1 - FRAME SIZE 800 x 554
PROJECT NO: 60-8389.00	DRAWING NO: 0006
	REV: A

Appendix 4

Fuel/CO₂ Capture Plants Equipment Lists

PLANT: CO2 Capture Study Case 2-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 100	
				Air Compression	
	21-K-201	4		Air Compressor	
				UNIT 200	
				Reformer	
	21-E-201	2		Make Gas Boiler	
	21-E-202	2		HP Steam Superheater	
	21-E-203	2		Turbine Steam Reheater	
	21-E-204	2		ATR Feed Heater	
	21-E-205	2		Hot Make Gas Boiler	
	21-K-101	2		Hydrogen Recycle Compressor	
	21-R-201	2		Auto-Thermal Reactor	
	21-R-101	4		Desulphuriser	
	21-V-201	2		Make Gas Boiler Steam Drum	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10/3/04	SBJS	6/4/04	SBJS	6/4/04	For Final Report

PLANT: CO2 Capture Study Case 2-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		Wking	St'by		
				UNIT 300 Shift Unit	
	21-E-301	2		Desulphuriser Feed Heater	
	21-E-302	2		BFW Heater	
	21-E-303	2		DMW Heater	
	21-E-304	2		Absorber Feed Cooler	
	21-E-305	2		Saturator Pre-heater	
	21-E-306	2		Fuel Gas Heater	
	21-E-307	2		Saturator Water Heater	
	21-P-301	2	2	Process Condensate Pump	
	21-R-301	2		HT Shift Reactor	
	21-R-302	2		LT Shift Reactor	
	21-T-301	2		Saturator	
	21-V-301	2		Process Condensate Drum 1	
	21-V-302	2		Process Condensate Drum 2	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10/3/04	SBJS	6/4/04	SBJS	6/4/04	For Final Report

PLANT: CO2 Capture Study Case 2-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		Wking	St'by		
				UNIT 400 Acid Gas removal	
	21-E-401	2		Stripper Reboiler	
	21-E-402	2		Lean / Semi-Lean Mdea	
	21-E-403	2		Lean Mdea Cooler	
	21-E-405	2		LP Flash Overhead	
	21-E-406	2		LP Flash Overhead Vent Cooler	
	21-P-401	2	2	Lean Mdea Pump	
	21-P-402	2	2	Lp Flash Reflux Pump	
	21-P-403	2	2	Semi-Lean Mdea Pump	
	21-P-404	2	2	Stripper Feed Pump	
	21-PT-401	2		Lean Mdea Pump Turbine	
	21-T-401	2		CO2 Absorber	
	21-T-402	2		CO2 Stripper	
	21-T-403	2		HP Flash Column	
	21-T-404	2		LP Flash Column	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10/3/04	SBJS	6/4/04	SBJS	6/4/04	For Final Report

PLANT: CO2 Capture Study Case 2-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 700 Power Block	
	21-E-701	2		Alternator Turbine Condenser	
	21-E-702	2		Condensate Stripper Feed / Product Exchanger	
	21-P-701	2	2	BFW Pump	
	21-P-702	2	2	Turbine Condensate Pump	
	21-Q-701	2		Alternator	
	21-QT-701	2		Alternator Turbine	
	21-T-701	1		De-Aerator Column	
	21-T-702	2		Process Condensate Stripper	
	21-V-701	1		De-Aerator Vessel	
	21-V-702	2		Turbine Condensate Vessel	
	21-Z-701	2		Turbine Ejector Unit	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10/3/04	SBJS	6/4/04	SBJS	6/4/04	For Final Report

PLANT: CO2 Captute Study Case 2-2

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 700 Power Block	
	22-E-701	2		Alternator Turbine Condenser	
	22-E-702	2		Condensate Stripper Feed / Product Exchanger	
	22-P-701	2	2	BFW Pump	
	22-P-702	2	2	Turbine Condensate Pump	
	22-Q-701	2		Alternator	
	22-QT-701	2		Alternator Turbine	
	22-T-701	1		De-Aerator Column	
	22-T-702	2		Process Condensate Stripper	
	22-V-701	1		De-Aerator Vessel	
	22-V-702	2		Turbine Condensate Vessel	
	22-Z-701	1		Turbine Ejector Unit	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	7/4/04	SBJS	7/4/04	For Final Report

EQUIPMENT LIST

60-8389-00/P.03/1400/A4

PLANT: CO2 Capture Study Case 3-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 300 Gasification Unit	Part of W-301
	31-E-301	4	1	LP Flash Condenser	Part of W-301
	31-E-302	4	1	BFW Heater 1	Part of W-301
	31-E-303	4	1	BFW Heater 2	Part of W-301
	31-E-304	4	1	Oxygen Heater	
	31-P-301	4	6	Black Water Pump	Part of W-301
	31-P-302	4	6	BFW Pump	Part of W-301
	31-P-303	4	6	Grey Water Pump	Part of W-301
	31-R-301	4	1	Gasifier	Part of W-301
	31-T-301	4	1	Scrubber	Part of W-301

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	23/3/04	SBJS	23/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 400	
				Gas Treatment	
	31-E-401	2		Shift Interchanger	
	31-E-402	2		High Pressure Boiler	
	31-E-403	2		High Pressure BFW Heater	
	31-E-404	2		High Pressure Water Heater 3	
	31-E-405	2		High Pressure Water Heater 2	
	31-E-406	2		High Pressure Water Heater 1	
	31-E-407	2		LP Boiler	
	31-E-408	2		Low Pressure BFW Heater	
	31-E-409	2		Expander Preheater	
	31-E-410	2		Fuel Gas Heater	
	31-E-412	2		N2 Heater	
	31-K-401	2		Fuel Gas Expander	
	31-K-402	2		Recycle Compressor	
	31-K-403	2		Selexol N2 Compressor	
	31-K-404	2		N2 Compressor	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	23/3/04	SBJS	23/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 500 Acid Gas removal	
	31-E-501	2		Stripper Reboiler	
	31-E-502	2		Stripped Gas Condenser	
	31-E-503	2		Lean/Rich Exchanger	
	31-E-504	2		Lean Solvent Cooler	
	31-E-505	2		Semi-Lean Cooler	
	31-E-506	2		Loaded Solvent Cooler	
	31-E-507	2		Compressed Gas Cooler	
	31-E-508	2		Flash Gas Cooler	
	31-TK-501	1		Selexol Storage Tank	
	31-TK-502	2		Sump	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	23/3/04	SBJS	23/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		Wking	St'by		
				UNIT 500	
				Acid Gas removal	
	31-P-501	2	2	Lean Solution Pump	
	31-P-502	2	2	Rich Solution Pump	
	31-P-503	10	2	Semi-lean Pump	
	31-P-504	2	2	Stripper Reflux Pump	
	31-P-505	2	2	Loaded Solvent Pump	
	31-PT-506	10		Rich solvent expander	
	31-T-501	2	2	H2S Absorber	
	31-T-502	2	2	H2S Concentrator	
	31-T-503	2	2	CO2 Absorber	
	31-T-504	2	2	Lean Solution Stripper	
	31-V-501	2	2	HP Flash Drum	
	31-V-502	2	2	MP Flash Drum	
	31-V-503	2	2	LP Flash Drum	
	31-V-504	2	2	Flash Gas KO Drum	
	31-V-505	2	2	Rich Flash	
	31-V-506	2	2	Stripper Overhead Drum	
	31-W-501	2	2	Claus unit	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	23/3/04	SBJS	23/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-1

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		Wking	St'by		
				UNIT 700 Power Block	
	31-E-705	1		Low Pressure Superheater	Part of W-701
	31-E-710	1		High Pressure Superheater	Part of W-701
	31-E-715	1		Steam Turbine Condenser	Part of W-701
	31-E-715	1		Steam Dump Condenser	
	31-K-701	1		Gas Turbine	Part of W-701
	31-K-702	1		Steam Turbine	Part of W-701
	31-P-704	2	1	Condensate Pump	Part of W-701
	31-V-701	1		De-areator	Part of W-701
	31-W-701	1		Combined Cycle Unit	Part of W-701

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	23/3/04	SBJS	23/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-2

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		Wking	St'by		
				UNIT 400	
				Gas Treatment	
	32-E-401	2		Shift Interchanger	
	32-E-402	2		High Pressure Boiler	
	32-E-403	2		High Pressure BFW Heater	
	32-E-404	2		High Pressure Water Heater 3	
	32-E-405	2		High Pressure Water Heater 2	
	32-E-406	2		High Pressure Water Heater 1	
	32-E-407	2		LP Boiler	
	32-E-408	2		Low Pressure BFW Heater	
	31-E-409	2		Expander Preheater	
	31-E-410	2		Fuel Gas Heater	
	32-K-401	2		Fuel Gas expander	
	32-K-402	2		Recycle Compressor	
	32-K-403	2		Selexol N2 Compressor	
	32-K-404	2		Nitrogen Compressor	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	24-Mar-04	SBJS	24/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-2

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 400	
				Gas Treatment	
	32-K-405	2		Main N2 Compressor	
	32-K-406	2		Tail Gas Compressor	
	32-P-401	2	2	Desaturator Circulation Pump	
	32-P-402	2	2	Low Pressure BFW Pump	
	32-P-403	2	2	Intermediate Pressure BFW Pump	
	32-P-404	2	2	BFW Circulating Pump	
	32-P-405	2	2	High Pressure BFW Pump	
	32-P-409	2	2	Process Water Make-up Pump	
	32-R-401	2		Shift Reactor	
	32-T-401	2		Desaturator	
	32-V-401	2		HP Steam Drum	
	32-V-402	2		LP Steam Drum	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	24-Mar-04	SBJS	24/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-2

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 500	
				Acid Gas removal	
	32-P-501	2	2	Lean Solution Pump	
	32-P-502	2	2	Rich Solution Pump	
	32-P-503	12	2	Semi-lean Pump	
	32-P-504	2	2	Stripper Recycle Pump	
	32-P-505	2	2	Loaded Solvent Pump	
	32-PT-506	12		Rich solvent expander	
	32-T-501	2		H2S Absorber	
	32-T-502	2		H2S Concentrator	
	32-T-503	2		CO2 Absorber	
	32-T-504	2		Lean Solution Stripper	
	32-V-501	2		HP Flash Drum	
	32-V-502	2		MP Flash Drum	
	32-V-503	2		LP Flash Drum	
	32-V-504	2		Flash Gas KO Drum	
	32-V-505	2		Rich Flash	
	32-V-506	2		Stripper Overhead Drum	
	32-W-501	2		Claus unit	

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	24-Mar-04	SBJS	24/3/04	For Final Report

PLANT: CO2 Capture Study Case 3-2

JOB NO.: 608389

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	Item Number	No. Installed		Description	Remarks
		W'king	St'by		
				UNIT 700	
				Power Block	
	32-K-701	2		Gas Turbine	Part of W-701
	32-K-702	1		Steam Turbine	Part of W-701
	32-P-703	4	2	HP BFW Pump	Part of W-701
	32-P-704	4	2	Condensate Pump	Part of W-701
	32-V-701	2		De-areator	Part of condenser
	32-V-702	2		HRSB HP Steam Drum	Part of W-701
	32-V-703	2		HRSB IP Steam Drum	Part of W-701
	32-V-704	2		HRSB LP Steam Drum	Part of W-701
	32-W-701	2		Combined Cycle Unit	Part of W-701

NOTES:

Rev	Made by	Date	Checked by	Date	Approved by	Date	Description
A	THLW	10-Mar-04	SBJS	24-Mar-04	SBJS	24/3/04	For Final Report

Appendix 5

Fuel/CO₂ Capture Plants Power Consumption/Production and Utility Usage

PLANT: CO2 Captute Study Case 2-2

LOCATION: NE Netherlands

CLIENT: IEA

PROJECT: 608389

Revised this issue ↓

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation

	Item no.	Item Name	no. operating	Power (kW) Each	Total	
1						
2						
3						
4						
5	22-K-101	Air Compressor	2	49,209	49,209	
6						
7						
8	22-K-201	Hydrogen Recycle Compressor	1	33	33	
9						
10						
11	22-P-301	Process Condensate	1	79		
12	22-K-301	Fuel Gas Compressor	1	4,767	4,845	
13						
14						
15	22-P-401	Lean Amine Pump	1	1,823		
16	22-P-402	Lp Flash Reflux Pump	1	3		
17	22-P-403	Semi-Lean Amine Pump	1	8,542		
18	22-P-404	Stripper Feed Pump	1	304		
19	22-PT-401	Rich Amine Pump Turbine	1	-3,109	7,563	
20						
21						
22	22-K-601	CO2 Compressor	1	15,937		
23	22-P-601	CO2 Compressor KO Drum Pump	1	8	15,945	
24						
25						
26	22-P-701	BFW Pump	1	1,019		
27	22-P-702	Turbine Condensate	1	4		
28	22-QT-701	Alternator Turbine	1	-35,530	-34,506	
29						
30						
31	22-P-901	Cooling Water Pump	2	2,359		
32		Misc		3,000	5,359	
33						
34						
35						
36						
37						
38						
39						
40						
41						
42						
43						
44						
45						
46						
47						
48						
49						
50						
51		Total Power output (MW)			48.4	
52		NOTE: All data is for 1 train				

Issue	A	Date		Date		Date		Date		
Description	For Report									
Made by / Revised by	THLW	10-mr-04								
Checked by										
Approved by										

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation

	Item no.	Item Name	no. operating	Power (kW) Each	Total
1					
2					
3					
4					
5	100	31-W-101 Air Separation Unit	1	44,309	
6					44,309
7	200	31-P-201 Coal Slurry Feed Pump	1	466	
8		31-W-201 Coal preparation	1	1,096	
9					1,562
10	300	31-P-301 Black Water Pump	1	6	
11		31-P-302 BFW Pump	1	21	
12		31-P-303 Grey Water Pump	1	28	
13		31-W-301 Gasification Package	1	259	
14					315
15	400	31-K-401 Fuel Gas Expander	1	-7,149	
16		31-K-402 Recycle Compressor	1	0	
17		31-K-403 Selexol N2 Compressor	1	3,672	
18		31-K-404 N2 Compressor	1	1,886	
19		31-K-405 Main N2 Compressor	1	27,101	
20		31-P-401 Desaturator Circulation Pump	1	825	
21		31-P-402 Low Pressure BFW Pump	1	86	
22		31-P-403 Intermediate Pressure BFW Pump	1	652	
23		31-P-404 BFW Circulating Pump	1	85	
24		31-P-405 High Pressure BFW Pump	1	352	
25		31-P-409 Process Water Make-up Pump	1	319	
26					27,828
27	500	31-P-501 Lean Solution Pump	1	2,003	
28		31-P-502 Rich Solution Pump	1	269	
29		31-P-503 Semi-lean Pump	5	9,521	
30		31-P-504 Stripper Reflux Pump	1	13	
31		31-P-505 Loaded Solvent Pump	1	144	
32		31-PT-506 Rich solvent expander	5	-2,787	
33					9,162
34	600	31-K-601 CO2 Compressor	1	25,617	
35		31-P-601 CO2 Compressor KO Drum Pump	1	2	
36					25,618
37	700	31-K-701 Gas Turbine	1	-22,000	
38		31-K-702 Steam Turbine	1	-65,916	
39		Losses GT & ST		1,072	
40					
41					
42		31-P-704 Condensate Pump	1	49	
43					86,796
44	900	31-P-901 Cooling Water Pump	2	3,392	
45		31-P-902 Back-up fuel pumps	2	0	
46		Misc		2,000	
47					5,392
48					
49					
50					
51		Total Power output (MW)			27.4
52		NOTE: All data is for 1 train			

Issue	A	Date	Date	Date	Date	Date	Date	
Description	For Report							Sht.
Made by / Revised by	THLW	10-mrt-04						16
Checked by	SBJS	23-mrt-04						of
Approved by	SBJS							20

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation

	Item no.	Item Name	no. operating	Power (kW) Each	Total	
1						
2						
3						
4						
5	100	32-W-101 Air Separation Unit	1		48,179	
6						48,179
7	200	32-P-201 Coal Slurry Feed Pump	1	487		
8		32-W-201 Coal preparation			1,223	
9						1,710
10	300	32-P-301 Black Water Pump	1	7		
11		32-P-302 BFW Pump	1	23		
12		32-P-303 Grey Water Pump	1	31		
13		32-W-301 Gasification Package	1		289	
14						351
15	400	32-K-401 Fuel Gas expander	1	-1,211		
16		32-K-402 Recycle Compressor	1	752		
17		32-K-403 Selexol N2 Compressor	1	3,992		
18		32-K-404 Nitrogen Compressor	1	319		
19		32-K-405 Main N2 Compressor	1	30,662		
20		32-K-406 Tail Gas Compressor	1	964		
21		32-P-401 Desaturator Circulation Pump	1	982		
22		32-P-402 Low Pressure BFW Pump	1	96		
23		32-P-403 Intermediate Pressure BFW Pump	1	599		
24		32-P-404 BFW Circulating Pump	1	61		
25		32-P-405 High Pressure BFW Pump	1	329		
26		32-P-409 Process Water Make-up Pump	1	356		
27						37,901
28						
29	500	32-P-501 Lean Solution Pump	1	2,234		
30		32-P-502 Rich Solution Pump	1	262		
31		32-P-503 Semi-lean Pump	6	10,619		
32		32-P-504 Stripper Recycle Pump	1	1		
33		32-P-505 Loaded Solvent Pump	1	132		
34		32-PT-506 Rich solvent expander	6	-3,658		
35						9,590
36	600	32-K-601 CO2 Compressor	1	27,854		
37		32-P-601 CO2 Compressor KO Drum Pump	1	2		
38						27,856
39	700	32-K-701 Gas Turbine	1	-44,000		
40		32-K-702 Steam Turbine	1	-89,451		
41		Losses GT & ST			1,622	
42						
43						
44		32-P-704 Condensate Pump	2	130		
45						-131,699
46	900	32-P-901 Cooling Water Pump	2	3,902		
47			0	0	0	
48		Misc			2,000	
49						5,902
50						
51		Total Power output (MW)			-0.2	
52		NOTE: All data is for 1 train				

Issue	A	Date		Date		Date		Date		Date
Description	For Report									
Made by / Revised by	THLV	10-mrt-04								
Checked by	SBJS	20-mrt-04								
Approved by	SBJS	0-jun-00								



JACOBS CONSULTANCY UK LTD
Utility Schedule Case 1

DOCUMENT No:
60-8389-00/P03/1700/A4

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: CO2 Capture Study
CLIENT: IEA

PROJECT: 60.8389.00
LOCATION: NE Netherlands

Rev.	PLANT SECTION	No. Op	Type of Utility											Remarks
						LP Steam	Condensate	Sea CW	Fresh CW	DMW	BFW	Elec Power		
						t/h	t/h	m ³ /hr	m ³ /hr	m ³ /hr	m ³ /hr	MW		
100														
200														
300														
400	Acid Gas Removal					619.2	-720.8	29430.5	960.0	17.2	101.6	11.2		NEGATIVE VALUE IMPLIES UTILITY GENERATION
500														
600	Product Gas Exports							14526.8	800.0			21.7		NEGATIVE VALUE IMPLIES UTILITY GENERATION
700														
800														
900	Offsites & Utilities							1840.0	-1760.0			5.6		NEGATIVE VALUE IMPLIES UTILITY GENERATION
Total						619.2	-720.8	45797.2	0.0	17.2	101.6	38.5		NEGATIVE VALUE IMPLIES UTILITY GENERATION

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	Sheet
	0	THLW	18/3/04	SBJS	22/3/04	SBJS	25/3/04	For Final Report	1
	1	THLW	30/4/04	SBJS	30/4/04	SBJS	30/4/04	Including case 1	of
	2	THLW	4/5/04	SBJS	4/5/04	SBJS	4/5/04	revised	5

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: CO2 Capture Study PROJECT: 60.8389.00
CLIENT: IEA LOCATION: NE Netherlands

Rev.	PLANT SECTION	No. Op	Type of Utility													Remarks	
				HP Steam t/h	MP Steam t/h	LP Steam t/h	Condensate t/h	Sea CW m ³ /hr	Fresh CW m ³ /hr	DMW m ³ /hr	BFW m ³ /hr	Elec Power MW	Oxygen t/h	N ₂ t/h			
100	Air Compression							4076.3	400.0					99.2			NEGATIVE VALUE IMPLIES UTILITY GENERATION
200	Reformer			-291.7	140.5	-2.8	-3.1		40.0			297.6	0.1				NEGATIVE VALUE IMPLIES UTILITY GENERATION
300	Shift						-70.2		20.0			104.3	0.2				NEGATIVE VALUE IMPLIES UTILITY GENERATION
400	Acid Gas Removal						110.4	-110.4	6166.7	40.0	12.9		15.5				NEGATIVE VALUE IMPLIES UTILITY GENERATION
500																	
600	Product Gas Exports							-12.3	7173.6	200.0			31.9				NEGATIVE VALUE IMPLIES UTILITY GENERATION
700	Power Block			291.7	-140.5	-107.6	180.6	2364.4	40.0	189.7	-401.8	-41.0					NEGATIVE VALUE IMPLIES UTILITY GENERATION
800																	
900	Offsites & Utilities							15.4	770.0	-740.0	-202.6		10.1				NEGATIVE VALUE IMPLIES UTILITY GENERATION
Total				0.0	0.0	0.0	0.0	20551.0	0.0	0.0	0.0	0.0	115.9				NEGATIVE VALUE IMPLIES UTILITY GENERATION

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	Sheet of 5
	0	THLW	18/3/04	SBJS	22/3/04	SBJS	25/3/04	For Final Report	
	1	THLW	30/4/04	SBJS	30/4/04	SBJS	30/4/04	Including case 1	
	2	THLW	4/5/04	SBJS	4/5/04	SBJS	4/5/04	revised	

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: CO2 Capture Study PROJECT: 60.8389.00
CLIENT: IEA LOCATION: NE Netherlands

Rev.	PLANT SECTION	No. Op	Type of Utility													Remarks	
				HP Steam	MP Steam	LP Steam	Condensate	Sea CW	Fresh CW	DMW	BFW	Elec Power	Oxygen	N ₂			
				t/h	t/h	t/h	t/h	m ³ /hr	m ³ /hr	m ³ /hr	m ³ /hr	MW	t/h	t/h			
100	Air Compression							4072.9	400.0				98.4				NEGATIVE VALUE IMPLIES UTILITY GENERATION
200	Reformer			-316.0	140.4	-3.1	-3.4		40.0			322.3	0.1				NEGATIVE VALUE IMPLIES UTILITY GENERATION
300	Shift							-50.8		20.0			9.7				NEGATIVE VALUE IMPLIES UTILITY GENERATION
400	Acid Gas Removal					19.4	-19.4	6161.5	40.0	12.9			15.1				NEGATIVE VALUE IMPLIES UTILITY GENERATION
500																	
600	Product Gas Exports							-12.3	7167.7	200.0			31.9				NEGATIVE VALUE IMPLIES UTILITY GENERATION
700	Power Block			316.0	-140.4	-107.2	70.2	10702.7	40.0	109.7	-322.3		-69.0				NEGATIVE VALUE IMPLIES UTILITY GENERATION
800																	
900	Offsites & Utilities							15.7	770.0	-740.0	-122.6		10.7				NEGATIVE VALUE IMPLIES UTILITY GENERATION
Total				0.0	0.0	-90.9	0.0	28874.9	0.0	0.0	0.0		96.9				NEGATIVE VALUE IMPLIES UTILITY GENERATION

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	Sheet 3 of 5
	0	THLW	18/3/04	SBJS	22/3/04	SBJS	25/3/04	For Final Report	
	1	THLW	30/4/04	SBJS	30/4/04	SBJS	30/4/04	Including case 1	
	2	THLW	4/5/04	SBJS	4/5/04	SBJS	4/5/04	revised	

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: CO2 Capture Study

PROJECT: 60.8389.00

CLIENT: IEA

LOCATION: NE Netherlands

Rev.	PLANT SECTION	No. Op	Type of Utility													Remarks		
			HP Steam	MP Steam	LP Steam	Condensa te	Process Conden	Sea CW	Fresh CW	DMW	BFW	Elec Power	Oxygen	N ₂				
			t/h	t/h	t/h	t/h	t/h	m ³ /hr	m ³ /hr	m ³ /hr	m ³ /hr	MW	t/h	t/h				
100	ASU									13572					96.36	-249.4	-645.8	NEGATIVE VALUE IMPLIES UTILITY GENERATION
200	Feedstock Preparation							64.4			300.0				3.4			NEGATIVE VALUE IMPLIES UTILITY GENERATION
300	Gasification Unit							1033.9	5262	30.0	76.9	-76.9	0.7	248.4				NEGATIVE VALUE IMPLIES UTILITY GENERATION
400	Gas Treatment unit							-1098.3	8427.8	420.0	632.3	76.9	75.8			126.332		NEGATIVE VALUE IMPLIES UTILITY GENERATION
500	Acid Gas Removal									7329	140.0	13.5	19.2	1.0				
600	Product Gas Export							1.5	1906.8	200.0					55.7		519.5	NEGATIVE VALUE IMPLIES UTILITY GENERATION
700	Power Block									57486.9	240.0				-263.4			NEGATIVE VALUE IMPLIES UTILITY GENERATION
800																		
900	Utilities and Offsites							715.5		1530.0	-1330.0	-722.7	11.8					NEGATIVE VALUE IMPLIES UTILITY GENERATION
Total								0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.4	0.0	0.0	NEGATIVE VALUE IMPLIES UTILITY GENERATION

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	Sheet of 5
	0	THLW	18/3/04	SBJS	22/3/04	SBJS	25/3/04	For Final Report	
	1	THLW	30/4/04	SBJS	30/4/04	SBJS	30/4/04	Including case 1	
	2	THLW	4/5/04	SBJS	4/5/04	SBJS	4/5/04	revised	

Appendix 6

Fuel/CO₂ Capture Plants Capital Cost Estimates

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: Capture Plant Case 1

PROJECT: 60.8389.00

CLIENT: IEA GHG

LOCATION: NE Netherlands

	Direct Materials	Construction	Engineering and Construction Services	Total	
					(*1000,000)
Acid Gas Removal	201.72	37.25	26.51	265.47	US \$
CO2 Compression & drying	15.91	3.92	10.33	30.15	US \$
Offsites & Utilities	19.00	8.40	14.62	42.02	US \$
Total	235.70	49.57	51.45	337.65	US \$
Contingency				33.76	US \$
Owners costs				23.64	US \$
Total Installed costs				395.05	US \$

Original estimates are 100% in US \$

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	
	0	SBJS	19-apr-04	AH	19-apr-04	SBJS	19-apr-04	For report	1
	1	SBJS	05-mei-04	AH	05-mei-04	SBJS	05-mei-04	Inc case 1 & revised case 2	of
	2	IJJ	05-mei-04			KOMI	07-mei-04	For Final Report	5
	3	IJJ	26 July 2004			KOMI	26 July 2004	For Final Report	



JACOBS CONSULTANCY UK LTD
Capital Cost Estimate Case 2-1

DOCUMENT No:

60-8389-00/P03/1200/A4

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: Capture Plant Case 2-1

PROJECT: 60.8389.00

CLIENT: IEA GHG

LOCATION: NE Netherlands

Plant Section	Engineering and			Total			
	Direct Materials	Construction	Construction Services				
						(*1000,000)	
Air Compression	53.32	13.15	34.62	101.09	US \$		
Reforming & HT Cooling	27.89	8.04	12.82	48.75	US \$		
Shift & LT Cooling	24.73	6.65	8.96	40.34	US \$		
Acid Gas Removal	50.64	21.57	45.77	117.99	US \$		
CO2 Compression & drying	19.55	4.82	12.69	37.06	US \$		
Power Generation	40.63	3.63	17.27	61.54	US \$	(*1000,000)	
Offsites & Utilities*	43.81	15.50	20.34	79.64	US \$		
						*Offsites & Utilities include:	
						Replace GT combustion chambers	16.53
						Extension demin water plant	3.69
						Cooling water intake/outfall	0.37
Total	260.58	73.36	152.47	486.40	US \$		
Contingency				48.64	US \$		
Owners costs				34.05	US \$		
Total Installed costs				569.09	US \$		

Original estimates are 2.3% in US \$ and 97.7% in € (€/US \$ = 1.23)

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	
	0	SBJS	19-apr-04	AH	19-apr-04	SBJS	19-apr-04	For report	
1	SBJS	05-mei-04	AH	05-mei-04	SBJS	05-mei-04	Inc case 1 & revised case 2	of	
2	IJJ	07-05-04	KOMI	07-05-04	KOMI	38114	For Final Report	5	
3	IJJ	26 July 2004			KOMI	26 July 2004	For Final Report		



JACOBS CONSULTANCY UK LTD
Capital Cost Estimate Case 2-2

DOCUMENT No:

60-8389-00/P03/1200/A4

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: Capture Plant Case 2-2

PROJECT: 60.8389.00

CLIENT: IEA GHG

LOCATION: NE Netherlands

Plant Section	Engineering and			Total	
	Direct Materials	Construction	Construction Services		
					(*1000,000)
Air Compression	53.32	13.15	34.62	101.09	US \$
Reforming & HT Cooling	27.89	8.04	12.82	48.75	US \$
Shift & LT Cooling	24.73	10.22	27.02	61.97	US \$
Acid Gas Removal	50.64	21.57	45.77	117.99	US \$
CO2 Compression & drying	19.55	4.82	12.69	37.06	US \$
Power Generation	57.75	5.16	24.55	87.46	US \$
Offsites & Utilities*	97.13	47.18	42.63	186.93	US \$
					(*1000,000)
					*Offsites & Utilities include:
					Replace GT combustion chambers
					Extension demin water plant
					Cooling water intake/outfall
					Long Distance Fuel Piping
Total	331.02	110.14	200.10	641.24	US \$
Contingency				64.12	US \$
Owners costs				44.89	US \$
Total Installed costs				750.25	US \$

Original estimates are 7% in US \$ and 93% in £ (€/US \$ = 1.23)

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	
	0	SBJS	19-apr-04	AH	19-apr-04	SBJS	19-apr-04	For report	
1	SBJS	05-mei-04	AH	05-mei-04	SBJS	05-mei-04	Inc case 1 & revised case 2	of	
2	IJJ	07-05-04	KOMI	07-05-04	KOMI	07-05-04	For Final Report	5	
3	IJJ	26 July 2004			KOMI	26 July 2004	For Final Report		

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: Capture Plant Case 3-1

PROJECT: 60.8389.00

CLIENT: IEA GHG

LOCATION: NE Netherlands

Plant Section	Direct Materials	Construction	Engineering and Construction Services	Total	
					(*1000,000)
ASU	96.52	23.81	62.66	182.98	US \$
Coal Receiving, grinding and slurry prep	20.33	10.94	21.03	52.30	US \$
Gasification Unit	109.27	33.50	60.43	203.20	US \$
Gas Treatment Package	35.74	7.27	20.98	63.99	US \$
Acid Gas Removal	24.84	10.58	22.45	57.87	US \$
CO2 Compression & drying	28.83	7.11	18.71	54.65	US \$
Combined Cycle Unit	52.49	4.69	22.31	79.50	US \$
Offsites & Utilities*	62.31	26.44	39.13	127.88	US \$
					(*1000,000)
					*Offsites & Utilities include:
					Replace GT combustion chambers 16.53
					Extension demin water plant 3.69
					Cooling water intake/outfall 1.10
Total	430.33	124.33	267.71	822.38	US \$
Contingency				82.24	US \$
Owners costs				57.57	US \$
Total Installed costs				962.18	US \$

Original estimates are 51% in US \$, 4% in £ and 45% in € (€/US \$ = 1.23, £/US \$ = 1.74)

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	
	0	SBJS	19-apr-04	AH	19-apr-04	SBJS	19-apr-04	For report	4
	1	SBJS	05-mei-04	AH	05-mei-04	SBJS	05-mei-04	Inc case 1 & revised case 2	of
	2	IJJ	07-05-04	KOMI	07-05-04	KOMI	07-05-04	For final report	5
	3	IJJ	26 July 2004			KOMI	26 July 2004	For Final Report	

The information contained herein is confidential, the property of JACOBS CONSULTANCY UK LTD, and not for publication. The information is issued on the understanding that no part thereof shall be copied or communicated to a third party without authorisation in writing from JACOBS CONSULTANCY UK LTD. The data contained in this document is subject to change during the design stage of any subsequent contract.

PLANT: Capture Plant Case 3-2

PROJECT: 60.8389.00

CLIENT: IEA GHG

LOCATION: NE Netherlands

Plant Section	Direct Materials	Construction	Engineering and Construction Services	Total		
					(*1000,000)	
ASU	102.35	25.24	66.44	194.03	US \$	
Coal Receiving, grinding and slurry prep	20.16	10.84	20.86	51.86	US \$	
Gasification Unit	107.80	33.05	59.61	200.47	US \$	
Gas Treatment Package	50.46	10.26	29.62	90.34	US \$	
Acid Gas Removal	24.51	10.44	22.15	57.10	US \$	
CO2 Compression & drying	30.57	7.54	19.84	57.95	US \$	
Combined Cycle Unit	92.60	8.28	39.36	140.24	US \$	(*1000,000)
Offsites & Utilities*	111.91	55.58	61.20	228.69	US \$	
						*Offsites & Utilities include:
						Replace GT combustion chambers
						Extension demin water plant
						Cooling water intake/outfall
						Long Distance Fuel Piping
Total	540.34	161.23	319.09	1020.66	US \$	86.34
Contingency				102.07	US \$	
Owners costs				71.45	US \$	
Total Installed costs				1194.18	US \$	

Original estimates are 50% in US \$, 9% in £ and 41% in € (€/US \$ = 1.23, £/US \$ = 1.74)

Notes	Rev.	Made by	Date	Checked by	Date	Approved by	Date	Description	
	0	SBJS	19-apr-04	AH	19-apr-04	SBJS	19-apr-04	For report	5
	1	SBJS	05-mei-04	AH	05-mei-04	SBJS	05-mei-04	Inc case 1 & revised case 2	of
	2	IJJ	07-05-04	KOMI	07-05-04	KOMI	07-05-04	For Final Report	5
	3	IJJ	26 July 2004			KOMI	26 July 2004	For Final Report	

Appendix 7

Cash Flow Calculations

IEA GREENHOUSE GAS R&D PROGRAMME															Cost Evaluation - CASE 1															Version	4.5				
30 Jul 2004 11:04																														Date	July 2004				
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				RESULTS SUMMARY			
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary																			
Fuel feedrate	1404.6	1404.6	MW	Installed costs	354.7	337.7	Fuel	132.9	132.9	Discount rate	10.0	%	Emission avoidance cost	73.241	\$/t CO2																				
Net power output	784.8	625.9	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	15.4	Load factor	90.0	90.0	Load factor	90.0	%																				
CO2 output	293.0	41.9	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	2.4	Fuel price	3.00	3.00	\$/GJ	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)																					
Solid waste output	0.00	0.04	t/h	Retrofit escalation basis year	24.8	23.6	Insurance and local taxes	7.1	13.8	CO2 price	73.2	73.2	\$/t	NPV	0.00	M\$																			
CO2 emissions	373	67	g/kWh	Retrofit expenditure escalation yearly	0%	0%	Waste disposal	0.0	0.1	Waste disposal cost	0.0	307.5	\$/t	IRR	10.00%																				
Reference plant data				For calculation of cost of emission avoidance				Total capital cost				415.0	395.1	Decommissioning cost				0	0	Breakdown of c/kWh cost															
CO2 emissions	373		g/kWh	Chemicals storage	0.2	0.2	Fuel storage	0.0	0.0	Administration	56%	56%	of operators cost					Fuel	57.14%																
Electricity cost	2.997		c/kWh	Retrofit year (n)	10	-	Chemicals storage	0.2	0.2	Fuel storage	0	0	days					Capital	32.30%																
				Retrofit Expenditure year (n-2)	0%	-	Fuel storage	0.0	0.0	Start up time	3	3	months					Other costs	10.56%																
				Retrofit Expenditure year (n-1)	40%	-	Total working capital	0.2	0.2	Retrofit down time	1	1	months																						
				Retrofit Expenditure year (n)	60%	-					Load factor, remainder year 1	90	90	%																					
CASH FLOW ANALYSIS																																			
Million \$																																			
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033						
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26						
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%						
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884						
Expenditure Factor		0%	40%	60%									0%	40%	60%																				
Revenues																																			
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	110.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9						
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	83.0	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7	110.7						
Operating Costs																																			
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6						
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-10.4	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8						
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8						
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-1.6	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1						
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1						
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8						
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-158.0	-237.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Decommissioning Cost																																			
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-109.0	-192.8	76.4	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	0.4						
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-146.5	-339.3	-262.9	-155.6	-48.3	59.1	166.4	273.7	381.0	488.4	595.7	703.0	810.4	917.7	1025.0	1132.4	1239.7	1240.1						

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - CASE 2.1

30 Jul 2004 11:04

	REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT			
Production				Capital Cost	Million \$	Million \$	Operating Costs	MM \$/year	MM \$/year	Economic parameters																			
Fuel feedrate	1404.6	1672.4	MW	Installed costs	354.7	486.4	at 100% load factor			Discount rate	10.0	%																	
Net power output	784.8	693.7	MW	Contingencies	10.0%	10.0%	Fuel	132.9	158.2	Load factor	90.0	%																	
CO2 output	293.0	50.1	t/h				Maintenance	7.9	18.7	Fuel price	3.00	\$/GJ																	
Solid waste output	0.00	0.01	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	11.1	CO2 price	95.0	\$/t																	
CO2 emissions	373	72	g/kWh		24.8	34.0	Insurance and local taxes	7.1	16.8	Waste disposal cost	0.0	\$/t																	
				Retrofit escalation basis year		10	Waste disposal	0.0	0.0	Insurance and local taxes	2%	% of installed cost																	
Reference plant data	<i>For calculation of cost of emission avoidance</i>			Retrofit Expenditure escalation yearly		0%	Operating labour	1.2	2.3	Number of operators	10	20																	
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation		0.0%				Cost per operator	75.0	\$/kWh																	
Electricity cost	2.997		c/kWh	Total capital cost	415.0	569.1				Administration	56%	% of operators cost																	
				Working Capital			Decommissioning cost	0	0	Fuel storage	0	days																	
Retrofit year (n)		10	-	Chemicals storage		0.2				Chemicals storage	30	days																	
Retrofit Expenditure year (n-2)		0%	-	Fuel storage		0.0				Start up time	3	months																	
Retrofit Expenditure year (n-1)		40%	-			0.0				Retrofit down time		1	months																
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0				Load factor, remainder year 1	90	%																	

Results summary
Emission avoidance cost **95.049** \$/t CO2
(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)
NPV **0.00** M\$
IRR **10.00%**

Breakdown of c/kWh cost
Fuel **55.37%**
Capital **32.96%**
Other costs **11.67%**

CASH FLOW ANALYSIS

Million \$

	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884
Expenditure Factor		0%	40%	60%									0%	40%	60%														
Revenues																													
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	122.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9
CO2 revenues (based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	117.4	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5	156.5
Operating Costs																													
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-106.8	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.6	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-227.6	-341.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.2
Decommissioning Cost																													0.0
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-178.6	-297.2	93.2	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	1.2
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-216.1	-513.4	-420.1	-288.1	-156.0	-24.0	108.1	240.1	372.1	504.2	636.2	768.3	900.3	1032.4	1164.4	1296.5	1428.5	1429.7

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - CASE 3.2										Version	4.5
30 Jul 2004 11:04																														Date	July 2004
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT											
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	1404.6	2306.4	MW	Installed costs	354.7	1020.7	Fuel	132.9	109.1	Discount rate	10.0	%	Emission avoidance cost	188.131	\$/t CO2																
Net power output	784.8	774.6	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	36.2	Load factor	90.0	85.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)																	
CO2 output	293.0	108.5	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	5.2	Fuel price	3.00	1.50	\$/GJ	NPV	0.00	M\$															
Solid waste output	0.00	1.84	t/h	Retrofit escalation basis year	24.8	71.4	Insurance and local taxes	7.1	27.5	CO2 price	168.1	168.1	\$/t	IRR	10.00%																
CO2 emissions	373	140	g/kWh	Retrofit expenditure escalation yearly	9	0%	Waste disposal	0.0	3.0	Waste disposal cost	0.0	184.5	\$/t																		
Reference plant data				For calculation of cost of emission avoidance				Retrofit Expenditure escalation				0.0%																			
CO2 emissions	373		g/kWh	Total capital cost	415.0	1194.2	Operating labour	1.2	4.7	Insurance and local taxes	2%	2%	of installed cost/y																		
Electricity cost	2.997		c/kWh	Working Capital		Decommissioning cost		0	0	Number of operators	10	40		Breakdown of c/kWh cost																	
Retrofit year (n)		10	-	Chemicals storage	0.2	0.5	Fuel storage	0.0	10.5	Cost per operator	75.0	75.0	\$/ky	Fuel	43.75%																
Retrofit Expenditure year (n-2)		20%	-	Fuel storage	0.0	10.5	Start up time	3	3	Administration	56%	56%	of operators cost	Capital	42.59%																
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	11.1	Retrofit down time	1	1	Fuel storage	0	30	days	Other costs	13.66%																
Retrofit Expenditure year (n)		35%	-					Load factor, remainder year 1	90	60	Chemicals storage	30	30	days																	
CASH FLOW ANALYSIS																															
Million \$																															
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
Expenditure Factor		0%	40%	60%									20%	45%	35%																
Revenues																															
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	91.5	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9		
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	119.7	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1	226.1		
Operating Costs																															
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-49.1	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7		
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-16.3	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7		
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7		
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-2.3	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4		
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5		
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5		
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-236.8	-537.4	-418.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-11.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Decommissioning Cost																															
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	-189.8	-488.4	-373.7	99.0	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	236.4	11.2		
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-276.3	-764.7	-1138.5	-1039.5	-803.1	-566.7	-330.3	-93.9	142.5	378.9	615.3	851.7	1088.1	1324.5	1560.9	1797.3	2033.7	2270.0	2281.3		

IEA GREENHOUSE GAS R&D PROGRAMME																									Cost Evaluation - Sensitivity fuelprice +100% CASE 2.1										Version	4.5		
30 Jul 2004 11:04																									Date	July 2004												
REFEREN					RETROFIT					REFEREN					RETROFIT					REFEREN					RETROFIT					Results summary								
Production					Capital Cost					Operating Costs at 100% load factor					Economic parameters					Emission avoidance cost																		
Fuel feedrate	1404.6	1672.4	MW	Installed costs	354.7	486.4	Fuel	265.8	316.4	Discount rate	10.0	%	Load factor	90.0	90.0	%	CO2 output	293.0	50.1	t/h	Contingencies	10.0%	10.0%	Maintenance	7.9	18.7	Fuel price	6.00	6.00	\$/GJ	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)	117.335	\$/t CO2					
Net power output	784.8	693.7	MW	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	11.2	CO2 price	117.3	117.3	\$/t	CO2 emissions	373	72	g/kWh	Insurance and local taxes	24.8	34.0	Waste disposal cost	0.0	307.5	\$/t	NPV	0.00	M\$	IRR	10.00%									
CO2 emissions	373	72	g/kWh	Retrofit escalation basis year	10	0%	Waste disposal	0.0	0.0	Insurance and local taxes	2%	2%	of installed cost/y																									
Reference plant data					For calculation of cost of emission avoidance					Retrofit Expenditure escalation yearly					Retrofit Expenditure escalation					Breakdown of c/kWh cost																		
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%	0.0%	Operating labour	1.2	2.3	Number of operators	10	20	Cost per operator	75.0	75.0	\$/ky	Fuel	0	0	days	Working Capital			Chemicals storage	0.2	1.0	Decommissioning cost	0	0	Fuel storage	0.0	0.0	Start up time	3	3	months	Capital	21.21%
Electricity cost	4.931		c/kWh	Total capital cost	415.0	569.1	Fuel storage	0.0	0.0	Retrofit down time	1	1	months	Administration	56%	56%	of operators cost	Other costs	7.53%																			
Retrofit year (n)		10	-	Working Capital			Total working capital	0.2	1.0	Load factor, remainder year 1	90	90	%	Fuel storage	0	0	days																					
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	1.0								Chemicals storage	30	30	days																					
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0								Start up time	3	3	months																					
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0								Retrofit down time	1	1	months																					
CASH FLOW ANALYSIS																																						
Million \$																																						
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033									
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26									
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%									
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884									
Expenditure Factor		0%	40%	60%									0%	40%	60%																							
Revenues																																						
Electricity				228.8	305.1	305.1	305.1	305.1	305.1	305.1	305.1	305.1	279.7	202.3	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7	269.7									
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	144.9	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2	193.2									
Operating Costs																																						
Fuel	0.0	0.0	0.0	-179.4	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-219.3	-213.6	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8	-284.8									
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.6	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8									
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3									
Chemicals & consumables	0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0									
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0									
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8									
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-227.8	-341.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0									
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0									
Decommissioning Cost																																						
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-178.6	-297.2	93.2	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	1.2									
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-216.1	-513.4	-420.1	-288.1	-156.0	-24.0	109.1	240.1	372.1	504.2	636.2	768.3	900.3	1032.4	1164.4	1296.5	1428.5	1429.7									

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Sensitivity fuelprice +100% CASE 3.1

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			RESULTS SUMMARY		
Production	Million \$	Million \$	MM \$/year	MM \$/year	Economic parameters	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	
Fuel feedrate	1404.6	2121.2	MW	Installed costs	354.7	822.4	Operating Costs at 100% load factor	Fuel	265.8	200.7	Discount rate	10.0	%	Load factor	90.0	85.0	%	Emission avoidance cost	115.288	\$/t CO2	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)						
Net power output	784.8	751.2	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	31.8	Fuel price	6.00	3.00	\$/GJ	CO2 price	115.3	115.3	\$/t	NPV	0.00	M\$							
CO2 output	293.0	97.6	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	4.7	Insurance and local taxes	7.1	23.5	Waste disposal cost	0.0	184.5	\$/t	IRR	10.00%									
Solid waste output	0.00	1.70	t/h	Retrofit escalation basis year	24.8	57.6	Insurance and local taxes	0.0	2.7	Waste disposal	0.0	2.7	of installed cost/y	2%	2%												
CO2 emissions	373	130	g/kWh	Retrofit Expenditure escalation yearly	9	0%	Operating labour	1.2	3.5	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky											
Reference plant data	For calculation of cost of emission avoidance						Retrofit Expenditure escalation	0.0%																			
CO2 emissions	373		g/kWh	Total capital cost	415.0	962.2	Chemicals storage	0.2	0.5	Administration	56%	56%	of operators cost						Breakdown of c/kWh cost								
Electricity cost	4.931		c/kWh	Working Capital			Fuel storage	0.0	19.4	Fuel storage	0	30	days						Fuel	62.80%							
Retrofit year (n)		10	-	Total working capital	0.2	19.9	Decommissioning cost	0	0	Chemicals storage	30	30	days						Capital	28.07%							
Retrofit Expenditure year (n-2)		20%	-							Start up time	3	3	months						Other costs	9.13%							
Retrofit Expenditure year (n-1)		45%	-							Retrofit down time	1	1	months														
Retrofit Expenditure year (n)		35%	-							Load factor, remainder year 1	90	60	%														

CASH FLOW ANALYSIS		Million \$																												
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor		0%	40%	60%									20%	45%	35%															
Revenues																														
Electricity				228.8	305.1	305.1	305.1	305.1	305.1	305.1	305.1	305.1	279.7	146.0	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8	275.8
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	83.1	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0	157.0
Operating Costs																														
Fuel		0.0	0.0	-179.4	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-219.3	-90.3	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6	-170.6
Maintenance		0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-14.3	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1
Labour		0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5
Chemicals & consumables		0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-2.1	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3
Insurance and local taxes		0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-192.4	-433.0	-336.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-19.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																														0.0
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	-143.4	-384.0	-292.5	74.3	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	201.8	20.0
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-229.9	-613.9	-906.5	-832.2	-630.4	-428.6	-226.8	-25.0	176.8	378.6	580.5	782.3	984.1	1185.9	1387.7	1589.5	1791.3	1993.1	2013.1

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Sensitivity fuelprice +100% CASE 3.2

30 Jul 2004 11:04

	REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		Results summary			
Production				Capital Cost	Million \$	Million \$	Operating Costs	MM \$/year	MM \$/year	Economic parameters									
Fuel feedrate	1404.6	2306.4	MW	Installed costs	354.7	1020.7	at 100% load factor			Discount rate	10.0	%				Emission avoidance cost	154.947 \$/t CO2		
Net power output	784.8	774.6	MW	Contingencies	10.0%	10.0%	Fuel	265.8	218.2	Load factor	90.0	85.0	%				(Note: Type 'Tools' Solver' 'Solve' to calculate		
CO2 output	293.0	108.5	t/h	Owners costs	7.0%	7.0%	Maintenance	7.9	36.2	Fuel price	6.00	3.00	\$/GJ				the CO2 emission avoidance cost that gives a zero NPV)		
Solid waste output	0.00	1.84	t/h	Retrofit escalation basis year	24.8	71.4	Chemicals + consumables	1.7	5.3	CO2 price	154.9	154.9	\$/t				NPV	0.00 M\$	
CO2 emissions	373	140	g/kWh	Retrofit Expenditure escalation yearly	9		Insurance and local taxes	7.1	27.5	Waste disposal cost	0.0	184.5	\$/t				IRR	10.00%	
Reference plant data	For calculation of cost of emission avoidance			Retrofit Expenditure escalation	0%		Waste disposal	0.0	3.0	Insurance and local taxes	2%	2%	of installed cost/y						
CO2 emissions	373		g/kWh	Total capital cost	415.0	1194.2	Operating labour	1.2	4.7	Number of operators	10	40							
Electricity cost	4.931		c/kWh	Working Capital			Chemicals storage	0.2	0.5	Cost per operator	75.0	75.0	\$/kly						
Retrofit year (n)		10	-	Chemicals storage	0.0	0.5	Fuel storage	0.0	21.1	Administration	56%	56%	of operators cost					Breakdown of c/kWh cost	
Retrofit Expenditure year (n-2)		20%	-	Fuel storage	0.0	21.1	Decommissioning cost	0	0	Fuel storage	0	30	days					Fuel	60.80%
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	21.6				Chemicals storage	30	30	days					Capital	29.69%
Retrofit Expenditure year (n)		35%	-							Start up time	3	3	months					Other costs	9.51%
										Retrofit down time		1	months						
										Load factor, remainder year 1	90	60	%						

CASH FLOW ANALYSIS																															
Million \$		2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
Year		000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
Load Factor					68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
Equivalent yearly hours					5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
Expenditure Factor			0%	40%	60%									20%	45%	35%															
Revenues																															
Electricity					228.8	305.1	305.1	305.1	305.1	305.1	305.1	305.1	305.1	279.7	150.6	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4
CO2 revenues(based on power output retrofit case)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	110.3	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4	208.4
Operating Costs																															
Fuel		0.0	0.0	0.0	-179.4	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-239.2	-219.3	-98.2	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5	-185.5
Maintenance		0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-16.3	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7
Labour		0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7
Chemicals & consumables		0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-2.4	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5
Insurance and local taxes		0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-238.8	-537.4	-418.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-21.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.8
Decommissioning Cost																															0.0
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	-189.8	-488.4	-373.7	88.9	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	237.4	21.8	
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-276.3	-764.7	-1138.5	-1049.5	-812.1	-574.7	-337.3	-99.9	137.6	375.0	612.4	849.8	1087.2	1324.6	1562.0	1799.4	2036.9	2274.3	2296.0	

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Reference CASE fuelprice -50%

30 Jul 2004 11:04

	REFEREN		RETROFIT		REFEREN		RETROFIT		REFEREN		RETROFIT		REFEREN		RETROFIT		REFEREN		RETROFIT													
Production					Capital Cost	Million \$	Million \$	Operating Costs	MM \$/year	MM \$/year	Economic parameters										Results summary											
Fuel feedrate	1404.6	1404.6	MW		Installed costs	354.7	337.7	at 100% load factor			Discount rate	10.0	%								Emission avoidance cost	203.562 \$/t CO2										
Net power output	784.8	625.9	MW		Contingencies	10.0%	10.0%	Fuel	66.4	66.4	Load factor	90.0	%									(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)										
CO2 output	293.0	41.9	t/h			35.5	33.8	Maintenance	7.9	15.4	Fuel price	1.50	1.50	\$/GJ							NPV	0.00 M\$										
Solid waste output	0.00	0.04	t/h		Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	2.4	CO2 price	203.6	203.6	\$/t							IRR	10.00%										
CO2 emissions	373	67	g/kWh		Retrofit escalation basis year		10	Insurance and local taxes	7.1	13.8	Waste disposal cost	0.0	307.5	\$/t																		
					Retrofit expenditure escalation yearly		0%	Waste disposal	0.0	0.1	Insurance and local taxes	2%	2%	of installed cost/y																		
Reference plant data	<i>For calculation of cost of emission avoidance</i>				Retrofit Expenditure escalation		0%	Operating labour	1.2	1.8	Number of operators	10	15																			
CO2 emissions	373		g/kWh		Retrofit Expenditure escalation		0%				Cost per operator	75.0	75.0	\$/ky																		
Electricity cost	2.031		c/kWh		Total capital cost	415.0	395.1				Administration	56%	56%	of operators cost								Breakdown of c/kWh cost										
					Working Capital			Decommissioning cost	0	0	Fuel storage	0	0	days								Fuel	47.59%									
Retrofit year (n)		100	-		Chemicals storage	0.2	0.2				Chemicals storage	30	30	days								Capital	38.82%									
Retrofit Expenditure year (n-2)		0%	-		Fuel storage	0.0	0.0				Start up time	3	3	months								Other costs	13.59%									
Retrofit Expenditure year (n-1)		40%	-		Total working capital	0.2	0.2				Retrofit down time		1	months																		
Retrofit Expenditure year (n)		60%	-								Load factor, remainder year 1	90	90	%																		
CASH FLOW ANALYSIS																																
Million \$																																
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033			
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26			
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%			
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884			
Expenditure Factor		0%	40%	60%																												
Revenues																																
Electricity				94.2	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7			
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Operating Costs																																
Fuel	0.0	0.0	0.0	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8			
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1			
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2			
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5			
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1			
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Decommissioning Cost																																
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	0.2			
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	11.5	60.5	109.5	158.5	207.5	256.5	305.5	354.5	403.5	452.5	501.5	550.5	599.4	648.4	697.4	746.4	795.4	795.6			

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - Sensitivity fuelprice -50% CASE 1										Version	4.5
30 Jul 2004 11:04																														Date	July 2004
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT											
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	1404.6	1404.6	MW	Installed costs	354.7	337.7		Fuel	66.4	66.4		Discount rate	10.0	%	Emission avoidance cost	65.231	\$/t CO2														
Net power output	784.8	625.9	MW	Contingencies	10.0%	10.0%		Maintenance	7.9	15.4		Load factor	90.0	90.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)															
CO2 output	293.0	41.9	t/h	Owners costs	7.0%	7.0%		Chemicals + consumables	1.7	2.4		Fuel price	1.50	1.50	\$/GJ	NPV	0.00	M\$													
Solid waste output	0.00	0.04	t/h	Retrofit escalation basis year	24.8	23.6		Insurance and local taxes	7.1	13.8		CO2 price	65.2	65.2	\$/t	IRR	10.00%														
CO2 emissions	373	67	g/kWh	Retrofit expenditure escalation yearly	10	0%		Waste disposal	0.0	0.1		Waste disposal cost	0.0	307.5	\$/t																
Reference plant data				For calculation of cost of emission avoidance				Retrofit Expenditure escalation				Number of operators																			
CO2 emissions	373		g/kWh	CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%			Cost per operator	75.0	75.0	\$/ky	Breakdown of c/kWh cost															
Electricity cost	2.031		c/kWh	Electricity cost	2.031		c/kWh	Total capital cost	415.0	395.1		Administration	56%	56%	of operators cost	Fuel		40.00%													
Retrofit year (n)		10	-	Working Capital				Chemicals storage	0.2	0.2		Fuel storage	0	0	days	Capital		45.22%													
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	0.2		Start up time	0.0	0.0		Chemicals storage	30	30	days	Other costs		14.78%													
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0		Retrofit down time	1	1	months	Load factor, remainder year 1	90	90	%																
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	0.2																									
CASH FLOW ANALYSIS																															
Million \$																															
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%			
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884			
Expenditure Factor		0%	40%	60%									0%	40%	60%																
Revenues																															
Electricity				94.2	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	115.2	75.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2	100.2			
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	74.0	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6	98.6			
Operating Costs																															
Fuel		0.0	0.0	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-54.8	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8			
Maintenance		0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-10.4	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8			
Labour		0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8			
Chemicals & consumables		0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-1.6	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1			
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1			
Insurance and local taxes		0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8			
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-158.0	-237.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Decommissioning Cost																												0.0			
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-109.0	-192.8	76.4	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	107.3	0.4			
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-146.5	-339.3	-262.9	-155.6	-48.3	59.1	166.4	273.7	381.0	488.4	595.7	703.0	810.4	917.7	1025.0	1132.4			

IEA GREENHOUSE GAS R&D PROGRAMME																									Cost Evaluation - Sensitivity fuelprice -50% CASE 2.1										Version	4.5
30 Jul 2004 11:04																									Date	July 2004										
REFEREN					RETROFIT					REFEREN					RETROFIT					REFEREN					RETROFIT					Results summary						
Production					Capital Cost					Operating Costs at 100% load factor					Economic parameters																					
Fuel feedrate	1404.6	1672.4	MW	Installed costs	354.7	486.4	Fuel	66.4	79.1	Discount rate	10.0	%	Emission avoidance cost	83.908	\$/t CO2																					
Net power output	784.8	693.7	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	18.7	Load factor	90.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)																							
CO2 output	293.0	50.1	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	11.1	Fuel price	1.50	1.50	\$/GJ	NPV	0.00	M\$																				
Solid waste output	0.00	0.01	t/h	Retrofit escalation basis year	24.8	34.0	Insurance and local taxes	7.1	16.8	CO2 price	83.9	83.9	\$/t	IRR	10.00%																					
CO2 emissions	373	72	g/kWh	Retrofit expenditure escalation yearly	10	0%	Waste disposal	0.0	0.0	Waste disposal cost	0.0	307.5	\$/t																							
Reference plant data					For calculation of cost of emission avoidance					Retrofit Expenditure escalation					Number of operators																					
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%	0.0%	Operating labour	1.2	2.3	Insurance and local taxes	2%	2%	of installed cost/y																							
Electricity cost	2.031		c/kWh	Total capital cost	415.0	569.1				Cost per operator	10	20																								
Working Capital					Decommissioning cost					Breakdown of c/kWh cost																										
Retrofit year (n)	10	-		Chemicals storage	0.2	1.0	Fuel storage	0	0	Fuel storage	0	0	days	Fuel	38.28%																					
Retrofit Expenditure year (n-2)	0%	-		Fuel storage	0.0	0.0	Start up time	3	3	Administration	56%	56%	of operators cost	Capital	45.58%																					
Retrofit Expenditure year (n-1)	40%	-		Total working capital	0.2	1.0	Retrofit down time	1	1	Fuel storage	0	0	days	Other costs	16.14%																					
Retrofit Expenditure year (n)	60%	-					Load factor, remainder year 1	90	90	Start up time	3	3	months																							
										Retrofit down time	1	1	months																							
										Load factor, remainder year 1	90	90	%																							
CASH FLOW ANALYSIS																																				
Million \$																																				
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033							
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26							
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%							
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884						
Expenditure Factor		0%	40%	60%									0%	40%	60%																					
Revenues																																				
Electricity				94.2	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	115.2	83.3	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1	111.1						
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	103.6	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2	138.2						
Operating Costs																																				
Fuel	0.0	0.0	0.0	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-54.8	-53.4	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2	-71.2						
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.6	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8						
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3						
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0						
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8						
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-227.8	-341.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Decommissioning Cost																														0.0						
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-178.6	-297.2	93.2	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	132.0	1.2						
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-216.1	-513.4	-420.1	-288.1	-156.0	-24.0	109.1	240.1	372.1	504.2	636.2	768.3	900.3	1032.4	1164.4	1296.5	1428.5	1429.7							

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Sensitivity fuelprice -50% CASE 3.1

30 Jul 2004 11:04

	REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT					
Production				Capital Cost			Operating Costs			Economic parameters																								
Fuel feedrate	1404.6	2121.2	MW	Installed costs	354.7	822.4	at 100% load factor			Discount rate	10.0	%																						
Net power output	784.8	751.2	MW	Contingencies	10.0%	10.0%	Fuel	66.4	50.2	Load factor	90.0	85.0	%																					
CO2 output	293.0	97.6	t/h				Maintenance	7.9	31.8	Fuel price	1.50	0.75	\$/GJ																					
Solid waste output	0.00	1.70	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	4.6	CO2 price	139.4	139.4	\$/t																					
CO2 emissions	373	130	g/kWh				Insurance and local taxes	7.1	23.5	Waste disposal cost	0.0	184.5	\$/t																					
				Retrofit escalation basis year		9	Waste disposal	0.0	2.7	Insurance and local taxes	2%	2%	of installed cost/y																					
Reference plant data				Retrofit Expenditure escalation yearly		0%	Operating labour	1.2	3.5	Number of operators	10	30																						
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation		0.0%				Cost per operator	75.0	75.0	\$/kWh																					
Electricity cost	2.031		c/kWh	Total capital cost		415.0	962.2			Administration	56%	56%	of operators cost																					
				Working Capital						Fuel storage	0	30	days																					
Retrofit year (n)		10	-	Chemicals storage		0.2	0.4			Chemicals storage	30	30	days																					
Retrofit Expenditure year (n-2)		20%	-	Fuel storage		0.0	4.9			Start up time	3	3	months																					
Retrofit Expenditure year (n-1)		45%	-	Total working capital		0.2	5.3			Retrofit down time		1	months																					
Retrofit Expenditure year (n)		35%	-							Load factor, remainder year 1	90	60	%																					

Results summary
Emission avoidance cost 139.405 \$/t CO2
(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)
NPV 0.00 M\$
IRR 10.00%

Breakdown of c/kWh cost
Fuel 29.76%
Capital 52.96%
Other costs 17.28%

CASH FLOW ANALYSIS

Million \$	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033			
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26			
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
Expenditure Factor		0%	40%	60%									20%	45%	35%																	
Revenues																																
Electricity				94.2	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	115.2	60.1	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	113.6	
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	100.5	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	189.8	
Operating Costs																																
Fuel	0.0	0.0	0.0	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-54.8	-22.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	-42.6	
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-14.3	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-2.1	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-192.4	-433.0	-336.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-5.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.4	
Decommissioning Cost																															0.0	
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	-143.4	-384.0	-292.5	88.1	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	200.4	5.4		
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-229.9	-613.9	-906.5	-818.4	-618.0	-417.6	-217.2	-16.8	183.6	384.0	584.4	784.9	985.3	1185.7	1386.1	1586.5	1786.9	1987.3	1992.7			

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Sensitivity fuelprice -50% CASE 3.2

30 Jul 2004 11:04

	REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		REFEREN	RETROFIT		Results summary			
Production				Capital Cost	Million \$	Million \$	Operating Costs	MM \$/year	MM \$/year	Economic parameters									
Fuel feedrate	1404.6	2306.4	MW	Installed costs	354.7	1020.7	at 100% load factor			Discount rate	10.0	%				Emission avoidance cost	174.723 \$/t CO2		
Net power output	784.8	774.6	MW	Contingencies	10.0%	10.0%	Fuel	66.4	54.8	Load factor	90.0	85.0	%				(Note: Type 'Tools' Solver' 'Solve' to calculate		
CO2 output	293.0	108.5	t/h				Maintenance	7.9	36.2	Fuel price	1.50	0.75	\$/GJ				the CO2 emission avoidance cost that gives a zero NPV)		
Solid waste output	0.00	1.84	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	5.2	CO2 price	174.7	174.7	\$/t				NPV	0.00 M\$	
CO2 emissions	373	140	g/kWh				Insurance and local taxes	7.1	27.5	Waste disposal cost	0.0	184.5	\$/t				IRR	10.00%	
				Retrofit escalation basis year		9	Waste disposal	0.0	3.0	Insurance and local taxes	2%	2%	of installed cost/y						
Reference plant data	For calculation of cost of emission avoidance			Retrofit Expenditure escalation yearly		0%	Operating labour	1.2	4.7	Number of operators	10	40							
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation		0.0%				Cost per operator	75.0	75.0	\$/kWh						
Electricity cost	2.031		c/kWh	Total capital cost	415.0	1194.2	Decommissioning cost	0	0	Administration	56%	56%	of operators cost					Breakdown of c/kWh cost	
				Working Capital			Chemicals storage	0.2	0.5	Fuel storage	0	30	days					Fuel	28.02%
Retrofit year (n)		10	-	Chemicals storage			Fuel storage	0.0	5.3	Chemicals storage	30	30	days					Capital	54.48%
Retrofit Expenditure year (n-2)		20%	-							Start up time	3	3	months					Other costs	17.50%
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	5.8				Retrofit down time		1	months						
Retrofit Expenditure year (n)		35%	-							Load factor, remainder year 1	90	60	%						

CASH FLOW ANALYSIS																															
Million \$		2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
Year		000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
Load Factor					68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
Equivalent yearly hours					5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor			0%	40%	60%									20%	45%	35%															
Revenues																															
Electricity					94.2	125.7	125.7	125.7	125.7	125.7	125.7	125.7	125.7	115.2	62.0	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1	117.1
CO2 revenues(based on power output retrofit case)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	124.4	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0	235.0
Operating Costs																															
Fuel		0.0	0.0	0.0	-44.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-59.8	-54.8	-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4
Maintenance		0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-16.3	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7
Labour		0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7
Chemicals & consumables		0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-2.3	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	
Insurance and local taxes		0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-238.8	-537.4	-418.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-5.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.9
Decommissioning Cost																															0.0
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-189.8	-488.4	-373.7	104.0	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	235.9	5.9
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-276.3	-764.7	-1138.5	-1034.5	-798.6	-562.7	-326.8	-90.9	144.9	380.8	616.7	852.6	1088.5	1324.4	1560.3	1796.2	2032.1	2267.9	2273.9	

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - Discount rate 5% CASE 1										Version	4.5				
30 Jul 2004 11:04																														Date	July 2004				
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				RESULTS SUMMARY			
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary																			
Fuel feedrate	1404.6	1404.6	MW	Installed costs	354.7	337.7	Fuel	132.9	132.9	Discount rate	5.0	%	Emission avoidance cost	59.429	\$/t CO2																				
Net power output	784.8	625.9	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	15.4	Load factor	90.0	90.0	Load factor	90.0	%																				
CO2 output	293.0	41.9	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	2.4	Fuel price	3.00	3.00	\$/GJ	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																					
Solid waste output	0.00	0.04	t/h	Retrofit escalation basis year	24.8	23.6	Insurance and local taxes	7.1	13.8	CO2 price	59.4	59.4	\$/t	NPV	0.00	M\$																			
CO2 emissions	373	67	g/kWh	Retrofit expenditure escalation yearly	0%	0%	Waste disposal	0.0	0.1	Waste disposal cost	0.0	307.5	\$/t	IRR	5.00%																				
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Total capital cost				415.0	395.1	Decommissioning cost				0	0	Breakdown of c/kWh cost															
CO2 emissions	373		g/kWh	Chemicals storage	0.2	0.2	Fuel storage	0.0	0.0	Number of operators	10	15	Cost per operator	75.0	75.0	\$/ky	Fuel	62.05%																	
Electricity cost	2.703		c/kWh	Retrofit expenditure escalation	0.0	0.0	Working Capital	Total working capital		0.2	0.2	Administration	56%	56%	of operators cost	Capital	25.48%																		
Retrofit year (n)		10	-	Chemicals storage	0.2	0.2	Decommissioning cost	0	0	Fuel storage	0	0	days	of operators cost	Other costs	12.48%																			
Retrofit Expenditure year (n-2)		0%	-	Fuel storage	0.0	0.0				Start up time	3	3	months																						
Retrofit Expenditure year (n-1)		40%	-	Total working capital	0.2	0.2				Retrofit down time	1	1	months																						
Retrofit Expenditure year (n)		60%	-							Load factor, remainder year 1	90	90	%																						
CASH FLOW ANALYSIS																																			
Million \$																																			
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033						
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26						
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%						
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884					
Expenditure Factor		0%	40%	60%									0%	40%	60%																				
Revenues																																			
Electricity				125.4	167.2	167.2	167.2	167.2	167.2	167.2	167.2	167.2	153.3	100.0	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4	133.4					
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	67.4	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8	89.8					
Operating Costs																																			
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6					
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-10.4	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8					
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8					
Chemicals & consumables	0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-1.6	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2	-2.2					
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1					
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8					
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-158.0	-237.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Decommissioning Cost																																			
Total Cash Flow (yearly)	0.0	-166.0	-249.0	20.8	30.7	30.7	30.7	30.7	30.7	30.7	30.7	30.7	-127.3	-209.6	49.8	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	71.9	0.4					
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-394.2	-363.5	-332.8	-302.1	-271.4	-240.7	-210.0	-179.3	-148.6	-117.9	-87.2	-56.5	-25.8	4.9	35.8	67.7	99.6	131.5	163.4	195.3	227.2	259.1	291.0	322.9	354.8	386.7	418.6	450.5				

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - Discount rate 5% CASE 2.1										Version	4.5
30 Jul 2004 11:04																														Date	July 2004
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT											
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	1404.6	1672.4	MW	Installed costs	354.7	486.4		Fuel	132.9	158.2		Discount rate	5.0	%	Emission avoidance cost	79.020	\$/t CO2														
Net power output	784.8	693.7	MW	Contingencies	10.0%	10.0%		Maintenance	7.9	18.7		Load factor	90.0	90.0 %	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																
CO2 output	293.0	50.1	t/h	Owners costs	7.0%	7.0%		Chemicals + consumables	1.7	11.2		Fuel price	3.00	3.00 \$/GJ	NPV	0.00	M\$														
Solid waste output	0.00	0.01	t/h	Retrofit escalation basis year	24.8	34.0		Insurance and local taxes	7.1	16.8		CO2 price	79.0	79.0 \$/t	IRR	5.00%															
CO2 emissions	373	72	g/kWh	Retrofit expenditure escalation yearly	10	0%		Waste disposal	0.0	0.0		Waste disposal cost	0.0	307.5 \$/t																	
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Retrofit Expenditure escalation				0%																			
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation		0.0%		Operating labour	1.2	2.3		Insurance and local taxes	2%	2% of installed cost/y																	
Electricity cost	2.703		c/kWh	Total capital cost	415.0	569.1		Number of operators	10	20		Cost per operator	75.0	75.0 \$/ky	Breakdown of c/kWh cost																
Retrofit year (n)		10	-	Working Capital				Administration	56%	56% of operators cost		Fuel storage	0	0 days	Fuel		59.72%														
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	1.0		Chemicals storage	30	30 days		Start up time	3	3 months	Capital		26.24%														
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0		Retrofit down time		1 months		Load factor, remainder year 1	90	90 %	Other costs		14.04%														
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0																									
CASH FLOW ANALYSIS																															
Million \$																															
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%			
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884			
Expenditure Factor		0%	40%	60%									0%	40%	60%																
Revenues																															
Electricity				125.4	167.2	167.2	167.2	167.2	167.2	167.2	167.2	167.2	153.3	110.9	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8	147.8			
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	97.6	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1	130.1			
Operating Costs																															
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-106.8	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4			
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.6	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8			
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3			
Chemicals & consumables	0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0			
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8			
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-227.8	-341.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Decommissioning Cost																												0.0			
Total Cash Flow (yearly)	0.0	-166.0	-249.0	20.8	30.7	30.7	30.7	30.7	30.7	30.7	30.7	-196.9	-314.0	61.3	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	89.5	1.2			
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-394.2	-363.5	-332.8	-302.1	-271.4	-240.7	-210.0	-179.3	-376.2	-690.2	-628.9	-539.5	-450.0	-360.5	-271.0	-181.6	-92.1	-2.6	86.9	176.4	265.8	355.3	444.8	624.9				

IEA GREENHOUSE GAS R&D PROGRAMME																									Cost Evaluation - Discount rate 5% CASE 3.1										Version	4.5																											
30 Jul 2004 11:04																									Date	July 2004																																					
REFEREN					RETROFIT					REFEREN					RETROFIT					REFEREN					RETROFIT					Results summary																																	
Production					Capital Cost					Operating Costs at 100% load factor					Economic parameters					Emission avoidance cost																																											
Fuel feedrate	1404.6	2121.2	MW	Installed costs	354.7	822.4	Fuel	132.9	100.3	Discount rate	5.0	%	Load factor	90.0	85.0	%	CO2 price	95.3	95.3	\$/t	Waste disposal cost	0.0	184.5	\$/t	Insurance and local taxes	2%	2%	of installed cost/y	NPV	0.00	M\$	IRR	5.00%																														
Net power output	784.8	751.2	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	31.8	Fuel price	3.00	1.50	\$/GJ	CO2 price	95.3	95.3	\$/t	Waste disposal cost	0.0	184.5	\$/t	Insurance and local taxes	2%	2%	of installed cost/y	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%
CO2 output	293.0	97.6	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	7.1	23.5	Waste disposal cost	0.0	184.5	\$/t	Insurance and local taxes	2%	2%	of installed cost/y	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%								
Solid waste output	0.00	1.70	t/h	Retrofit escalation basis year	24.8	57.6	Insurance and local taxes	7.1	23.5	Operating labour	1.2	3.5	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%													
CO2 emissions	373	130	g/kWh	Retrofit expenditure escalation yearly	0%	0%	Operating labour	1.2	3.5	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Reference plant data	For calculation of cost of emission avoidance			Total capital cost	415.0	962.2	Decommissioning cost	0	0	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
CO2 emissions	373		g/kWh	Working Capital			Chemicals storage	0.2	0.5	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Electricity cost	2.703		c/kWh	Chemicals storage	0.2	0.5	Fuel storage	0.0	9.7	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Retrofit year (n)		10	-	Total working capital	0.2	10.2	Decommissioning cost	0	0	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Retrofit Expenditure year (n-2)		20%	-	Chemicals storage	0.2	0.5	Fuel storage	0.0	9.7	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Retrofit Expenditure year (n-1)		45%	-	Fuel storage	0.0	9.7	Decommissioning cost	0	0	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
Retrofit Expenditure year (n)		35%	-	Total working capital	0.2	10.2	Decommissioning cost	0	0	Number of operators	10	30	Cost per operator	75.0	75.0	\$/ky	Administration	56%	56%	of operators cost	Fuel storage	0	30	days	Chemicals storage	30	30	days	Start up time	3	3	months	Retrofit down time	1	1	months	Load factor, remainder year 1	90	60	%	Breakdown of c/kWh cost	Fuel	47.67%	Capital	35.28%	Other costs	17.05%																
CASH FLOW ANALYSIS																																																															
Million \$																																																															
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033																																		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26																																		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%																																		
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446																																	
Expenditure Factor		0%	40%	60%									20%	45%	35%																																																
Revenues																																																															
Electricity				125.4	167.2	167.2	167.2	167.2	167.2	167.2	167.2	167.2	153.3	80.0	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2	151.2																																
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	68.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7	129.7																																	
Operating Costs																																																															
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-45.2	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3																																	
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-14.3	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1																																	
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5																																	
Chemicals & consumables	0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-2.1	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0	-4.0																																	
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3																																	
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5																																	
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-192.4	-433.0	-336.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0																																	
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-10.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0																																	
Decommissioning Cost																																																															
Total Cash Flow (yearly)	0.0	-166.0	-249.0	20.8	30.7	30.7	30.7	30.7	30.7	30.7	-161.7	-402.3	-309.3	48.7	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	135.2	10.3																																	
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-394.2	-363.5	-332.8	-302.1	-271.4	-240.7	-210.0	-371.7	-774.0	-1083.3	-1034.6	-899.5	-764.3	-629.1	-493.9	-358.7	-223.5	-88.3	46.8	182.0	317.2	452.4	587.6	722.8	858.0	868.3																																		

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Discount rate 5% CASE 3.2

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			RESULTS SUMMARY				
							Million \$			Million \$			MM \$/year			MM \$/year													
Production							Capital Cost				Operating Costs at 100% load factor				Economic parameters										Results summary				
Fuel feedrate	1404.6	2306.4	MW	Installed costs	354.7	1020.7	Fuel	132.9	109.1	Discount rate	5.0	%	Emission avoidance cost	123.881	\$/t CO2														
Net power output	784.8	774.6	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	36.2	Load factor	90.0	85.0	Load factor	90.0	85.0	(\$/GJ)													
CO2 output	293.0	108.5	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	5.3	Fuel price	3.00	1.50	CO2 price	123.9	123.9	(\$/t)													
Solid waste output	0.00	1.84	t/h	Retrofit escalation basis year	24.8	71.4	Insurance and local taxes	7.1	27.5	CO2 price	123.9	123.9	Waste disposal cost	0.0	184.5	(\$/t)													
CO2 emissions	373	140	g/kWh	Retrofit expenditure escalation yearly	0%	0%	Waste disposal	0.0	3.0	Waste disposal cost	0.0	184.5	Insurance and local taxes	2%	2%	of installed cost/y													
Reference plant data	<i>For calculation of cost of emission avoidance</i>			Retrofit Expenditure escalation yearly	0%	0%	Operating labour	1.2	4.7	Number of operators	10	40	Cost per operator	75.0	75.0	(\$/ky)													
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%	0.0%	Total capital cost	415.0	1194.2	Administration	56%	56%	of operators cost																
Electricity cost	2.703		c/kWh	Working Capital			Decommissioning cost	0	0	Fuel storage	0	30	days																
Retrofit year (n)		10	-	Chemicals storage	0.2	0.5				Start up time	3	3	months																
Retrofit Expenditure year (n-2)		20%	-	Fuel storage	0.0	10.5				Retrofit down time		1	months																
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	11.1				Load factor, remainder year 1	90	60	%																
Retrofit Expenditure year (n)		35%	-																										
CASH FLOW ANALYSIS																													
Million \$																													
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor		0%	40%	60%									20%	45%	35%														
Revenues																													
Electricity				125.4	167.2	167.2	167.2	167.2	167.2	167.2	167.2	167.2	153.3	82.5	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9	155.9
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	88.2	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6
Operating Costs																													
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-49.1	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-16.3	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7
Chemicals & consumables	0.0	0.0	0.0	-1.2	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-2.4	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5	-4.5
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-238.8	-537.4	-418.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-11.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																													0.0
Total Cash Flow (yearly)	0.0	-166.0	-249.0	20.8	30.7	30.7	30.7	30.7	30.7	30.7	-208.1	-506.7	-390.5	58.4	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	159.8	11.2
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-394.2	-363.5	-332.8	-302.1	-271.4	-240.7	-210.0	-418.1	-924.8	-1315.3	-1256.9	-1097.1	-937.3	-777.4	-617.6	-457.8	-298.0	-138.1	21.7	181.5	341.4	501.2	661.0	820.8	991.9	

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Retrofit year - 5 year CASE 2.2

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			RESULTS SUMMARY		
Production	Million \$	Million \$	Million \$	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year
Fuel feedrate	1404.6	1671.0	MW	354.7	641.2	Operating Costs at 100% load factor	132.9	158.1	Discount rate	10.0	%	Emission avoidance cost	116.761	\$/t CO2													
Net power output	784.8	667.4	MW	10.0%	10.0%	Fuel	7.9	22.1	Load factor	90.0	90.0	Cost per operator	75.0	75.0	\$/ky												
CO2 output	293.0	49.9	t/h	35.5	64.1	Maintenance	1.7	10.7	Fuel price	3.00	3.00	\$/GJ	56%	56%	of operators cost												
Solid waste output	0.00	0.01	t/h	7.0%	7.0%	Chemicals + consumables	7.1	19.9	CO2 price	116.8	116.8	\$/t	0	0	days												
CO2 emissions	373	75	g/kWh	24.8	44.9	Insurance and local taxes	0.0	0.0	Waste disposal cost	0.0	307.5	\$/t	30	30	months												
Reference plant data	For calculation of cost of emission avoidance			Retrofit escalation basis year	5	Decommissioning cost	0	0	Insurance and local taxes	2%	2%	of installed cost/y	1	1	months												
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation yearly	0%	Operating labour	1.2	3.5	Number of operators	10	30		90	90	%												
Electricity cost	2.997		c/kWh	Retrofit Expenditure escalation	0.0%	Total capital cost	415.0	750.3	Administration	56%	56%		3	3	months												
Retrofit year (n)		5	-	Total working capital	0.2	1.0	Working Capital	Decommissioning cost	0	0	Fuel storage	0	0	days													
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	1.0	Chemicals storage	30	30	days	Start up time	3	3	months													
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0	Fuel storage	3	3	months	Retrofit down time	1	1	months													
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0	Total working capital	0.2	1.0	Load factor, remainder year 1	90	90	%														

CASH FLOW ANALYSIS																													
Million \$																													
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	
Equivalent yearly hours				5913	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884
Expenditure Factor		0%	40%	60%			0%	40%	60%																				
Revenues																													
Electricity				139.1	185.5	185.5	185.5	170.0	118.3	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7	157.7
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	137.6	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4	183.4
Operating Costs																													
Fuel		0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-109.6	-106.7	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3	-142.3
Maintenance		0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-6.5	-14.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9
Labour		0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5
Chemicals & consumables		0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.4	-7.2	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Insurance and local taxes		0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9	-19.9
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	-300.1	-450.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																													0.0
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	-251.1	-405.9	102.5	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	145.8	1.1
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-533.6	-939.5	-837.0	-691.2	-545.4	-399.5	-253.7	-107.9	37.9	183.7	329.5	475.3	621.1	767.0	912.8	1058.6	1204.4	1350.2	1496.0	1641.8	1787.6	1934.6

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Retrofit year - 5 year CASE 3.1

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			RESULTS SUMMARY			
Production	Million \$	Million \$	MM \$/year	MM \$/year	Economic parameters	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	
Fuel feedrate	1404.6	2121.2	MW	Installed costs	354.7	822.4	Operating Costs at 100% load factor	Fuel	132.9	100.3	Discount rate	10.0	%	Results summary	Emission avoidance cost	118.922	\$/t CO2											
Net power output	784.8	751.2	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	31.8	Load factor	90.0	85.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)	NPV	0.00	M\$											
CO2 output	293.0	97.6	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	4.6	Fuel price	3.00	1.50	\$/GJ	IRR	10.00%													
Solid waste output	0.00	1.70	t/h	Retrofit escalation basis year	24.8	57.6	Insurance and local taxes	7.1	23.5	CO2 price	118.9	118.9	\$/t															
CO2 emissions	373	130	g/kWh	Retrofit expenditure escalation yearly	4	0%	Waste disposal	0.0	2.7	Waste disposal cost	0.0	184.5	\$/t															
Reference plant data	For calculation of cost of emission avoidance			Retrofit Expenditure escalation	0.0%	0.0%	Operating labour	1.2	3.5	Insurance and local taxes	2%	2%	of installed cost/y															
CO2 emissions	373		g/kWh	Total capital cost	415.0	962.2	Decommissioning cost	0	0	Number of operators	10	30																
Electricity cost	2.997		c/kWh	Working Capital			Chemicals storage	0.2	0.4	Cost per operator	75.0	75.0	\$/ky	Breakdown of c/kWh cost	Fuel	36.78%												
Retrofit year (n)		5	-	Chemicals storage	0.0	9.7	Fuel storage	0.0	9.7	Administration	56%	56%	of operators cost	Capital	47.10%													
Retrofit Expenditure year (n-2)		20%	-	Total working capital	0.2	10.1	Start up time	3	3	Fuel storage	0	30	days	Other costs	16.12%													
Retrofit Expenditure year (n-1)		45%	-				Retrofit down time	1	1	Chemicals storage	30	30	days															
Retrofit Expenditure year (n)		35%	-				Load factor, remainder year 1	90	60				%															

CASH FLOW ANALYSIS																													
Million \$																													
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
Equivalent yearly hours				5913	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
Expenditure Factor		0%	40%	60%			20%	45%	35%																				
Revenues																													
Electricity				139.1	185.5	185.5	185.5	170.0	88.8	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	85.7	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	161.9	
Operating Costs																													
Fuel		0.0	0.0	-89.7	-119.6	-119.6	-119.6	-109.6	-45.2	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	
Maintenance		0.0	0.0	-5.3	-7.1	-7.1	-7.1	-6.5	-14.3	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	
Labour		0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	
Chemicals & consumables		0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.4	-2.1	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	
Insurance and local taxes		0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	-192.4	-433.0	-336.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	-10.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Decommissioning Cost																													
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	-143.4	-384.0	-292.5	74.5	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	183.9	10.3	
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-474.9	-858.9	-1151.4	-1076.9	-893.0	-709.1	-525.2	-341.2	-157.3	26.6	210.6	394.5	578.4	762.4	946.3	1130.2	1314.2	1498.1	1682.0	1866.0	2049.9	2233.8	2428.0

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - Retrofit year + 5 year CASE 1										Version	4.5
30 Jul 2004 11:04																														Date	July 2004
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT											
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	1404.6	1404.6	MW	Installed costs	354.7	337.7		Fuel	132.9	132.9		Discount rate	10.0	%	Emission avoidance cost	82.770	\$/t CO2														
Net power output	784.8	625.9	MW	Contingencies	10.0%	10.0%		Maintenance	7.9	15.4		Load factor	90.0	90.0 %	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																
CO2 output	293.0	41.9	t/h	Owners costs	7.0%	7.0%		Chemicals + consumables	1.7	2.4		Fuel price	3.00	3.00 \$/GJ	NPV	0.00	M\$														
Solid waste output	0.00	0.04	t/h	Retrofit escalation basis year	24.8	23.6		Insurance and local taxes	7.1	13.8		CO2 price	82.8	\$/t	IRR	10.00%															
CO2 emissions	373	67	g/kWh	Retrofit expenditure escalation yearly	15	0%		Waste disposal	0.0	0.1		Waste disposal cost	0.0	307.5 \$/t																	
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Retrofit Expenditure escalation				Number of operators																			
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%			Operating labour	1.2	1.8		Insurance and local taxes	2%	2% of installed cost/y																	
Electricity cost	2.997		c/kWh	Total capital cost	415.0	395.1						Cost per operator	10	15																	
				Working Capital				Decommissioning cost	0	0		Administration	56%	56% of operators cost	Breakdown of c/kWh cost																
Retrofit year (n)		15	-	Chemicals storage	0.2	0.2						Fuel storage	0	0 days	Fuel		59.92%														
Retrofit Expenditure year (n-2)		0%	-	Fuel storage	0.0	0.0						Chemicals storage	30	30 days	Capital		30.27%														
Retrofit Expenditure year (n-1)		40%	-	Total working capital	0.2	0.2						Start up time	3	3 months	Other costs		9.81%														
Retrofit Expenditure year (n)		60%	-									Retrofit down time	1	1 months																	
												Load factor, remainder year 1	90	90 %																	
CASH FLOW ANALYSIS																															
Million \$																															
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%		
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884		
Expenditure Factor		0%	40%	60%												0%	40%	60%													
Revenues																															
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	110.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9	147.9		
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	93.8	125.1	125.1	125.1	125.1	125.1	125.1	125.1	125.1	125.1	125.1		
Operating Costs																															
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6		
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-10.4	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8		
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8		
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-1.6	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1		
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1		
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8		
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-158.0	-237.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Decommissioning Cost																															
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-109.0	-182.8	87.2	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	0.4		
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	11.5	60.5	109.5	158.5	207.5	98.5	-94.3	-7.2	114.6	236.3	358.0	479.8	601.5	723.3	845.0	966.7	1088.5			

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - Retrofit year + 5 year CASE 2.1										Version	4.5
30 Jul 2004 11:04																														Date	July 2004
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT											
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	1404.6	1672.4	MW	Installed costs	354.7	486.4												Discount rate	10.0	%	Emission avoidance cost	107.494	\$/t CO2								
Net power output	784.8	693.7	MW	Contingencies	10.0%	10.0%												Load factor	90.0	90.0	%	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>									
CO2 output	293.0	50.1	t/h	Owners costs	7.0%	7.0%												Fuel price	3.00	3.00	\$/GJ	NPV	0.00	M\$							
Solid waste output	0.00	0.01	t/h	Retrofit escalation basis year	24.8	34.0												CO2 price	107.5	107.5	\$/t	IRR		10.00%							
CO2 emissions	373	72	g/kWh	Retrofit expenditure escalation yearly		0%												Waste disposal cost	0.0	307.5	\$/t										
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Retrofit Expenditure escalation				0%																			
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation		0.0%												Insurance and local taxes	2%	2%	of installed costly										
Electricity cost	2.997		c/kWh	Total capital cost	415.0	569.1												Number of operators	10	20		Breakdown of c/kWh cost									
Retrofit year (n)		15	-	Working Capital														Cost per operator	75.0	75.0	\$/ky	Fuel		58.55%							
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	1.0												Administration	56%	56%	of operators cost	Capital		31.04%							
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0												Fuel storage	0	0	days	Other costs		10.41%							
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0												Start up time	3	3	months										
																		Retrofit down time		1	months										
																		Load factor, remainder year 1	90	90	%										
CASH FLOW ANALYSIS																															
Million \$																															
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%		
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884		
Expenditure Factor		0%	40%	60%													0%	40%	60%												
Revenues																															
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	122.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9	163.9		
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	132.7	177.0	177.0	177.0	177.0	177.0	177.0	177.0	177.0	177.0	177.0		
Operating Costs																															
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-106.8	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4	-142.4		
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.6	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8		
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3		
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0		
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8		
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-227.6	-341.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Decommissioning Cost																													0.0		
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-178.6	-297.2	108.6	152.5	152.5	152.5	152.5	152.5	152.5	152.5	152.5			
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	11.5	60.5	109.5	158.5	207.5	28.8	-268.4	-159.8	-7.3	145.3	297.8	450.4	602.9	755.4	908.0	1060.5	1213.0			

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Retrofit year + 5 year CASE 3.1

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT							
Production				Capital Cost	Million \$	Million \$	Operating Costs	MM \$/year	MM \$/year	Economic parameters							Results summary												
Fuel feedrate	1404.6	2121.2	MW	Installed costs	354.7	822.4	Fuel	132.9	100.3	Discount rate	10.0	%				Emission avoidance cost	159.710	\$/t CO2											
Net power output	784.8	751.2	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	31.8	Load factor	90.0	85.0 %				(Note: Type 'Tools' Solver' 'Solve' to calculate													
CO2 output	293.0	97.6	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	4.6	Fuel price	3.00	1.50 \$/GJ				the CO2 emission avoidance cost that gives a zero NPV)													
Solid waste output	0.00	1.70	t/h	Retrofit escalation basis year	24.8	57.6	Insurance and local taxes	7.1	23.5	CO2 price	159.7	159.7 \$/t				NPV	0.00	M\$											
CO2 emissions	373	130	g/kWh	Retrofit expenditure escalation yearly	14	0%	Waste disposal	0.0	2.7	Waste disposal cost	0.0	184.5 \$/t				IRR	10.00%												
Reference plant data	<i>For calculation of cost of emission avoidance</i>			Retrofit Expenditure escalation	0.0%		Operating labour	1.2	3.5	Insurance and local taxes	2%	2% of installed cost/y																	
CO2 emissions	373		g/kWh	Total capital cost	415.0	962.2				Number of operators	10	30																	
Electricity cost	2.997		c/kWh	Working Capital			Decommissioning cost	0	0	Cost per operator	75.0	75.0 \$/ky				Breakdown of c/kWh cost													
Retrofit year (n)		15	-	Chemicals storage	0.2	0.4				Administration	56%	56% of operators cost				Fuel		52.68%											
Retrofit Expenditure year (n-2)		20%	-	Fuel storage	0.0	9.7				Fuel storage	0	30 days				Capital		36.13%											
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	10.1				Start up time	3	3 months				Other costs		11.18%											
Retrofit Expenditure year (n)		35%	-							Retrofit down time	1	1 months																	
										Load factor, remainder year 1	90	60 %																	
CASH FLOW ANALYSIS																													
Million \$																													
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor		0%	40%	60%													20%	45%	35%										
Revenues																													
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	88.8	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7	167.7
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	115.1	217.4	217.4	217.4	217.4	217.4	217.4	217.4	217.4	217.4	217.4
Operating Costs																													
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-45.2	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3	-85.3
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-14.3	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1	-27.1
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-2.1	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9	-3.9
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5	-23.5
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-192.4	-433.0	-336.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-10.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																													
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-143.4	-384.0	-292.5	103.9	239.5	239.5	239.5	239.5	239.5	239.5	239.5	
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	11.5	60.5	109.5	158.5	15.0	-368.9	-661.5	-557.6	-318.1	-78.7	160.8	400.3	639.7	879.2	1118.7	1358.1	1597.6	

IEA GREENHOUSE GAS R&D PROGRAMME

Cost Evaluation - Retrofit year + 5 year CASE 3.2

30 Jul 2004 11:04

	REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			REFEREN			RETROFIT			RESULTS SUMMARY				
Production	Million \$	Million \$	MM \$/year	MM \$/year	Economic parameters	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year	MM \$/year		
Fuel feedrate	1404.6	2306.4	MW	Installed costs	354.7	1020.7	Operating Costs at 100% load factor	Fuel	132.9	109.1	Discount rate	10.0	%	Results summary	Emission avoidance cost	203.562	\$/t CO2												
Net power output	784.8	774.6	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	36.2	Load factor	90.0	85.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate															
CO2 output	293.0	108.5	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	5.2	Fuel price	3.00	1.50	\$/GJ	the CO2 emission avoidance cost that gives a zero NPV)															
Solid waste output	0.00	1.84	t/h	Retrofit escalation basis year	24.8	71.4	Insurance and local taxes	7.1	27.5	CO2 price	203.6	203.6	\$/t	NPV															
CO2 emissions	373	140	g/kWh	Retrofit expenditure escalation yearly	14	0%	Waste disposal	0.0	3.0	Waste disposal cost	0.0	184.5	\$/t	IRR															
Reference plant data	For calculation of cost of emission avoidance			Retrofit Expenditure escalation	0.0%		Operating labour	1.2	4.7	Insurance and local taxes	2%	2%	of installed cost/y																
CO2 emissions	373		g/kWh	Total capital cost	415.0	1194.2	Number of operators	10	40	Cost per operator	75.0	75.0	\$/ky	Breakdown of c/kWh cost															
Electricity cost	2.997		c/kWh	Working Capital			Administration	56%	56%	of operators cost				Fuel															
Retrofit year (n)		15	-	Chemicals storage	0.2	0.5	Fuel storage	0	30	days				Capital															
Retrofit Expenditure year (n-2)		20%	-	Fuel storage	0.0	10.5	Start up time	3	3	months				Other costs															
Retrofit Expenditure year (n-1)		45%	-	Total working capital	0.2	11.1	Retrofit down time		1	months																			
Retrofit Expenditure year (n)		35%	-				Load factor, remainder year 1	90	60	%																			
CASH FLOW ANALYSIS																													
Million \$																													
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	83%	45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7227	3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor		0%	40%	60%														20%	45%	35%									
Revenues																													
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	91.5	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9	172.9
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	144.9	273.8	273.8	273.8	273.8	273.8	273.8	273.8	273.8	273.8	273.8
Operating Costs																													
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-49.1	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7	-92.7
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-16.3	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7	-4.7
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-2.3	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4	-4.4
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5	-27.5
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-238.8	-537.4	-418.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																													
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-189.8	-488.4	-373.7	124.2	284.0	284.0	284.0	284.0	284.0	284.0	284.0	284.0
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	11.5	60.5	109.5	158.5	-31.4	-519.7	-893.5	-769.3	-485.2	-201.2	82.9	366.9	651.0	935.0	1219.1	1503.1	1787.1	1798.4

Appendix 8

Task 1 – Same Output Retrofit

Task 1 – Same Output Retrofit

Introduction

The common basis for the study is the capture of 85% of carbon in the feedstock. This results in a reduced and widely variable net output of electricity across the cases, as compared to the reference plant, from less than 2% to more than 25%.

Some operators might be interested in an option to capture 85% of the carbon and at the same time retain the original plant output. This may be required to maintain installed nameplate capacity at specific parts of the network for regulatory compliance, or it could be to comply with an existing off-take agreement.

In order to achieve this it is necessary in most cases to install supplementary combined cycle power plants. These would operate, in the same mode as the refuelled CCPP with 85% of the carbon in the fuel captured as CO₂. The closest fit gas turbine is chosen for each case to generate a total plant output as close as possible to the reference plant.

Process Description and Performances

A breakdown of the additional power generation required to bring each of the capture cases back to the reference case output is given in table 1 below. A summary of the revised plant performances and costs are given in tables 2, 3 and 4 below with further details at the end of this appendix.

Table 1 Additional Power Requirements

Additional Power Requirements	Ref.	1	2-1	2-2	3-1	3-2	
Combined Cycle Power Plant Net Electrical Output	784.8	664.3	809.6	764.3	806.0	774.3	MWe
CO ₂ Capture Plant Auxiliary Power Consumption	0.0	-38.5	-158.9	-168.0	-244.9	-269.1	MWe
CO ₂ Capture Plant Power Production	0.0	0.0	43.0	71.1	190.1	269.4	MWe
Total Overall Plant Net Power Output	784.8	625.9	693.7	667.4	751.2	774.6	MWe
Additional Power Required	0	158.9	91.1	117.4	33.6	10.2	MWe

Case 1

For Case 1 an additional 159 MWe is required to bring the total output up to that of the Reference Case. The best fit for this additional output is to add a GE 9EA in combined cycle. This operates on natural gas in parallel to the original CCPP. The flue gases are routed to additional Acid Gas Removal trains and the CO₂ is combined with that from the original CCPP and sent to an increased capacity CO₂ Compression and Drying section. The throughput increase required in the Acid Gas Removal and CO₂ Compression and Drying units is 27%.

Case 2-1

In Case 2-1 an additional 91 MWe is required to bring the output to that of the reference plant. CO₂ free fuel gas feeds a supplementary GE 6FA, operating in combined cycle to generate this extra power. The GE 6 FA is well proven operating in syngas. The entire fuel generation part of the flowsheet (encompassing everything apart from the CCPP) is increased to generate the extra 16% fuel gas.

Case 2-2

Case 2-2 requires extra output of 117 MWe. The best fit turbine is a GE 9EA operating again in combined cycle. The GE 9 EA is well proven operating in syngas. Similar areas of the flowsheet to Case 2-1 increase in throughput to generate the CO₂ free fuel gas required. The required increased output of CO₂ free fuel gas is 27%.

Case 3-1

Case 3-1 has a shortfall of 34 MWe against the reference case. In this case the extra power is generated by an additional GE 6B gas turbine in combined cycle. This is added to the existing GE 6B gas turbines used in the Power Block for this case. The additional gas turbine also superheats the additional steam, generated by the increased fuel flow in the enlarged capture plant.

The fuel throughput increase required in this case is 10% over the original flowscheme. The entire flowscheme is increased to create this higher fuel requirement, with the exception of the original Power Block, which has an additional gas turbine added, and the CCPP, which remains the same as it, does in all the cases.

Case 3-2

The additional power required for Case 3-2 is only 10 MW. This is generated by 'stretching' the original flowscheme by increased supplementary firing in the HRSG of the Power Block. This extra duct burning actually reduces the surface required in the Power Block HRSG by improving the temperature driving force in the coils.

The fuel generation part of the plant is increased in throughput by 1%.

Table 2 – Plant Power Output (Reference Case Output)

Plant Power Output	Ref.	1	2-1	2-2	3-1	3-2	
Combined Cycle Power Plant Net Electrical Output	784.8	664.3	809.6	764.3	806.0	774.3	MWe
Revised Capture Plant Auxiliary Power Consumption	0.0	-48.8	-177.5	-194.2	-268.4	-272.0	MWe
Revised Capture Plant Power Production	0.0	164.7	154.8	235.3	256.3	281.7	MWe
Revised Overall Plant Net Power Output	784.8	780.2	786.9	805.4	793.9	784.0	MWe
Difference from Reference Plant	0	-0.6	0.3	2.6	1.2	-0.1	%

Table 3 - Plant Performance (Reference Case Output)

Plant Performance	Ref.	1	2-1	2-2	3-1	3-2	
Revised Overall Plant Fuel Consumption (LHV)	1404.6	1780.1	1940.7	2123.1	2324.6	2331.6	MWth
Fuel Gas to Combined Cycle Power Plant	1404.6	1404.6	1672.4	1671.0	2121.2	2306.4	MWth
Revised Overall Plant CO ₂ emissions	2.31	0.42	0.46	0.5	0.8	0.82	Mt/y
Revised Overall Plant Net Electrical Efficiency	55.9	43.8	40.6	37.9	34.2	33.6	%

Economic Analysis

Table 4 – Additional Capital Expenditures (Reference Case Output)

Additional Capital Expenditures	Ref.	1	2-1	2-2	3-1	3-2	
Additional Capital Costs ¹	-	584	712	978	1045	1210	Million US \$
Specific Total Investment	529	1280	1432	1729	1839	2073	US \$/MWe
CO ₂ Emission	0.373	0.068	0.074	0.078	0.135	0.140	t/MWh
Avoided CO ₂ Emission (% of ref.)	-	81.8	80.2	78.9	63.9	62.5	%
Costs of Avoided CO ₂	-	74.3	98.2	128.9	136.9	167.5	US \$/ton

Notes

1. On top of capital expenditure for reference plant of 415 million US \$
2. Calculated with electricity at 30.0 US \$/MWh

Conclusions

The study demonstrates that the reference case output can be generated with CO₂ capture using additional gas turbines all of which are commercially proven on syngas. In all cases the overall efficiency is reduced. This is because the additional gas turbines are all less efficient than the GE 9FA used in the CCPP. In case 3-2, the reduction in efficiency is very small, because the additional power generation is achieved by a small, 1%, increase in capture plant capacity. No additional gas turbines are added and the plant configuration is not changed.

The reduced efficiency means that in all cases the CO₂ emitted per MWh increases and the increased throughput means that the avoided CO₂ when compared with the reference plant is also reduced.

The specific investment costs differ marginally (within 1%) for all cases compared to the original calculations.

IEA GREENHOUSE GAS R&D PROGRAMME															Cost Evaluation - CASE 1															Version	4.5				
29 Jul 2004 12:40																														Date	July 2004				
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				RESULTS SUMMARY			
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary																			
Fuel feedrate	1404.6	1780.1	MW	Installed costs	354.7	499.2	Fuel	132.9	168.4	Discount rate	10.0	%	Emission avoidance cost	74.307	\$/t CO2																				
Net power output	784.8	780.2	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	19.0	Load factor	90.0	%	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)																						
CO2 output	293.0	53.2	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	2.4	Fuel price	3.00	\$/GJ	NPV	0.00	M\$																				
Solid waste output	0.00	0.06	t/h	Retrofit escalation basis year	24.8	34.9	Insurance and local taxes	7.1	17.1	CO2 price	74.3	\$/t	IRR	10.00%																					
CO2 emissions	373	68	g/kWh	Retrofit expenditure escalation yearly	10	0%	Waste disposal	0.0	0.2	Waste disposal cost	0.0	307.5	\$/t																						
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Retrofit Expenditure escalation				Number of operators																							
CO2 emissions	373		g/kWh	Retrofit Expenditure escalation	0.0%		Operating labour	1.2	1.8	Insurance and local taxes	2%	2%	of installed cost/y																						
Electricity cost	2.997		c/kWh	Total capital cost	415.0	584.0	Decommissioning cost				0				0																				
Retrofit year (n)		10	-	Working Capital				Decommissioning cost				0				0																			
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	0.2																													
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0																													
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	0.2																													
CASH FLOW ANALYSIS																																			
Million \$																																			
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033						
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26						
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%						
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884					
Expenditure Factor		0%	40%	60%									0%	40%	60%																				
Revenues																																			
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	138.3	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4	184.4					
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	104.6	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5	139.5					
Operating Costs																																			
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-113.7	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6	-151.6					
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-12.8	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1					
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8	-1.8					
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-1.6	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1	-2.1					
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1					
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1	-17.1					
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-233.6	-350.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Decommissioning Cost																																			
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-184.6	-306.2	95.6	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	134.1	0.4					
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-222.1	-528.3	-432.7	-298.6	-164.5	-30.5	103.6	237.7	371.7	505.8	639.9	773.9	908.0	1042.0	1176.1	1310.2	1444.2	1444.6						

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - CASE 2.1										Version	4.5				
29 Jul 2004 12:40																														Date	July 2004				
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				RESULTS SUMMARY			
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary																			
Fuel feedrate	1404.6	1940.7	MW	Installed costs	354.7	608.6	Fuel	132.9	183.6	Discount rate	10.0	%	Emission avoidance cost	98.189	\$/t CO2																				
Net power output	784.8	786.9	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	21.4	Load factor	90.0	%	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																						
CO2 output	293.0	58.1	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	11.1	Fuel price	3.00	\$/GJ	NPV	0.00	M\$																				
Solid waste output	0.00	0.01	t/h	Retrofit escalation basis year	24.8	42.6	Insurance and local taxes	7.1	19.3	CO2 price	98.2	\$/t	IRR	10.00%																					
CO2 emissions	373	74	g/kWh	Retrofit expenditure escalation yearly	10	0%	Waste disposal	0.0	0.0	Waste disposal cost	0.0	307.5 \$/t																							
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Total capital cost				Total working capital				Decommissioning cost				Breakdown of c/kWh cost															
CO2 emissions	373		g/kWh	Chemicals storage	0.2	1.0	Fuel storage	0.0	0.0	Number of operators	10	20	Fuel	54	87%																				
Electricity cost	2.997		c/kWh	Retrofit expenditure escalation	0.0	0.0	Chemicals storage	0.2	1.0	Cost per operator	75.0	75.0 \$/ky	Capital	33	54%																				
Retrofit year (n)		10	-	Working Capital			Fuel storage	0.0	0.0	Administration	56%	56% of operators cost	Other costs	11	59%																				
Retrofit Expenditure year (n-2)		0%	-	Total working capital	0.2	1.0	Start up time	3	3 months	Fuel storage	0	0 days																							
Retrofit Expenditure year (n-1)		40%	-				Retrofit down time	1	1 months	Chemicals storage	30	30 days																							
Retrofit Expenditure year (n)		60%	-				Load factor, remainder year 1	90	90 %	Start up time	3	3 months																							

CASH FLOW ANALYSIS																														
Million \$																														
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884
Expenditure Factor		0%	40%	60%									0%	40%	60%															
Revenues																														
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	139.5	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0	186.0
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	136.8	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4	182.4
Operating Costs																														
Fuel		0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-123.9	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2	-165.2
Maintenance		0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-14.4	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3
Labour		0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3
Chemicals & consumables		0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-7.5	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0	-10.0
Waste disposal		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Insurance and local taxes		0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3
Fixed Capital Expenditures		0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-284.8	-427.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Working Capital		0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Decommissioning Cost																														0.0
Total Cash Flow (yearly)		0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-235.8	-383.0	107.8	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	152.3	1.2
Total Cash Flow (cumulated)		0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-273.3	-656.3	-548.5	-396.3	-244.0	-91.7	60.5	212.8	365.1	517.4	669.6	821.9	974.2	1126.5	1278.7	1431.0	1583.3	1584.4

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation - CASE 2.2										Version	4.5				
29 Jul 2004 12:40																														Date	July 2004				
REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				REFEREN				RETROFIT				RESULTS SUMMARY			
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary																			
Fuel feedrate	1404.6	2123.1	MW	Installed costs	354.7	835.7	Fuel	132.9	200.9	Discount rate	10.0	%	Emission avoidance cost	128.935	\$/t CO2																				
Net power output	784.8	805.4	MW	Contingencies	10.0%	10.0%	Maintenance	7.9	26.5	Load factor	90.0	%	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																						
CO2 output	293.0	63.4	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	1.7	10.7	Fuel price	3.00	\$/GJ	NPV	0.00	M\$																				
Solid waste output	0.00	0.01	t/h	Retrofit escalation basis year	24.8	58.5	Insurance and local taxes	7.1	23.8	CO2 price	128.9	\$/t	IRR	10.00%																					
CO2 emissions	373	79	g/kWh	Retrofit expenditure escalation yearly	10	0%	Waste disposal	0.0	0.0	Waste disposal cost	0.0	307.5	\$/t																						
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Total capital cost				415.0	977.8	Decommissioning cost				0	0	Breakdown of c/kWh cost															
CO2 emissions	373		g/kWh	Chemicals storage	0.2	1.0	Fuel storage	0.0	0.0	Number of operators	10	30	Fuel	52.53%																					
Electricity cost	2.997		c/kWh	Retrofit expenditure escalation	0.0%	0.0%	Total working capital	0.2	1.0	Cost per operator	75.0	75.0	Administration	56%	56%																				
Retrofit year (n)		10	-	Working Capital						Fuel storage	0	0	days	52.53%																					
Retrofit Expenditure year (n-2)		0%	-	Chemicals storage	0.2	1.0				Chemicals storage	30	30	days	35.54%																					
Retrofit Expenditure year (n-1)		40%	-	Fuel storage	0.0	0.0				Start up time	3	3	months	11.93%																					
Retrofit Expenditure year (n)		60%	-	Total working capital	0.2	1.0				Retrofit down time	1	1	months																						
										Load factor, remainder year 1	90	90	%																						
CASH FLOW ANALYSIS																																			
Million \$																																			
Year	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033						
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26						
Load Factor				68%	90%	90%	90%	90%	90%	90%	90%	90%	83%	68%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%						
Equivalent yearly hours				5913	7884	7884	7884	7884	7884	7884	7884	7884	7227	5913	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884	7884					
Expenditure Factor		0%	40%	60%									0%	40%	60%																				
Revenues																																			
Electricity				139.1	185.5	185.5	185.5	185.5	185.5	185.5	185.5	185.5	170.0	142.7	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3	190.3					
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	180.9	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2	241.2					
Operating Costs																																			
Fuel	0.0	0.0	0.0	-89.7	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-119.6	-109.6	-135.6	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8	-180.8					
Maintenance	0.0	0.0	0.0	-5.3	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-6.5	-17.9	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8					
Labour	0.0	0.0	0.0	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-1.2	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5					
Chemicals & consumables	0.0	0.0	0.0	-1.1	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.5	-1.4	-7.2	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7	-9.7					
Waste disposal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Insurance and local taxes	0.0	0.0	0.0	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8	-23.8					
Fixed Capital Expenditures	0.0	-166.0	-249.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-391.1	-586.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Working Capital	0.0	0.0	0.0	-0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
Decommissioning Cost																																			
Total Cash Flow (yearly)	0.0	-166.0	-249.0	34.5	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	-342.1	-542.4	134.6	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	189.9	1.1					
Total Cash Flow (cumulated)	0.0	-166.0	-415.0	-380.5	-331.5	-282.5	-233.5	-184.5	-135.5	-86.5	-37.5	-379.6	-922.0	-787.4	-597.5	-407.6	-217.7	-27.9	162.0	351.9	541.8	731.7	921.6	1111.5	1301.4	1491.3	1681.2	1871.1	1872.2						

Appendix 9

Task 3 – Pre-Implementation Retrofit

Task 3 - Pre-Implementation Retrofit

Introduction

A major problem facing an intended new power plant investor is the choice between a plant design that cannot capture CO₂ and one that can only operate with CO₂ capture. With the former, he will face penalties under any carbon tax levy for which his only recourse is to pay. The latter choice will give him an uncompetitive plant for today that produces by-product CO₂ to no benefit.

The ideal option would be a plant designed to be capable of operating efficiently with or without CO₂ capture, dependant on the prevailing commercial conditions. However, it is generally perceived that a plant capable of capturing CO₂ cannot be operated efficiently when operating without CO₂ capture and existing IGCC plant design require major and costly changes to allow them to capture CO₂. Previous work by Jacobs demonstrates that a plant with pre-investment for future CO₂ capture could be commercially competitive if full advantage is taken of the non-captured CO₂ in increasing capture plant internal power output and reducing the parasitic power load by removing the requirement to inject nitrogen.

This option can be made available using the designs for Cases 3-1 and 3-2, renamed Cases 3-3 and 3-4 respectively. These designs could be operated to advantage without CO₂ capture. The fuel gas diluent of nitrogen and water vapour, both of which are energy intensive to use, could be replaced simply by leaving the CO₂ in the fuel gas. Here it acts as the diluent and is eventually discharged up the stacks of the CCPP and Power Block.

Process Description and Performances

Case 3-3

The flowscheme of the fuel production plant (rather than a capture plant) is very similar to the flowscheme for the capture plant. The three differences are that the Acid Gas Removal unit does not remove CO₂ from the fuel gas, the CO₂ Compression and Drying section is omitted as are the large nitrogen compressors from the Fuel Gas Conditioning section.

The equipment to remove CO₂ from the fuel gas can easily be added to the Acid Gas Removal unit as can the equipment for CO₂ Compression and Drying and the nitrogen compressors required for the Fuel Gas Conditioning section.

The gas leaving the Acid Gas Removal section is therefore sulphur free, but rich in CO₂. The Gas Conditioning section simply heats the gas using heat recovered from the Cooling section. There is no need for any nitrogen addition as this gas is in fact ideal for feeding to the CCPP, having a flame temperature coincident with 25ppm NO_x.

The hot syngas passes to the Power Block and the CCPP as in the CO₂ removal case.

One difference to the CO₂ removal case is that the Power Block in this case requires two GE 6B gas turbines to make best use of the stream generated from waste heat recovered in the Cooling section. The power generation in this case is therefore significantly larger than the CO₂ removal case reported, due to the existence of the additional gas turbine together with the additional fuel gas mass flow achieved using CO₂ as a diluent rather than nitrogen. Therefore the output from the gas turbines in

both the Power Block and the CCPP are increased. There is also lower internal power consumption as there is no need to compress CO₂ or large quantities of nitrogen.

A summary of the plant performance and costs is given in tables 1 and 2 below and at the end of this appendix.

Case 3-4

This case is essentially the same as case 3-3 although with the remote turbine there is no preheating of the fuel to the CCPP. Instead this is achieved using steam from the HRSG of the CCPP. The steam is condensed and returned to the HRSG as there is no need for additional diluent for the gas turbine as there was in the CO₂ removal case.

The Gas Conditioning block in this case only preheats the Power Block fuel as these are local to the fuel gas generation plant.

The Power Block in this case has the same number of gas turbines as the CO₂ removal case, so there is no increased output due to this although all the other factors mentioned above for case 3-3 also apply to this case as well.

A summary of the plant performance and costs is given in tables 1 and 2 below and at the end of this appendix.

Table 1 – Plant Performance Output (No CO₂ Capture)

Plant Performance Output	Ref.	3-3	3-4	
Combined Cycle Power Plant Net Electrical Output	784.8	846.6	820.8	MWe
Fuel Plant Auxiliary Power Consumption	-	-154.3	-158.9	MWe
Fuel Plant Power Production	-	281.3	270.7	MWe
Overall Plant Net Power Output	784.8	973.6	932.6	MWe
Total Plant Fuel Consumption (LHV)	1404.6	2388.7	2390.7	MWth
Fuel Gas to Combined Cycle Power Plant	1404.6	1478.8	1406.3	MWth
Overall Plant Net Electrical Efficiency	55.9	40.8	39.1	%

The heat rate of the gas turbine when operating on fuel gas diluted primarily with CO₂ is higher than operating on syngas diluted primarily with nitrogen. This is because the higher mass flow of fuel gas requires a reduced firing temperature to avoid overloading the gas turbine shaft.

Economic Analysis

Table 2 – Additional Capital Expenditure (No CO₂ Capture)

Additional Capital Expenditure	Ref.	3-3	3-4	
Additional Capital Costs ¹	-	949	1102	Million US \$
Specific Total Investment	529	1401	1627	US \$/MWe
Costs of Electricity	30.3	44.4	49.8	US \$/MWh

Notes

1. On top of capital expenditure for reference plant of 415 million USD

Conclusions

A fuel plant can be built which is CO₂ capture ready and used to refuel an existing gas turbine at similar efficiencies and costs to a traditional IGCC without the ability to capture CO₂. The prices for natural gas and coal as used in the study means that the cost of electricity produced by such a plant is not competitive with electricity produced from natural gas in a combined cycle. However, there are some parts of the world, most notably North America where the price differential between coal (or petroleum coke) and natural gas would mean that refuelling a natural gas combined cycle with syngas are now commercially attractive.

Despite the lower heat rate of the gas turbine when operating on CO₂ contain syngas, the power output of the CCPP is increased and overall efficiency is in line with commercial IGCC's operating on solid feedstock.

Just as in the CO₂ capture cases 3-1 and 3-2, the remote fuel plant, case 3-4 is less efficient than the local fuel plant. This is because power cannot be recovered from the expander, as the fuel gas is piped at high pressure and also heat from the fuel plant cannot be used to preheat the fuel gas to the CCPP. This function is carried out by using steam taken from the HRSG of the CCPP, which reduces the overall output of the CCPP when compared with the local case.

29 Jul 2004 14:41

Production	REFERENCE		RETROFIT		Capital Cost	REFEREN		RETROFIT		Operating Costs at 100% load factor	REFERENCE		RETROFIT		Economic parameters	REFERE		RETROFIT		Results summary
	MM \$/year	MM \$/year	MM \$/year	MM \$/year		MM \$/year	MM \$/year	MM \$/year	MM \$/year		MM \$/year	MM \$/year	MM \$/year	MM \$/year		MM \$/year	MM \$/year			
Fuel feedrate	2388.7	0.0	MW		Installed costs	1165.5	0.0			Fuel	113.0	0.0	Discount rate	10.0	%	Emission avoidance cost	167.527	\$/t CO2		
Net power output	973.6	0.0	MW		Contingencies	10.0%	10.0%			Maintenance	31.6	0.0	Load factor	85.0	0.1 %	(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)				
CO2 output	0.0	0.0	t/h		Owners costs	7.0%	7.0%			Chemicals + consumables	4.2	0.0	Fuel price	1.50	1.50 \$/GJ	NPV	0.00	M\$		
Solid waste output	1.70	1.70	t/h		Retrofit escalation basis year	81.6	0.0			Insurance and local taxes	23.3	0.0	CO2 price	167.5	167.5 \$/t	IRR	10.00%			
CO2 emissions	-	-	g/kWh		Retrofit Expenditure escalation yearly		9			Waste disposal	2.7	0.0	Waste disposal cost	184.5	184.5 \$/t					
Reference plant data	For calculation of cost of emission avoidan				Retrofit Expenditure escalation	0%				Operating labour	3.5	0.0	Insurance and local taxes	2%	2%	of installed costly				
CO2 emissions	-	-	g/kWh		Retrofit Expenditure escalation	0.0%							Number of operators	30	30					
Electricity cost	4.442		c/kWh		Total capital cost	1363.6	0.0			Decommissioning cost	0	0	Cost per operator	75.0	75.0 \$/ky					
Retrofit year (n)	100	-			Working Capital								Administration	56%	56%	of operators cost				
Retrofit Expenditure year (n-2)	20%	-			Chemicals storage	0.4	0.0						Fuel storage	30	30	days				
Retrofit Expenditure year (n-1)	45%	-			Fuel storage	10.9	0.0						Chemicals storage	30	30	days				
Retrofit Expenditure year (n)	35%	-			Total working capital	11.3	0.0						Start up time	3	3	months				
													Retrofit down time	1	1	months				
													Load factor, remainder year	60	60	%				

Breakdown of c/kWh cost	
Fuel	29.82%
Capital	51.25%
Other costs	18.92%

CASH FLOW ANALYSIS																													
Million \$																													
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Load Factor				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
Equivalent yearly hours				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
Expenditure Factor		0%	40%	60%																									
Revenues																													
Electricity				170.5	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0	322.0
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Operating Costs																													
Fuel	0.0	0.0	0.0	-50.8	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-96.0	-624.1
Maintenance	0.0	0.0	0.0	-14.2	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-26.9	-174.8
Labour	0.0	0.0	0.0	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-23.9
Chemicals & consumables	0.0	0.0	0.0	-1.9	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-23.1
Waste disposal	0.0	0.0	0.0	-1.2	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-2.3	-15.2
Insurance and local taxes	0.0	0.0	0.0	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-23.3	-159.0
Fixed Capital Expenditures	0.0	-545.5	-818.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-1065.5
Working Capital	0.0	0.0	0.0	-11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-7.0
Decommissioning Cost																													0
Total Cash Flow (yearly)	0.0	-545.5	-818.2	64.1	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	166.4	11.3
Total Cash Flow (cumulated)	0.0	-545.5	-1363.6	-1299.5	-1133.1	-966.8	-800.4	-634.0	-467.6	-301.3	-134.9	31.5	197.9	364.2	530.6	697.0	863.4	1029.7	1196.1	1362.5	1528.8	1695.2	1861.6	2028.0	2194.3	2360.7	2527.1	2693.5	-2092.7

IEA GREENHOUSE GAS R&D PROGRAMME																				Cost Evaluation Case 3.4										Version	4.5
29 Jul 2004 14:41																														Date	: July 2004
REFERENCE		RETROFIT		REFERENCE		RETROFIT		REFERENCE		RETROFIT		REFERENCE		RETROFIT		REFERENCE		RETROFIT													
Production				Capital Cost				Operating Costs at 100% load factor				Economic parameters				Results summary															
Fuel feedrate	2390.7	0.0	MW	Installed costs	1296.8	0.0	Fuel	113.1	0.0	Discount rate	10.0	%	Emission avoidance cost	187.527	\$/t CO2																
Net power output	932.6	0.0	MW	Contingencies	10.0%	10.0%	Maintenance	34.6	0.0	Load factor	85.0	0.1	%	<i>(Note: Type 'Tools' Solver' 'Solve' to calculate the CO2 emission avoidance cost that gives a zero NPV)</i>																	
CO2 output	0.0	0.0	t/h	Owners costs	7.0%	7.0%	Chemicals + consumables	4.3	0.0	Fuel price	1.50	1.50	\$/GJ	NPV	0.00	M\$															
Solid waste output	1.84	1.70	t/h	Retrofit escalation basis year	9		Insurance and local taxes	25.9	0.0	CO2 price	167.5	167.5	\$/t	IRR	10.00%																
CO2 emissions	-	-	g/kWh	Retrofit Expenditure escalation yearly	0%		Waste disposal	3.0	0.0	Waste disposal cost	184.5	184.5	\$/t																		
Reference plant data				<i>For calculation of cost of emission avoidance</i>				Operating labour				Number of operators																			
CO2 emissions	-		g/kWh	Retrofit Expenditure escalation	0.0%		Waste disposal	3.0	0.0	Insurance and local taxes	2%	2%	of installed cost/y																		
Electricity cost	4.984		c/kWh	Total capital cost	1517.2	0.0	Operating labour	3.5	0.0	Number of operators	30	30																			
Retrofit year (n)		100	-	Working Capital			Decommissioning cost	0	0	Cost per operator	75.0	75.0	\$/y																		
Retrofit Expenditure year (n-2)		20%	-	Chemicals storage	0.4	0.0				Administration	56%	56%	of operators cost																		
Retrofit Expenditure year (n-1)		45%	-	Fuel storage	10.9	0.0				Fuel storage	30	30	days	Breakdown of c/kWh cost																	
Retrofit Expenditure year (n)		35%	-	Total working capital	11.3	0.0				Chemicals storage	30	30	days	Fuel	27.78%																
										Start up time	3	3	months	Capital	53.03%																
										Retrofit down time	1	1	months	Other costs	19.20%																
										Load factor, remainder year	60	60	%																		
CASH FLOW ANALYSIS																															
Million \$																															
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033		
Year	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
Load Factor				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
Equivalent yearly hours				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
Expenditure Factor		0%	40%	60%																											
Revenues																															
Electricity				183.2	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1	346.1		
CO2 revenues(based on power output retrofit case)				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Operating Costs																															
Fuel	0.0	0.0	0.0	-50.9	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1	-96.1		
Maintenance	0.0	0.0	0.0	-15.6	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4	-29.4		
Labour	0.0	0.0	0.0	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5	-3.5		
Chemicals & consumables	0.0	0.0	0.0	-1.9	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6		
Waste disposal	0.0	0.0	0.0	-1.3	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5	-2.5		
Insurance and local taxes	0.0	0.0	0.0	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9	-25.9		
Fixed Capital Expenditures	0.0	-606.9	-910.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Working Capital	0.0	0.0	0.0	-11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Decommissioning Cost																													0.0		
Total Cash Flow (yearly)	0.0	-606.9	-910.3	72.7	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	185.0	11.3		
Total Cash Flow (cumulated)	0.0	-606.9	-1517.2	-1444.5	-1259.5	-1074.6	-889.6	-704.6	-519.6	-334.7	-149.7	35.3	220.3	405.2	590.2	775.2	960.2	1145.1	1330.1	1515.1	1700.1	1885.0	2070.0	2255.0	2440.0	2624.9	2809.9	2994.9	3006.2		