



The IEAGHG Power Plant Assessment Program (PPAP)

Development and testing June 2002 –October 2005

**Report Number 2005/7
December 2005**

*This document has been prepared for the Executive Committee of the Programme.
It is not a publication of the Operating Agent, International Energy Agency or its Secretariat.*



IEA GHG POWER PLANT ASSESSMENT PROGRAM FOR NOVEL CO₂ CAPTURING ELECTRICITY GENERATING PROCESSES

Background to the study

The IEA Greenhouse gas R&D programme has conducted many studies on CO₂ capture from large power stations. Such studies are normally conducted by an experienced contractor and typically cost upwards of £40,000. In order to perform such studies leading to a capital costs estimate within +30% it is necessary to have a reasonably detailed description of the process and all of the main equipment which is required. In addition the contractor needs to have a reliable database of cost information on the equipment. From time to time novel schemes are put forward but detailed evaluation is inhibited by the high cost of a full study. Furthermore factors other than cost may be important in determining how interesting a novel system is and it may be difficult to predict the cost of exotic equipment. IEAGHG thus developed a simple assessment program in order to be able to carry out a first screening of novel process without incurring large costs. This report summarises the work which has been done on the development of this computer program and the experience with using it on a number of novel schemes.

Approach adopted

The program was written in Excel using a consultant from CRE, a consultancy company based in the UK. Testing of the program and a number of process evaluations were carried out by a small independent consultancy, GasConsult, based in Reading UK.

Results and Discussion

The Power Plant Assessment Program (PPAP) was first completed in April 2002. It was used on several processes including conventional capture processes in order to test and calibrate it. A number of revisions were made and additional processes were evaluated to check how the program performed. A major change was to make it possible to input heat and material balance information produced by external process simulators as an alternative to relying on the rather simple routines in PPAP. The tool has been useful in gaining insight into the merits of novel processes and has proved useful in discussions with process developers. Simple evaluations leading to a consistent analysis of the performance and risks of a novel process can be carried out by experienced process engineers at commercial rates at a cost of £2000-£4000.



The program uses a weighted multi-criteria analysis to take into account factors other than electricity price in assessing the performance of CO₂ capturing power plant. It also includes a simple but systematic evaluation of the risks which could be involved in developing each technology. The analysis enables a simple strategic view to be formed of the competing novel technologies and also appears to assist process developers in better appreciation of the main barriers to successful commercial development in a competitive world.

Major Conclusions

There are factors relating to CO₂ capturing power plant which cannot easily be expressed in purely monetary terms. Multi-criteria analysis as applied in PPAP forces consideration of these factors in monetary terms. From the novel processes which have so far been evaluated it would seem that the effect of these factors could range from being almost nothing to the equivalent of several ¢/kWh on the electricity price. The methodology promotes objective comparison of competing processes. Some of the innovative evaluated processes could mount a serious challenge to conventional capture processes. However none of those evaluated so far would appear to have a clear lead.

Recommendations

PPAP has been used exclusively “in house” giving IEAGHG the ability to systematically screen novel capture processes at low cost. The program is only suitable for use by experienced Chemical Engineers preferably with access to process simulation software. It is recommended that the tool be retained for “in house” use in the first screening of novel capture processes as and when these come to our attention prior to making proposals for in depth studies.



The development of a Power Plant Assessment Program (PPAP)

Summary of development work from June 2002 through October 2005

CONTENTS

1	Summary	3
2	Introduction	3
3	Description of the assessment programme.....	4
3.1	Programme platform	4
3.2	Programme capabilities	4
3.3	Use of externally calculated heat and material balance simulation programs	6
3.4	Calibration of the multicriteria analysis	6
3.5	Results of evaluations – the search for a better process.....	8
3.6	Presentation of results	8
3.7	Use of results.....	10
3.8	Specific results	10
3.8.1	Oxy-combustion heating of steam (hybrid processes)	11
3.9	Comparison of specific results.	15
4	PPAP input and output sheets and GasConsult evaluation reports	18
4.1	Using PPAP.....	18
Appendix A Multi criteria questions and answers		
GasConsult reports	- Base cases	
	- CES process	
	- ZESOFc process	
	- CO ₂ acceptor PCDC process	
	- Barium oxide chemical looping process	
	- Israeli-Russian cryogenic process	
PPAP output sheets	- Introduction pages	
	- Base case CCGT	
	- Base case PF coal	
	- Base case air partial oxidation PCDC	
	- PF coal + amine	
	- CES process	
	- ZESOFc process	
	- CO ₂ Acceptor process	
	- Barium oxide chemical looping	
	- Copper oxide chemical looping	
	- Israeli-Russian cryogenic process	

1 Summary

Novel schemes for generating power from fossil fuel with CO₂ capture are underdevelopment and from time to time new schemes are proposed. Development of this sort of technology is both costly and potentially risky. A tool to screen such novel proposals in order to assess their performance and viability on a consistent basis has been developed. The tool uses standardised basic data on costs for common components and performs simplified calculation of basic gas and steam cycles if detailed information is not available. The program also manages the input of the overall heat and mass balance to ensure that losses and auxiliary power consumption are treated on a consistent basis. Where detailed heat and mass balances are available from a simulation program the tool allows key results to be input.

The viability of a proposed technology is assessed in two ways using standardised questions about the state of development of the process, the complexity of the flow scheme, the type of materials, severity of process conditions, safety and environmental aspects. Answering these questions relies to some extent on sound chemical and mechanical engineering judgment and the tool is thus intended for use by professionals experienced in the power generation and heavy chemical process field. The program assesses the overall commercial performance on a multi-criteria scoring basis taking into account, CO₂ emissions, fuel consumption, capital and operating costs as well as the process complexity and severity, construction material and natural resource requirements, development requirements, safety and environmental impacts. Credit is given in the scoring for good performance whilst use of exotic materials, extreme process conditions, dangerous processes or toxic materials is penalised.

The tool also makes an assessment of the likelihood of success on a comparative, (i.e not absolute) scale. This allows results to be plotted in a two dimensional way so that the competitive position of process can be visualised both in terms of likely commercial performance and risk. The tool has been calibrated with several conventional baseline processes both with and without capture. This provides a backdrop on which novel competitors for the next generation of CO₂ capturing power plant can be plotted. The tool is offered as a means of screening out novel processes which have little chance of commercial success and also helping those which are more competitive to understand their potential strengths and weaknesses from a commercial as well as a technical viewpoint.

2 Introduction

Capture of CO₂ from large power plant and its geological sequestration is a technology which has the potential to contribute large reductions in the emission of CO₂. Power is generated on a very large scale, power station operators would be able to manage the operation of the required technology and, although the CO₂ is quite dilute, the quantities available at each emission point give good economies of scale.

There are a host of potential CO₂ capture processes ranging from those based on existing technology to exotic systems using for example chemical looping, high temperature membranes, rocket fuel burning technology and fuel cells. Detailed analysis and comparison of options is expensive and time consuming. The IEA GHG programme has along with other research organisations conducted such assessments for a variety of processes in varying degrees of detail. Cost for such evaluations can range from tens to hundreds of thousands of dollars. Evaluation of more exotic processes which may offer a breakthrough in cost or performance but equally may prove to exhibit serious technical or commercial drawbacks, is inhibited by this high cost of assessment. For this reason IEAGHG R&D programme sought to develop a simpler and cheaper screening system. The latest version of this development and further results are presented in this report.

3 Description of the assessment programme

3.1 Programme platform

The programme is Excel spreadsheet based, and makes extensive use of macros. There are also a number of visual basic routines for thermodynamic property calculations. The input and output are in the form of a set of worksheets through which the user is guided by interlinks. One of the disadvantages of using the Excel platform is the need to update when newer version of Excel are released. This has been partially alleviated in the latest version by having a facility to import data from earlier versions on the basis of data labels. The programme presents results in two output worksheets as well as a worksheet with a complete vector of all inputs and outputs which is useful for detailed comparisons and cross checking.

3.2 Programme capabilities

The programme performs the following main tasks on the basis of the data input by the user.

- Overall heat and material balance reconciliation
- Capital cost estimate
- Thermodynamic calculations of simple steam and gas turbine cycles
- Multicriteria assessments of the proposed process
- Performance and unit cost calculations for the complete power plant

The programme checks for a full reconciliation of the overall fuel and energy flows for the power plant under assessment. This ensures that where fuel and energy is split between different devices and working cycles that the overall energy balance is not violated. Power and heat consumed in auxiliary systems has to be accounted and default values for common items such as mechanical and generator losses are automatically

applied. This ensures that as far as possible every process is evaluated on a common basis and that all assumptions regarding losses and efficiencies are clearly highlighted.

The capital cost estimate is built up partly from standard data held in the programme and partly from external inputs. Costs and scaling factors are available for a variety of standard elements such as gas turbines, heat recovery generators, oxygen plant, combustors and boilers. For other elements the user has to enter appropriate data but can specify and use scaling factors if only a single cost/capacity datum is available. This allows the basic table of standard costs to be built up to include other types of equipment. Multiple trains can be specified for any of the costed units and the programme automatically applies the appropriate scaling factor. Standard costs can be altered by specifying a multiplier but when this is done it is clearly visible on the cost data entry sheet. At present the cost database is populated with a few costs extracted from earlier studies and could benefit from further extension. A systematic way of escalating cost data from the year in which they were estimated to a later reference date would also be useful but is not yet included.

Most processes for power generation make use of steam or gas turbine cycles. The programme therefore contains simple routines for calculating the efficiency of these cycles. However where better data is available, perhaps from a more detailed simulation, the programme values can be overridden. In practice the efficiency of more sophisticated steam cycles tends to be slightly higher than the simpler ones which are calculated by the program. After a first assessment it may pay to refine the results by inputting a more accurate simulation.

There is no particular control on the efficiencies specified for compressors and expanders. Those using the program have to have the competence to assess these realistically, although conservative defaults are included where no such data is known.

A multicriteria analysis is included in the program. This assesses several attributes. Some of these are strictly related to the predicted performance of the plant as calculated by the programme. These include the power cost, the CO₂ emission per Kw and the specific fuel consumption. Other parameters are assessed on a descriptive basis and include safety, environmental impact, materials of construction, severity of process and process complexity. In order to standardise the assessment of these attributes there is a set of standard questions and multiple choice answers. The user simply chooses the most appropriate answer to each question. There are two questions for each attribute, one is aimed at understanding the likely degree of cost escalation presuming that the process will be technically possible. Scores thus reflect the need for greater or less financial input to complete development of a fully commercial product. The second set of questions is designed to assess the likelihood that the process will be technically workable and commercially saleable. Most of the emphasis here is on the technical track record with the development. Some attributes such as those relating to safety and environment may be controllable technically but still reduce the chance of successful deployment for example because of public or institutional resistance.

The unit costs of electricity, total capital cost, operating cost, efficiency, fuel consumption CO₂ emissions are all calculated and presented by the program. These along with the multi-criteria analysis results form the output of the assessment. Full details of the questions and answers used in the multi-criteria analysis are given in appendix A.

3.3 Use of externally calculated heat and material balance simulation programs

For those in possession of licences to chemical engineering simulation programs such as Hysis, Gatecycle, Aspen and Pro-vision the marginal cost of simulating a power plant cycle may be quite low. In order to facilitate the transfer of key results from this type of simulation program an additional input option which bypasses the internal calculation of steam and turbine cycles is incorporated in the latest version. The key efficiencies and powers are entered here excluding allowances for certain specified mechanical and electrical losses. Such losses are assessed by the program. A check is made to ensure that the values entered are consistent with the specified fuel quantities.

3.4 Calibration of the multicriteria analysis

One way to appreciate the multi-criteria analysis is to consider the assigned weightings as painting a scenario about commercial power generation at a future date when carbon capture and sequestration is commonplace. In this future world there is a value to not emitting CO₂, just as there is to having a low electricity price. The parameters are currently set so that this value is \$50/ton CO₂. Additional value is also placed on low fuel consumption. A premium of an extra \$1.5/Mbtu for coal and \$3/Mbtu for gas is applied which effectively applies a penalty for any fuel consumption higher than that of conventional state of the art power plants. The other attributes feed in to the score through their weighting in effect by loading the technology with extra development costs which have to be recovered. Low scores effectively increase the capital cost per Kw over and above that derived from the basic capital cost estimate. The figure 1 illustrates how the weightings are built up. Note that the multi-criteria performance score is intended to bear a close relationship to overall cost.

The weightings chosen for any multi-criteria analysis are inevitably based on choice and an appreciation of the relative value of the different attributes. The choice of the attributes themselves is also an issue of debate. The attributes used in the program were chosen by a group of experts invited to a forum. The same experts also suggested weightings but these were set without the transparency of converting them to equivalent costs and some of the values chosen initially were clearly anomalous.




Figure 1 Multi-criteria weightings

The second dimension of the multi-criteria analysis is the risk that the technology will not succeed. This could be either for technical or non-technical reasons. For example some attributes of a process, such as complexity, safety and environmental impact, might put potential buyers off even if the process seems attractive in strictly commercial terms. The risk of failure score is thus intended to be independent of the performance score and as far as possible divorced from costs. It is dependent to quite a degree on the practical results which have been obtained in the laboratory or pilot plant, and represents those situations where money or price can do little to alter technological and commercial realities. Risk scores are assigned for each of the main attributes except for the power cost and emission factors and both the average risk and the highest individual score are determined. For the purposes of comparison the highest score is considered to be more important than the average score, because one show stopping attribute is much worse than several minor difficulties.

Obviously changes to weighting factors can be made but it is recommended that if done this is in the context of a complete scenario in which all factors are reviewed. Furthermore for consistency it would be better to develop additional scenarios keeping intact those which have already been used for a set of evaluations rather than adjust individual weightings in existing scenarios.

3.5 Results of evaluations – the search for a better process

Over the last three years IEAGHG has kept a watching brief for novel CO₂ capture processes and employed a consultancy to evaluate most of them using the PPAP software. Not all results are reported since some of the information on processes was provided on a confidential basis. In those cases the results proved to be quite helpful to the developers of the processes concerned.

3.6 Presentation of results

For each evaluation a separate Excel file is prepared. It is advisable to prepare a set of notes describing the process, listing references, explaining the reason behind choices for the input and with a copy of any external simulation work which has been done. In order to reach conclusions about new processes is necessary to make comparisons with others and this has to be done externally. The programme contains two simple charts to help visualise the performance of the evaluated process relative to a state of the art non-CO₂ capturing base line plant. It is not yet set up to plot multiple results.

A good way to compare results is to plot them on a chart with two axes similar to the one embedded in the “results” sheet. On the vertical axis is the performance score and on the horizontal axis the “likelihood of success”. Fig 1 is an example of this type of chart as produced by the programme. The chart in the program plots a second point on the chart which shows the same “risk” but excludes all factors except cost of electricity from the performance score. This “score” shows in effect how the process would be viewed in the context of a today’s cost competitive electricity market.





Figure 2 Performance and risk plot

The chart falls naturally into four quadrants as illustrated in figure 2.

- High performance with low risk, - an ideal combination but to date no processes fall into this category
- Low performance with low risk, - typical of the current leading capture options
- High performance with high risk - the region in which to expect promising novel processes to emerge.
- High Risk Low performance - processes which are unlikely to be worth developing

Today's processes tend to occupy the low risk, low performance quadrant. Above this quadrant lies an area of low risk and better performance and any CO₂ capturing power generation process which plotted here would be a front runner for development. However it is unlikely that low risk processes with much better performance will be found. To the side of this "preferred" area is one where performance is good but risk is high. This is the



most likely area where a viable new process will be found. There is likely to be a trade off between risk and performance. Investments in development of processes falling in this area will have to have a strong element of "venture". Finally there is a quadrant of low performance and high risk. Processes which fall in this area should be regarded as not worth further development.

Figure 3. Risk performance matrix

As a refinement of the two dimensional plot a "bubble" plot can be used with the size of the bubble representing the average risk level. This gives an additional comparison particularly between closely competing processes indicating the extent of the critical development problems which may have to be overcome. It should be remembered that the likely cost of overcoming them is already factored into the performance score by the multi criteria analysis.

The other small chart included in the output is a stacked bar chart which shows how the main elements of the performance score of the process compares with those of a base case. This is on the "comparison" sheet. Data for the base case has to be entered in order for this chart to be created. This comparison is done on the basis of an "effective" cost of electricity. The effect of multi-criteria scores is translated into an effective extra electricity price. Lower fuel consumption and reduced CO₂ emissions are also "translated" into effective electricity price changes. This can give a good appreciation of how emission credits are being offset by development costs and extra fuel consumption. A second bar shows the overall difference, positive or negative.




Figure 4 Comparison of performance

TABLE 1 SUMMARY OF RESULTS FROM PPAP EVALUATIONS

Process	Fuel	Cost ¢/kWh	Performance score (1pt equiv to .05¢/kWh)	Highest risk factor (0-100)	Average Risk level (0- 100)	Fuel use kW/kW	Efficiency % based on LHV	CO2 emissions gm/kWh
CCGT no capture	Gas	2.9	216.2	11	5	1.73	57.9	365
APO/PCDC	Gas	4.0	199.9	11	5	1.98	50.5	62
Chemical looping (CuO)	Gas	3.8	187.6	100	40	2.19	45.6	0
Pulverised fuel no capture (PF)	Coal	3.8	186.4	5	2	2.22	45	728
Chemical looping (BaO)	Gas	3.7	181.3	100	48	2.26	44.3	0
Clean energy Systems (CES) (with 1200C max TIT)	Gas	4.8	170.1	20	11	2.20	45.4	0
PCDC with circulating Dolomite CO2 acceptor	Gas	5.2	165.2	100	21	2.10	47.7	70
SOFC hybrid	Gas	7.4	128.1	63	20	1.55	64.6	3
PF + Amine scrubbing	Coal	7.3	125.5	10	3	2.88	34.7	94
Israeli-Russian Cryogenic process.	Coal	8.4	56.9	63	16	3.97	25.2	389

3.7 Use of results

The results of an evaluation are based upon the available information and state of development at the time. Some scores will change as development proceeds. The underlying reasons which build up a score on either axis can be determined easily by examining the answers to the various questions and hence give direction for improvement. The results are particularly useful when comparing competing processes enabling an understanding of how the different attributes are affecting their chances. With suggestions for so many potential processes it is becoming increasingly important to identify the future winners as the need for serious action on climate change increases. This type of analysis should be valuable for funding institutions and proponents of specific technologies alike in understanding where best to direct development. It is possible to perform a “what if” exercise to determine how the multi criteria analysis results would change as progress is made in the development.

3.8 Specific results

The following processes have been evaluated to date. They fall into several classes.

Firstly there are base line processes. Examples for calibration were based on information reported in previous IEAGHG studies. Coal and gas fired processes fare differently in the analysis mainly because coal generates more CO₂ and is evaluated with a lower unit fuel price. Thus care should be taken when comparing a gas fired process with a coal fired one. For both base fuels a “with capture” and a “without capture” case was evaluated. For gas fired power plant a conventional Combined Cycle Gas Turbine system (CCGT) was evaluated as the “without capture” base-line. An air blown partial oxidation pre-combustion decarbonisation process (APO/PCDC) making a hydrogen/nitrogen mixture which is fed to a CCGT was used for the “with capture” alternative. For coal fired plant a conventional supercritical pulverised fuel steam boiler plant was evaluated as the “no capture” base case with addition of flue gas amine scrubbing for the “with capture” case.

Seven novel CO₂ capturing processes have been evaluated and the results from five of these are discussed below. They are:

Coal fired process with cryogenic expansion system for CO₂ recovery. (Proposed by Israeli-Russian research centre)

Gas fired oxycombustion using the “Clean Energy Systems” (CES) water recycling process

Gas fired fluid bed chemical looping system using Barium Oxide. Also evaluated with copper oxide. (NB Manganese and Iron oxides based processes were also investigated but no evaluation performed as these seemed less viable)

Gas fired Pre-combustion decarbonisation in the presence of a regenerable CaO/MgO CO₂ receptor

Gas fired pressurised Solid Oxide Fuel Cell hybrid (part based on a Rolls Royce concept)

The evaluations were all performed by a small specialised consultancy “Gasconsult”. The individual reports on each evaluation and the PPAP spreadsheets are contained in the appendices.

The results of the PPAP evaluations lead to some interesting conclusions about what the important features of a leading capture process might be. Efficiency and hence also specific fuel consumption are important. These are generally obtained by processes which achieve high top temperatures in the power generation working fluids. Achieving high temperature by supplementary firing of fuel which is not decarbonised appears to be a good strategy since the improvements in performance score due to efficiency tend to outweigh the losses due to higher CO₂ emissions. Process which are simple also do well in the evaluation.

The forgoing insights lead to preliminary examination of a novel hybrid process which are described below.

3.8.1 Oxy-combustion heating of steam (hybrid process)

The concept of this process is to use oxy-combustion of natural gas to raise the temperature of steam from a power plant by direct firing to the maximum level which modern gas turbine technology can tolerate, i.e to around 1500C. The CO₂ steam mixture would then be expanded and after condensation of the steam CO₂ can be recovered. This is the essence of the power generation cycle of the CES process. This hybrid process might be applied to any steam turbine based process whether it be driven by coal, nuclear or renewable energy. This combination would become valuable if the gains in efficiency for the host process outweigh the parasitic power losses of the oxy-combustion element as illustrated in the diagrams below




Fig 5 Hybrid process combination

Fig 6 Advantages and disadvantages

A short report on the findings of this investigation is to be found in APP X. The main findings were:-

The amount of heat which has to be supplied by oxy-combustion to raise steam from the range 400-600C up to 1500 C is considerable and represents up to 70% of the total

process heat input. Thus up to 70% or so of the thermal input is derived by oxy-combustion and thus is subject to the energy penalty associated with oxygen production. This restricts the advantage which the process could offer to a mere 30% of the total, the rest would have only the performance of a gas fired oxy-combustion process. The amount of thermal energy which would have to be supplied by oxy-combustion in this hybrid scheme depends mainly on the temperature to which the steam is raised by the host and the target top temperature for the oxy-combustion. This is illustrated in the figure below.




Fig 7 Split of energy inputs between host and oxy-combustion in hybrid process

In principle a power generation cycle with 1500°C top temperature should approach 60% efficiency. However the efficiency of the basic cycle used in the CES process with these inlet conditions falls short of this in simulations by about 5%. This is sufficient to negate much of the advantage which the overall process might otherwise have had. The reason for the lower efficiency stems in part from the presence of the CO₂ which alters the condensing curve of the working fluid so that no condensation occurs in the final stages of the expansion turbine. None of the latent heat of condensation of the steam can be converted to power and is all rejected to the low temperature cooling utility. This effect is compounded by the much higher outlet temperature of the last stage of the turbine, due to the much higher inlet temperature as compared to that in a conventional steam cycle.

The following table shows the efficiency results for a combination of a host process generating steam at 124 bar with an efficiency of electrical generation of 37.1 %. Two options were examined, one with the configuration proposed by CES with two stages of oxy-combustion and a back pressure on the final turbine of 55mb. The other with one stage of oxy-combustion and a back pressure on the process of 1.04bar. Heat from the final cooling of the turbine exhaust is recovered into the process.

Configuration	Host efficiency %	Overall efficiency	Effective efficiency of oxy-combustion element	Percent of power from oxy-combustion
Two stage with 55mb back pressure	37.1	47.9	50.6	16.7
One stage with 1.04 bar back pressure	37.1	45.5	50.0	29.6

An additional observation is that not only is the latent heat rejected in the CES type cycle but also a large amount of superheat has to be removed under vacuum conditions. Although this heat can be usefully recovered, the cooler in the exit of the turbine is expected to very large and expensive. This is because the low pressure results in very low heat transfer coefficients in the de-superheating region. The simulation with raised backpressure overcomes this drawback to some extent without apparently detracting from overall performance. There may be possibilities to improve the cycle either by using much higher inlet pressures which takes the turbine design into uncharted territory or to revert to a combined cycle system in which the outlet pressure of the topping cycle is kept at several bars so that the latent heat of steam can be recovered at a useful temperature. A conventional all steam bottoming cycle would then be added. However these options have not been explored.




Fig 8 Hybrid oxy-combustion process with low back pressure and single reheat




Fig 9 Hybrid oxy-combustion process with no reheat and high back pressure

In conclusion the hybrid process described indicates the ability to achieve power generation from natural gas with an effective efficiency around 50% which is similar to the performance of post-combustion capture.

However the hybrid can be viewed from another perspective which is as an addition to a base CES type process in which steam from an add-on process is mixed into the gas from the CES oxy-fired generators. This additional steam could be raised to full temperature by running the generators at a higher temperature and allowing the two streams to mix. This would enable the heat from the add-on process to be converted to electricity at the same efficiency as the basic CES cycle without the parasitic losses for oxygen production or CO₂ compression. This potentially boosts the efficiency of use of the steam up to around 55% which is the efficiency of the basic CES cycle without subtraction of the parasitic losses for oxygen production and CO₂ compression.




Figure 10 Boosting performance of low efficiency steam cycle by integration with oxy-combustion cycle

3.9 Comparison of specific results.

The main results of the evaluations are summarised in table 1. The results are also plotted on the performance risk chart as described earlier see figure 4. In addition figure 5 illustrates the performance rankings using the multi-criteria analysis as compared to the ranking based on electricity costs alone. For the processes analysed the multi-criteria results tended to widen the range of performance scores but did not significantly change the actual rank order with exception of the gas fired PCDC process which improved its ranking.

Specific conclusions about the processes are as follows. The base cases with capture both lose in performance compared to the no capture alternatives. This indicates that for the scenario incorporated into PPAP, which values CO₂ emission reduction at \$50/ton and fuel efficiency with a 3\$/Gj premium, there is not a compelling case for capture especially for coal fired units. The main reasons for this are the higher capital costs but also the extra fuel penalty since both capture processes result in considerable increases in specific fuel consumption.

Of the new processes the cryogenic process proposed by the Israeli-Russian research centre shows up with very poor performance which alone is enough to question any further development. This coupled with a quite high development risk score places this process in the “unfavourable” quadrant.

The chemical looping processes using either Barium or Copper oxides had a reasonable but not outstanding performance score but were evaluated as having very high development risk. The risks are intrinsic to this type of process which involves circulation of massive amounts of solid materials at high temperature. Some way of significantly improving the performance would be needed to make this process a serious contender. Net efficiencies were only 44.3%(Barium oxide)/45.6% (Copper oxide) with little prospect of changing the process to raise them.

By contrast the CES process evaluates with much lower risks and has a performance which brings the version using 1200°C turbine inlet temperatures just inside the “high performance low risk” quadrant. The efficiency was only 45.4% but this could be improved significantly if turbine inlet temperatures can be raised from the assumption of 1200°C to the same level as those attained in the current generation of gas turbines. However the efficiency loss due to the parasitic power required to produce the oxygen required and to recompress CO₂ amount to about 14%. This is offset by very high turbine efficiency (61.5%) achieved because a condensing system with quite low vacuum pressure is employed. Moving to higher inlet temperatures should allow this process to challenge the efficiency of the CCGT with pre combustion decarbonisation.




Figure 5 Strategic position of novel and baseline processes

The CO₂ capturing solid oxide fuel cell process evaluated as having a fairly high risk and only moderate performance, it was just below the top of the poor performance high risk quadrant. The poor performance score is due mainly to rather high estimated costs for the equipment which more than offset the high efficiency of 64.8% which was calculated for this process. A significant breakthrough in fuel cell costs would be required to make this process a serious contender.

In the CO₂ acceptor process gas is reformed in the presence of dolomite (CaO/MgO). This shifts the reaction so that no separate shift conversion is needed. As a result the reformed gas does not have to be cooled down for the shift conversion and can be fed at high pressure and temperature directly to a gas turbine. This greatly reduces thermodynamic losses. The regeneration of the circulating Dolomite was also set to occur at high temperature to maximise the efficiency of power generation from the heat removed from the streams exiting this system




Figure 6 Relative ranking of processes

Regeneration was also modelled at high pressure thus reducing the power required for compression of captured CO₂. The overall efficiency of the process at 47.7% was encouraging but still a few points less than that calculated for air blown partial oxidation pre-combustion decarbonisation process (50.5%). This process was also evaluated as having high development risk because of the massive high temperature solids re-circulation system which this process has in common with the BaO/CuO chemical looping systems.

4 PPAP input and output sheets and GasConsult evaluation reports

All the PPAP outputs and gas consult reports are collected in Appendices to this report. The GasConsult reports include basic commentary on each evaluation as well as flow sheets and material and heat balances from Hysis simulations where used. Also included are comments about the usability of PPAP which have been used to upgrade the programme. Original studies were done on a version with different weighting factors and without evaluation of development risk. The processes which were evaluated on the earlier version were rerun later on the newer version.

4.1 Using PPAP

PPAP comes complete with a help section which explains how to use it and there is thus no separate manual. In addition many of the cells have explanatory notes attached which are intended to clarify the information. This CD also contains a copy of the latest version of PPAP which is thus available for installation and use.

APPENDIX A

Questions and standard answers for multi criteria analysis

The primary answer text gives the multiple choices which are used to determine the performance score. The qualifying answer texts shown in boxes are used in *conjunction* with the primary answer texts to generate the risk scores. As such these qualifying answers **DO NOT** affect the performance score. The actual weighting factors can be inspected in the program in the lower part of the “analysis” worksheet. Score contributions are accessed through lookup tables in this part of the worksheet.

Raw material availability;

Primary text

Qualifying text

Globally Common
 Locally Common
 Moderately Common +
 Scarce
 Very Scarce

with unlimited availability
 with some limits to availability
 with severe limits to availability
 with totally inadequate
 availability

+ for the scale of this application

Process conditions:

Temperature & Pressure texts

Qualifying text

<1200K
 1200K-1600K
 1600K-2000K +
 >2000K
 Cryogenic

Atmospheric
 <10bar
 10-60bar
 60-150bar
 >150bar

+

but no significant technical barriers
 needs tech breakthrough with known parallels
 needs tech breakthrough without parallels,
 theory/principles accepted
 uses unproven effects not yet accepted by scientific
 community

Novelty of materials

Selection text

Qualifying text

Carbon Steel
 Stainless Steel
 Existing Special Alloy +
 New Special Alloy
 Exotic Ceramic

known material in known environment
 or known material but in new environment
 or newly discovered material proven in similar duty
 or newly discovered material proven in different duty
 or new material yet to be developed
 or totally new material yet to be discovered

Process novelty

Primary text

First qualifier

Second qualifier

industrial applications in operation
 initial industrial application
 and extensive pilotscale demonstration
 but limited pilot scale demonstration
 and extensive benchscale testing
 but limited benchscale testing
 credited scientific proof of concept

Fully Proven
Minor Modifications
Major Modifications +
Major New Ideas

highly
successful
promising
problematical
unsuccessful
no

+

Safety risk:
Primary text

Qualifying text

Benign
Small Risk
Risk
Major In Plant Risk
Major Ex Plant Risk

extensively demonstrated and publicly accepted
or demonstrated but concerns emerging in public domain
or NOT demonstrated, high degree of public concern existing or likely

Environmental impact:
Primary text

Qualifying text

Useful byproducts
Benign Waste
Mildly Harmful Waste
Moderately Harmful Waste
Extremely Harmful Waste

extensively demonstrated and publicly accepted
or demonstrated but concerns emerging in public domain
or NOT demonstrated, high degree of public concern existing or likely

IEA GREENHOUSE GAS R&D PROGRAMME

**PPAP EVALUATION OF EARLIER STUDIES ON POWER
GENERATION WITH CO₂ CAPTURE:**

- **PF COAL + AMINE WASH (IEAGHG/SR3, 1993)**
- **PRECOMBUSTION DECARBONISATION OF
NATURAL GAS (IEA/CON/97/22, 1998)**

**IEA CONTRACT NO. IEA/CON/02/75
GASCONSULT LTD CONTRACT NO. 012 - 003**

AUGUST 2002

CONTENTS

1. INTRODUCTION.....	4
2. DESIGN BASIS.....	4
3. CASE A: PF COAL + AMINE WASH.....	4
3.1. Steam Cycle Conditions.....	4
3.2. SO ₂ Removal.....	4
3.3. CO ₂ Removal	5
3.4. Generating Efficiency	5
3.5. PPAP Capital Cost	5
3.6. PPAP Criteria & Scores	6
3.7. Comments	6
4. CASE B: PRECOMBUSTION DECARBONISATION OF NATURAL GAS	7
4.1. Steam Cycle Conditions.....	7
4.2. PPAP Capital Cost	7
4.3. PPAP Criteria & Scores	7
4.4. Comments	8
5. CONCLUSIONS	8
6. GENERAL COMMENTS ON PPAP ASSESSMENTS.....	8
7. TABLES AND FIGURES	10

EXECUTIVE SUMMARY

With a view to establishing two ‘benchmarks’ against which innovative power generation schemes with CO₂ capture can be assessed, IEA has commissioned Gasconsult Ltd to use IEA’s in-house PPAP software to re-assess two earlier studies on power generation with capture of CO₂. These two studies are:-

IEAGHG/SR3 Appendix A (1993):- CO₂ capture by MEA wash from flue gases of conventional pulverised coal fired plant.

IEA/CON/22 Case G (1998):- Combined cycle plant with precombustion decarbonisation of the natural gas fuel by catalytic partial oxidation.

Gasconsult has only been asked to apply PPAP to these two studies, with the subsidiary task of using PPAP to assess the efficiency and performance of a steam cycle. Gasconsult has not been required to calculate or otherwise investigate the potential for redesign or upgrading of these two systems.

The main conclusions to be drawn from the present work are:

1. When used in conjunction with a calculated or representative steam cycle thermal efficiency, PPAP has given values for specific investment cost that are close to those generated in the two original studies.
2. PPAP typically gives steam cycle efficiency that is rather higher than the true efficiency for the selected cycle conditions. This appears to originate in part from minor errors in calculation formulae.
3. It might now be appropriate to consider whether a more modern version of the PF + amine route could be used as a benchmark. Improvements in the PCDC system may also now be possible aimed at lower capex and improved operability – specifically elimination of the problematic feed/effluent exchanger downstream of the ATR reactor, substitution of medium pressure steam for high pressure steam generation and superheating.

1. INTRODUCTION

In order to assess and put in context future results from PPAP, the IEA Greenhouse Gas R&D Programme has commissioned Gasconsult to produce two PPAP case assessments of generating plant with CO₂ capture as a type of 'benchmark'. These two cases are:-

CASE A

The early 1990's design sub-critical coal PF fired plant with flue gas desulphurisation and MEA CO₂ removal as described in 'The Capture of Carbon Dioxide from Fossil Fuel Fired Power Stations' (IEAGHG/SR1, 1993).

CASE B

The gas-fired combined cycle plant with precombustion decarbonisation (PCDC) by catalytic partial oxidation as described in IEA/CON/22 Case G (1998).

Gasconsult's current work includes the subsidiary task of using PPAP to assess the steam cycle efficiency (particularly of the steam cycle in Case A).

Gasconsult has specifically not been required at this moment to calculate or otherwise investigate the potential for redesign or upgrading of the two systems.

2. DESIGN BASIS

The current work has been carried out on the basis of the standard IEA assessment conditions. These include an electric power output of nominally 500MWe at the generator terminals after deduction of internal electrical consumption.

3. CASE A: PF COAL + AMINE WASH

3.1. Steam Cycle Conditions

The steam cycle conditions assumed in the PPAP assessment are near to those given in Appendix A of 'Greenhouse Gas Releases from Fossil Fuel Power Stations' (IEAGHG/SR1, 1993). These conditions include superheater exit at 190bar/568.5⁰C and a single reheat to 565⁰C.

3.2. SO₂ Removal

To reduce as much as reasonable irreversible degradation of the MEA solution by SO_x, the original study IEAGHG/SR3 provided for almost complete removal of SO₂ (to 1ppm concentration) at the inlet to the CO₂ absorber. As limestone-based FGD cannot achieve so low an SO₂ concentration, the study proposed use of the 'Cansolv' liquid wash process. The Cansolv process may well be, and probably is, a satisfactory

means of SO₂ removal for this duty, but it should be noted that the extent of practical experience with Cansolv is much less than with limestone-based FGD. It is understood that no full-scale unit has ever been built. Moreover a technical solution which required the substitution of a Cansolv unit for existing limestone sorption equipment would add significantly to the cost of retrofitting CO₂ capture to existing coal-fired plant.

3.3. CO₂ Removal

The specific heat requirement for regeneration and reclamation of the MEA solvent is not given in IEAGHG/SR3, but it is likely to be >60 kWh(th)/kmol CO₂ removed. The rather large drop in overall generating efficiency due to CO₂ capture (from 40% to 28% approximately reported in IEAGHG/SR3) is mostly due to this LP steam demand. Substitution of more recently developed solvents might perhaps approximately halve the specific solvent regeneration heat requirement. If this is substantiated, the penalty in generating efficiency due to CO₂ capture would also be approximately halved.

3.4. Generating Efficiency

PPAP gives an Estimated Steam Cycle Efficiency for the cycle shown in IEAGHG/SR1 Appendix A of about 46%. However Appendix A (p 87) when modified to be consistent with PPAP scope suggests 42%. These efficiencies include boiler feed pumps and condensate pumps within the steam cycle (please refer to Sect 6). They exclude power requirements for solids handling, fans, turbine mechanical losses, generator and transformer losses, cooling water pumps, FGD plus CO₂ removal (if installed). The latter are either considered in PPAP as auxiliaries or are external and subtracted afterwards from the power made (please see summary on Gas Cycle page).

The steam cycle described in Appendix A of IEAGHG/SR1 was also simulated on HYSYS using ASME steam data. This returns about 43.8% excluding boiler losses – which would come down to 40% overall if these were included to put on the basis in the above paragraph. It does seem therefore that the efficiency calculated for this particular case by PPAP may be too high. Based on enthalpies in PPAP a much lower efficiency is calculated. Therefore the efficiency calculation based on calculating the area of the thermodynamic cycle on the TS diagram is suspect.

When an agreed view of the most representative state of the art efficiency is available, it may be possible to insert this value into PPAP and develop new scores.

3.5. PPAP Capital Cost

This is shown in Table 1 (Sect 7). The costs shown in IEAGHG/SR3 Appendix A are on a 1991 basis whereas PPAP costs are from around 1999. On a comparable basis there is reasonably close agreement, though the Appendix A total is slightly (5%) higher. However, this figure over represents the probable agreement as a significant

proportion of the items have been simply copied from the Appendix A column to PPAP or vice-versa.

3.6. PPAP Criteria & Scores

Criteria:-

Raw Material: Locally Common	90
Process Conditions: Atm<1200 K	100
Materials: Stainless Steel	95
Process: Minor Modifications	95
Safety: Small Risk	80
Environmental: Mildly Harmful Waste	50

Scores:-

Heat In	1546.5MWth
Estm. Net Electricity Output	500.0MWe
Net Efficiency LHV	32.3%
CO ₂ output	14.1kg/s
CO ₂ output	0.101kg/kWh
Estimated Capital Cost	1240.6Mill \$
Estimated Op Cost	7.2c/kWh

Multi-Criteria Assessment:-

Decision Factor Scores	
Acceptance	68.0
Applicability	66.9
Confidence	91.3
Estimated Cost	60.1

3.7. Comments

Due in part to the considerations described above relating to removal of SO₂ and CO₂ and in part to the improvements in steam cycle conditions and steam turbine efficiencies since 1993, it may now be appropriate to consider whether a more modern version of the PF + amine route could be used as a benchmark.

4. CASE B: PRECOMBUSTION DECARBONISATION OF NATURAL GAS**4.1. Steam Cycle Conditions**

As IEA/CON/22 does not provide very much information on the steam cycle, the efficiency of the steam cycle has been calculated by PPAP. As noted under Case A above, this is likely to give a steam cycle efficiency rather higher than the true efficiency for the cycle conditions selected. As, however, in this Case B scheme the steam cycle only contributes about a third of the total power output, the efficiency overestimate due to PPAP is only likely to be only around 1 %.

4.2. PPAP Capital Cost

The capital cost predicted by PPAP is \$458 million. This corresponds to about \$386 million when Owners Costs and Contingency are not included. The latter compares well with that predicted in IEA/CON/22 (a range of \$347 to 459 million depending on the assumed cost of the base combined cycle).

4.3. PPAP Criteria & Scores

Criteria:-

Raw Material: Locally Common	90
Process Conditions: 10-60 bar, 1200 -1600K	80
Materials: Existing Special Alloys	90
Process: Minor Modifications	95
Safety: Small Risk	80
Environmental: Benign Waste	80

Scores:-

Heat In	986.0MWth
Estm Net Electricity Output	467.8MWe
Net Efficiency	47.4%
CO ₂ output	8.6kg/s
CO ₂ output	0.066kg/kWh
Estimated Capital Cost	458.2Mill\$
Estimated Op Cost	3.3c/kWh

Multi-Criteria Assessment**Decision Factor Scores**

Acceptance	80.0
Applicability	73.0
Confidence	77.5
Estimated Cost	78.3

4.4. Comments

Since the completion of IEA/CON/22 in 1998, Gasonsult has suggested improvements aimed mainly at reducing the complexity of the installation, removing potentially problematic components and reducing investment cost.

5. CONCLUSIONS

PPAP Scores

These have been developed. Further effort is required to assess the precise significance of these figures.

Investment Cost:

PPAP has given investment costs that are close to those previously generated by IEA for both the Cases examined.

Steam Cycle Efficiency:

PPAP typically gives steam cycle efficiency that is rather higher than the representative efficiency for the cycle conditions selected in this study. This appears to be due to errors in the calculation routine.

PF + Amine:

It might now be appropriate to consider whether a more modern version of the PF + amine route could be used as a benchmark

PCDC:

Since the completion of IEA/CON/22 in 1998, improvements in PCDC have been suggested aimed mainly at reducing the complexity of the installation, removing potentially problematic components and reducing investment cost. Improvements in the PCDC system may also now be possible.

6. GENERAL COMMENTS ON PPAP ASSESSMENTS

The steam cycle efficiency definition used by PPAP appears to be defined as the ratio of power out to fuel LCV in, all auxiliaries being subtracted later from the gross power made. However, it is not entirely clear how the boiler feed pump power is included in PPAP. It does not appear in the summary with other auxiliaries, which are all brought together and are summarised on the Gas Cycle page. This supporting efficiency calculation is actually on the Steam Cycle page, but is in a hidden area. It is suspected that the boiler feed pump power is not specifically included here, as, if the boiler feed pump pressure is changed to an absurdly high value (say 1000 bar), the cycle efficiency is unchanged in spite of the extra power consumed by the feed pumps. It would be useful to raise this query with the originators of PPAP. The same comment must apply to the condensate pumps though these are not so important.

Also it is not clear how CO₂ removal by amine is included in PPAP. The Acid Gas Removal entry on the Costing page appears to be tied to H₂S removal. CO₂ separation is included in the Plant Components page, but does not appear explicitly on the Costing page. It has been assumed that this is intended to be included as a user defined item.

7. TABLES AND FIGURES

Table 1 Capital Cost Comparison – Case A

Description	Scaling parameter	Size per unit	No of units	Cost multiplier	PPAP 1276.3 MW in Predicted cost M\$ (1999)	APPENDIX A 1254.4 MW in Predicted cost M\$ (1991)	APP A COMMENTS	**
Solids handling	kg/s	61.9	1	1	15.63	26.40		
Coal pulverise+dry (gasif)								
Oxygen production	kg/s feed	0.0	0	1	0.00			
Gasifier (Shell, inc hopper, cool/filt/scrub)	kg/s O2	0.0	0	1	0.00			
Acid gas removal (scrubbing)	MW fuel feed LHV	0.0	0	1	0.00			
CFBC	kmol/s feed gas	0.0	1	1	0.00			
CO2 compressor (motor driven)	MW fuel feed LHV	0.0	0	1	0.00			
Gas turbine, complete	MWe	54.5	1	1	55.28	43.64	AS PPAP	
Gas turbine, compressor only	MWe	0.0	0	1	0.00			
Gas turbine, turbine only	MW consumed							
Gas turbine, generator only	MW							
HRSG	MWe							
Steam turbine+pipes+cooling system	MWth transferred	590.8	1	1	150.57	117.80	GG Releases App A p 90	
PF coal boiler	MWe	1546.5	1	1	210.30	123.50	GG Releases App A p 90	
FGD (limestone gypsum)	MW fuel feed LHV							
Gasifier fuel gas cooler (fire tube)	kmol/s feed	0.0	1	1	0.00			
Gasifier fuel gas cooler (water tube)	MW transferred	0.0	0	1	0.00			
Candle filter (400C)	MW transferred	0.0	0	1	0.00			
PFBC combustor	kmol/s feed	0.0	0	1	0.00			
Gas/gas exchanger, 20bar, 30C delta T	MW fuel feed	0.0	0	1	0.00			
Acid gas removal (SO2 & CO2)	MW transferred	0.0	0	1	383.58	302.80	C Cap App A A12 p166	
Other	User Defined	0.0	0					
Other	User Defined	0.0	0		0.00	24.40	ESP	
Other	User Defined	0.0	0		0.00	7.30	WTP	
Other	User Defined					10.70	C&I	
Other	User Defined							
Other	User Defined							
Electrical distribution	MWe gross	500.0	1	1	11.48	19.60		
Sub-Total					826.84	676.14		
Balance of plant	% of above	10			82.68	72.20	MISC	
SUBTOTAL					909.53	748.34		
Engineering, indirects, owners cost	% of above	24			218.29	179.60	AS PPAP	
SUBTOTAL					1127.81	927.94	AS PPAP	
Project contingency	% of above	10			112.78	92.79	AS PPAP	
TOTAL (1991)						1020.74		
TOTAL (1999)					1240.59	1293.04		
Cost escalation assumed 91/99		1.267						**

**PPAP EVALUATIONS
GCL Contract No 014-002**

Evaluation of CES Technology

We now have pleasure in submitting for your comments the draft Report of our PPAP Evaluation of the CES (Clean Energy Systems, Inc) Zero Emissions power technology.

1. INTRODUCTION

Our evaluation of the CES technology is based on the three files, describing the system, which you e-mailed to us on 24 April 2003:

CES thermodynamic_analysis1.pdf
CES_Cost_Eff1.pdf
CES.ppt

The meeting with Dr. Keith Pronske on 15th July 2003 also provided valuable background information.

While the CES technology can in principle be used (via upstream gasification) with a wide range of primary fuels, this present evaluation is based only on natural gas fuel.

2. BASIS OF DESIGN

The Basis of Design for the evaluation is IEA Technical and Financial Assessment Criteria Rev B 1999, with these exceptions:

- 2.1 Natural gas cost is \$3 /GJ.
- 2.2 Carbon capture is 100% of the carbon content of the incoming natural gas. It is likely that some improvement in thermal efficiency may be obtained by reducing carbon capture to the standard 85%, perhaps through driving the ASU compressors by a conventional combined cycle. This idea was, however, not pursued, as being contrary to the “zero emission” concept of the technology. Moreover it would add to an already rather complex arrangement of turbo-machinery.

3. TECHNOLOGY DISCUSSION

3.1 Basic Concept

The core of the CES is high-pressure stoichiometric combustion of a fuel (in this case natural gas) with oxygen and quench water, thereby forming a CO₂/steam mixture containing around % CO₂ and % steam. This mixture is then expanded to sub atmospheric pressure, in a series of turbine stages, with intermediate reheat by combustion of more natural gas with oxygen according

to variant. The steam content of the turbine exhaust is condensed against cooling water. The CO₂ is compressed, liquefied and exported for disposal.

3.2 Variant Studied

CES has provided flowsheets for several variants, with progressively increasing expansion temperatures to reflect future advances in turbine materials and technology. By agreement with IEA and CES, Gasconsult (GCL) has concentrated on a variant with 816 C inlet temperature to the HP turbine and 1200 C inlet to the MP turbine. This variant is intended for application in the medium term, perhaps by 2010.

3.3 Simulation of Heat and Material Balance

The heat and material balance for the selected case was simulated on HYSYS using the information on the CES flow diagram (please see flow diagram PFD2.jpg and Worksheet MATBAL2.xls attached). After allowance for the power required to produce oxygen and deliver it at high pressure, the resulting overall gas-to-power efficiency for this "Medium Term" scheme worked out at 46.9%, which is close to the efficiency predicted by CES.

3.4 Plant Design Aspects

It is assumed that the CES combustion/quench reactor, based on rocket engine technology, has been satisfactorily demonstrated to achieve the stoichiometric combustion required on a small scale. There will be questions over scale-up and reactor life, and the developers may be confident on those counts, taking into consideration the possibility of multiple reactor assemblies, and the small size of the reactor facilitating rapid repair/replacement.

Considering the plant as a whole, there are several aspects that may place the technology at a disadvantage relative to competing alternatives, at least in the near term:

- Difficulty in providing turbine cooling fluids, particularly for the HP turbine. There is no cooling steam available. Recycled CO₂ may be a possibility
- While the HP turbine can be foreseen as an extension of steam turbine practice, and the MP turbine could be based on the expansion section of a gas turbine, the LP turbine will also require a considerable development effort. This is due to its proposed operation with high vacuum and exhaust temperature of 330⁰C. This temperature is 250-300⁰C higher than the exhaust temperature of a normal condensing steam turbine.
- The quench water heater located down stream of the LP turbine also has demanding duty. High heat load, vacuum on the shell side, stainless steel or titanium on both shell and tube sides due to CO₂ corrosion/erosion.

- The main steam condenser also has an unusual duty, relative to a normal steam condenser. High non-condensable fraction (>20% CO₂), with all-stainless steel or titanium construction unavoidable due to the wet CO₂.
- Another less desirable feature is the rather large number of more or less complex rotating machine duties. Natural gas compression, oxygen compression (although an ASU with oxygen pump can eliminate oxygen compressors as such), complex and developmental turbine assembly, and multi-stage stainless steel wet CO₂ compression with overall compression ratio (110/0.05) = 2200.
- Any defect or trip in the process will disable the whole power production unit. In this, CES is less attractive than, say, CO₂ capture by flue gas scrubbing or PCDC, with which power production can be maintained in event of shut-down of the carbon capture equipment.

4. MAIN PPAP INPUTS

Plant Components:-

Gas Turbines x 1

Gasifier x 1

ASU 86.42 kg/s delivered at 72 bar (mean of HP/LP O₂)

CO₂ compression/pumping to 110 bar

Fuel Specification:-

NG 100% CV 46920, C fraction 0.739

Mass & Energy: Fuel 23.00 kg/s

% to Gasification: 100% - all recovered to Gas Cycle

Gas Cycle details (from the HYSYS simulation):-

CO₂ and O₂ Compression power 155.2 MW (It is assumed this includes the power required for the ASU air compressor)

GT Power 663 MW

Overall efficiency after losses 46.87 %

Overall power output 505.7 MW

Costing:-

The values predicted by PPAP for the major components were compared with the CES data and it was thought that there was overall order of magnitude agreement. The only correction that was felt necessary was to the Gasifier where PPAP correlated conventional large units whereas the small CES devices based on rocket technology must be much less costly. A correction factor of 0.5 was inserted.

Total investment cost \$ 718 million.

Operating Cost:-

Natural Gas \$3/GJ

Power cost is ~5.5 c/kWh.


Multi-Criteria Analysis:-

Parameter: Raw Material Availability
 Value: Locally Common with some limits to availability
 Parameter: Process Conditions
 Value: T 1200-1600 degK, 60-150 bar but no significant technical barriers
 Parameter: Novelty of Materials
 Value: Existing Special Alloys known material but in new environment
 Parameter: Plant Complexity
 Value: 5 Major Units, no recycle
 Parameter: Novelty of Process
 Value: Major Modifications with promising and extensive pilot scale demonstration (this is looking into the future a few years and is not today's situation)
 Parameter: Safety Risk
 Value: Risk – extensively demonstrated and publicly accepted
 Parameter: Environmental Impact
 Value: Benign Waste – extensively demonstrated and publicly accepted


5. RESULTS

Summary			
Process:	CES Process (medium term)		GCL Contract 014-002
Heat Input		1079.2	MW
Estimated	Net Electricity Output	505.7	MW
	Net Efficiency	46.9	%
	CO2 output/ kg/s	0.0	kg/s
	CO2 output/kWh	0.000	kg/kWh
Estimated Capital Cost		717.9	M\$
Estimated Op Cost		5.5	c/kWh
Multi-Criteria Assessment			
Decision Factor Scores			
Acceptance		28.0	
Applicability		27.6	
Confidence		29.0	
Estimated Cost		73.3	
	Total	157.9	
	Total cost only	233.3	
Risk assessment			
Averaged risk level		15	
Controlling risk level	Raw material	25	

CES Process



CES PROCESS MEDIUM TERM
GCL contract 014-002



Workbook: Case (Main)

CES PROCESS

Streams

Name	01 NATURAL GAS	01A	01B	01D	01E
Vapour Fraction	1	1	1	1	1
Temperature (C)	20	20	20	82.72	27
Pressure (bar)	28.6	28.6	28.6	60	58.8
Molar Flow (kgmole/h)	4267.9	2020	2247.9	2020	2020
Mass Flow (kg/h)	82794.9	39187.2	43607.7	39187.2	39187.2
Heat Flow (kW)	-99305.3	-47001.6	-52303.7	-45706.1	-47228.2
Comp Molar Flow (CO2) (kgmole/h)	76.8	36.4	40.5	36.4	36.4
Comp Molar Flow (Nitrogen) (kgmole/h)	17.1	8.1	9	8.1	8.1
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	3580.7	1694.8	1886	1694.8	1694.8
Comp Molar Flow (Ethane) (kgmole/h)	392.6	185.8	206.8	185.8	185.8
Comp Molar Flow (Propane) (kgmole/h)	140.8	66.7	74.2	66.7	66.7
Comp Molar Flow (n-Butane) (kgmole/h)	59.8	28.3	31.5	28.3	28.3

Name	2	03 HP OXYGEN	5	05A	6
Vapour Fraction	1	1	1	0	1
Temperature (C)	91.68	20	819	819	438.3
Pressure (bar)	124	124	124	124	11.9
Molar Flow (kgmole/h)	2020	4641.4	40625.7	0	40625.7
Mass Flow (kg/h)	39187.2	148340.7	795751.4	0	795751.4
Heat Flow (kW)	-45969.9	-1397.6	-2.49E+06	0	-2.66E+06
Comp Molar Flow (CO2) (kgmole/h)	36.4	0	2415.9	0	2415.9
Comp Molar Flow (Nitrogen) (kgmole/h)	8.1	46.4	54.5	0	54.5
Comp Molar Flow (Oxygen) (kgmole/h)	0	4595	37.9	0	37.9
Comp Molar Flow (H2O) (kgmole/h)	0	0	38117.4	0	38117.4
Comp Molar Flow (Methane) (kgmole/h)	1694.8	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	185.8	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	66.7	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	28.3	0	0	0	0

Name	06A	07 LP OXYGEN	10	10A	11
Vapour Fraction	1	1	1	0	1
Temperature (C)	220	20	1201	1201	309
Pressure (bar)	11.4	20	10.9	10.9	5.50E-02
Molar Flow (kgmole/h)	40625.7	5088.3	48187	0	48187
Mass Flow (kg/h)	795751.4	162826.1	1.00E+06	0	1.00E+06
Heat Flow (kW)	-2.75E+06	-428	-2.81E+06	0	-3.31E+06
Comp Molar Flow (CO2) (kgmole/h)	2415.9	0	5104.4	0	5104.4
Comp Molar Flow (Nitrogen) (kgmole/h)	54.5	0	63.5	0	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	37.9	5088.3	55	0	55
Comp Molar Flow (H2O) (kgmole/h)	38117.4	0	42964.1	0	42964.1
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	12	13	14	16	17
Vapour Fraction	0.9918	0.4901	0	1	1
Temperature (C)	31.11	27	27	27	129.4
Pressure (bar)	5.00E-02	4.50E-02	4.50E-02	4.50E-02	0.12
Molar Flow (kgmole/h)	48187	48187	24572.1	23614.9	23614.9
Mass Flow (kg/h)	1.00E+06	1.00E+06	442671.9	559511.4	559511.4
Heat Flow (kW)	-3.44E+06	-3.74E+06	-1.95E+06	-1.79E+06	-1.77E+06
Comp Molar Flow (CO2) (kgmole/h)	5104.4	5104.4	0.1	5104.3	5104.3
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	63.5	0	63.5	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	55	55	0	55	55
Comp Molar Flow (H2O) (kgmole/h)	42964.1	42964.1	24572	18392.1	18392.1
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	18	18A	18B	19	20
Vapour Fraction	0.3125	1	0	1	0.7677
Temperature (C)	27	27	27	152.7	27
Pressure (bar)	0.12	0.12	0.12	0.45	0.45
Molar Flow (kgmole/h)	23614.9	7380.1	16234.8	7380.1	7380.1
Mass Flow (kg/h)	559511.4	267024	292487.4	267024	267024
Heat Flow (kW)	-1.99E+06	-702905.4	-1.29E+06	-693058.6	-723839.2
Comp Molar Flow (CO2) (kgmole/h)	5104.3	5103.6	0.6	5103.6	5103.6
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	63.5	0	63.5	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	55	55	0	55	55
Comp Molar Flow (H2O) (kgmole/h)	18392.1	2157.9	16234.2	2157.9	2157.9
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	20A	20B	21	22	22A
Vapour Fraction	1	0	1	0.9697	1
Temperature (C)	27	27	141.2	40	40
Pressure (bar)	0.45	0.45	1.5	1.5	1.5
Molar Flow (kgmole/h)	5665.9	1714.2	5665.9	5665.9	5494.1
Mass Flow (kg/h)	236134	30890	236134	236134	233038.6
Heat Flow (kW)	-587932	-135907.2	-580869.6	-589280	-575712
Comp Molar Flow (CO2) (kgmole/h)	5103.3	0.3	5103.3	5103.3	5103.2
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	0	63.5	63.5	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	55	0	55	55	55
Comp Molar Flow (H2O) (kgmole/h)	444	1713.9	444	444	272.4
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	22B	23	24	24A	24B
Vapour Fraction	0	1	0.9654	1	0
Temperature (C)	40	177.6	40	40	40
Pressure (bar)	1.5	6	5	5	5
Molar Flow (kgmole/h)	171.7	5494.1	5494.1	5304.2	189.9
Mass Flow (kg/h)	3095.4	233038.6	233038.6	229609	3429.5
Heat Flow (kW)	-13568	-567329.7	-578191.7	-563177.2	-15014.5
Comp Molar Flow (CO2) (kgmole/h)	0.1	5103.2	5103.2	5102.9	0.3
Comp Molar Flow (Nitrogen) (kgmole/h)	0	63.5	63.5	63.5	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	55	55	55	0
Comp Molar Flow (H2O) (kgmole/h)	171.6	272.4	272.4	82.8	189.6
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	25	26	26A	26B	27
Vapour Fraction	1	0.9868	1	0	1
Temperature (C)	177.5	27	27	27	128.1
Pressure (bar)	20	18.5	18.5	18.5	55
Molar Flow (kgmole/h)	5304.2	5304.2	5234.3	69.9	5234.3
Mass Flow (kg/h)	229609	229609	228334.7	1274.3	228334.7
Heat Flow (kW)	-555201.1	-565674.3	-560111.6	-5562.8	-554938
Comp Molar Flow (CO2) (kgmole/h)	5102.9	5102.9	5102.4	0.6	5102.4
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	63.5	63.5	0	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	55	55	55	0	55
Comp Molar Flow (H2O) (kgmole/h)	82.8	82.8	13.4	69.4	13.4
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	28	28A	28B	29	30
Vapour Fraction	0.9993	1	0	1	0
Temperature (C)	27	27	27	62.19	27
Pressure (bar)	53	53	53	80	75
Molar Flow (kgmole/h)	5234.3	5230.8	3.5	5230.8	5230.8
Mass Flow (kg/h)	228334.7	228270.2	64.5	228270.2	228270.2
Heat Flow (kW)	-563242.7	-562964.4	-278.3	-561555.6	-572263.7
Comp Molar Flow (CO2) (kgmole/h)	5102.4	5102.3	0.1	5102.3	5102.3
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	63.5	0	63.5	63.5
Comp Molar Flow (Oxygen) (kgmole/h)	55	55	0	55	55
Comp Molar Flow (H2O) (kgmole/h)	13.4	10	3.4	10	10
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	52	53 CO2	61	62	63
Vapour Fraction	0	1	0.0001	1	0
Temperature (C)	27	38.56	27.01	27.01	27.01
Pressure (bar)	75	115	4.50E-02	4.50E-02	4.50E-02
Molar Flow (kgmole/h)	5230.8	5230.8	42692.8	4.2	42688.6
Mass Flow (kg/h)	228270.2	228270.2	769144.7	100.6	769044.2
Heat Flow (kW)	-572263.7	-571652.7	-3.38E+06	-323.5	-3.38E+06
Comp Molar Flow (CO2) (kgmole/h)	5102.3	5102.3	1.1	0.9	0.2
Comp Molar Flow (Nitrogen) (kgmole/h)	63.5	63.5	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	55	55	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	10	10	42691.7	3.3	42688.4
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	64	66	67	68	69
Vapour Fraction	0	0.0017	1	0	0
Temperature (C)	27.16	36.14	27.22	27.22	27.22
Pressure (bar)	5	5	5	5	5
Molar Flow (kgmole/h)	42688.6	263.3	0	42951.9	33762
Mass Flow (kg/h)	769044.2	4768.3	0	773812.5	608248.4
Heat Flow (kW)	-3.38E+06	-20855.5	0	-3.40E+06	-2.68E+06
Comp Molar Flow (CO2) (kgmole/h)	0.2	0.9	0	1.1	0.9
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	42688.4	262.4	0	42950.8	33761.1
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	EXPORT CONDENS	71	71R	CW0	CW1
Vapour Fraction	0	0	0	0	0
Temperature (C)	27.22	31.18	27	17	17
Pressure (bar)	5	130	130	5	5
Molar Flow (kgmole/h)	9189.9	33762	33762	2.87E+06	1.42E+06
Mass Flow (kg/h)	165564.1	608248.4	608225.3	5.16E+07	2.56E+07
Heat Flow (kW)	-728516.3	-2.67E+06	-2.68E+06	-2.28E+08	-1.13E+08
Comp Molar Flow (CO2) (kgmole/h)	0.2	0.9	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	9189.7	33761.1	33762	2.87E+06	1.42E+06
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	CW2	CW3	CW4	CW5	CW6
Vapour Fraction	0	0	0	0	0
Temperature (C)	27	17	27	17	27
Pressure (bar)	4	5	4	5	4
Molar Flow (kgmole/h)	1.42E+06	1.06E+06	1.06E+06	147060.9	147060.9
Mass Flow (kg/h)	2.56E+07	1.91E+07	1.91E+07	2.65E+06	2.65E+06
Heat Flow (kW)	-1.12E+08	-8.42E+07	-8.40E+07	-1.17E+07	-1.17E+07
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	1.42E+06	1.06E+06	1.06E+06	147060.9	147060.9
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	CW7	CW8	CW9	CW10	CW11
Vapour Fraction	0	0	0	0	0
Temperature (C)	17	27	17	27	17
Pressure (bar)	5	4	5	4.92	5
Molar Flow (kgmole/h)	40182.2	40182.2	51895.5	51895.5	50038.3
Mass Flow (kg/h)	723886.7	723886.7	934903.3	934903.3	901445.6
Heat Flow (kW)	-3.19E+06	-3.19E+06	-4.12E+06	-4.11E+06	-3.98E+06
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	40182.2	40182.2	51895.5	51895.5	50038.3
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	CW12	CW13	CW14	CW15	CW16
Vapour Fraction	0	0	0	0	0
Temperature (C)	27	17	27	17	27
Pressure (bar)	4	5	4	5	4
Molar Flow (kgmole/h)	50038.3	39677.5	39677.5	51160	51160
Mass Flow (kg/h)	901445.6	714794.9	714794.9	921652.8	921652.8
Heat Flow (kW)	-3.97E+06	-3.15E+06	-3.15E+06	-4.07E+06	-4.06E+06
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	50038.3	39677.5	39677.5	51160	51160
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0

Name	CW17	CW18	EFFY %	O2-20BAR	O2-5BAR
Vapour Fraction	0	0		1	1
Temperature (C)	17	27	46.87	192.9	20
Pressure (bar)	5	4		20	5
Molar Flow (kgmole/h)	7272.2	7272.2		31.3	31.3
Mass Flow (kg/h)	131010.3	131010.3		1000	1000
Heat Flow (kW)	-578043.6	-576521.5		43.2	-1.6
Comp Molar Flow (CO2) (kgmole/h)	0	0		0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0		0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0		31.3	31.3
Comp Molar Flow (H2O) (kgmole/h)	7272.2	7272.2		0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0		0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0		0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0		0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0		0	0

Name	VENT 51	W2	W3R	WK102	WK103
Vapour Fraction	1	0	0		
Temperature (C)	27	215.9	326		
Pressure (bar)	75	127	124		
Molar Flow (kgmole/h)	0	33762	33762		
Mass Flow (kg/h)	0	608225.3	608225.3		
Heat Flow (kW)	0	-2.54E+06	-2.44E+06	498711.3	23632.9
Comp Molar Flow (CO2) (kgmole/h)	0	0	0		
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0		
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0		
Comp Molar Flow (H2O) (kgmole/h)	0	33762	33762		
Comp Molar Flow (Methane) (kgmole/h)	0	0	0		
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0		
Comp Molar Flow (Propane) (kgmole/h)	0	0	0		
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0		

Name	WK104	WK105	WK106	WK107	WK108
Vapour Fraction					
Temperature (C)					
Pressure (bar)					
Molar Flow (kgmole/h)					
Mass Flow (kg/h)					
Heat Flow (kW)	9846.8	7062.4	8382.3	7976.1	5173.6
Comp Molar Flow (CO2) (kgmole/h)					63482.9 CO2comp
Comp Molar Flow (Nitrogen) (kgmole/h)					154626.5 CO2 + O2 comp
Comp Molar Flow (Oxygen) (kgmole/h)					
Comp Molar Flow (H2O) (kgmole/h)					
Comp Molar Flow (Methane) (kgmole/h)					
Comp Molar Flow (Ethane) (kgmole/h)					
Comp Molar Flow (Propane) (kgmole/h)					
Comp Molar Flow (n-Butane) (kgmole/h)					

Name	WK109	WK-101	WK-100A	WK-100B	WKNETPOWER
Vapour Fraction					
Temperature (C)					
Pressure (bar)					
Molar Flow (kgmole/h)					
Mass Flow (kg/h)					
Heat Flow (kW)	1408.8	167677.2	1295.5	1258.3	505657.2
Comp Molar Flow (CO2) (kgmole/h)					
Comp Molar Flow (Nitrogen) (kgmole/h)					
Comp Molar Flow (Oxygen) (kgmole/h)					
Comp Molar Flow (H2O) (kgmole/h)					
Comp Molar Flow (Methane) (kgmole/h)					
Comp Molar Flow (Ethane) (kgmole/h)					
Comp Molar Flow (Propane) (kgmole/h)					
Comp Molar Flow (n-Butane) (kgmole/h)					

Name	WKO2	WKO2 POWER	WP-100	WP-101	WP-102
Vapour Fraction					
Temperature (C)					
Pressure (bar)					
Molar Flow (kgmole/h)					
Mass Flow (kg/h)					
Heat Flow (kW)	44.8	91143.6	140.3	2799.7	611
Comp Molar Flow (CO2) (kgmole/h)					
Comp Molar Flow (Nitrogen) (kgmole/h)					
Comp Molar Flow (Oxygen) (kgmole/h)					
Comp Molar Flow (H2O) (kgmole/h)					
Comp Molar Flow (Methane) (kgmole/h)					
Comp Molar Flow (Ethane) (kgmole/h)					
Comp Molar Flow (Propane) (kgmole/h)					
Comp Molar Flow (n-Butane) (kgmole/h)					

PPAP EVALUATIONS
GCL Contract No 014-004
Evaluation of Solid Oxide Fuel Cell Technology
Revised 02/12/2004 using PPAP v3.02

We now have pleasure in submitting for your comments the Report on our PPAP Evaluation of the Solid Oxide Fuel Cell technology.

1 INTRODUCTION

Our evaluation of the SOFC technology is based on the following files, describing the system:

E-mailed by IEA on 20 February 2004:

Attachment "Design of CO₂ Capturing Solid Oxide Fuel Cell"

E-mail of 19 and 24 February 2004

Re costs of SOFC fuel cells

E-mail of 19 and 24 February 2004

Re pressure drop of Rolls-Royce fuel cells

The process scheme defined by IEA in the above-mentioned attachment is essentially an adaptation of the published Roll-Royce Solid Oxide Fuel Cell (SOFC) technology, modified to achieve essentially complete capture of the incoming carbon.

2 BASIS OF DESIGN

The Basis of Design for the evaluation is IEA Technical and Financial Assessment Criteria Rev B 1999, except as noted below:

2.1 Natural Gas Cost

The cost of natural gas is taken as \$3/GJ (LHV)

2.2 Carbon Capture

The SOFC process scheme outlined by IEA in the document "Design of CO₂ Capturing Solid Oxide Fuel Cell" gives almost 100% capture of the carbon content of the incoming natural gas, together with a gas-to-power efficiency evaluated by us at 67%. Accordingly this evaluation has been based on 99-100% carbon capture. It would have been possible for this PPAP evaluation to have been based on 85% carbon capture, (the target capture for most earlier PPAP studies), by firing 15% of the incoming natural gas on the oxygen-rich cathode exhaust gas from SOFC stacks. However such after firing was seen as unattractive, due to (1) the low pressure ratio - and consequent low efficiency - of the gas turbine part of the process scheme and (2) the need (avoided in the current evaluation) for a steam cycle.

2.3 SOFC Design Basis

The main parameters laid down by IEA for operation of the SOFC stack are as follows:

pressure (anode and cathode sides)	bar abs	7
cathode side pressure drop	%	2
anode recycle/feed ratio	mol/mol	2:1
cathode recycle/feed ratio	mol/mol	1:1
cathode side inlet temperature	degC	760
stack outlet temperature (anode and cathode sides)	⁰ C	900
post combustor outlet temperature	⁰ C	1000
theoretical combustion air (lambda)	mol/mol	2.0
theoretical combustion O ₂ to stack	%	80
theoretical combustion O ₂ to post combustor	%	20

3 DESIGN DISCUSSION

3.1 Rolls-Royce and IEA SOFC Concepts

According to our understanding, the two significant features of the Rolls-Royce SOFC concept are:

- Operation of the SOFC cell stack (anode and cathode sides) at around 7 bar abs, this medium pressure reducing the size and cost of the stack without too much loss of electrochemical performance.
- Final preheating of the anode and cathode feed streams by ejector recycle.

As modified by IEA to achieve carbon capture, the exit streams from the anode and cathode fed separately to a membrane post combustor, in which sufficient oxygen diffuses from the cathode side to stoichiometrically combust the H₂, CO and CH₄ content of the anode exit stream. The post-combusted anode stream thus consists only of CO₂ and steam, apart from any nitrogen contained in the incoming natural gas.

3.2 HYSYS Simulation

A heat and material balance was simulated on HYSYS. This is shown on attached SOFC1.jpg and MATBAL1.xls.

Some minor changes have been introduced to the parameters laid down by IEA as the technical basis for SOFC operation (see 2.3 above):

- On the anode side, it was deemed by us inadvisable - for fear of cracking C₄+ components - to heat bulk flows of natural gas in conventional heat exchangers to a temperature higher than 450⁰C. The preferred inlet temperature to the cathode side being 760⁰C (see 2.3 above), the inlet temperature to the anode side has been fixed at 720⁰C, with the aim of reducing thermal stresses resulting from the two sides of the cell having significantly different inlet temperatures. In order to achieve that temperature of 720⁰C at the anode inlet, the anode recycle:feed ratio has been increased to 3:1.
- On the cathode side, the feed air is heated to 580⁰C upstream of the cathode side inlet by indirect heat exchange, first with the gas turbine exhaust and

secondly with the post combustor “anode” product. In order to achieve the specified cathode side inlet temperature of 760⁰C, the recycle:feed ratio has been decreased increased to 0.6:1.

To achieve a reasonably close fit of three parameters, the percentage of theoretical oxygen going to the stack has been increased from the specified 80% to 85 %, and the stack outlet temperature has been reduced to 870⁰C from the specified 900⁰C. These alterations result in the post-combustor outlet at 1020⁰C – without them, it would be over 1050⁰C, which is probable too much for the available material of construction of the post combustor.

- The ejectors have been modelled as a compressor in the recycle stream driven by an expander in the feed stream. Both compressors and ejectors have been assigned efficiencies of 50%, the net ejector efficiency therefore being approximately $0.5^2 = 0.25$.

3.3 No Steam Cycle

With intercooling of the air compressor, and by suitable heat recovery from the expander and post-combustor “anode” streams, the gas turbine exhaust is cooled to 163⁰C, and the post combustor “anode” stream to 490⁰C. Accordingly no steam cycle is provided, thereby reducing the complexity and cost of the plant. Perhaps by further study the rejection of heat from the anode stream (to cooling water, in this evaluation) can be reduced.

3.4 Desulphurisation

For the present evaluation, it is assumed that the incoming natural gas will be desulphurised with active carbon. In a large plant, it will however be more economical, following steam reforming practice, to use CoMo catalyst to hydrogenate organic sulphur to H₂S and then to absorb the total H₂S present with zinc oxide. However this would require the availability at plant start-up of an external source of hydrogen, to ensure around 2% mol H₂ at the inlet to the CoMox hydrogenator. This question should be investigated further, with knowledge of the tolerance of the SOFC to sulphur in the feed gas - can some sulphur slip from the desulphurisers be tolerated at start-up?

3.5 Equipment Design

The plant equipment outside the stack assembly (considered for this purpose to comprise the SOFC stack itself, the post-combustor and the recycle ejectors), employs existing technology.

The air compressor could be an industrial air compressor.

The expander, with an inlet conditions 6 bar/1000⁰C, will have probably to be specially developed, although not requiring any new basic technology. Perhaps the LP expansion turbine of an existing gas turbine could be adapted.

3.6 Plant Capacity

Subject to IEA’s requirements, the scheme has been evaluated on the basis of 50MWe modules - ten modules therefore making up the total 500MWe specified. Since in any event the SOFC part, which accounts for most of the investment cost, will be made up from numerous individual stacks, there will

not be much economy of scale in formulating a single-line 500MWe installation. The 50MWe module could provide power for a population of around 100,000 and may eventually provide local district heating. With very low emissions, low elevation, low noise, it would be suitable for unmanned operation in urban areas. The CO₂ production (circa 15 tonnes/h) could be railed daily to remote sequestration sites.

3.7 Manifolding

Assuming that the final air heater E-113 (air heated by 1000⁰C CO₂ + steam) is associated with each SOFC stack, the manifolding serving all the stacks (air supply, CO₂ + steam collection, GT expander feed) will be in conventional materials. In event of mechanical failure of a few SOFC stacks (anode and cathode sides coming into communication), it may be feasible to isolate the air and CO₂ + steam connections to those stacks, allowing the failed stacks to “float” on the GT expander inlet pressure until repairs can be effected.

3.8 Generating Efficiency

Our evaluation indicates a generation efficiency of approximately 67%, allowing for 7% (?) average loss in stack electronics and the turbine generator.

3.9 Capital cost

Where possible (e.g. for gas turbines) capital cost figures have been generated by PPAP – but a factor has been included to compensate for the low size and pressure ratio of the machines required, which must increase the cost per unit of power produced.

The low size arises from the need to generate 500e MW from 10 x 50 MWe units; however the does not have much effect on the cost of the fuel cell stacks as these are essentially already subdivided. The cost of these items is included in the User Defined category on the PPAP Costing Sheet as in the table below.

COST ESTIMATE for 50 MWe nominal output

ITEM	BASIS	ERECTED COST (USD MILLIONS)
SOFC Stacks	IEA E-mail 24/03/04: 42.29MWe at USD500/kWe x installation factor 2.0	42.3
Post Combustor	IEA E-mail 24/03/04: 42.29MWe at USD100/kWe x installation factor 2.0	8.5
Power Electronics	IEA E-mail 24/03/04: 42.29MWe at USD100/kWe x installation factor 2.0	8.5
Misc. Compressors and Expanders	4000kW @ USD500/kW x installation factor 2.0	4.0
Air Comp/Expander	Included in PPAP GT	0.0
Electric Generator	9292kW @ USD200/kW x installation factor 2.0	3.7
Desulphurisers	287 kmol/h NG guess	2
Heat Exchangers D-112/3/4	22.87 Gcal/h @ USD 50,000/Gcal.h x installation factor 3.0	3.5
Manifolds		7

TOTAL USER-DEFINED ITEMS		79.5
---------------------------------	--	-------------

The total capital cost for 10 streams generating a nominal 500 MWe, including owner's costs, indirect costs and contingency etc. is US\$ 1326 million. This very high cost largely arises from the cost of the SOFC stacks themselves (almost 7 times that was included in a previous evaluation for equivalent membrane reactor heat exchangers. It remains to be seen whether either of these estimates are realistic.

4 MAIN PPAP INPUTS

Plant Components

GT

Other major plant item

CO₂ compression/pumping to 110 bar

Fuel Cell

Fuel Specification

Natural gas 100% CV 46920, C fraction 0.739

Mass & energy fuel 15.47 kg/s

CO₂ recovered 99%

Fraction to fuel cell 65% % - 90% recovered to power

PPAP Lite Details

CO ₂ compression power	8.1	MW
O ₂ compression power	0	MW
HRSG on GT	0	MW
GT power	92.92	MW
ST power	0	MW
Percent of heat available to Steam cycle	0	%
Overall electrical efficiency after losses	64.6	%
Efficiency GT Cycle	35	%
Efficiency ST cycle	0	%
Overall power output	469	MW
Power from direct generation	423.97	MW
Other power from GT/ST waste heat	0	MW
Energy content of fuel	725.85	MW

Capital Cost

Gas turbine complete generated by PPAP

Other items as above 3.9

Operating Cost

Natural gas \$3/GJ

Power cost is 7.4 c/kWh.

Interest rate, plant life span, load factor and O&M on the software as supplied by IEA are not as previously used, and will have to be reviewed.

Multi-Criteria Analysis

Parameter:	Raw Material Availability
Value:	Locally Common with unlimited availability
Parameter:	Process Conditions
Value:	T 1200-1600 ⁰ K, <10bar – needs tech breakthrough with known parallels
Parameter:	Novelty of Materials
Value:	Exotic ceramics – newly discovered material proven in similar duties
Parameter:	Plant Complexity
Value:	11 Major Units, no recycle (as generated by PPAP – this may need review)
Parameter:	Novelty of Process
Value:	Major new ideas with promising industrial units in operation
Parameter:	Safety Risk
Value:	Small Risk – extensively demonstrated and publicly accepted
Parameter:	Environmental Impact
Value:	Benign Waste – extensively demonstrated and publicly accepted

5 RESULTS

The full summary output from PPAP is as follows:

Heat Input		725.9	MW
Estimated Net Electricity Output		469.0	MW
Net Efficiency		64.6	%
CO2 output/ kg/s		0.4	kg/s
CO2 output/kWh		0.003	kg/kWh
Estimated Capital Cost		1338.1	M\$
Estimated Op Cost		7.4	c/kWh

Multi-Criteria Assessment**Decision Factor Scores**

Acceptance		32.0
Applicability		40.1
Confidence		21.0
Estimated Cost		35.0
	Total	128.1
	Total cost only	195.1

Risk assessment

Averaged risk level		20
Controlling risk level	Materials	63

Design of CO₂ capturing solid oxide fuel cell

The basic principle is to use a so called “4” pole cell in which anode and cathode gas are fully segregated throughout the device.

Designs may be able to achieve this degree of separate manifolding which is an unusual design feature since in typical cells the waste anode and cathode gas are allowed to combine in order to complete oxidation of the fuel. The design most nearly achieving this has been the Siemens Westinghouse tubular design which uses a tubes closed at one end which project through a number of ceramic board tube sheets. Air is supplied via small ceramic tubes, one each, leading air to the closed end from whence it flows back through the annular space around the injection tube. This forms an internal heat exchanger (a bit like a double pipe) which allows air to be introduced well below the operating temperature (about 600C is typical) without causing thermal shock. Fuel is on the outside of the main tubes and can be segregated from the exhaust air by having additional tube sheets. There are two tube sheets in the traditional design leaving a space which can be used to provide an anode gas recycle. Normally the net anode gas leaks through the second tube sheet to mix with spent cathode gas. If this last tube sheet is sealed than the anode gas can be fully segregated from the cathode gas. This seal at 1000C is a huge technological challenge even at atmospheric pressure. When operating in hybrid mode (i.e pressurized) the sealing clearances become even more onerous. The ceramic boards are porous and do not provide a full seal. Some form of barrier layer, e.g. a metal foil would have to be introduced. Also the tubes slide in the tube sheet in the conventional design providing a further leak path which is difficult to seal. A fixed final tube sheet and another solution for accommodating tube expansion is an alternative solution. Siemens has also experimented with flattened tubes to increase active area and the sealing of non-circular penetrations could present an additional challenge.

Rolls Royce has developed a similar layout to the above based on oblong section tubes (prisms) closed at one end. Fuel flows inside these tubes rather than outside as in the Siemens design. The tubes are sealed into a flat base plate at one end and are thus free to expand longitudinally. The base plates have to be sealed together to keep the fuel from the cathode gas which flows around the outside of the tubes. The tubes are made from cheap porous ceramic material and the fuel cell layers are screen printed on to this support making for a very cheap production process. The RR design does not provide an intrinsic air pre heat so a higher inlet temperature is probably needed to avoid thermal shock, typically 800-950C judging by their article. RR has a clever design to achieve high air inlet temperatures without an expensive recuperator. They compress the air adiabatically to 350 C and then recycle cathode gas which is further heated by burning the anode gas in it. This of course mixes all of the concentrated anode exit gas into the cathode gas which is no good for capture!

There are also some slightly odd things about the temperatures shown on the RR diagram. Firstly there is no temperature rise over the cell which is impossible as the energy which does not get converted to power all ends up as heat so the product stream must be hotter than the inlet stream. The internal reforming heat exchange does not

prevent this net temperature rise!. Rough calculations show that the RR design is somewhat more efficient than the design with recuperators even when say a 1 bar pressure drop is taken for driving the ejector which induces the recycle. The recycle could either be from downstream of the cell but before the afterburner or presuming all the air goes through the afterburner could be taken from the exit of the afterburner which is hotter. This seems to indicate that with a recycle ratio of 1 the net stoichiometric flow should be about 2-3 times. Recycling from downstream of the afterburner seems to be more efficient. The 350 C adiabatic compression temperature from the air compressor is quite high suggesting a rather inefficient compressor in the RR design. This may be the reality of the very small machines they are considering at this stage in development.


The final design is simply to use a conventional flat plate design. This does require high air inlet temperatures as the flat plates are very susceptible to thermal shock. Conventional wisdom says that no more than 100C temperature rise is acceptable across this type of cell. Also the flat plate designs have not as yet aspired to MW capacities because it is difficult to make big stacks. In principle the sealing problem is much less since the edges of the plates have to be sealed anyway. The manifolds on the inlet side have to be sealed and the same construction can be used for the outlet side. Main problem with this design is that the basic sealing between plates is still problematical.

There is a flat plate design in which the gases are introduced at the centre of a disc and flow radially outwards. (Sulzer Hexis). The manifolding for the inlet gases is all at the centre, there is basically a large hole down the centre of the discs. However the gases are released at the periphery of the discs and freely mix. It is not practical to manifold the periphery. If this is not necessary you can see that this arrangement is very attractive.


My proposal is to try simulating first a RR based system using their cathode gas ejector recycle but without the combustor. The recycle should be taken from the outlet of the afterburning device. A net stoichiometric air ratio of about 2 with a recycle of the same molar amount. You need to assume that say 80% of the fuel is consumed in the main stack, electrical voltage is 700mv giving a DC efficiency for the fuel consumed in the stack of 67.3%. A target stack exit temperature of 900C completes the boundary conditions. This temperature will rise to about 980C at the outlet of the afterburning device. This afterburning device has all of the air flow through it and transports oxygen to the fuel until it is precisely combusted. You should assume precise stoichiometric combustion in this device i.e zero fuel in the final stack gas but no excess oxygen transported. This should lead to a system with a stack air inlet temperature of about 740C. O₂ content in the afterburner outlet would be about 11% and in the stack inlet about 15.8% giving plenty of partial pressure for operation of the cell. Use suitable efficiencies for the compressor and expander, suggest 85% is a conservative estimate for larger systems.

DC to AC conversion losses have to be included, suggest 95% efficiency is a top limit for big systems but maybe 90% is more realistic. With 95% I predicted an efficiency of about 59% overall but this is a very rough estimate!

CO2 separating SOFC power cycle for PPAP evaluation



Gasconsult Limited
SOFC Evaluation 17-05-2004 for IEAGHG
50 MW net output



Workbook: Case (Main)

SOFC HYSIS SIMULATION

Material Streams

Name	A1	A2	A3	A4	A5
Vapour Fraction	1	1	1	1	0
Pressure (bar)	1.013	4	3.8	3.8	3.8
Temperature (C)	25	198.3	25	25	25
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1.8	1.8	1.8	1.8	0
Comp Molar Flow (Nitrogen) (kgmole/h)	4809.1	4809.1	4809.1	4809.1	0
Comp Molar Flow (Oxygen) (kgmole/h)	1289.9	1289.9	1289.9	1289.9	0
Comp Molar Flow (Argon) (kgmole/h)	57.9	57.9	57.9	57.9	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	41.3	41.3	41.3	41.3	0
Molar Flow (kgmole/h)	6200	6200	6200	6200	0
Mass Flow (kg/h)	179131	179131	179131	179131	0
Molecular Weight	28.89	28.89	28.89	28.89	18.02
Heat Flow (kW)	-2979.4	5775.4	-3020.4	-3020.4	0
Mass Lower Heating Value (kcal/kg)					

Name	A6	A7	A8	A9	C1
Vapour Fraction	1	1	1	1	1
Pressure (bar)	8.25	8.05	7.65	6.8	6.8
Temperature (C)	113.6	500	580	567.7	1000
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1.8	1.8	1.8	1.8	343.3
Comp Molar Flow (Nitrogen) (kgmole/h)	4809.1	4809.1	4809.1	4809.1	1.1
Comp Molar Flow (Oxygen) (kgmole/h)	1289.9	1289.9	1289.9	1289.9	0.1
Comp Molar Flow (Argon) (kgmole/h)	57.9	57.9	57.9	57.9	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	41.3	41.3	41.3	41.3	618.8
Molar Flow (kgmole/h)	6200	6200	6200	6200	963.3
Mass Flow (kg/h)	179131	179131	179131	179131	26290.3
Molecular Weight	28.89	28.89	28.89	28.89	27.29
Heat Flow (kW)	1422.3	21730.6	26134.1	25452.6	-67878.5
Mass Lower Heating Value (kcal/kg)					

Name	C2	C3	C4	C5	C6
Vapour Fraction	1	1	0.3575	0	1
Pressure (bar)	6.8	6.8	6.6	6.6	6.6
Temperature (C)	649.3	489.5	25	25	25
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	343.3	343.3	343.3	1.9	341.3
Comp Molar Flow (Nitrogen) (kgmole/h)	1.1	1.1	1.1	0	1.1
Comp Molar Flow (Oxygen) (kgmole/h)	0.1	0.1	0.1	0	0.1
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	618.8	618.8	618.8	617	1.8
Molar Flow (kgmole/h)	963.3	963.3	963.3	618.9	344.4
Mass Flow (kg/h)	26290.3	26290.3	26290.3	11199.1	15091.2
Molecular Weight	27.29	27.29	27.29	18.1	43.82
Heat Flow (kW)	-72282.1	-74159.1	-86608.6	-49123.6	-37485
Mass Lower Heating Value (kcal/kg)					

Name	C7	C8	C9	C10	C11
Vapour Fraction	1	0.9969	0	1	1
Pressure (bar)	21	20.7	20.7	20.7	65.91
Temperature (C)	135.5	25	25	25	138.1
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	341.3	341.3	0	341.3	341.3
Comp Molar Flow (Nitrogen) (kgmole/h)	1.1	1.1	0	1.1	1.1
Comp Molar Flow (Oxygen) (kgmole/h)	0.1	0.1	0	0.1	0.1
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	1.8	1.8	1.1	0.7	0.7
Molar Flow (kgmole/h)	344.4	344.4	1.1	343.3	343.3
Mass Flow (kg/h)	15091.2	15091.2	19.7	15071.5	15071.5
Molecular Weight	43.82	43.82	18.26	43.9	43.9
Heat Flow (kW)	-37085.9	-37560.7	-86	-37474.8	-37110.2
Mass Lower Heating Value (kcal/kg)					

Name	C12	C13	C14	CW1	CW2
Vapour Fraction	0	0	0	0	0
Pressure (bar)	65.41	120	110	1.5	4
Temperature (C)	25	38.63	36.8	20	20.02
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	341.3	341.3	341.3	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	1.1	1.1	1.1	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0.1	0.1	0.1	0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	0.7	0.7	0.7	106620.2	106620.2
Molar Flow (kgmole/h)	343.3	343.3	343.3	106620.2	106620.2
Mass Flow (kg/h)	15071.5	15071.5	15071.5	1.92E+06	1.92E+06
Molecular Weight	43.9	43.9	43.9	18.02	18.02
Heat Flow (kW)	-38304.7	-38262.2	-38262.2	-8.46E+06	-8.46E+06
Mass Lower Heating Value (kcal/kg)					

Name	CW11	CW12	CW13	CW14	CW21
Vapour Fraction	0	0	0	0	0
Pressure (bar)	4	4	4	4	3
Temperature (C)	20.02	20.02	20.02	20.02	30
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	40928.2	57924.3	2209.5	5558.3	40928.2
Molar Flow (kgmole/h)	40928.2	57924.3	2209.5	5558.3	40928.2
Mass Flow (kg/h)	737324.8	1.04E+06	39804.8	100133.2	737324.8
Molecular Weight	18.02	18.02	18.02	18.02	18.02
Heat Flow (kW)	-3.25E+06	-4.60E+06	-175404.5	-441248.9	-3.24E+06
Mass Lower Heating Value (kcal/kg)					

Name	CW22	CW23	CW24	FG1	FG2
Vapour Fraction	0	0	0	1	1
Pressure (bar)	3	3	3	6.6	1
Temperature (C)	30	30	30	1048	612.4
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	1.8	1.8
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	4809.1	4809.1
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	642.3	642.3
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	57.9	57.9
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	57924.3	2209.5	5558.3	41.3	41.3
Molar Flow (kgmole/h)	57924.3	2209.5	5558.3	5552.4	5552.4
Mass Flow (kg/h)	1.04E+06	39804.8	100133.2	158408.1	158408.1
Molecular Weight	18.02	18.02	18.02	28.53	28.53
Heat Flow (kW)	-4.59E+06	-174929.7	-440054.3	47044.1	24554
Mass Lower Heating Value (kcal/kg)					

Name	FG3	LAMBDA	NG1	NG2	NG3
Vapour Fraction	1	1.9922	1	1	1
Pressure (bar)	1		28	26.5	26.1
Temperature (C)	184.9		20	19.09	450
Comp Molar Flow (Hydrogen) (kgmole/h)	0		0	0	0
Comp Molar Flow (CO) (kgmole/h)	0		0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1.8		5.2	5.2	5.2
Comp Molar Flow (Nitrogen) (kgmole/h)	4809.1		1.1	1.1	1.1
Comp Molar Flow (Oxygen) (kgmole/h)	642.3		0	0	0
Comp Molar Flow (Argon) (kgmole/h)	57.9		0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0		240.8	240.8	240.8
Comp Molar Flow (Ethane) (kgmole/h)	0		26.4	26.4	26.4
Comp Molar Flow (Propane) (kgmole/h)	0		9.5	9.5	9.5
Comp Molar Flow (i-Butane) (kgmole/h)	0		4	4	4
Comp Molar Flow (n-Butane) (kgmole/h)	0		0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0		0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0		0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0		0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0		0	0	0
Comp Molar Flow (H2O) (kgmole/h)	41.3		0	0	0
Molar Flow (kgmole/h)	5552.4		287	287	287
Mass Flow (kg/h)	158408.1		5567.7	5567.7	5567.7
Molecular Weight	28.53		19.4	19.4	19.4
Heat Flow (kW)	4245.7		-6692.6	-6692.6	-4815.6
Mass Lower Heating Value (kcal/kg)					

Name	NG4	NG5	NG1 CV	OX1	OX2
Vapour Fraction	1	1	1	1	1
Pressure (bar)	12.25	7	28	6.8	6.8
Temperature (C)	449.3	424.7	20	763	763
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	5.2	5.2	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	1.1	1.1	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	647.6	534.3
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	240.8	240.8	240.8	0	0
Comp Molar Flow (Ethane) (kgmole/h)	26.4	26.4	26.4	0	0
Comp Molar Flow (Propane) (kgmole/h)	9.5	9.5	9.5	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	4	4	4	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	287	287	280.7	647.6	534.3
Mass Flow (kg/h)	5567.7	5567.7	5308.2	20723	17096.5
Molecular Weight	19.4	19.4	18.91	32	32
Heat Flow (kW)	-4815.6	-4945.2	-6125.8	4313.3	3558.5
Mass Lower Heating Value (kcal/kg)			1.18E+04		

Name	OX3	OX RATIO	OX2r	PO1	PO2
Vapour Fraction	1	1.0002	1	1	1
Pressure (bar)	6.8		6.8	6.8	6.8
Temperature (C)	763		763	759.1	759.1
Comp Molar Flow (Hydrogen) (kgmole/h)	0		0	0	0
Comp Molar Flow (CO) (kgmole/h)	0		0	0	0
Comp Molar Flow (CO2) (kgmole/h)	0		0	3.1	1.9
Comp Molar Flow (Nitrogen) (kgmole/h)	0		0	8031.1	5007.7
Comp Molar Flow (Oxygen) (kgmole/h)	113.3		534.3	1720.2	1072.6
Comp Molar Flow (Argon) (kgmole/h)	0		0	96.6	60.3
Comp Molar Flow (Methane) (kgmole/h)	0		0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0		0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0		0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0		0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0		0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0		0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0		0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0		0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0		0	0	0
Comp Molar Flow (H2O) (kgmole/h)	0		0	68.9	43
Molar Flow (kgmole/h)	113.3		534.3	9920	6185.5
Mass Flow (kg/h)	3626.5		17097.1	285261.3	177871.3
Molecular Weight	32		32	28.76	28.76
Heat Flow (kW)	754.8		3558.6	57652.8	35948.7
Mass Lower Heating Value (kcal/kg)					

Name	PO3	PO4	PO5	PO6	PO7
Vapour Fraction	1	1	1	1	1
Pressure (bar)	6.8	6.8	6.8	6.6	6.6
Temperature (C)	759.1	763	760.4	1357	880
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1.2	1.2	3.1	3.1	3.1
Comp Molar Flow (Nitrogen) (kgmole/h)	3023.4	3023.4	8031.1	8031.1	8031.1
Comp Molar Flow (Oxygen) (kgmole/h)	647.6	0	1072.6	1072.6	1072.6
Comp Molar Flow (Argon) (kgmole/h)	36.4	36.4	96.6	96.6	96.6
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	25.9	25.9	68.9	68.9	68.9
Molar Flow (kgmole/h)	3734.5	3086.9	9272.4	9272.4	9272.4
Mass Flow (kg/h)	107390.1	86667.1	264538.4	264538.4	264538.4
Molecular Weight	28.76	28.08	28.53	28.53	28.53
Heat Flow (kW)	21704.1	17526.1	53474.8	106068.9	63780.3
Mass Lower Heating Value (kcal/kg)					

Name	PO8	PO9	PO10	PO10r	PR1
Vapour Fraction	1	1	1	1	1
Pressure (bar)	6.6	6.6	6.8	6.8	7
Temperature (C)	1048	1048	1067	1067	721.3
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	121.8
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	80.5
Comp Molar Flow (CO2) (kgmole/h)	3.1	1.2	1.2	1.2	231.5
Comp Molar Flow (Nitrogen) (kgmole/h)	8031.1	3222	3222	3222	2.2
Comp Molar Flow (Oxygen) (kgmole/h)	1072.6	430.3	430.3	430.3	0
Comp Molar Flow (Argon) (kgmole/h)	96.6	38.8	38.8	38.8	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	240.8
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	26.4
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	9.5
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	4
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	68.9	27.6	27.6	27.6	431.3
Molar Flow (kgmole/h)	9272.4	3720	3720	3720	1148
Mass Flow (kg/h)	264538.4	106130.2	106130.2	106130.3	25828.6
Molecular Weight	28.53	28.53	28.53	28.53	22.5
Heat Flow (kW)	78562.7	31518.6	32200.1	32200.2	-52956.6
Mass Lower Heating Value (kcal/kg)					

Name	PR2	PR3	PR4	PR5	PR6
Vapour Fraction	1	1	1	1	1
Pressure (bar)	7	7	6.8	6.8	6.8
Temperature (C)	717.1	604.8	2517	880	880
Comp Molar Flow (Hydrogen) (kgmole/h)	121.8	275.5	0	258	136.2
Comp Molar Flow (CO) (kgmole/h)	99.6	92.4	0	170.5	90
Comp Molar Flow (CO2) (kgmole/h)	231.5	275.3	542.9	479.5	253.2
Comp Molar Flow (Nitrogen) (kgmole/h)	2.2	2.2	2.2	2.2	1.1
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	319	282.4	107.2	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	412.2	331.7	957.6	913.8	482.5
Molar Flow (kgmole/h)	1186.3	1259.5	1609.8	1824.1	963.1
Mass Flow (kg/h)	25828.6	25828.6	42924.8	42924.9	22664
Molecular Weight	21.77	20.51	26.66	23.53	23.53
Heat Flow (kW)	-52956.4	-52956.4	-49397.8	-101991.9	-53850.9
Mass Lower Heating Value (kcal/kg)					

Name	PR7	PR8	PR8r
Vapour Fraction	1	1	1
Pressure (bar)	6.8	7	7
Temperature (C)	880	892.4	892.4
Comp Molar Flow (Hydrogen) (kgmole/h)	121.8	121.8	121.8
Comp Molar Flow (CO) (kgmole/h)	80.5	80.5	80.5
Comp Molar Flow (CO2) (kgmole/h)	226.3	226.3	226.3
Comp Molar Flow (Nitrogen) (kgmole/h)	1	1	1
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0
Comp Molar Flow (Methane) (kgmole/h)	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0
Comp Molar Flow (i-Butane) (kgmole/h)	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0
Comp Molar Flow (i-Pentane) (kgmole/h)	0	0	0
Comp Molar Flow (n-Pentane) (kgmole/h)	0	0	0
Comp Molar Flow (n-Hexane) (kgmole/h)	0	0	0
Comp Molar Flow (Ammonia) (kgmole/h)	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	431.3	431.3	431.3
Molar Flow (kgmole/h)	861	861	861
Mass Flow (kg/h)	20260.9	20260.9	20260.9
Molecular Weight	23.53	23.53	23.53
Heat Flow (kW)	-48140.9	-48011.4	-48011.4
Mass Lower Heating Value (kcal/kg)			
Compositions			

Name	PREREFORMER-Liquid	REFORMER-Liquid	COMBUSTOR-Liquid	POST COMBUSTOR-Liquid	INVERT HEAVIES-Liquid
Comp Mole Frac (Hydrogen)	0.2187	0.1415	0	0	0.1027
Comp Mole Frac (CO)	0.0734	0.0935	0	0	0.084
Comp Mole Frac (CO2)	0.2186	0.2629	0.3372	0.3563	0.1952
Comp Mole Frac (Nitrogen)	0.0017	0.0012	0.0014	0.0012	0.0018
Comp Mole Frac (Oxygen)	0	0	0	0.0001	0
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0.2242	0	0.0666	0	0.2689
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.2634	0.501	0.5948	0.6423	0.3475

Name	NG1	NG3	NG5	PR8r	PR1
Comp Mole Frac (Hydrogen)	0	0	0	0.1415	0.1061
Comp Mole Frac (CO)	0	0	0	0.0935	0.0701
Comp Mole Frac (CO2)	0.018	0.018	0.018	0.2629	0.2017
Comp Mole Frac (Nitrogen)	0.004	0.004	0.004	0.0012	0.0019
Comp Mole Frac (Oxygen)	0	0	0	0	0
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0.839	0.839	0.839	0	0.2098
Comp Mole Frac (Ethane)	0.092	0.092	0.092	0	0.023
Comp Mole Frac (Propane)	0.033	0.033	0.033	0	0.0082
Comp Mole Frac (i-Butane)	0.014	0.014	0.014	0	0.0035
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0	0	0	0.501	0.3757

Name	PR3	A1	A2	PO10r	A9
Comp Mole Frac (Hydrogen)	0.2187	0	0	0	0
Comp Mole Frac (CO)	0.0734	0	0	0	0
Comp Mole Frac (CO2)	0.2186	0.0003	0.0003	0.0003	0.0003
Comp Mole Frac (Nitrogen)	0.0017	0.7757	0.7757	0.8661	0.7757
Comp Mole Frac (Oxygen)	0	0.208	0.208	0.1157	0.208
Comp Mole Frac (Argon)	0	0.0093	0.0093	0.0104	0.0093
Comp Mole Frac (Methane)	0.2242	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.2634	0.0067	0.0067	0.0074	0.0067

Name	PO1	PO4	PR4	PR5	PO6
Comp Mole Frac (Hydrogen)	0	0	0	0.1415	0
Comp Mole Frac (CO)	0	0	0	0.0935	0
Comp Mole Frac (CO2)	0.0003	0.0004	0.3373	0.2629	0.0003
Comp Mole Frac (Nitrogen)	0.8096	0.9794	0.0014	0.0012	0.8661
Comp Mole Frac (Oxygen)	0.1734	0	0	0	0.1157
Comp Mole Frac (Argon)	0.0097	0.0118	0	0	0.0104
Comp Mole Frac (Methane)	0	0	0.0666	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0069	0.0084	0.5948	0.501	0.0074

Name	PO7	PR8	PR6	PO10	OX2r
Comp Mole Frac (Hydrogen)	0	0.1415	0.1415	0	0
Comp Mole Frac (CO)	0	0.0935	0.0935	0	0
Comp Mole Frac (CO2)	0.0003	0.2629	0.2629	0.0003	0
Comp Mole Frac (Nitrogen)	0.8661	0.0012	0.0012	0.8661	0
Comp Mole Frac (Oxygen)	0.1157	0	0	0.1157	1
Comp Mole Frac (Argon)	0.0104	0	0	0.0104	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0074	0.501	0.501	0.0074	0

Name	C1	PO8	FG1	PR7	NG4
Comp Mole Frac (Hydrogen)	0	0	0	0.1415	0
Comp Mole Frac (CO)	0	0	0	0.0935	0
Comp Mole Frac (CO2)	0.3563	0.0003	0.0003	0.2629	0.018
Comp Mole Frac (Nitrogen)	0.0012	0.8661	0.8661	0.0012	0.004
Comp Mole Frac (Oxygen)	0.0001	0.1157	0.1157	0	0
Comp Mole Frac (Argon)	0	0.0104	0.0104	0	0
Comp Mole Frac (Methane)	0	0	0	0	0.839
Comp Mole Frac (Ethane)	0	0	0	0	0.092
Comp Mole Frac (Propane)	0	0	0	0	0.033
Comp Mole Frac (i-Butane)	0	0	0	0	0.014
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.6423	0.0074	0.0074	0.501	0

Name	PO9	FG2	PR2	OX RATIO	PO3
Comp Mole Frac (Hydrogen)	0	0	0.1027		0
Comp Mole Frac (CO)	0	0	0.084		0
Comp Mole Frac (CO2)	0.0003	0.0003	0.1952		0.0003
Comp Mole Frac (Nitrogen)	0.8661	0.8661	0.0018		0.8096
Comp Mole Frac (Oxygen)	0.1157	0.1157	0		0.1734
Comp Mole Frac (Argon)	0.0104	0.0104	0		0.0097
Comp Mole Frac (Methane)	0	0	0.2689		0
Comp Mole Frac (Ethane)	0	0	0		0
Comp Mole Frac (Propane)	0	0	0		0
Comp Mole Frac (i-Butane)	0	0	0		0
Comp Mole Frac (n-Butane)	0	0	0		0
Comp Mole Frac (i-Pentane)	0	0	0		0
Comp Mole Frac (n-Pentane)	0	0	0		0
Comp Mole Frac (n-Hexane)	0	0	0		0
Comp Mole Frac (Ammonia)	0	0	0		0
Comp Mole Frac (H2O)	0.0074	0.0074	0.3475		0.0069

Name	PO2	OX1	PO5	OX2	OX3
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.0003	0	0.0003	0	0
Comp Mole Frac (Nitrogen)	0.8096	0	0.8661	0	0
Comp Mole Frac (Oxygen)	0.1734	1	0.1157	1	1
Comp Mole Frac (Argon)	0.0097	0	0.0104	0	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0069	0	0.0074	0	0

Name	A3	A4	A5	A6	A8
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.0003	0.0003	0	0.0003	0.0003
Comp Mole Frac (Nitrogen)	0.7757	0.7757	0	0.7757	0.7757
Comp Mole Frac (Oxygen)	0.208	0.208	0	0.208	0.208
Comp Mole Frac (Argon)	0.0093	0.0093	0	0.0093	0.0093
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0067	0.0067	0.9999	0.0067	0.0067

Name	NG2	FG3	A7	C2	C3
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.018	0.0003	0.0003	0.3563	0.3563
Comp Mole Frac (Nitrogen)	0.004	0.8661	0.7757	0.0012	0.0012
Comp Mole Frac (Oxygen)	0	0.1157	0.208	0.0001	0.0001
Comp Mole Frac (Argon)	0	0.0104	0.0093	0	0
Comp Mole Frac (Methane)	0.839	0	0	0	0
Comp Mole Frac (Ethane)	0.092	0	0	0	0
Comp Mole Frac (Propane)	0.033	0	0	0	0
Comp Mole Frac (i-Butane)	0.014	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0	0.0074	0.0067	0.6423	0.6423

Name	C4	C6	C5	C7	C8
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.3563	0.991	0.0031	0.991	0.991
Comp Mole Frac (Nitrogen)	0.0012	0.0033	0	0.0033	0.0033
Comp Mole Frac (Oxygen)	0.0001	0.0004	0	0.0004	0.0004
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.6423	0.0052	0.9969	0.0052	0.0052

Name	C10	C9	C11	C12	C13
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.9941	0.0094	0.9941	0.9941	0.9941
Comp Mole Frac (Nitrogen)	0.0033	0	0.0033	0.0033	0.0033
Comp Mole Frac (Oxygen)	0.0004	0	0.0004	0.0004	0.0004
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0021	0.9906	0.0021	0.0021	0.0021

Name	C14	CW11	CW21	CW12	CW22
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0.9941	0	0	0	0
Comp Mole Frac (Nitrogen)	0.0033	0	0	0	0
Comp Mole Frac (Oxygen)	0.0004	0	0	0	0
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	0.0021	1	1	1	1

Name	CW13	CW23	CW14	CW24	CW1
Comp Mole Frac (Hydrogen)	0	0	0	0	0
Comp Mole Frac (CO)	0	0	0	0	0
Comp Mole Frac (CO2)	0	0	0	0	0
Comp Mole Frac (Nitrogen)	0	0	0	0	0
Comp Mole Frac (Oxygen)	0	0	0	0	0
Comp Mole Frac (Argon)	0	0	0	0	0
Comp Mole Frac (Methane)	0	0	0	0	0
Comp Mole Frac (Ethane)	0	0	0	0	0
Comp Mole Frac (Propane)	0	0	0	0	0
Comp Mole Frac (i-Butane)	0	0	0	0	0
Comp Mole Frac (n-Butane)	0	0	0	0	0
Comp Mole Frac (i-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Pentane)	0	0	0	0	0
Comp Mole Frac (n-Hexane)	0	0	0	0	0
Comp Mole Frac (Ammonia)	0	0	0	0	0
Comp Mole Frac (H2O)	1	1	1	1	1

Name	CW2	LAMBDA	NG1 CV
Comp Mole Frac (Hydrogen)	0		0
Comp Mole Frac (CO)	0		0
Comp Mole Frac (CO2)	0		0
Comp Mole Frac (Nitrogen)	0		0
Comp Mole Frac (Oxygen)	0		0
Comp Mole Frac (Argon)	0		0
Comp Mole Frac (Methane)	0		0.8579
Comp Mole Frac (Ethane)	0		0.0941
Comp Mole Frac (Propane)	0		0.0337
Comp Mole Frac (i-Butane)	0		0.0143
Comp Mole Frac (n-Butane)	0		0
Comp Mole Frac (i-Pentane)	0		0
Comp Mole Frac (n-Pentane)	0		0
Comp Mole Frac (n-Hexane)	0		0
Comp Mole Frac (Ammonia)	0		0
Comp Mole Frac (H2O)	1		0
Energy Streams			

Name	WK-101	WK-102	Q-SEP101	QREF	STACK POWER
Heat Flow (kW)	129.5	681.5	135.3	52594.1	42288.6
Name	QP-C	WGTC-101	WGTEXP-101	WGTC-102	WK-111
Heat Flow (kW)	14782.4	8754.8	22490.1	4442.7	399.1
Name	WK-112	WP-111	WP-121		
Heat Flow (kW)	364.6	42.5	175.9		

PPAP EVALUATIONS
GCL Contract No 014-011

Evaluation of CO₂ Acceptor Technology

Gasconsult Ltd (GCL) now has pleasure in submitting for IEA's comments this Report of our PPAP Evaluation of a process for power production from natural gas with CO₂ capture, based on simultaneous steam reforming and CO shift over a nickel catalyst and CO₂ sorption by limestone or dolomite. This work was authorised by IEA in e-mail of 18 June 2004.

1. INTRODUCTION

The process and the recommended operation conditions were advised to GCL in IEA's e-mails 30 April (with attachment) and 11 June 2004.

2. BASIS OF DESIGN

The Basis of Design for the evaluation is IEA Technical and Financial Assessment Criteria Rev B 1999, with these exceptions:

- 2.1 Natural gas cost is \$3 /GJ.
- 2.2 Calculated carbon capture for the reaction conditions chosen is 83.3%, slightly lower than the target 85% set by IEA. It is probable that 85% capture can be achieved, but such fine-tuning would, on our view, best be left until after the prospective stage of pilot-scale testing and demonstration discussed below.

3. TECHNOLOGY DISCUSSION

3.1 Basic Concept

The basic process feature consists of admitting a natural gas plus steam into a fluidised bed containing both a nickel-based steam reforming catalyst and free calcium oxide. The hydrocarbon and steam are converted over the nickel catalyst into hydrogen and carbon oxides by the steam reforming and CO shift reactions, while the lime removes the CO₂ produced. The favourable effect of the continuous removal of CO₂ permits the reforming/shift reactions to be operated at a much lower temperature (around 600⁰-700⁰C) than in a normal steam reforming plant, that temperature being sufficiently low for the lime to capture most of the CO₂ produced. The gas leaving the reforming reactor, consisting mainly of hydrogen and unreacted steam with some residual methane and carbon oxides, is used directly as fuel for a gas turbine.

The spent limestone (partly converted to CaCO₃) flows to a regeneration reactor, in which it is heated to around 1000⁰C by combustion of an auxiliary stream of natural gas with oxygen, thus releasing the CO₂ absorbed in the reforming reactor. The regenerated CaO then returns to the reforming reactor.

The outlet gas from this second reactor, consisting of CO₂ plus steam, can be cooled to ambient temperature to condense its water content and then sent, at close to the feed natural gas pressure, for liquefaction and sequestration. Alternatively it can be expanded in a power recovery turbine to a lower pressure, prior to cooling and removal of condensed steam, in which case the CO₂ is sent for sequestration at that lower pressure and accordingly requires more compression energy in the liquefaction stage.

If successfully implemented, and in comparison with a normal steam reforming process, the new scheme would:

- avoid the investment and energy loss resulting from cooling the fuel gas before, and reheating after, CO₂ removal
- produce the captured CO₂ at elevated pressure, thereby saving net liquefaction energy.

3.2 Process Parameters

Our simulations have been based on the following assumptions:

- Reforming pressure of 25 bar, assumed to be sufficient pressure to provide fuel directly to a modified gas turbine with 20:1 pressure ratio
- Natural gas preheated initially to 380⁰C, as needed for desulphurisation by CoMo/ZnO.
- No allowance has been made at this stage for recycle of the small amount of hydrogen from the reformer outlet that is necessary to provide the required concentration (about 2% H₂) upstream of the desulphurisers. As the required flow is only about 100kmol/h, the effect of this omission on efficiency and investment will be negligible.
- 4 mols of reforming steam per mol of carbon (in hydrocarbon) in natural gas.
- Reformer mixed feed inlet temperature 625⁰C.
- The base sorbent was assumed to be 50% mol CaCO₃ + 50% mol% MgO.
- Sorbent feed to reformer (mol%): CaO 27.5, CaCO₃ 22.5, MgO 50.
- 50% of CaO entering reformer converted to CaCO₃.
- Reformer equilibrium approaches (⁰C): CH₄/stm 10, shift 0, CO₂ capture 0.
- Nominal fluidising/transport CO₂ recycle to regenerator of 1810kmol/h.
- Subcritical steam cycle HP turbine inlet 150 bar/540⁰C, reheat to 540⁰C.
- Supercritical steam cycle HP turbine inlet 250 bar/600⁰C, reheat to 540⁰C.
- Optional CO₂/steam expansion turbine inlet 25 bar/1070⁰C, outlet 3 bar.

3.3 Simulation of Heat and Material Balance

The heat and material balance for the selected case was simulated on HYSYS (please see flow diagram CaOCaCO3.jpg and Worksheet CaOCaCO3.xls attached). After allowance for the power required to produce oxygen and deliver it at high pressure, the resulting overall gas-to-power efficiencies are:

	<u>% LHV</u>
- Subcritical steam cycle	48.3
- Subcritical steam cycle with CO ₂ /steam expander	47.1
- Supercritical steam cycle	49.2

In view of the very small differences and rather small HP turbine capacity (50MW approx shaft power), we have based PPAP evaluation on the subcritical steam cycle (without CO₂/steam expander).

3.4 Plant Design Aspects

Considering the plant as a whole, there are aspects of the new scheme that will require further experimental work to determine if it offers a realistic alternative to steam reforming technologies, particularly:

- Verification of reaction equilibrium approaches in the reformer
- Nickel catalyst replacement rate. There is only some prospect of keeping this within acceptable limits if a dense, attrition-resistant catalyst is available, or can be developed, that will largely remain in the reformer reactor. Fluid bed steam reformers are understood to have been piloted by Exxon and GTI Chicago.
- Confirmation of gas filter performance, particularly for the regenerator outlet gas stream. Conceivably this could be overcome by locating the primary cyclones directly at the regenerator outlet (Stream C2 on the simulation) and the secondary cyclones and filters at Stream C3, where the gas temperature have been reduced to under 600⁰C.

Another factor, relating to plant design rather to the basic process, is the possibility of integrating the gas turbine with the oxygen plant. In the present simulation, the molar exhaust flow of the gas turbine is 111% of the compressor flow, whereas in an equivalent gas turbine fired with natural gas the exhaust flow is about 104% of the compressor flow. This opens up the possibility, with the new process, of extracting some air from the discharge of the GT air compressor, to restore the relative flows of a methane-fired gas turbine. The extracted air can then be diverted to the oxygen plant, thereby reducing the normal investment there in air compressors. Development of this option is, however, beyond the scope of this evaluation.

4. MAIN PPAP INPUTS

Plant Components

GT

ST

PFBC

ASU

CO₂ compression/pumping to 110 bar

Fuel Specification

Natural gas 100% CV 48912 kJ/kg, C fraction 0.74

Mass & energy fuel 21.57 kg/s

CO₂ recovered 83.3%

PPAP Lite Details

CO ₂ compression power	5.1	MW
O ₂ compression power	13.6	MW
HRSG on GT	400	MW
GT power	398	MW
ST power	166	MW
Percent of heat available to Steam cycle	25	%
Overall electrical efficiency after losses	47.7	%
Efficiency GT Cycle	35	%
Efficiency ST cycle	35	%
Overall power output	503	MW
Power from direct generation	0.00	MW
Other power from GT/ST waste heat	0	MW
Energy content of fuel	1055.03	MW

Capital Cost

Oxygen Plant generated by PPAP

Gas turbine complete by PPAP with 30% cost enhancement

HRSTG by PPAP

Steam system & turbine etc by PPAP

Reformer & regenerator by PPAP using PFBC with 50% cost enhancement

\$US 40 million total included for gas filters and catalyst handling

Total bottom line capital cost \$ 737 million

Operating Cost

Natural gas \$3/GJ

Power cost is 5.2 c/kWh.

Interest rate, plant life span, load factor and O&M as on the software v 3.0.2, supplied by IEA.

No special allowance has been made in the PPAP input for the cost of catalyst consumed. This could be quite considerable.

Multi-Criteria Analysis

Parameter: Raw Material Availability

Value: Locally Common with unlimited availability

Parameter: Process Conditions

Value: T 1200-1600⁰K, 10-60bar – but no significant technical barriers

Parameter: Novelty of Materials

Value: Existing special alloys – known material in known environment

Parameter: Plant Complexity

Value: 6 Major Units, no recycle (as generated by PPAP – this may need review)

Parameter: Novelty of Process

Value: Major Modifications with problematical credited scientific proof of concept. The warning “very high risk of failure” is produced by PPAP

Parameter: Safety Risk
 Value: Small Risk – extensively demonstrated and publicly accepted

Parameter: Environmental Impact
 Value: Benign Waste – extensively demonstrated and publicly accepted

5. RESULTS

The full summary output from PPAP is as follows:

Heat Input		1055.0	MW
Estimated Net Electricity Output		503.0	MW
Net Efficiency		47.7	%
CO ₂ output/ kg/s		9.8	kg/s
CO ₂ output/kWh		0.070	kg/kWh
Estimated Capital Cost		737.1	M\$
Estimated Op Cost		5.2	c/kWh

Multi-Criteria Assessment

Decision Factor Scores

Acceptance		32.0
Applicability		28.4
Confidence		30.0
Estimated Cost		74.8
	Total	165.2
	Total cost only	238.9

Risk assessment

Averaged risk level		21
Controlling risk level	Process novelty	100


6. CONCLUSIONS

The combined steam reforming and CO₂ chemisorption technology evaluated in this PPAP study could show promise of evolving into a technically feasible solution for electric power generation from natural gas with CO₂ capture.

Additional experimental and pilot plant work is, however, necessary for the purpose of determining a satisfactory method of ensuring that nickel losses in the spent dolomite do not exceed economically and environmentally acceptable levels. It might be concluded that the economics of this process are not so encouraging relative to much simpler processes, to justify this.

GASCONSULT LIMITED
CO2 Acceptor scheme

PPAP Jan 8 2005



CaOCaCO3 Workbook: Case (Main)

Streams

Name	A1	A2	A3	A4	A5
Vapour Fraction	1	1	1	1	1
Temperature (C)	9	461.2	461.2	461.2	461.2
Pressure (bar)	1	20	20	20	20
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	280.6	280.6	0	280.6	238.5
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	73051.7	73051.7	0	73051.7	62093.9
Comp Molar Flow (Oxygen) (kgmole/h)	19593.3	19593.3	0	19593.3	16654.3
Comp Molar Flow (Argon) (kgmole/h)	879.1	879.1	0	879.1	747.3
Comp Molar Flow (H2O) (kgmole/h)	637.9	637.9	0	637.9	542.2
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	94442.5	94442.5	0	94442.5	80276.2
Molecular Weight	28.93	28.93	28.93	28.93	28.93
Mass Flow (kg/h)	2.73E+06	2.73E+06	0	2.73E+06	2.32E+06
Heat Flow (kW)	-85871.5	271128	0	271128	230458.8

Name	A6	A7	A8	ASU kW	C1
Vapour Fraction	1	1	1		1
Temperature (C)	461.2	461.2	461.2		1303
Pressure (bar)	20	20	20		25
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0		1.1
Comp Molar Flow (CO) (kgmole/h)	0	0	0		0
Comp Molar Flow (CO2) (kgmole/h)	42.1	29.5	12.6		3403.1
Comp Molar Flow (Methane) (kgmole/h)	0	0	0		0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0		0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0		0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0		0
Comp Molar Flow (Nitrogen) (kgmole/h)	10957.8	7670.4	3287.3		7.9
Comp Molar Flow (Oxygen) (kgmole/h)	2939	2057.3	881.7		0
Comp Molar Flow (Argon) (kgmole/h)	131.9	92.3	39.6		44.6
Comp Molar Flow (H2O) (kgmole/h)	95.7	67	28.7		2960.8
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0		0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0		0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0		0
Molar Flow (kgmole/h)	14166.4	9916.5	4249.9		6417.5
Molecular Weight	28.93	28.93	28.93		31.96
Mass Flow (kg/h)	409851.1	286895.8	122955.3		205114.7
Heat Flow (kW)	40669.2	28468.4	12200.8	39985	-466891.9

Name	C2	C3	C4	C5	C6
Vapour Fraction	1	1	1	1	0.9001
Temperature (C)	1069	556.6	425	233.8	155
Pressure (bar)	25	24.7	24.4	23.9	23.4
Comp Molar Flow (Hydrogen) (kgmole/h)	1.1	1.1	1.1	1.1	1.1
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	5921.3	5921.3	5921.3	5921.3	5921.3
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	7.9	7.9	7.9	7.9	7.9
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	44.6	44.6	44.6	44.6	44.6
Comp Molar Flow (H2O) (kgmole/h)	2960.8	2960.8	2960.8	2960.8	2960.8
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	8935.7	8935.7	8935.7	8935.7	8935.7
Molecular Weight	35.36	35.36	35.36	35.36	35.36
Mass Flow (kg/h)	315938.9	315938.9	315938.9	315938.9	315938.9
Heat Flow (kW)	-726917.8	-791023.4	-806176.4	-827162.1	-844810.3

Name	C7	C8	C9	C10	C11
Vapour Fraction	0.6673	1	0	1	1
Temperature (C)	30	30	30	52.42	52.42
Pressure (bar)	23.1	23.1	23.1	30	30
Comp Molar Flow (Hydrogen) (kgmole/h)	1.1	1.1	0	1.1	0.3
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	5921.3	5893.9	27.4	5893.9	1789
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	7.9	7.9	0	7.9	2.4
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	44.6	44.6	0	44.6	13.5
Comp Molar Flow (H2O) (kgmole/h)	2960.8	15.7	2945.1	15.7	4.8
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	8935.7	5963.1	2972.5	5963.1	1810
Molecular Weight	35.36	43.88	18.25	43.88	43.88
Mass Flow (kg/h)	315938.9	261676.3	54262.6	261676.3	79427
Heat Flow (kW)	-883554	-647184.1	-236369.9	-645932.7	-196060.9

Name	C12	C13	C14	C15	C16
Vapour Fraction	1	1	1	1	0
Temperature (C)	50.64	50.64	52.42	141.9	27
Pressure (bar)	28	28	30	75	74.7
Comp Molar Flow (Hydrogen) (kgmole/h)	0.3	1.1	0.7	0.7	0.7
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1789	1788.5	4104.9	4104.9	4104.9
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	2.4	2.4	5.5	5.5	5.5
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	13.5	13.3	31	31	31
Comp Molar Flow (H2O) (kgmole/h)	4.8	4.8	10.9	10.9	10.9
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	1810	1810	4153.1	4153.1	4153.1
Molecular Weight	43.88	43.87	43.88	43.88	43.88
Mass Flow (kg/h)	79427	79397.4	182249.3	182249.3	182249.3
Heat Flow (kW)	-196060.9	-196006.1	-449871.7	-446286.7	-461646.4

Name	C17	C18	CaO Conversion	Carbon Capture	CW1
Vapour Fraction	0	0	0.5	0.8351	0
Temperature (C)	36.56	35.1			27
Pressure (bar)	120	110			1
Comp Molar Flow (Hydrogen) (kgmole/h)	0.7	0.7			0
Comp Molar Flow (CO) (kgmole/h)	0	0			0
Comp Molar Flow (CO2) (kgmole/h)	4104.9	4104.9			0
Comp Molar Flow (Methane) (kgmole/h)	0	0			0
Comp Molar Flow (Ethane) (kgmole/h)	0	0			0
Comp Molar Flow (Propane) (kgmole/h)	0	0			0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0			0
Comp Molar Flow (Nitrogen) (kgmole/h)	5.5	5.5			0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0			0
Comp Molar Flow (Argon) (kgmole/h)	31	31			0
Comp Molar Flow (H2O) (kgmole/h)	10.9	10.9			258491.3
Comp Molar Flow (CaO*) (kgmole/h)	0	0			0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0			0
Comp Molar Flow (MgO*) (kgmole/h)	0	0			0
Molar Flow (kgmole/h)	4153.1	4153.1			258491.3
Molecular Weight	43.88	43.88			18.02
Mass Flow (kg/h)	182249.3	182249.3			4.66E+06
Heat Flow (kW)	-461203.4	-461203.4			-2.05E+07

Name	CW2	CW3	E1	E2	E3
Vapour Fraction	0	0	1	1	1
Temperature (C)	27.09	17	1401	1317	581.7
Pressure (bar)	4	3.5	20	20	1.013
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	0	0	1028.8	1058.3	1058.3
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	62105.2	69775.7	69775.7
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	10331.5	12388.8	12388.8
Comp Molar Flow (Argon) (kgmole/h)	0	0	747.3	839.6	839.6
Comp Molar Flow (H2O) (kgmole/h)	258491.3	258491.3	19789.9	19856.9	19856.9
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	258491.3	258491.3	94002.8	103919.3	103919.3
Molecular Weight	18.02	18.02	26.62	26.84	26.84
Mass Flow (kg/h)	4.66E+06	4.66E+06	2.50E+06	2.79E+06	2.79E+06
Heat Flow (kW)	-2.05E+07	-2.05E+07	-213923.1	-185454.7	-940661.2

Name	E4	E5	E6	E7	E8
Vapour Fraction	1	1	1	1	1
Temperature (C)	577.2	532.1	210	170	115.1
Pressure (bar)	1.013	1.013	1.013	1.013	1.013
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)	1070.9	1070.9	1070.9	1070.9	1070.9
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	73063	73063	73063	73063	73063
Comp Molar Flow (Oxygen) (kgmole/h)	13270.5	13270.5	13270.5	13270.5	13270.5
Comp Molar Flow (Argon) (kgmole/h)	879.1	879.1	879.1	879.1	879.1
Comp Molar Flow (H2O) (kgmole/h)	19885.6	19885.6	19885.6	19885.6	19885.6
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	108169.2	108169.2	108169.2	108169.2	108169.2
Molecular Weight	26.92	26.92	26.92	26.92	26.92
Mass Flow (kg/h)	2.91E+06	2.91E+06	2.91E+06	2.91E+06	2.91E+06
Heat Flow (kW)	-928460.5	-973653.4	-1.28E+06	-1.32E+06	-1.37E+06

Name	F1	F2	F3	F5	F6
Vapour Fraction	1	1	1	1	1
Temperature (C)	30.98	30	380	380	380
Pressure (bar)	28	26	25.5	25.5	25.5
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CO) (kgmole/h)	0.1	0.1	0.1	0	0.1
Comp Molar Flow (CO2) (kgmole/h)	0.1	0.1	0.1	0	0.1
Comp Molar Flow (Methane) (kgmole/h)	3505.5	3505.5	3505.5	1151.4	2354.1
Comp Molar Flow (Ethane) (kgmole/h)	382.7	382.7	382.7	125.7	257
Comp Molar Flow (Propane) (kgmole/h)	137.3	137.3	137.3	45.1	92.2
Comp Molar Flow (n-Butane) (kgmole/h)	58.2	58.2	58.2	19.1	39.1
Comp Molar Flow (Nitrogen) (kgmole/h)	16.9	16.9	16.9	5.5	11.3
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)	0.3	0.3	0.3	0.1	0.2
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	0
Molar Flow (kgmole/h)	4101	4101	4101	1347	2754
Molecular Weight	18.94	18.94	18.94	18.94	18.94
Mass Flow (kg/h)	77668.4	77668.4	77668.4	25511.2	52157.2
Heat Flow (kW)	-88364.5	-88364.5	-67378.8	-22131.5	-45247.4

Name	FG1	In E-105	In E-106	LHV Efficiency	MF1
Vapour Fraction	1	0	0	0.4831	1
Temperature (C)	700	17	17		310.3
Pressure (bar)	25	3.5	3.5		25.5
Comp Molar Flow (Hydrogen) (kgmole/h)	9752.9	0	0		0
Comp Molar Flow (CO) (kgmole/h)	33.2	0	0		0.1
Comp Molar Flow (CO2) (kgmole/h)	42.3	0	0		0.1
Comp Molar Flow (Methane) (kgmole/h)	714.9	0	0		2354.1
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0		257
Comp Molar Flow (Propane) (kgmole/h)	0	0	0		92.2
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0		39.1
Comp Molar Flow (Nitrogen) (kgmole/h)	11.3	0	0		11.3
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0		0
Comp Molar Flow (Argon) (kgmole/h)	0	0	0		0
Comp Molar Flow (H2O) (kgmole/h)	8065.1	185107	73384.4		13204.4
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0		0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0		0
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0		0
Molar Flow (kgmole/h)	18619.7	185107	73384.4		15958.2
Molecular Weight	9.642	18.02	18.02		18.17
Mass Flow (kg/h)	179532.1	3.33E+06	1.32E+06		290031.4
Heat Flow (kW)	-444383.7	-1.47E+07	-5.83E+06		-901477.2

Name	MF2	MF3	Jet kWe Steam Cycl	Out E-105	Out E-106
Vapour Fraction	1	1		0	0
Temperature (C)	625	621.3		27	27
Pressure (bar)	25.2	25.2		2.5	2.5
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0		0	0
Comp Molar Flow (CO) (kgmole/h)	0.1	186.3		0	0
Comp Molar Flow (CO2) (kgmole/h)	0.1	0.1		0	0
Comp Molar Flow (Methane) (kgmole/h)	2354.1	3114.8		0	0
Comp Molar Flow (Ethane) (kgmole/h)	257	0		0	0
Comp Molar Flow (Propane) (kgmole/h)	92.2	0		0	0
Comp Molar Flow (n-Butane) (kgmole/h)	39.1	0		0	0
Comp Molar Flow (Nitrogen) (kgmole/h)	11.3	11.3		0	0
Comp Molar Flow (Oxygen) (kgmole/h)	0	0		0	0
Comp Molar Flow (Argon) (kgmole/h)	0	0		0	0
Comp Molar Flow (H2O) (kgmole/h)	13204.4	13018.1		185107	73384.4
Comp Molar Flow (CaO*) (kgmole/h)	0	0		0	0
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0		0	0
Comp Molar Flow (MgO*) (kgmole/h)	0	0		0	0
Molar Flow (kgmole/h)	15958.2	16330.6		185107	73384.4
Molecular Weight	18.17	17.76		18.02	18.02
Mass Flow (kg/h)	290031.4	290031.5		3.33E+06	1.32E+06
Heat Flow (kW)	-838628.5	-838628.5	165689.3	-1.47E+07	-5.82E+06

Name	OX1	OX2	PST1	PST2	Reformer Heat Duty
Vapour Fraction	1	1	1	1	
Temperature (C)	20	19.49	300.4	300.4	
Pressure (bar)	27	25	30	30	
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0	0	
Comp Molar Flow (CO) (kgmole/h)	0	0	0	0	
Comp Molar Flow (CO2) (kgmole/h)	0	0	0	0	
Comp Molar Flow (Methane) (kgmole/h)	0	0	0	0	
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0	0	
Comp Molar Flow (Propane) (kgmole/h)	0	0	0	0	
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0	0	
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0	0	
Comp Molar Flow (Oxygen) (kgmole/h)	3092.6	3092.6	0	0	
Comp Molar Flow (Argon) (kgmole/h)	31.2	31.2	0	0	
Comp Molar Flow (H2O) (kgmole/h)	0	0	13204.2	13204.2	
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0	0	
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0	0	
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0	0	
Molar Flow (kgmole/h)	3123.8	3123.8	13204.2	13204.2	
Molecular Weight	32.08	32.08	18.02	18.02	
Mass Flow (kg/h)	100210.7	100210.7	237874.2	237874.2	
Heat Flow (kW)	-309.8	-309.8	-856229.4	-856229.8	109608.6

Name	Regen Heat Loss	SO1	SO2	SO3	SO4
Vapour Fraction		0	0	0	0
Temperature (C)		700	1303	1069	1069
Pressure (bar)		25	25	25	25
Comp Molar Flow (Hydrogen) (kgmole/h)		0	0	0	0
Comp Molar Flow (CO) (kgmole/h)		0	0	0	0
Comp Molar Flow (CO2) (kgmole/h)		0	0	0	0
Comp Molar Flow (Methane) (kgmole/h)		0	0	0	0
Comp Molar Flow (Ethane) (kgmole/h)		0	0	0	0
Comp Molar Flow (Propane) (kgmole/h)		0	0	0	0
Comp Molar Flow (n-Butane) (kgmole/h)		0	0	0	0
Comp Molar Flow (Nitrogen) (kgmole/h)		0	0	0	0
Comp Molar Flow (Oxygen) (kgmole/h)		0	0	0	0
Comp Molar Flow (Argon) (kgmole/h)		0	0	0	0
Comp Molar Flow (H2O) (kgmole/h)		0	0	0	0
Comp Molar Flow (CaO*) (kgmole/h)		2510.8	2510.8	5029	5021.6
Comp Molar Flow (CaCO3*) (kgmole/h)		6619.6	6619.6	4101.4	4108.8
Comp Molar Flow (MgO*) (kgmole/h)		9130.2	9130.2	9130.2	9130.2
Molar Flow (kgmole/h)		18260.6	18260.6	18260.6	18260.6
Molecular Weight		64.14	64.14	58.07	58.09
Mass Flow (kg/h)		1.17E+06	1.17E+06	1.06E+06	1.06E+06
Heat Flow (kW)	3486.7	-3.95E+06	-3.70E+06	-3.44E+06	-3.44E+06

Name	SW1	SW2	SW3	W GTEXP	WGTCOMP
Vapour Fraction	0	0	0		
Temperature (C)	7	7.058	16		
Pressure (bar)	1	3	2.5		
Comp Molar Flow (Hydrogen) (kgmole/h)	0	0	0		
Comp Molar Flow (CO) (kgmole/h)	0	0	0		
Comp Molar Flow (CO2) (kgmole/h)	0	0	0		
Comp Molar Flow (Methane) (kgmole/h)	0	0	0		
Comp Molar Flow (Ethane) (kgmole/h)	0	0	0		
Comp Molar Flow (Propane) (kgmole/h)	0	0	0		
Comp Molar Flow (n-Butane) (kgmole/h)	0	0	0		
Comp Molar Flow (Nitrogen) (kgmole/h)	0	0	0		
Comp Molar Flow (Oxygen) (kgmole/h)	0	0	0		
Comp Molar Flow (Argon) (kgmole/h)	0	0	0		
Comp Molar Flow (H2O) (kgmole/h)	291000.7	291000.7	291000.7		
Comp Molar Flow (CaO*) (kgmole/h)	0	0	0		
Comp Molar Flow (CaCO3*) (kgmole/h)	0	0	0		
Comp Molar Flow (MgO*) (kgmole/h)	0	0	0		
Molar Flow (kgmole/h)	291000.7	291000.7	291000.7		
Molecular Weight	18.02	18.02	18.02		
Mass Flow (kg/h)	5.24E+06	5.24E+06	5.24E+06		
Heat Flow (kW)	-2.32E+07	-2.32E+07	-2.31E+07	755206.6	356999.5

Name	WK-101	WK-102	WP-101	WP-102	WP-103
Vapour Fraction					
Temperature (C)					
Pressure (bar)					
Comp Molar Flow (Hydrogen) (kgmole/h)					
Comp Molar Flow (CO) (kgmole/h)					
Comp Molar Flow (CO2) (kgmole/h)					
Comp Molar Flow (Methane) (kgmole/h)					
Comp Molar Flow (Ethane) (kgmole/h)					
Comp Molar Flow (Propane) (kgmole/h)					
Comp Molar Flow (n-Butane) (kgmole/h)					
Comp Molar Flow (Nitrogen) (kgmole/h)					
Comp Molar Flow (Oxygen) (kgmole/h)					
Comp Molar Flow (Argon) (kgmole/h)					
Comp Molar Flow (H2O) (kgmole/h)					
Comp Molar Flow (CaO*) (kgmole/h)					
Comp Molar Flow (CaCO3*) (kgmole/h)					
Comp Molar Flow (MgO*) (kgmole/h)					
Molar Flow (kgmole/h)					
Molecular Weight					
Mass Flow (kg/h)					
Heat Flow (kW)	1251.5	3585.1	443	356.7	482.3



GASCONSULT LTD

**CONTRACT NO. 012-001
MARCH 2002**

IEA GREENHOUSE GAS R&D PROGRAMME

**EVALUATION OF BARIUM OXIDE-BASED
POWER GENERATION CONCEPT WITH CO₂
CAPTURE**

GASCONSULT LTD CONTRACT NO. 012-001

MARCH 2002



CONTENTS

1. INTRODUCTION	3
2. DESIGN BASIS	3
3. SCREENING OF PROCESS OPTIONS	3
4. DESCRIPTION OF SELECTED PROCESS	4
5. COMMENTS ON SELECTED PROCESS	5
6. PPAP INPUTS AND RESULTS	6
7. CONCLUSIONS	8
8. COMMENTS ON PPAP SOFTWARE	8
9. HEAT AND MATERIAL BALANCES	10

EXECUTIVE SUMMARY

In 1999 IEA carried out a preliminary evaluation of a proposed process for power generation from natural gas with capture of CO₂ described by Jody et al. This process employs absorption of oxygen from air by oxidation of barium oxide BaO to barium peroxide BaO₂, followed by decomposition of the resulting BaO₂ at higher temperatures with release of free oxygen. The released oxygen is reacted with natural gas (or in principle with other carbonaceous fuels) to form CO₂ and steam, from which substantially pure CO₂ can be recovered for sequestration. High-grade heat evolved in both the oxygen absorption and decomposition/combustion stages is recovered for use in power generation.

IEA has commissioned Gasconsult Ltd to make a further assessment of this BaO/BaO₂ cycle. It has been concluded that the BaO/BaO₂ process has some merit in that almost 100% carbon capture is apparently achievable using an adaptation of existing AFBC technology. Overall thermal efficiency at around 45% is comparable with other natural gas fired CO₂ capture power generation options. However there are serious and unresolved concerns over the toxicity, availability and cost of the barium oxide make-up, and over the cost and practicalities of disposing of or recycling the fines. Moreover the very high barium oxide recirculation rate between the oxidiser and the decomposer/combustor (circa 1 tonne/s for 500 MWe) should be noted.

It is possible that alternative chemical oxygen carrier systems may be worth investigating.



1. INTRODUCTION

In 1999 IEA carried out a preliminary evaluation of a proposed process for power generation from natural gas with capture of CO₂ described by Jody et al¹. This process employs absorption of oxygen from air by oxidation of barium oxide BaO to barium peroxide BaO₂, followed by decomposition of the resulting BaO₂ at higher temperatures with release of free oxygen. The released oxygen is reacted with natural gas (or in principle with other carbonaceous fuels) to form CO₂ and steam, from which substantially pure CO₂ can be recovered for sequestration. High-grade heat evolved in both the oxygen absorption and decomposition/combustion stages is recovered for use in power generation.

In response to continuing interest in this concept, IEA has commissioned Gasconsult Ltd to make a further assessment of this BaO/BaO₂ cycle. This assessment has been performed in two stages. In the first stage, several variants of the process were simulated using HYSYS, in combination with additional thermodynamic data for the BaO/ BaO₂ system obtained from Kubachewski & Alcock and from the Handbook of Chemistry and Physics. The resulting simulation has enabled consistent calculation of the reaction heats and equilibria in the reaction system, together with the steam cycle. In the second stage, the resulting process scheme was evaluated using IEA's techno-economic evaluation PPAP software.

In order to produce, as far as possible, an independent assessment, only limited reference has been made to IEA's earlier evaluation of this process.

¹ Integrating O₂ Production with Power Systems to Capture CO₂: Jody B.J., Daniels E.J., Wolsky A.M, Energy Conv & Management Vol. 38 Suppl. pp S135-S140, 1997.

2. DESIGN BASIS

The work has been carried out on the basis of the standard IEA assessment conditions, except that it has been assumed that natural gas is pure methane, as for the previous assessment.

3. SCREENING OF PROCESS OPTIONS

At the outset of this new study, consideration was given to a number of possible process variants within the principle of circulating barium oxides between an oxidiser and a combustor. These were:

- Option A A combined cycle type of operation, in which the BaO₂ decomposer/methane combustor would essentially take the place of the combustor of a gas turbine (GT) and operate at elevated pressure (20–30 bar). The BaO oxidiser would operate at atmospheric pressure. The GT compressor would operate on recycled CO₂. The GT expander would be followed by heat recovery steam generation, supplying steam turbines. The HRSG outlet gas would be cooled and water of combustion separated. Some of the resulting CO₂ stream would be bled from the cycle and compressed for disposal, while the balance would be recycled to the suction of the GT compressor.
- Option B As Option A, but the oxidiser would also operate at the same pressure (20–30 bar) as the decomposer/combustor. The depleted air (nitrogen) would be heated and expanded, thus forming a second GT cycle.
- Option C Low (essentially atmospheric) pressure operation for both oxidiser and decomposer/combustor, with a steam cycle providing all the power output.

One clear disadvantage of the basic process is the great amount of solid material BaO/BaO₂ that must be recycled round the system – approximately 3400 tonnes/h, or almost one tonne per second at the scale studied (500MWe net power production). This high solids recirculation arises because 0.5 kmol



of O_2 (16 kg) requires 1 kmol of BaO (153kg) for transport, a weight ratio of about 10. In contrast, the combustion of 16 kg of oxygen by carbon requires only 6 kg of solid material, a weight ratio of about 0.375. Thus, on a simple oxygen basis, the mass solids transport required for the process studied is a factor of 30 over combustion of coal. This is somewhat compensated for by the higher s.g. of BaO/BaO₂ (ca 5). To transmit this amount of material over a substantial pressure difference, e.g. via lock hoppers, would be very expensive even if possible.

For this reason Option A was eliminated, and attention was then given to Option B. Examination of the chemical equilibria shows that enhanced pressure is not required to carry out the oxidation reaction. Enhanced pressure also makes the combustion step somewhat more problematic, as it is necessary to maintain the oxygen partial pressure in this step below a fixed value. Therefore when the total pressure in the decomposer/combustor is raised, the oxygen concentration must be reduced in order to limit the oxygen partial pressure. Achieving this may under some circumstances require a significant recycle of product CO₂ to the decomposer/combustor. Moreover, the operation of the absorber at elevated pressure in this option requires provision of a form of gas turbine to compress the oxidising air to 20-30 bar and to expand the oxygen-depleted air leaving the absorber to atmospheric pressure. In order for this secondary GT to generate net power, it would be necessary to raise the temperature of the depleted air leaving the absorber. If this were done by direct combustion of natural gas, the resulting CO₂ would be discharged to the atmosphere, while the temperature achievable with indirect heating would be limited and hence little power made

Option C was therefore selected. The oxidiser and decomposer both operate at near-atmospheric pressure, and both reactors are assumed to be of fluidised-bed type, employing AFBC-type technology.

It should be note that this is a different arrangement from IEA's previous assessment of this process, which incorporated a version of Option A with low-pressure absorber and high-pressure decomposer/combustor.

4. DESCRIPTION OF SELECTED PROCESS

Please refer to the attached schematic Process Flow Diagram and Material Balance in Section 9.

Air supplied by the Air Blower enters the fluid-bed BaO Oxidiser, which operates at near-atmospheric pressure and 500⁰C. The oxidation of BaO to BaO₂ effectively removes almost all the oxygen from the incoming air. The reaction is exothermic, and the reaction heat is used to generate HP steam. The Oxidiser off-gas (essentially nitrogen) leaves the reactor at 500⁰C. After passing through a Cyclone, gas Filter and Boiler Feedwater Heater, the gas is scrubbed with water to remove traces of barium oxides before it is discharged to atmosphere. The solid material recovered in the cyclone is returned to the Oxidiser, but the fines from the filter and Wet Scrubber system are rejected.

The solids leaving the Oxidiser, which are assumed to contain 95mol% BaO₂, pass to the Decomposer/Combustor. This is also a fluidised reactor and operates at near atmospheric pressure and 800⁰C. This reactor is supplied with a fluidising gas consisting of the natural gas supply to the plant plus some recycled CO₂ sweep gas. At the operating temperature of 800⁰C, the incoming BaO₂ is decomposed into BaO, which is recycled to the Oxidiser, and oxygen, which reacts with methane to form CO₂ and steam. The regeneration of BaO from BaO₂ is itself endothermic, but the combustion of the methane in the evolved oxygen results in a strongly exothermic overall reaction. As with the Oxidiser, the heat evolved is used to generate HP steam.

It may be feasible to burn the natural gas without any sweep gas, but the flow rate of natural gas alone, which is very much less than the reactor exit gas flow, would probably be insufficient to fluidise the bed. Since the design of the combustor is unknown, an arbitrary provision has been made for a CO₂ sweep gas flow.



The gas leaving the Decomposer/Combustor consists of a mixture of CO₂, water vapour and a trace oxygen. It would be impractical simultaneously to avoid both residual methane and residual oxygen. Residual oxygen is on balance preferred, due to a desire to avoid formation of carbon in the Decomposer/Combustor.

After removal of solids a Cyclone and gas Filter system, the outlet gas is cooled successively in an HP steam generator/BFW heater and a final gas cooler. The cold gas after removal of condensed water of combustion consists of almost pure CO₂. After some gas has been separated for recycle to the Decomposer/Combustor as described above, the balance of the CO₂ is compressed to about 60 bar, at which pressure it is condensed. The liquid CO₂ is then pumped to storage at 110 bar.

Heat removed from the Oxidiser and from the Decomposer/Combustor and its exit gas together are also used to generate and reheat HP steam. The steam balance has been calculated as a typical supercritical system with primary conditions 255 bar/600degC and reheat to 58 bar/610degC

The corresponding process flows are also shown in Section 9.

5. COMMENTS ON SELECTED PROCESS

The process achieves a clear objective in that the only outputs are power, almost pure nitrogen and almost pure CO₂. The oxidation/decomposition cycle can also be well integrated with supercritical pressure steam power generation. The calculated thermal efficiency (LHV) is 45.5%. It is anticipated that the efficiency would be ~2 % less using the sub-critical conditions of the previous IEA study.

At some locations the very pure nitrogen may have some value as well as the CO₂, for example to enhance oil recovery.

A consequence of the high solids circulation mentioned above is that there will probably be considerable attrition of the circulating solids. A further potential cause of particle size reduction is degradation at a molecular level, due to the stresses induced by addition and removal of an oxygen atom as the material circulates between the oxidiser and the decomposer/combustor. Whilst these factors will not affect the chemistry of the process, they will aggravate the difficult of efficient separation of solids, disposal of fines and prevention of significant process losses. For instance, even if 99.95 % cyclone collection efficiency is obtained downstream of both the oxidiser and the decomposer/combustor, a make-up of BaO of 3.4 tonnes/h would still be required. The use of hot gas filters in the proposed flowsheet, plus final wet scrubbing on the waste nitrogen stream from the oxidiser, should substantially eliminate barium oxide losses to the environment, but the above-mentioned BaO flowrate in the cyclone discharge indicates the probable scale of fines disposal.

Another possible difficulty is that the circulating solid may become contaminated with carbon, resulting from thermal cracking of natural gas, particularly heavier components of some natural gases, in the decomposer/combustor. If any carbon formed is not burned off in the oxidiser, there could be a gradual accumulation of fine carbon in the system. It is not clear, however, whether this would necessarily inhibit chemical reaction.

As it is likely that a substantial continuous make-up of BaO will be needed, the availability and cost of BaO are important considerations. It might be possible to develop a method for reconstituting BaO dust into larger particles that could be used as make-up.

It would be necessary to assess whether any atmospheric losses of barium compounds at all would be acceptable (barium compounds are generally considered hazardous - see below) or whether any potential losses would have to be captured in a liquid or solid form. We addressed this point in Safety Risk and Environmental in the PPAP assessment Section 6. If further study discloses that the toxicity of barium oxides is a serious obstacle to further development, other chemical systems such as sodium nitrate/nitrite, or nickel or other metal oxide systems, could be considered in the future.



6. PPAP INPUTS AND RESULTS

The IEA Power Plant Assessment Program (PPAP), written in MS Excel, is designed to be a powerful yet easy to use program for producing a quick relative assessment of power generation processes. The program aims to lead the engineer assessing the process through a series of screens that gather information about the power generation process. The required information ranges from the technical process specification, through costing, to risk assessment. The more data that is available to the engineer, the more accurate the final assessment will be. However, if the information is not sufficiently detailed it is possible to make simplifying assumptions. Although the program is designed to be easy to use, it should be noted that considerable experience in power plant design and analysis is still required for its use.

The sections below record the main inputs to the various screens in PPAP

Plant Components

Gas Turbines x 0
Combustors 2 x FBC
Supercritical steam cycle
HRSG x1
Other major plant items x 1
CO₂ compression/pumping to 110 bar
Solids handling assumed included in FBC's

Fuel Specification

NG 100%
Mass & Energy: Fuel 21.88 kg/s
% to combustion or steam: 100

Steam Cycle

Efficiency 50 %. This value has been chosen so that the net power closely corresponds to the results of our simulation with a supercritical steam cycle.

Costing

Because the program does not appear in this case to input any data automatically for the FBC option, some assumptions have been made as follows. On the basis that one CFBC to fit the total capacity predicts an erected cost of \$245 million, and two (each sized for 100%) PFBC's gives \$268 million, two atmospheric FBC's are assumed to be approximately 50% of this (\$130 million) included under Other Equipment (User Defined). It is reasonable to put in two 100% units here, as the fuel and oxygen are not split into two parallel streams but in a sense are processed twice in series. The solids handling auto-entry is tied to coal feed and is therefore zero.

Other items :

- two candle filter units: cost multiplier 2 (as higher temperature)
- cyclones: assumed included in FBC's.

Total investment cost \$522 million.

The program predicts 503 MWe net power c.f. the 501 MW from HYSYS simulation.



Operating Cost

Using the standard IEA assumptions (except that pure methane has been used for NG - a very minor difference), power cost is ~3.75 c/kWh.

Multi-Criteria Analysis

PPAP uses the following criteria: 0 is most unfavourable, 100 is most favourable.

Raw Material: Rating 60 (Moderately Available)

We have not found any quoted price for supply of BaO, for example in Chemical Marketing Reporter. Kirk Othmer says that it is not being currently manufactured in the US, and need is met from imports. We have made enquires with a supplier and await a response. As it is manufactured by thermal decomposition of barium carbonate, this might possibly be performed within the power plant, with some savings in cost.

The hydrated form Ba(OH)₂ is widely used; in lubricating oils and greases, plastics stabilisers, as a papermaking additive, as an ingredient in sealants, vulcanisation accelerators, pigment dispersant, in PF foams, and as a protectant for limestone fine art objects.

Process Conditions Rating: 100 <1200degK, atmospheric pressure

On the basis that the steam cycle part is well known, it is not considered under this heading.

Material Rating: 100 Carbon steel

With refractory lining, as AFBC boiler construction.

Recycles: Only one major recycle (BaO_x), the CO₂ recycle being considered minor.

Novelty Rating: 60 Major Modifications

Safety Risk Rating: 30 Major In-Plant Risk

BaO/BaO₂ is toxic. Kirk Othmer does mention that soluble barium compounds are poisonous and the hydroxide is certainly soluble, and quotes a lethal dose between 1 and 15 g. The hydroxide is nevertheless used in a great range of consumer products mentioned above. There may be a great difference in toxicity between the hydrated material, which is not easily inhaled, and the anhydrous material as a fine dust. Kirk Othmer also refers to fire hazard, presumably due to spontaneous oxidation of BaO.

US/Canada EPA Data/Scorecard states "not a recognised or suspect carcinogen", but gives "Data Gap" for both non-cancer inhalation risk and Ambient Air Quality Standard.

JT Baker Material Safety Data Sheet says: Health Rating 3 - Severe (Life), and gives following Airborne Exposure Limits for Soluble Barium Compounds: OSHA Permissible Exposure Limit (PEL): 0.5mg (Ba)/m³, ACGIH Threshold Limit Value (TLV) 0.5 mg (Ba)/m³ A4 - not classifiable as a human carcinogen. It says not considered a fire hazard (which seems to contradict Kirk Othmer).

In the process considered here, the equipment containing the material is at atmospheric pressure. It could even be run under induced draught, so risk of escape would be low always provided process control was such as to eliminate any possibility of explosive combustion. On this basis we have chosen Major In-Plant Risk, rather than Major Ex-Plant Risk.

**Environmental Impact Rating: 50 Mildly Harmful Waste**

On the basis that the barium compounds could be almost totally collected, e.g. finally by wet scrubbing, there should be no atmospheric emissions. This rating assumes that discharge of all liquid barium-containing waste will be minimised. This would imply a facility to re-crystallise $Ba(OH)_2$ and recover BaO from the wet scrubber and other gas/liquid separators. This re-crystallisation has not been allowed for in the flowsheet at this stage of the study. We therefore suggest Mildly Harmful Waste.

PPAP Results

Power cost (based on 503 MWe) is 3.75 c/kWh

Decision Factor Scores

	BaO Process	Typical proven technology for comparison
Acceptance	38.0	Paul, please could you see if you have the scores that we can use, e.g. for gas-fired combined cycle with post combustion scrubbing
Applicability	54.4	I don't have figs I think either on disk
Confidence	77.5	or in the book. Would you like to advise please?
Estimated Cost	71.2	

7. CONCLUSIONS

The BaO/BaO₂ process has some merit in that almost 100% carbon capture is apparently achievable using an adaptation of existing AFBC technology. Overall thermal efficiency at around 45% is comparable with other natural gas fired CO₂ capture power generation options. However there are serious and unresolved concerns over the toxicity, availability and cost of the barium oxide make-up, and over the cost and practicalities of disposing of or recycling the fines. Moreover the very high barium oxide recirculation rate between the oxidiser and the decomposer/combustor (circa 1 tonne/s) should be noted.

The low acceptance score arises in part from the toxicity issue which, though serious, may not be worse than for many other chemical processes commonly in use. However, it is clearly more serious than for a normal power plant. This risk would have to be assessed in relation to the proposed power plant location.

Alternative chemical systems could be assessed, such as sodium nitrate/nitrite, or nickel or other metal oxide systems. Sodium nitrate/nitrite is superficially attractive due to probably lower cost, greater availability, lower density and safety, relative to BaO. Its high solubility in water would also facilitate recycle of fines by recrystallisation. However the performance of sodium nitrate/nitrite in its basic function as an oxygen carrier would have to be evaluated from first principles.

8. COMMENTS ON PPAP SOFTWARE

The following features were noted in the version of the PPAP software used and installed by us.


Costing Sheet: the program does not appear in this case to input any data automatically for the FBC option (it does for the PFBC, CFBC and PF cases).



Costing Sheet/Plant Components Sheet: as the number of units of a given type for a given total capacity is varied, the size per unit alters accordingly on the "Plant Components" sheet but does not appear to vary at all on the "Costing" sheet. As the type of steam cycle is changed on the "Plant Components" sheet, the capital cost of the steam cycle appears to stay constant on the "Costing" sheet. This, of course, may be intentional.



9. HEAT AND MATERIAL BALANCES



Streams	1	2	3	4	5	6	7	8
Name	AIR IN	N2 TO ATM	BaO TO OXDR	BaO2 TO COMB	NG TO COMB	CO2 SWEEP	COMB EXIT G	CO2 DISCH
Temp (C)	20	70	800	500	30	53.57	800	30.54
Pr (bar abs)	1	1.114	1.2	1.2	1.2	1.5	1.101	110
kmol/h								
H2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
CO2	0.0	0.0	0.0	0.0	0.0	1754.8	6693.3	4933.3
CH4	0.0	0.0	0.0	0.0	4938.5	0.0	0.0	0.0
N2 +Ar	37651.4	37651.4	0.0	0.0	0.0	0.0	0.0	0.0
O2	10008.6	18.1	0.0	0.0	0.0	0.0	0.0	0.0
H2O	0.0	0.0	0.0	0.0	0.0	55.2	9933.1	10.2
BaO	0.0	12.9	21053.8	1059.9	0.0	0.0	0.0	0.0
BaO2	0.0	253.1	1108.1	20836.0	0.0	0.0	0.0	0.0
Total	47660.0	37935.4	22161.9	21896.0	4938.5	1810.0	16626.4	4943.5
kg/h								
H2	1.38E+06	1.10E+06	3.42E+06	3.69E+06	79228.2	78222.3	473515.8	217296.4
Mol Wt	28.85	29.00	154.10	168.60	16.04	43.22	28.48	43.96



IEA GREENHOUSE GAS R&D PROGRAMME

**PPAP EVALUATION OF CRYOGENIC CO₂
SEPARATION FROM BOILER FLUE GASES
(SCHEME PROPOSED BY JOINT ISRAELI-RUSSIAN
LABORATORY FOR ENERGY RESEARCH)**

**IEA CONTRACT NO. IEA/CON/02/75
GASCONSULT CONTRACT NO. 012 - 002**

NOVEMBER 2002



EXECUTIVE SUMMARY

IEA has commissioned Gasconsult Ltd (GCL) to make an evaluation of a cryogenic process, proposed by the Joint Israeli-Russian Laboratory for Energy Research, for capture of CO₂ from the flue gases of a power station boiler. This evaluation uses the IEA in-house PPAP software.

The key features of this process, as outlined in a 1997 paper by Dr G Saksonov of the Laboratory, are as follows:

- Compressing the flue gas
- Cooling the gas to the near the temperature at which solid CO₂ is formed
- Expanding the cold gas to atmospheric pressure in a turbine
- Separating the solid CO₂ formed in the turbine
- Recovering the separated CO₂ in a form suitable for permanent disposal.

GCL's current evaluation is based on the flue gas composition and temperature given for a PF-fired generating station with Flue Gas Desulphurisation (FGD) taken from IEAGHG/SRI.

The main conclusions drawn from the present work are as follows:

- 1 With compression of flue gas to 3 bar, as proposed by the Laboratory, GCL has calculated CO₂ capture in the region of only 20-25%. The present evaluation is based on 15 bar expander inlet, giving a predicted CO₂ capture of 70% to 80%.
- 2 Mechanical separation of condensed water from the compressed flue gas, as proposed by the Laboratory, will not avoid frosting, and consequent blockage, in the cryogenic gas cooler. A silica gel dryer is therefore recommended, to remove residual water vapour before the gas enters the cryogenic zone.
- 3 The effect of SO₂ in the flue gas has not been fully investigated. Preliminary work suggests, however, that SO₂ could be preferentially removed or co-captured with the solid CO₂. If this is substantiated, it might be possible to eliminate conventional FGD.
- 4 Although relatively small expanders currently condense directly over 30% of inlet hydrocarbon vapours streams, an expander condensing around 10 mol% of its feed stream in the form of solid CO₂ has probably not yet been demonstrated. When the high output required (around 30MW in a large plant) is considered, this would be a major new development.
- 5 Another key aspect of the Laboratory's process is the separation and liquefaction of the very large flow of solid CO₂ formed (up to 600 t/h @500MWe coal-based). GCL suggests a thermally efficient method of subliming the dry ice and liquefying the resulting vapour at low pressure and temperature. This also would require intensive development.
- 6 The economic performance of the process emerging from PPAP appears somewhat worse than for mainstream flue gas CO₂ capture proposals. Considerable development work would be needed, particularly on the expander and the handling/processing of the solid CO₂. The possibility of co-capture of SO₂ could, however, be a positive feature.



CONTENTS

- 1. INTRODUCTION**
- 2. DESIGN BASIS**
- 3. DESIGN DISCUSSION**
- 4. PROCESS DESCRIPTION**
- 5. PPAP CRITERIA AND SCORES**
- 6. CONCLUSIONS**



1. INTRODUCTION

IEA has commissioned Gasconsult Ltd to evaluate a cryogenic process, proposed by the Joint Israeli-Russian Laboratory for Energy Research, for capture of CO₂ from the flue gases of a power station boiler. This evaluation has been made using IEA in-house PPAP software.

The basic elements of this cryogenic process, as outlined in a 1997 paper by Dr G Saksonov of the Laboratory, are as follows:

- Compressing the flue gases to around 3 bar (all pressures in this report are absolute)
- Using the adiabatic heat of compression to heat boiler feed water in the upstream steam cycle
- Cooling the compressed gas and separating the condensed water
- Cooling the compressed gas further to around the temperature at which solid CO₂ is formed
- Expanding the cold gas to near atmospheric pressure in a turbine
- Separating the solid CO₂ formed in the expansion turbine
- Reheating the CO₂ depleted gas and discharging it to the atmosphere
- Recovering the separated CO₂ in a form suitable for permanent disposal.

It has been assumed that the facility will comprise a single conventional limestone-based FGD unit, removing 90% of the SO_x content of the boiler flue gas, followed by cryogenic CO₂ capture. Due to capacity limitations of compressors and gas dryers, however, the cryogenic part would be divided into two parallel 50% capacity lines.

As agreed with IEA, the overall carbon capture (percentage capture of inlet CO₂) has been set at 70%, requiring the flue gases to be compressed to give an expander inlet pressure of 15 bar.

The products from the facility are liquid CO₂ at 110 bar and ambient temperature, and a CO₂ depleted dry flue gas discharged to the boiler stack at 92⁰C, equal to the flue gas inlet temperature.

Acid condensate from the cryogenic process is recycled to the upstream FGD unit.

2. DESIGN BASIS

The current work has been carried out on the basis of the standard IEA assessment conditions, except that the target for CO₂ capture has been reduced as above. The incoming flue gas composition and temperature, defined in the table below, have been taken from IEAGHG/SR1 for a PF-fired generating station:

Composition	mol%	H ₂ O	10.9
		O ₂	4.5
		CO ₂	12.6
		Ar	0.9
		N ₂	71.2
		total	100.1
	mg/Nm ³	SO _x	190
		NO _x	650
Pressure		bar	1.016
Temperature		⁰ C	92

3. DESIGN DISCUSSION

3.1 Expander Calculation

A key aspect of the proposed process is the expander, in which CO₂ is captured from the boiler flue gas in the form of solid “dry ice”.

The formation of solid CO₂ and the mechanical power generated in the expander have been calculated by a procedure which combines HYSYS simulation with information from an Internet source on the



vapour pressure, temperature, entropy and enthalpy data for saturated CO₂ vapour and solid CO₂. This physical property data was curve-fitted on a spreadsheet.

The method of calculation was as follows:

- (1) A first estimate was made of the expander outlet temperature.
- (2) The % solidification of the inlet CO₂ content was varied until the sum of the component entropies at the inlet and outlet of the expander were equal.
- (3) This gave an exit CO₂ partial pressure in the expander outlet gas stream, which was compared with the true vapour pressure of solid CO₂ at the temperature estimated in (1) above.
- (4) The temperature estimate in (1) was then varied until agreement on CO₂ partial pressure was obtained, thus providing a prediction of the performance of a 100% efficient expander.
- (5) The above procedure could have been repeated with isentropic efficiencies less than 100%, to represent the performance of real expanders. Since no industrial experience has however been identified with solidifying expanders, it has been agreed with IEA that this initial evaluation of the process should be based on isentropic expansion (100% expander efficiency), thus giving the most optimistic process assessment.

3.2 Expander Inlet Pressure

The calculation procedure described above, applied with 3 bar expander inlet pressure as foreseen in the Laboratory's paper, resulted in only 25% solidification (capture) of CO₂. This appears far too low for a practical application. The expander inlet pressure was therefore raised to 15 bar, giving a 70% to 80% CO₂ capture prediction by above procedure.

3.3 Expander Availability and Development

The availability of an expander capable of condensing up to 10 mol % of its feed stream as solid CO₂ is a critical factor affecting process feasibility. Existing designs of expander used by the natural gas, oil and petrochemical industries achieve over 30% liquefaction of their inlet hydrocarbon streams. These expanders, however, are relatively small in inlet flow volume and power output. Moreover reliable operation with condensation of a solid phase has probably not yet been demonstrated.

3.4 Two Parallel Process Lines

Due to capacity limitations of available compressors and gas drying equipment, (see below), this cost assessment has been based on two parallel 50% lines downstream of FGD.

3.5 Compressor/Expander Groups

Each 50% compressor/expander group comprises an axial flow low-pressure flue gas compressor, a radial flow high-pressure flue gas compressor, a cryogenic flue gas expander and a make-up electric motor. The order-of-magnitude powers for each group are:

Compressors	100 MW
Expander	30 MW
Motor	70 MW

The choice of electric motor drives is convenient for the purposes of this evaluation, as it minimises reconfiguring of the main steam cycle. In practice, however, steam turbines would be a feasible and perhaps preferable make-up drivers.

3.6 Flue Gas Drying

The Laboratory's paper showed removal of condensed water vapour from the compressed flue gas, but no gas drying. As a result their scheme would most probably suffer ice fouling in the downstream exchangers. Accordingly the present evaluation includes gas drying by thermally regenerated silica gel. The investment cost is based on the cost of the dryers used in large air separation plants.



Two drying lines are envisaged, each approximately equivalent in mass flow to the dryers for a 6000 tonnes/day ASU. In some areas it may be necessary to upgrade the materials of construction of the dryers to take account of the higher acidity of any condensate formed, relative to operation on air.

For the present assessment the dryers are located downstream of the high-pressure flue gas compressors. An alternative location downstream of the low-pressure flue gas compressors may be investigated at a later stage.

3.7 Gas/Gas Heat Exchangers

The two heat exchangers provided for cooling the compressed flue gas with cold residue gas are based on the plate-fin type of exchanger used in air separation plants. The cryogenic exchanger E-107 would be constructed of aluminium, and the smaller, warmer exchanger E-104 of stainless steel.

3.8 Separation of Solid CO₂

The solid CO₂ formed in the expanders (up to 600 t/h for a 500MWe coal-based station) is separated by cyclones. These cyclones have not been sized, but multiple units will probably be required.

3.9 Recovery of Liquid CO₂

Application of the Laboratory's process requires the development of a means of handling the very large flow of solid CO₂ as above and recovering it as liquid.

The present assessment is based on a fluidised bed sublimator, operating together with the cyclones at around 1.05 bar. The solid CO₂ is conveyed pneumatically from the cyclones to the fluidised bed sublimator, using a small stream of compressed CO₂ as the motive fluid. In the sublimator, a stream of CO₂ vapour fluidises the solid CO₂. The heat required to sublime the solid CO₂ is provided by condensation of liquid CO₂ in tubing immersed in the fluidised region. The CO₂ vapour is then compressed, but only to around 5 bar, at which it is condensed to liquid at -55°C. The liquid CO₂ formed is then pumped to 120 bar, reheated to ambient temperature and exported at 100 bar.

This concept potentially provides a means of handling the large throughput of low-density solid CO₂ and converting it into high-pressure liquid, without having to move the solid from one pressure region to another by means of lock-hoppers, and without significant waste of latent heat of condensation. Mechanical compression of the solid into blocks as practised by the commercial dry ice industry appears impractical due to the high throughput, and there would still be the problem of how to convert the blocks into liquid CO₂.

3.10 Removal of SO_x

For the present assessment, it has been assumed that 90% of the SO₂ in the incoming flue gas will be removed in a conventional limestone-based FGD unit, and that the remaining 10% will report to the residue gas discharged to the stack. This FGD unit is shown as a single block on the enclosed Schematic Flowsheet, although it may comprise more than one line, depending on the technology used. Acidic condensate from the two 50% cryogenic lines is recycled to the FGD unit.

The appeal of the Laboratory's process could be increased substantially if it could be shown that the sufficient SO_x (mainly SO₂) could be co-solidified from the flue gas with the captured CO₂ and exported with it from the plant as single liquid stream.

In order to obtain an indication of the potential for co-capture of SO₂, the FGD-treated flue gas containing 190 mg/Nm³ of SO₂ from IEAGHG/SR1 was notionally dried and compressed to 50 bar. HYSYS gave -44°C for the liquid dew-point of this stream and -61°C for the onset of CO₂ solidification. The simulation showed that cooling this gas to -60°C liquefies 2.5% of the incoming CO₂ plus 47% of the SO₂ (and incidentally 86% of the NO₂).

Then, to simulate a flue gas from an approx. 2.5% sulphur coal without FGD, the SO₂ content was increased to 3800 mg/Nm³. Under the same conditions as above, 5% of the incoming CO₂ was liquefied plus 63% of the SO₂ (and 92% of the NO₂).



Extrapolation of this data to the process described in this report (CO₂ solidification with an expander inlet 15 bar) would, if substantiated, suggest that cryogenic capture of 60-70% of the CO₂ from the non-FGD-treated flue gas could co-capture over 90% of its SO₂ content. This could open up the prospect of eliminating conventional limestone-based FGD, with environmentally beneficial relief from limestone supply and gypsum disposal. This could be an unexpected credit for the cryogenic CO₂ capture process, relative for example to MEA scrubbing, but it would require general acceptance of the presence of up to 5 wt % SO₂ in the dry liquid CO₂ sent for permanent disposal.

4. PROCESS DESCRIPTION

Please refer to the Schematic Flowsheet attached at the end of this report.

The incoming flue gas from the PF-fired generating plant flows first to a conventional limestone-based FGD unit, which is assumed to remove 90% of its SO_x content.

The outlet gas (Stream 1) at 92^oC is divided into two equal streams, each flowing to one of two 50% capacity cryogenic CO₂ separation units. One of these streams (Stream 2) flows first to direct-contact Flue Gas Inlet Cooler T-101, in which it is cooled to 30^oC by a circulating stream of treated water. T-101 also serves to wash solid material from the incoming gas, and this is blown down from the circulating water and recycled to the FGD unit. Condensate Circulating Pumps P-101A/B pump the circulating water through plate-type Condensate Cooler E-109.

The cooled and washed flue gas is next compressed to 6 bar in axial flow LP Flue Gas Compressor C-101, emerging at around 235^oC. The compressed gas is cooled first in LP Steam Cycle Exchanger E-101 to 125^oC, notionally transferring heat to the BFW system of the upstream generating unit. The gas is then further cooled to 34^oC in Flue Gas Intercooler E-102, and condensed water is removed in LP Condensate Separator D-101.

The cooled gas is next compressed to 17 bar in radial flow HP Flue Gas Compressor C-102, emerging at around 155^oC. The compressed gas is cooled first in LP Steam Cycle Exchanger E-103 to 125^oC, notionally transferring heat to the BFW system of the upstream generating unit. The gas is then further cooled to 52^oC in Residue Gas Reheater E-104, to 34^oC in Flue Gas Aftercooler E-105, and then to 15^oC in Flue Gas Chiller E-106. Condensed water is removed in HP Condensate Separator D-102.

The chilled water used to cool the gas in E-106 is produced by Chilled Water Package X-102 (not shown on the Schematic Flowsheet). The chilled compressed gas next flows to Flue Gas Dryer Package X-101, in which its dew point is lowered to -80^oC by adsorptive drying with silica gel. The dry chilled gas is cooled in Cryogenic Interchanger E-107 to the temperature (-78^oC) at which solid CO₂ starts to appear (Stream 3). It then enters Expander EXP-101 at 15 bar, leaving at 1.05 bar/-110^oC with 70% of its CO₂ content in solid form (Stream 4). The expander outlet stream flows directly to Expander Outlet Cyclone(s) D-103, in which the gas and solid phases are separated.

The CO₂ depleted residue gas (Stream 5) leaving D-103 is reheated to 5^oC in E-107, and then to 92^oC in E-104 (Stream 6). It is then joined by the residue gas from the second 50% line and is discharged to the stack (Stream 7). The solid CO₂ gravitates from the base of D-103 through Rotary Valve(s) X-103, and is pneumatically conveyed by a small flow of CO₂ into CO₂ Sublimator D-104.

D-104 consists of a vertical vessel in which the incoming solid CO₂ is fluidised by a further stream of CO₂, with a tubular Sublimator Exchanger E-108 suspended in the fluid bed. E-108 transfers heat to the fluid bed, sublimating the solid CO₂ directly into saturated CO₂ vapour at -77^oC. Some CO₂ is recycled as fluidising gas to the base of D-104 by CO₂ Circulator C-104. CO₂ Compressor C-103 compresses the net output of CO₂ to around 5 bar. The compressor outlet stream then flows to the tube side of E-108, where it condenses at -55^oC.

The condensed liquid flows to CO₂ Accumulator D-105. From there it is pumped by CO₂ Export Pumps P-102A/B at 120 bar through E-107, in which it is heated to ambient temperature (Stream 9). This stream is then joined by CO₂ from the second 50% line and is exported at 110 bar (Stream 10).

The acidic condensate from D-101, D-102 and X-101 joins the purge from T-101 and is then recycled with acidic condensate from the second 50% line to the FGD unit.



5. PPAP CRITERIA AND SCORES

Criteria:-

Raw Material: Locally Common	90
Process Conditions: 10-60 bar <1200 K	90
Materials: Stainless Steel	95
Process: Major New Ideas	20
Safety: Small Risk	80
Environmental: Mildly Harmful Waste	50

Scores:-

Heat In	1982.3MWth
Estm. Net Electricity Output	500.0MWe
Net Efficiency LHV	25.2%
CO ₂ output	54.1kg/s
CO ₂ output	0.389kg/kWh
Estimated Capital Cost	1382.0Mill \$
Estimated Op Cost	8.3c/kWh

Multi-Criteria Assessment:-

Decision Factor Scores	
Acceptance	68.0
Applicability	64.1
Confidence	70.0
Estimated Cost	30.9

6. CONCLUSIONS

6.1 Percentage CO₂ Capture

Calculations indicate that the CO₂ capture feasible with compression of the flue gas to 3 bar, as proposed by the Laboratory, would only be in the region of 20-25%. After discussion with IEA, this present evaluation has been based on compression of the flue gas to give 15 bar at the expander inlet. This will result in a predicted CO₂ capture of about 70% to 80%, based on a 100% efficient expander.

6.2 Water Vapour Removal

The separation of condensed water from the compressed flue gas as proposed by the Laboratory is insufficient to avoid formation of water ice in the downstream cryogenic heat exchanger and resultant blocking. It is therefore necessary to provide a dryer stage (for example silica gel) to remove residual water vapour before the flue gas enters the cryogenic exchanger.

6.3 SO_x Removal

Allowance must be made in due course for the presence of SO_x (mainly SO₂) in the incoming flue gas. The present study assumes bulk removal of SO_x upstream in a limestone-based FGD unit, with recycle of acidic condensate to FGD. The effect of the residual SO₂ on the adsorptive dryer will also require future evaluation, as will the likely distribution of SO₂ between the solid CO₂ formed in the expander and the residual gas.

Preliminary simulations suggest that cryogenic capture of 60-70% of the CO₂ from the non-FGD-treated flue gas could co-capture over 90% of its SO₂ content. If substantiated, this could open up the prospect of eliminating conventional FGD altogether, with environmentally beneficial relief from limestone supply and gypsum disposal. This could be an unexpected credit for the cryogenic CO₂ capture process, relative for example to MEA scrubbing, but it would require general acceptance of the



presence of up to 5 wt% SO₂ in the exported dry liquid CO₂. Reliable prediction of the extent of co-capture of SO₂ in the solidified CO₂ would require more study and, probably, experimental verification.

6.4 Availability of Expander


The availability of a circa 30MWe expander capable of condensing around 10 mol% of its feed stream in the form of solid CO₂ is a critical to the feasibility of the Laboratory's process. Existing designs of expander used by the natural gas, oil and petrochemical industries achieve over 30% liquefaction of the hydrocarbon streams. These expanders, however, are relatively small in inlet flow volume and power output. Moreover reliable operation with a condensation of a solid phase has probably not yet been demonstrated.

6.5 Solid CO₂ Handling

Another key aspect of the Laboratory's process, requiring intensive development, is the means of handling the very large flow of solid CO₂ (up to 600 t/h @500MWe coal-based). The solid CO₂ produced in the expander has to be separated from the residual gas and then converted into the export stream of liquid CO₂ at 110 bar and ambient temperature as required in IEA's standard design basis. Mechanical compression of the solid into blocks as practised by the commercial dry ice industry appears impractical due to the high throughput, and there would be the problem of converting the blocks into liquid CO₂. GCL suggests a thermally efficient sequence of separating the solid CO₂ from the expander outlet in cyclone(s), pneumatically conveying it to a fluidised bed sublimator, and compressing/condensing the CO₂ vapour produced at low pressure and temperature.

6.6 Comparison with Alternatives

The economic performance of the process emerging from PPAP appears somewhat worse than for mainstream flue gas CO₂ capture proposals. Moreover, it is clear that a considerable amount of development work is needed, particularly on the expander and the handling/processing of the solid CO₂. However, the possibility of co-capture of SO₂ could be a positive feature.



The PPAP help files. Understanding the worksheets

Associated with the PPAP program is a help file which contains much useful information about how to add data to the worksheets and what the program does with it. A copy of this interactive help file is included separately on this CD and can be opened independently to assist with interpretation of the worksheets which follow.

Power Plant Assessment program

Introductory worksheet pages to PPAP

Intro
Intro2

Power Generation Process Assessment Facility

This is an Excel spreadsheet that takes some basic information about a power generation process and attempts to provide an insight into the viability of the process.

The calculations are performed in a number of stages each represented by a series of interacting worksheets. To start the assessment procedure Click on the Start button.

Written for IEA Greenhouse Gas Project
by CRE Group Ltd, (c) 1997,1999

Version 1.1 by TR Dennish April 2002

Version 2.1 by TR Dennish March 2003,

Incorporating changes requested by M Haines (IEA GHG)

Version 3.0 by T R Dennish August 2003,

With PPAP Lite page as designed by M Haines (IEA GHG)

Incorporating changes requested by M Haines (IEA GHG)

Power Generation Process Assessment Facility

Please enter a name to identify this process: [Base Combined Cycle \(rerun\)](#)

The procedure for plant assessment involves four stages of operator input

First: Input of process information

Second: Input of costing information

Third: Multi-Criteria analysis

Fourth: View results summary sheet

OR Import data from a Version 2 or later spreadsheet

Power Plant Assessment program

**Worksheets for baseline gas fired Combined Cycle Gas Turbine
(CCGT) power plant without CO₂ capture**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input checked="" type="checkbox"/>	Gas Turbine	1	331.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	161.0	MWe
<input type="checkbox"/>	Combustor	0	0.0	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input checked="" type="checkbox"/>	HRSG	1	355.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	
	Aux Power Req'd		10000	kJ/Unit size
<input type="checkbox"/>	Other major plant item	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Compression	0		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	46884
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		46884	kJ/kg	
Combined Carbon fraction		0.75		
Combined Ash Fraction		0		

Process Detail Specification

If you have data from an external mass and heat balance program
You can select Use PPAP Lite to enter summary data
from this into PPAP, this bypasses many of the calculations within PPAP
You may still need to set information to account for some losses in the Process Assumptions page too.

Bypass Steam and GT cycle and enter data directly from external process simulation

Or configure the steam and gas cycle details by using the buttons below

Steam Cycle details **Steam Cycle Setup not available when using PPAP Lite**

Gas Turbine details **GT Cycle Setup not available when using PPAP Lite**

Process Assumptions

Cycle Analysis

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1	kg/s		
Air/Fuel Ratio by Mass for Gas Turbine	40.3	====>	Air flow of	40.30 kg/s
Air Bleed for Blade Cooling	6.27%	====>	Cooling flow of	2.53 kg/s
HRSB heat loss	1.0%			

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50	kJ/kg
	Sorbent	50	kJ/kg
	Ash	50	kJ/kg
Oxygen Production	950	kJ/kg O2	
Combustor fans (PF)	8	kJ/MJ fuel	
FGD	8	kJ/MJ fuel	
Cooling water system	7	kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	0	MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	0	MW	Added into cell J45	Sheet CycleAnalysis
HRSO on GT	355	MW	Transferred to B7	Sheet CycleAnalysis
GT power	331	MW	Transferred to D65	Sheet CycleAnalysis
ST power	161	MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	0	%	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	57.9	%	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	41.95	%	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	46.3	%	Transferred to D18	Sheet CycleAnalysis
Overall power output	478	MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	0.00	MW
Other power from GT/ST waste heat	0	MW
Energy content of fuel	825.63	MW

Losses

GT mech loss	1.66	MW
GT gen loss	4.97	MW
ST mech loss	0.81	MW
ST mech loss	2.42	MW
GT + ST transformer loss	1.97	MW
Transformer loss direct power generated	0.00	MW
Subtotal	11.81	MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:

	PPAP	External	hidden calc
Fuel	0	0	
Sorbant	0.00	0	
Residue	0.00	0	
Oxygen Production	0	0	
Combustor fans (PF)	0.00	0.00	
FGD	0.00	0.00	
Cooling water system	0.61	0.61	86.46 MW ST rejection
Misc	1.43	1.43	0.00 MW compression losses
H2S Sepn	0	0	
CO2 Sepn	0	0	
Other	0	0	
Subtotal	2.04	MW	

TOTAL Losses/Auxiliaries 13.85 MW

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	355000 kJ/s from	HRSG before losses	43.00	20159.0	355.000
GT loss	7130 kJ/s from	Stack	19.49	9139.1	160.939
GT Efficiency			41.95		
Total			104.44		

Gas cycle Output

Estimated GT Efficiency	0.4195	Value imported	
Gross avail. energy to GT cycle	46884 kJ/kg		
GT Output	19667.84 kJ/kg	equiv to	346350.6 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.463	Value imported	
Heat Balance			
From Combustion	0 kJ/kg		HRSG Heat available 20159 kJ/kg
From Gasification	0 kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	19957.41 kJ/kg		HRSG to Steam Cycle 19957.41 kJ/kg
From Direct Generation	0 kJ/kg		
Export/Import	0 kJ/kg		
Heat available to steam cycle	19957.41 kJ/kg	equiv to	351450 kW
ST Output	9206.17 kJ/kg	equiv to	162120.6 kW

Total Potential Output 28874.01 kJ/kg equiv to 508471.3 kW

Process Losses		Total	GT	ST
Turbine Mech Loss	0.50%	2542.4	1731.8	810.6
Generator Loss	1.50%	7627.1	5195.3	2431.8
Transformer Loss	0.40%	2033.9	1385.4	648.5

Gross Power Output 28181.03 kJ/kg equiv to 496268 kW

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg	0	0	
	Sorbent	50 kJ/kg	0	0	
	Ash	50 kJ/kg	0	0	
Fan and compressor mech eff.		93%			
Oxygen Production		950 kJ/kg O2	0	0	
Oxygen Compression			Value imported	0	0.7 Is good nur
CO2 Compression			0	0	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel	0	0	
FGD		8 kJ/MJ fuel	0	0	
Cooling water system		7 kJ/MJ rejected	1	75.01991	Steam Cycle Condens
Misc		0.30% of gross		84.54309	
H2S Sepn				0	
CO2 Sepn				0	
Other				0	
Total Auxiliaries				159.563 kJ/kg	


Total Input	46884 kJ/kg		
Total Output (Net)	28021.47 kJ/kg	=>	478000 kW Value imported
Efficiency	57.9 %		Value imported -14

GT Output (Generator Terminals)	331.00 MW	Value imported	2.13164
ST Output (Generator Terminals)	161.00 MW	Value imported	-11.8684
Direct O/P (Gross)	0 MW		

% heat available to steam cycle 0 % **Value imported**

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		0	0	1	0.00
Gas turbine, complete	MWe	0	331	1	1	56.62
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		355	1	1	28.36
Steam turbine+pipes+cooling system	MWe		161	1	1.1	62.47
PF coal boiler	MW fuel feed LHV		0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	1	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	1	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		478	1	1	11.08
Sub-Total						158.53
Balance of plant	% of above		10			15.85
Engineering, indirects, owners cost	% of above		24			41.85
Project contingency	% of above		10			21.62
TOTAL						237.86

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ
Calculated Fuel Cost		3.0000	\$/GJ
Fuel cost of electricity		1.8653	c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="25"/> years
Load Factor	<input type="text" value="0.9"/>

Interest during construction	36.0582	M\$
Annual capital Charge	30.1774	M\$/y
Capital Charges	0.8002	c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.03"/>	Other Materials Cost	<input type="text" value="20"/>	\$/tonne
Fixed O&M cost	0.1892	Residue Disposal Cost	<input type="text" value="20"/>	\$/tonne
Variable O&M cost	0.0000			

Estimated Operating Costs **2.8547 c/kWh**

Multi-Criteria Analysis

This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.
 To edit the percentages allocated to different attributes scroll down the page

Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score	
Fuel Consumption kJ/kW	1.727	No risk	64	42.9	APPLICABILITY	36.3	
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10			
Process Conditions Temperature Pressure NB Use least well known part of process	1200K-1600K 10-60 bar but no significant technical barriers	No risk	11	80	CONFIDENCE IN WHETHER IT WILL WORK	35.5	
Novelty of Materials which is	Existing Special Alloys known material in known environment	No risk	6	90			10
Plant Complexity No. of major units No. of major recycles	3 0		85	10			
Novelty of Process with	Fully proven highly successful industrial applications in operation	No risk	0	100	10	ESTIMATED COSTS	
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.365		-2	40	112.4		
Costs Total Operating c/kWh	2.85		103	100			
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	20	ACCEPTANCE	
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk	5	80	20		
TOTALS						216.2	
		Averaged risk level	5				
		Controlling risk level	11	Process conditions			

Results of Analysis

Summary

Process: **Base Combined Cycle (rerun)**

Heat Input 825.6 MW

Estimated Net Electricity Output 478.0 MW
 Net Efficiency 57.9 %
 CO2 output/ kg/s 48.4 kg/s
 CO2 output/kWh 0.365 kg/kWh

NOTE GT efficiency calculated by program as ... 42.0 %
 NOTE Steam cycle efficiency calculated as... 46.3 %
 NOTE percentage of input energy to steam cycle .. 0.0 %

Estimated Capital Cost 237.9 M\$
 Estimated Op Cost 2.9 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance 32.0
 Applicability 36.3
 Confidence 35.5
 Estimated Cost 112.4
 Total 216.2
 Total cost only 285.9

Risk assessment

Averaged risk level 5
 Controlling risk level **Process conditions** 11




Comparison with Base Case CCGT

			This Case \$ct/kWh	Base Case \$ct/kWh	Difference \$ct/kWh	Base rates	
CO2 emission penalty	50 \$/ton						
CO2 emissions	0.365 kg/kWh		Fuel cost	1.865	1.865	0.0000	3.0000 \$/GJ
CO2 emission cost	1.824 c/kWh		CO2 charge	1.824	1.824	0.0000	50 \$/ton
			Base capex	0.989	0.989	0.0000	
			Extra capex	0.094	0.094	0.0000	
			Other opex	0.000	0	0.0000	
							Total 0.0000
Factor analysis		Effect on costs of electricity	TOTAL	4.7724	4.7724	0.0000	
	Scores		Extra fuel			0.0000	
Raw materials	90	0.0099	Extra capex			0.0000	
Process conditions	80	0.0198	Total extra			0.0000	
Novelty of materials	90	0.0099	CO2 tax benefit			0.0000	
Complexity	85	0.0148					
Safety	80	0.0198					
Environmental	80	0.0198					
TOTAL		0.0940					

Base Case data

Fuel cost	1.865 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.824 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	0.989 c/kWh		
Extra Capex	0.094 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.6E-05
Mix kgC/kJ	1.6E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.352 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3519 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		Base Combined Cycle (rerun)
Power Out	MWe	478
Efficiency	%	57.9
CO2 emitted	%	100
CO2 emitted	kg/kWh	0.364726
Fuel in	kg/s	17.61
Fuel in	MW	825.6272
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	0.00
Gas Cycle Efficiency	%	0.42
Steam Cycle Efficiency	%	0.46
Est Capital Cost	M\$	237.86
Est Operating Cost	ct/kWh	2.85
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	0
	Cost	0.00
Gas turbine, complete	MWe	331
	Number	1
	Cost	56.62
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	355
	Number	1
	Cost	28.36
Steam turbine+pipes+cooling syst	MWe	177.1

BaseCombCycle.xls

	Number	1
	Cost	62.47
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	478
	Number	1

	Cost	11.08
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		2
Press max		3
Process Conditions Qualifier		1
Construction Materials		3
Construction Materials Qualifier		1
No of Recycles		0
Novelty		1
Novelty Qualifier 1		1
Novelty Qualifier 2		1
Safety Risk		2
Safety Risk Qualifier		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		5
Controlling Risk Level		11
Controlling Risk is		Process conditions
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		80
Process Conditions Extra Cost	ct/kWh	0
Novelty		90
Novelty Extra Cost	ct/kWh	0
Complexity		85
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	1.865285
CO2 Charge	\$/ct/kWh	1.82363
Base Capex	\$/ct/kWh	0.989444
Extra Capex	\$/ct/kWh	0.093997
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	4.772356
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		46884
Mixture LCV		46884
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

BaseCombCycle.xls

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	0
O2 compression power	MW	0
HRSG on GT	MW	355
GT power	MW	331
ST power	MW	161
Percent of heat available to Steam	MW	0
Overall electrical efficiency after lo	MW	57.9
Efficiency GT Cycle	MW	41.95
Efficiency ST cycle	MW	46.3
Overall power output	MW	478
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for baseline Pulverized Fuel (PF) coal fired power plant
without CO₂ capture**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input type="checkbox"/>	Gas Turbine	0	0.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	526.5	MWe
<input checked="" type="checkbox"/>	Combustor	1	43.7	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input type="checkbox"/>	HRSG	0	0.0	MW
<input checked="" type="checkbox"/>	FGD	1		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		10000	kJ/Unit size
<input type="checkbox"/>	Other major plant item	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	2	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Compression	0		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		1	0	0
LCV	kJ/kg	25000	42000	50013
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		100.00%	0.00%	0.00%
Fuel Fractions Sum (must = 1)		1		
Combined LCV		25000	kJ/kg	
Combined Carbon fraction		0.62		
Combined Ash Fraction		0.12		

ASSUMPTIONS - Process

Gas Cycle

Actual Fuel flow rate to Gas Turbine	1 kg/s		
	40.3	====> Air flow of	40.30 kg/s
Air Bleed for Blade Cooling	6.27%	====> Cooling flow of	2.53 kg/s
HRSG heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	0 MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J45	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	0 MW	Transferred to D65	Sheet CycleAnalysis
ST power	526.5 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	100 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	44.95 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	0 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	46.3 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	491 MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	0.00 MW
Other power from GT/ST waste heat	0 MW
Energy content of fuel	1092.50 MW

Losses

GT mech loss	0.00 MW
GT gen loss	0.00 MW
ST mech loss	2.63 MW
ST mech loss	7.90 MW
GT + ST transformer loss	2.11 MW
Transformer loss direct power generated	0.00 MW
Subtotal	12.64 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:		PPAP	External	hidden calc
Fuel	2.185 MW	2.185	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	8.74 MW	8.74	0	
FGD	8.74 MW	8.74	0	
Cooling water system	1.98 MW	1.98	0	282.73 MW ST rejection
Misc	1.47 MW	1.47	0	0.00 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	23.12 MW			
TOTAL Losses/Auxiliaries	35.75 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

	Value imported		% of heat		
			I/P to GT	kJ/kg	MW
To steam	0 kJ/s from	HRSG before losses	0.00	0.0	0.000
GT loss	0 kJ/s from	Stack	0.00	0.0	0.000
GT Efficiency			0.00		
Total			<u>0.00</u>		

Gas cycle Output

Estimated GT Efficiency	0 Value imported			
Gross avail. energy to GT cycle	1E-07 kJ/kg			
GT Output	0 kJ/kg	equiv to		0 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.463 Value imported			
Heat Balance				
From Combustion	25000 kJ/kg			HRSG Heat available 0 kJ/kg
From Gasification	0 kJ/kg			HRSG heat loss 1.0%
From GT HRSG etc after losses	0 kJ/kg			HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0 kJ/kg			
Export/Import	0 kJ/kg			
Heat available to steam cycle	<u>25000 kJ/kg</u>	equiv to	1092500 kW	
ST Output	11532.27 kJ/kg	equiv to	503960.2 kW	

Total Potential Output 11532.27 kJ/kg equiv to 503960.2 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	2519.8	0.0	2519.8
Generator Loss	1.50%	7559.4	0.0	7559.4
Transformer Loss	0.40%	2015.8	0.0	2015.8

Gross Power Output 11255.5 kJ/kg equiv to 491865.1 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg	1	50	
	Sorbent	50 kJ/kg	1	0	
	Ash	50 kJ/kg	1	0	
Fan and compressor mech eff.		93%			
Oxygen Production		950 kJ/kg O2	0	0	
Oxygen Compression				0	Value imported 0.7 Is good nur
CO2 Compression			0	0	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel	1	200	
FGD		8 kJ/MJ fuel	1	200	
Cooling water system		7 kJ/MJ rejected	1	93.975	Steam Cycle Condensate
Misc		0.30% of gross		33.76649	
H2S Sepn				0	
CO2 Sepn				0	
Other				0	
Total Auxiliaries				577.7415 kJ/kg	

Total Input	25000 kJ/kg				
Total Output (Net)	10677.75 kJ/kg	=>	491000 kW	Value imported	
Efficiency	44.95 %	Value imported			-35.5
GT Output (Generator Terminals)	0.00 MW	Value imported			0
ST Output (Generator Terminals)	526.50 MW	Value imported			-35.5
Direct O/P (Gross)	0 MW				
% heat available to steam cycle	100 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		43.7	1	1	13.60
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		0	0	1	0.00
Gas turbine, complete	MWe	0	0	0	1	0.00
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		0	0	1	0.00
Steam turbine+pipes+cooling system	MWe		526.5	1	1.1	151.92
PF coal boiler	MW fuel feed LHV		1092.5	1	1	159.26
FGD (limestone gypsum)	kmol/s feed		10.74729	1	1	42.84
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	0	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	0.477	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		491	1	1	11.32
Sub-Total						378.93
Balance of plant	% of above		10			37.89
Engineering, indirects, owners cost	% of above		24			100.04
Project contingency	% of above		10			51.69
TOTAL						568.55

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ

Calculated Fuel Cost 1.5000 \$/GJ
 Fuel cost of electricity 1.2013 c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="25"/> years
Load Factor	<input type="text" value="0.85"/>

Interest during construction 86.1879 M\$
 Annual capital Charge 72.1313 M\$/y

Capital Charges 1.9716 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/> \$/tonne
Fixed O&M cost	0.6216 c/kWh	Residue Disposal Cost	<input type="text" value="20"/> \$/tonne
Variable O&M cost	0.0000 c/kWh		

Estimated Operating Costs 3.7946 c/kWh

Multi-Criteria Analysis										
This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process. To edit the percentages allocated to different attributes scroll down the page										
Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score				
Fuel Consumption kJ/kW	2.225	No risk	39	42.9	APPLICABILITY	26.6				
Raw Material Availability	Universally Common with unlimited availability for scale of this application	0	100	10						
Process Conditions Temperature Pressure NB Use least well known part of process	<1200K Atmospheric but no significant technical barriers	No risk 0	100	10	CONFIDENCE IN WHETHER IT WILL WORK	38.0				
Novelty of Materials which is	Carbon Steel known material in known environment	No risk 0	100	10						
Plant Complexity No. of major units No. of major recycles	4 0		80	10						
Novelty of Process with	Fully proven highly successful industrial applications in operation	No risk 0	100	10	ESTIMATED COSTS	88.8				
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.728		-14	40						
Costs Total Operating c/kWh	3.79		84	100						
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk 5	80	20	ACCEPTANCE	32.0				
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk 5	80	20						
<table border="1"> <tr> <td>Averaged risk level</td> <td>2</td> </tr> <tr> <td>Controlling risk level</td> <td>5</td> </tr> </table>					Averaged risk level	2	Controlling risk level	5	TOTALS	185.4
Averaged risk level	2									
Controlling risk level	5									

Safety

Results of Analysis

Summary

Process: **PF Alone (Base Case)**

Heat Input 1092.5 MW

Estimated Net Electricity Output 491.0 MW
 Net Efficiency 45.0 %
 CO2 output/ kg/s 99.3 kg/s
 CO2 output/kWh 0.728 kg/kWh

NOTE GT efficiency calculated by program as ... 0.0 %
 NOTE Steam cycle efficiency calculated as... 46.3 %
 NOTE percentage of input energy to steam cycle .. 100.0 %

Estimated Capital Cost 568.6 M\$
 Estimated Op Cost 3.8 c/kWh


Multi-Criteria Assessment

Decision Factor Scores


Acceptance 32.0
 Applicability 26.6
 Confidence 38.0
 Estimated Cost 88.8
 Total 185.4
 Total cost only 267.1

Risk assessment

Averaged risk level 2
 Controlling risk level **Safety** 5



		This Case	Base Case	Difference	Base rates	
		\$ct/kWh	\$ct/kWh	\$ct/kWh		
CO2 emission penalty	50 \$/ton					
CO2 emissions	0.728 kg/kWh	Fuel cost	1.201	1.201	0.0000	1.5000 \$/GJ
CO2 emission cost	3.642 c/kWh	CO2 charge	3.642	3.642	0.0000	50 \$/ton
		Base capex	2.593	2.593	0.0000	
		Extra capex	0.156	0.156	0.0000	
		Other opex	0.000	0	0.0000	
						Total 0.0000
Factor analysis		TOTAL	7.5921	7.5921	0.0000	
	Effect on costs of electricity					
	Scores					
Raw materials	100	0.0000			0.0000	
Process conditions	100	0.0000			0.0000	
Novelty of materials	100	0.0000				
Complexity	80	0.0519				
Safety	80	0.0519				
Environmental	80	0.0519				
	TOTAL	0.1556				
Base Case data						
Fuel cost	1.201 c/kWh	Based on	1.5 \$/GJ			
CO2 Tax	3.642 c/kWh	Based on	50 \$/tonne			
Base Capex+Opex	2.593 c/kWh					
Extra Capex	0.156 c/kWh					
Other Opex	0 c/kWh					



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.5E-05
Mix kgC/kJ	0.0000248
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.330 kg/kWh
Calorific fraction of gas	0
Calorific fraction of oil	0
CO2 allowance	0.6177 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		PF Alone (Base Case)
Power Out	MWe	491
Efficiency	%	44.95
CO2 emitted	%	100
CO2 emitted	kg/kWh	0.728393
Fuel in	kg/s	43.7
Fuel in	MW	1092.5
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	0.00
Gas Cycle Efficiency	%	0.00
Steam Cycle Efficiency	%	0.46
Est Capital Cost	M\$	568.55
Est Operating Cost	ct/kWh	3.79
Capital Cost Items		
Solids handling	'Size'	43.7
	Number	1
	Cost	13.60
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	0
	Cost	0.00
Gas turbine, complete	MWe	0
	Number	0
	Cost	0.00
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	0
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	579.15

	Number	1
	Cost	151.92
PF coal boiler	MW fuel feed LHV	1092.5
	Number	1
	Cost	
FGD (limestone gypsum)	kmol/s feed	10.74729
	Number	1
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	491
	Number	1

	Cost	11.32
Multi Criteria		
Feed Material		1
Feed Material Qualifier		1
Temp max		1
Press max		1
Process Conditions Qualifer		1
Construction Materials		1
Construction Materials Qualifier		1
No of Recycles		0
Novelty		1
Novelty Qualifer 1		1
Novelty Qualifer 2		1
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		2
Controlling Risk Level		5
Controlling Risk is	Safety	
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		100
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		100
Process Conditions Extra Cost	ct/kWh	0
Novelty		100
Novelty Extra Cost	ct/kWh	0
Complexity		80
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$ct/kWh	1.201335
CO2 Charge	\$ct/kWh	3.641963
Base Capex	\$ct/kWh	2.593238
Extra Capex	\$ct/kWh	0.155594
Other Opex	\$ct/kWh	0
Total	\$ct/kWh	7.592131
Fuel Mix		
Solid	frac	1
Liquid	frac	0
Gas	frac	0
Solid LCV		25000
Liquid LCV		42000
Gas LCV		50013
Mixture LCV		25000
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	0
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	0
ST power	MW	526.5
Percent of heat available to Steam	MW	100
Overall electrical efficiency after lo	MW	44.95
Efficiency GT Cycle	MW	0
Efficiency ST cycle	MW	46.3
Overall power output	MW	491
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

Worksheets for baseline gas fired Air blown Partial Oxidation Pre-Combustion De-Carbonisation (APO.PCDC) power plant with CO₂ capture

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input checked="" type="checkbox"/>	Gas Turbine	1	330.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	204.0	MWe
<input type="checkbox"/>	Combustor	0	0.0	kg/s fuel
<input checked="" type="checkbox"/>	Gasifier	1	21.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input checked="" type="checkbox"/>	HRSG	1	355.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	3	0	ton/day
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	Other major plant item	1	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Separation	1	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	46884
Carbon fraction	%mass	0.62	0.86	0.74
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		46884	kJ/kg	
Combined Carbon fraction		0.74		
Combined Ash Fraction		0		

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1	kg/s	
Air/Fuel Ratio by Mass for Gas Turbine	56.8635	====>	Air flow of 56.86 kg/s
Air Bleed for Blade Cooling	6.27%	====>	Cooling flow of 3.57 kg/s
HRSRG heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50	kJ/kg
	Sorbent	50	kJ/kg
	Ash	50	kJ/kg
Oxygen Production	950	kJ/kg O2	
Combustor fans (PF)	8	kJ/MJ fuel	
FGD	8	kJ/MJ fuel	
Cooling water system	7	kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	20.9 MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J45	Sheet CycleAnalysis
HRSG on GT	355 MW	Transferred to B7	Sheet CycleAnalysis
GT power	330 MW	Transferred to D65	Sheet CycleAnalysis
ST power	204 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	45 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	50.5 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	41.95 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	43.4 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	498 MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	0.00 MW
Other power from GT/ST waste heat	0 MW
Energy content of fuel	985.97 MW

Losses

GT mech loss	1.65 MW
GT gen loss	4.95 MW
ST mech loss	1.02 MW
ST mech loss	3.06 MW
GT + ST transformer loss	2.14 MW
Transformer loss direct power generated	0.00 MW
Subtotal	12.82 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:		PPAP	External	hidden calc
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	0.95 MW	0.95	0	115.46 MW ST rejection
Misc	1.49 MW	1.49	0	20.71 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	2.45 MW			
TOTAL Losses/Auxiliaries	15.26 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

	Value imported		% of heat		
			I/P to GT	kJ/kg	MW
To steam	355000	kJ/s from HRSG before losses	47.38	16880.6	355.000
GT loss	9989	kJ/s from Stack	19.60	6983.1	146.854
GT Efficiency			41.95		
Total			<u>108.92</u>		

Gas cycle Output

Estimated GT Efficiency	0.4195	Value imported	
Gross avail. energy to GT cycle	35631.84	kJ/kg	
GT Output	14947.56	kJ/kg	equiv to 314347.1 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.434	Value imported	
Heat Balance			HRSG Heat available 16880.65
From Combustion	0	kJ/kg	HRSG heat loss 1.0%
From Gasification	10783.32	kJ/kg	HRSG to Steam Cycle 16711.84
From GT HRSG etc after losses	16711.84	kJ/kg	
From Direct Generation	0	kJ/kg	
Export/Import	9985.735	kJ/kg	
Heat available to steam cycle	17509.43	kJ/kg	
ST Output	7569.163	kJ/kg	equiv to 159179.5 kW
Total Potential Output	22516.72	kJ/kg	equiv to 473526.6 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	2367.6	1571.7	795.9
Generator Loss	1.50%	7102.9	4715.2	2387.7
Transformer Loss	0.40%	1894.1	1257.4	636.7


Gross Power Output	21976.32	kJ/kg	equiv to 462162 kW
---------------------------	-----------------	--------------	--------------------

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg		0	0	
	Sorbent	50 kJ/kg		0	0	
	Ash	50 kJ/kg		0	0	
Fan and compressor mech eff.		93%				
Oxygen Production		950 kJ/kg O2		0	0	
Oxygen Compression			Value imported	993.8184		0.7
CO2 Compression				1	0	Value imported
Combustor fans (PF)		8 kJ/MJ fuel		0	0	
FGD		8 kJ/MJ fuel		0	0	
Cooling water system		7 kJ/MJ rejected		1	70.93068	Steam Cycl
Misc		0.30% of gross			65.92896	
H2S Sepn					0	
CO2 Sepn					0	
Other					0	
Total Auxiliaries					1130.678 kJ/kg	
Total Input		46884 kJ/kg				
Total Output (Net)		20845.64 kJ/kg	=>	498000 kW	Value imported	
Efficiency		50.5 %	Value imported			-36
GT Output (Generator Terminals)		330.00 MW	Value imported			2.6928
ST Output (Generator Terminals)		204.00 MW	Value imported			-33.3072
Direct O/P (Gross)		0 MW				
% heat available to steam cycle		45 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		985.9705	1	1	123.92
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		0	1	1	0.00
Gas turbine, complete	MWe	0	330	1	1	56.49
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		355	1	1	28.36
Steam turbine+pipes+cooling system	MWe		204	1	1	67.83
PF coal boiler	MW fuel feed LHV		0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	1	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	1	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		15	1		0.00
Other	User Defined		0	1		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		498	1	1	11.45
Sub-Total						288.05
Balance of plant	% of above		10			28.81
Engineering, indirects, owners cost	% of above		24			76.05
Project contingency	% of above		10			39.29
TOTAL						432.19

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ
Calculated Fuel Cost		3.0000	\$/GJ
Fuel cost of electricity		2.1386	c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="30"/> years
Load Factor	<input type="text" value="0.8"/>

Interest during construction	65.5168	M\$
Annual capital Charge	52.7965	M\$/y
Capital Charges	1.5118	c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.03"/>	Other Materials Cost	<input type="text" value="20"/>	\$/tonne
Fixed O&M cost	0.3713	Residue Disposal Cost	<input type="text" value="20"/>	\$/tonne
Variable O&M cost	0.0000			

Estimated Operating Costs **4.0216 c/kWh**

Multi-Criteria Analysis										
<p>This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.</p> <p>To edit the percentages allocated to different attributes scroll down the page</p>										
Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score				
Fuel Consumption kJ/kW	1.980	No risk	51	42.9	APPLICABILITY	30.9				
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10						
Process Conditions Temperature Pressure NB Use least well known part of process	1200K-1600K 10-60 bar but no significant technical barriers	No risk	11	80	CONFIDENCE IN WHETHER IT WILL WORK	34.0				
Novelty of Materials which is	Existing Special Alloys known material in known environment	No risk	6	90			10			
Plant Complexity No. of major units No. of major recycles	5 0		75	10						
Novelty of Process with	Minor modifications highly successful industrial applications in operation	No risk	0	95	10	ESTIMATED COSTS				
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.062		35	40	103.0					
Costs Total Operating c/kWh	4.02		80	100						
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	20	ACCEPTANCE				
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk	5	80	20					
<table border="1"> <tr> <td>Averaged risk level</td> <td>5</td> </tr> <tr> <td>Controlling risk level</td> <td>11</td> </tr> </table>					Averaged risk level	5	Controlling risk level	11	TOTALS	199.9
Averaged risk level	5									
Controlling risk level	11									

Results of Analysis

Summary

Process: **FW APO PCDC rerun GCL Contract No 013-003**

Heat Input 986.0 MW

Estimated Net Electricity Output	498.0 MW	NOTE GT efficiency calculated by program as ...	42.0 %
Net Efficiency	50.5 %	NOTE Steam cycle efficiency calculated as...	43.4 %
CO2 output/ kg/s	8.6 kg/s	NOTE percentage of input energy to steam cycle ..	45.0 %
CO2 output/kWh	0.062 kg/kWh		

Estimated Capital Cost 432.2 M\$

Estimated Op Cost 4.0 c/kWh


Multi-Criteria Assessment

Decision Factor Scores


Acceptance	32.0
Applicability	30.9
Confidence	34.0
Estimated Cost	103.0
Total	199.9
Total cost only	262.5

Risk assessment

Averaged risk level	5
Controlling risk level	Process conditions 11



CO2 emission penalty			50 \$/ton	Fuel cost	2.139	1.865	-0.2733	3.0000 \$/GJ
CO2 emissions	0.062 kg/kWh			CO2 charge	0.309	1.824	1.5143	50 \$/ton
CO2 emission cost	0.309 c/kWh			Base capex	1.883	0.989	-0.8936	
				Extra capex	0.198	0.094	-0.1037	
				Other opex	0.000	0	0.0000	
								Total 0.2436
Factor analysis			Effect on costs of electricity	TOTAL	4.5287	4.7724	0.2436	
	Scores			Extra fuel			0.2733	
Raw materials	90	0.0188		Extra capex			0.9973	
Process conditions	80	0.0377		Total extra			1.2706	
Novelty of materials	90	0.0188		CO2 tax benefit			1.5143	
Complexity	75	0.0471						
Safety	80	0.0377						
Environmental	80	0.0377						
	TOTAL	0.1977						
Base Case data								
Fuel cost	1.865 c/kWh	Based on 3 \$/GJ						
CO2 Tax	1.824 c/kWh	Based on 50 \$/tonne						
Base Capex+Opex	0.989 c/kWh							
Extra Capex	0.094 c/kWh							
Other Opex	0 c/kWh							



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.578E-05
Mix kgC/kJ	1.578E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.347 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3472 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title

FW APO PCDC rerun GCL Contra

Power Out	MWe	498
Efficiency	%	50.5
CO2 emitted	%	15
CO2 emitted	kg/kWh	0.061874
Fuel in	kg/s	21.03
Fuel in	MW	985.9705
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	48.50
Gas Cycle Efficiency	%	0.42
Steam Cycle Efficiency	%	0.43
Est Capital Cost	M\$	432.19
Est Operating Cost	ct/kWh	4.02
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	985.9705
	Number	1
	Cost	123.92
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	1
	Cost	0.00
Gas turbine, complete	MWe	330
	Number	1
	Cost	56.49
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	355
	Number	1
	Cost	28.36
Steam turbine+pipes+cooling syst	MWe	204

	Number	1
	Cost	67.83
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	1
	Cost	0.00
Other	User Defined	0
	Number	1
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	498
	Number	1

	Cost	11.45
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		2
Press max		3
Process Conditions Qualifer		1
Construction Materials		3
Construction Materials Qualifier		1
No of Recycles		0
Novelty		2
Novelty Qualifer 1		1
Novelty Qualifer 2		1
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		5
Controlling Risk Level		11
Controlling Risk is		Process conditions
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		80
Process Conditions Extra Cost	ct/kWh	0
Novelty		90
Novelty Extra Cost	ct/kWh	0
Complexity		75
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	2.138614
CO2 Charge	\$/ct/kWh	0.309369
Base Capex	\$/ct/kWh	1.883023
Extra Capex	\$/ct/kWh	0.197717
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	4.528723
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		46884
Mixture LCV		46884
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	20.9
O2 compression power	MW	0
HRSG on GT	MW	355
GT power	MW	330
ST power	MW	204
Percent of heat available to Steam	MW	45
Overall electrical efficiency after lo	MW	50.5
Efficiency GT Cycle	MW	41.95
Efficiency ST cycle	MW	43.4
Overall power output	MW	498
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for Baseline Pulverized Fuel (PF) coal fired power plant
with CO₂ capture using Amine scrubbing of flue gas**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input type="checkbox"/>	Gas Turbine	0	0.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	580.9	MWe
<input checked="" type="checkbox"/>	Combustor	1	55.0	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input type="checkbox"/>	HRSG	0	0.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		10000	kJ/Unit size
<input checked="" type="checkbox"/>	Other major plant item	1	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Separation	1	1	
	Aux Power Req'd		18500	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		1	0	0
LCV	kJ/kg	25000	42000	50013
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		100.00%	0.00%	0.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		25000	kJ/kg	
Combined Carbon fraction		0.62		
Combined Ash Fraction		0.12		

ASSUMPTIONS - Process

Gas Cycle

Actual Fuel flow rate to Gas Turbine	1 kg/s		
	40.3	====> Air flow of	40.30 kg/s
Air Bleed for Blade Cooling	6.27%	====> Cooling flow of	2.53 kg/s
HRSO heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%	
Generator Loss	1.50%	
Transformer Loss	0.40%	
Fan and compressor mech eff.	93.00%	
Misc power consumption	0.30%	of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O ₂	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	54.4 MW	Added into cell J45	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J44	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	0 MW	Transferred to D65	Sheet CycleAnalysis
ST power	580.9 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	100 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	34.7 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	0 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	46.3 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	477 MW	Transferred to G61	Sheet CycleAnalysis
Power from direct generation	0.00 MW		
Other power from GT/ST waste heat	0 MW		
Energy content of fuel	1375.00 MW		

Losses

GT mech loss	0.00 MW
GT gen loss	0.00 MW
ST mech loss	2.90 MW
ST mech loss	8.71 MW
GT + ST transformer loss	2.32 MW
Transformer loss direct power generated	0.00 MW
Subtotal	13.94 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:

		PPAP	External	hidden calc
Fuel	2.75 MW	2.75	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	11.00 MW	11.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	2.21 MW	2.21	0	311.94 MW ST rejection
Misc	1.43 MW	1.43	0	3.81 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	18.5 MW	18.5	0	
Other	0 MW	0	0	
Subtotal	35.89 MW			
TOTAL Losses/Auxiliaries	49.83 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	0	kJ/s from HRSG before losses	0.00	0.0	0.000
GT loss	0	kJ/s from Stack	0.00	0.0	0.000
GT Efficiency			<u>0.00</u>		
Total			<u>0.00</u>		

Gas cycle Output

Estimated GT Efficiency	0	Value imported		
Gross avail. energy to GT cycle	1E-07	kJ/kg		
GT Output	0	kJ/kg	equiv to	0 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.463	Value imported		
Heat Balance				
From Combustion	25000	kJ/kg		HRSG Heat available 0 kJ/kg
From Gasification	0	kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	0	kJ/kg		HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0	kJ/kg		
Export/Import	5381.818	kJ/kg		
Heat available to steam cycle	19618.18	kJ/kg	equiv to	1079000 kW
ST Output	9049.687	kJ/kg	equiv to	497732.8 kW

Total Potential Output 9049.687 kJ/kg equiv to 497732.8 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	2488.7	0.0	2488.7
Generator Loss	1.50%	7466.0	0.0	7466.0
Transformer Loss	0.40%	1990.9	0.0	1990.9

Gross Power Output 8832.494 kJ/kg equiv to 485787.2 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg		1	50	
	Sorbent	50 kJ/kg		0	0	
	Ash	50 kJ/kg		1	0	
Fan and compressor mech eff.		93%				
Oxygen Production		950 kJ/kg O2		0	0	
Oxygen Compression			Value imported		0	0.7 Is good nur
CO2 Compression				1	989.0909	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel		1	200	
FGD		8 kJ/MJ fuel		0	0	
Cooling water system		7 kJ/MJ rejected		1	75.39475	Steam Cycle Condensate
Misc		0.30% of gross			26.49748	
H2S Sepn					0	
CO2 Sepn					336.3636	
Other					0	
Total Auxiliaries					1677.347 kJ/kg	

Total Input	25000 kJ/kg					
Total Output (Net)	7155.147 kJ/kg	=>	477000 kW	Value imported		
Efficiency	34.7 %	Value imported				-103.9
GT Output (Generator Terminals)	0.00 MW	Value imported				0
ST Output (Generator Terminals)	580.90 MW	Value imported				-103.9
Direct O/P (Gross)	0 MW					
% heat available to steam cycle	100 %	Value imported				

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation						
Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		55	1	1	14.91
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		54.4	1	1	55.22
Gas turbine, complete	MWe	0	0	0	1	0.00
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		0	0	1	0.00
Steam turbine+pipes+cooling system	MWe		580.9	1	1.1	163.55
PF coal boiler	MW fuel feed LHV		1375	1	1	191.43
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	0	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	0.477	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Acid Gas removal	CC App A A12p166 (adj)		0	1		383.58
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		477	1	1	11.06
Sub-Total						819.75
Balance of plant	% of above		10			81.97
Engineering, indirects, owners cost	% of above		24			216.41
Project contingency	% of above		10			111.81
TOTAL						1229.95

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ

Calculated Fuel Cost 1.5000 \$/GJ
 Fuel cost of electricity 1.5562 c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="25"/> years
Load Factor	<input type="text" value="0.85"/>

Interest during construction 186.4503 M\$
 Annual capital Charge 156.0418 M\$/y
 Capital Charges 4.3904 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/> \$/tonne
Fixed O&M cost	1.3842 c/kWh	Residue Disposal Cost	<input type="text" value="20"/> \$/tonne
Variable O&M cost	0.0000 c/kWh		

Estimated Operating Costs 7.3308 c/kWh

Multi-Criteria Analysis										
<p>This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process. To edit the percentages allocated to different attributes scroll down the page</p>										
Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score				
Fuel Consumption kJ/kW	2.882	No risk	6	42.9	APPLICABILITY	12.5				
Raw Material Availability	Universally Common with unlimited availability for scale of this application	0	100	10						
Process Conditions Temperature Pressure NB Use least well known part of process	<1200K Atmospheric but no significant technical barriers	No risk	0	100	CONFIDENCE IN WHETHER IT WILL WORK	38.0				
Novelty of Materials which is	Carbon Steel known material in known environment	No risk	0	100						
Plant Complexity No. of major units No. of major recycles	4 0		80	10						
Novelty of Process with	Fully proven highly successful industrial applications in operation	No risk	0	100						
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.094		64	40	ESTIMATED COSTS	48.9				
Costs Total Operating c/kWh	7.33		13	100						
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	ACCEPTANCE	26.0				
Environmental Impact Management of these impacts	Mildly harmful waste extensively demonstrated and publicly accepted	No risk	10	50						
<table border="1"> <tr> <td>Averaged risk level</td> <td>3</td> </tr> <tr> <td>Controlling risk level</td> <td>10</td> </tr> </table>					Averaged risk level	3	Controlling risk level	10	TOTALS	125.5
Averaged risk level	3									
Controlling risk level	10									
					Environment					

Results of Analysis

Summary

Process: **PF+ FGD + Amine (rerun)**

Heat Input 1375.0 MW

Estimated Net Electricity Output 477.0 MW
 Net Efficiency 34.7 %
 CO2 output/ kg/s 12.5 kg/s
 CO2 output/kWh 0.094 kg/kWh

NOTE GT efficiency calculated by program as ... 0.0 %
 NOTE Steam cycle efficiency calculated as... 46.3 %
 NOTE percentage of input energy to steam cycle .. 100.0 %

Estimated Capital Cost 1229.9 M\$
 Estimated Op Cost 7.3 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance 26.0
 Applicability 12.5
 Confidence 38.0
 Estimated Cost 48.9
 Total 125.5
 Total cost only 196.3

Risk assessment

Averaged risk level 3
 Controlling risk level **Environment 10**




Comparison with Base Case CCGT

			This Case	Base Case	Difference	Base rates	
			\$/ct/kWh	\$/ct/kWh	\$/ct/kWh		
CO2 emission penalty	50 \$/ton						
CO2 emissions	0.094 kg/kWh						
CO2 emission cost	0.472 c/kWh						
Factor analysis		Effect on costs of electricity					
	Scores						
Raw materials	100	0.0000					
Process conditions	100	0.0000					
Novelty of materials	100	0.0000					
Complexity	80	0.1155					
Safety	80	0.1155					
Environmental	50	0.2887					
TOTAL		0.5197					
			TOTAL	8.3223	3.7194	-4.6029	
			Extra fuel			0.6363	
			Extra capex			5.2921	
			Total extra			5.9284	
			CO2 tax benefit			1.3255	
						Total	-4.6029

Base Case data

Fuel cost	1.839864 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.797309 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	0.941026 c/kWh		
Extra Capex	0.061167 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.5E-05
Mix kgC/kJ	0.0000248
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.330 kg/kWh
Calorific fraction of gas	0
Calorific fraction of oil	0
CO2 allowance	0.6177 kg/kWh

PF+Amine latest

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		PF+ FGD + Amine (rerun)
Power Out	MWe	477
Efficiency	%	34.7
CO2 emitted	%	10
CO2 emitted	kg/kWh	0.094365
Fuel in	kg/s	55
Fuel in	MW	1375
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	112.53
Gas Cycle Efficiency	%	0.00
Steam Cycle Efficiency	%	0.46
Est Capital Cost	M\$	1229.95
Est Operating Cost	ct/kWh	7.33
Capital Cost Items		
Solids handling	'Size'	55
	Number	1
	Cost	14.91
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	54.4
	Number	1
	Cost	55.22
Gas turbine, complete	MWe	0
	Number	0
	Cost	0.00
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	0
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	638.99

PF+Amine latest

	Number	1
	Cost	163.55
PF coal boiler	MW fuel feed LHV	1375
	Number	1
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	1
	Cost	383.58
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	477
	Number	1

PF+Amine latest

	Cost	11.06
Multi Criteria		
Feed Material		1
Feed Material Qualifier		1
Temp max		1
Press max		1
Process Conditions Qualifer		1
Construction Materials		1
Construction Materials Qualifier		1
No of Recycles		0
Novelty		1
Novelty Qualifer 1		1
Novelty Qualifer 2		1
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		3
Environmental Impact Qualifier		1
Average Risk Level		3
Controlling Risk Level		10
Controlling Risk is		Environment
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		100
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		100
Process Conditions Extra Cost	ct/kWh	0
Novelty		100
Novelty Extra Cost	ct/kWh	0
Complexity		80
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		50
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	1.556196
CO2 Charge	\$/ct/kWh	0.471824
Base Capex	\$/ct/kWh	5.774608
Extra Capex	\$/ct/kWh	0.519715
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	8.322343
Fuel Mix		
Solid	frac	1
Liquid	frac	0
Gas	frac	0
Solid LCV		25000
Liquid LCV		42000
Gas LCV		50013
Mixture LCV		25000
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

PF+Amine latest

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	54.4
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	0
ST power	MW	580.9
Percent of heat available to Steam	MW	100
Overall electrical efficiency after lo	MW	34.7
Efficiency GT Cycle	MW	0
Efficiency ST cycle	MW	46.3
Overall power output	MW	477
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

Worksheets for gas fired CO₂ capturing power plant utilizing oxy-combustion with water recirculation according to the Clean Energy Systems process

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input checked="" type="checkbox"/>	Gas Turbine	1	663.0	MWe
<input type="checkbox"/>	Steam Turbine	0	0.0	MWe
<input type="checkbox"/>	Combustor	0	0.0	kg/s fuel
<input checked="" type="checkbox"/>	Gasifier	1	23.0	kg/s fuel
<input checked="" type="checkbox"/>	Air Separation Unit	1	86.42	kg/s O2
	O2 compression Press.		72	bar
<input type="checkbox"/>	HRSG	0	0.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	Other major plant item	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	1	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	46920.3
Carbon fraction	%mass	0.62	0.86	0.739
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		46920.3	kJ/kg	
Combined Carbon fraction		0.739		
Combined Ash Fraction		0		

Mass & Energy Balance

This datasheet requires some details on the feed and outlet streams of the process:
Please enter data for figures shown in **blue**

Basis :	Flow kg/s	LCV kJ/kg	kg Carbon /kg	Carbon Balance kg/s
Fuel	<input type="text" value="23"/>	46920.3	<input type="text" value="0.739"/>	16.997
Other Materials	<input type="text" value="0"/>	<input type="text" value="0"/>	<input type="text" value="0"/>	0
Residue	<input type="text" value="0"/>	<input type="text" value="0"/>	<input type="text" value="0"/>	0
% CO2 recovered =	<input type="text" value="100.0%"/>			
CO2 recovered	62.32	0	0.273	16.997
CO2 emitted	0.00	0	0.273	0
Gross available energy		46920.3 kJ/kg fuel		
		1079167 kJ Total		

Fuel/Energy Distribution

Percent of Input Fuel direct to combustion or steam cycle	<input type="text" value="0%"/>	0
Percent of Input Fuel to gasification system	<input type="text" value="100%"/>	46920.3
Heat recovered from gasifier to steam cycle	<input type="text" value="0%"/>	0
Heat recovered from gasifier to gas cycle	<input type="text" value="100%"/>	46920.3
Percent of Input Fuel direct to Fuel Cell/MHD etc	<input type="text" value="0%"/>	0
Percent of fuel to direct generation Converted to power	<input type="text" value="0%"/>	0
Heat recovered from direct generation to steam cycle	<input type="text" value="0%"/>	0
Heat recovered from direct generation to gas cycle	<input type="text" value="0%"/>	0
Heat from Steam cycle lost to Process or ?	<input type="text" value="0"/>	kW

ASSUMPTIONS - Process

Gas Cycle

Actual Fuel flow rate to Gas Turbine	1 kg/s		
Air/Fuel Ratio by Mass for Gas Turbine	3.75	====>	Air flow of 3.75 kg/s
Air Bleed for Blade Cooling	6.27%	====>	Cooling flow of 0.24 kg/s
HRSR heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	921 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	63.5 MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	91.1 MW	Added into cell J45	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	663 MW	Transferred to D65	Sheet CycleAnalysis
ST power	0 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	0 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	45.4 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	61.5 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	0 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	490 MW	Transferred to G61	Sheet CycleAnalysis
Power from direct generation	0.00 MW		
Other power from GT/ST waste heat	0 MW		
Energy content of fuel	1079.17 MW		

Losses

GT mech loss	3.32 MW
GT gen loss	9.95 MW
ST mech loss	0.00 MW
ST mech loss	0.00 MW
GT + ST transformer loss	2.65 MW
Transformer loss direct power generated	0.00 MW
Subtotal	15.91 MW

Auxiliaries

Solids handling:

		PPAP	External	hidden calc
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	overridden MW	79.59282	overridden	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	1.07 MW	1.07	0	
Misc	1.47 MW	1.47	0	
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	2.54 MW			

NB external entries of <>0 override PPAP calculated values

0.00 MW ST rejection
153.16 MW compression losses

TOTAL Losses/Auxiliaries 18.45 MW

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	0 kJ/s from	HRSG before losses	0.00	0.0	0.000
GT loss	820 kJ/s from	Stack	17.04	7995.8	183.903
GT Efficiency			61.50		
Total			<u>78.54</u>		

Gas cycle Output

Estimated GT Efficiency	0.615	Value imported		
Gross avail. energy to GT cycle	46920.3	kJ/kg		
GT Output	28855.98	kJ/kg	equiv to	663687.6 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0	Value imported		
Heat Balance				
From Combustion	0	kJ/kg		HRSG Heat available 0 kJ/kg
From Gasification	0	kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	0	kJ/kg		HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0	kJ/kg		
Export/Import	0	kJ/kg		
Heat available to steam cycle	0	kJ/kg	equiv to	0 kW
ST Output	0	kJ/kg	equiv to	0 kW

Total Potential Output 28855.98 kJ/kg equiv to 663687.6 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	3318.4	3318.4	0.0
Generator Loss	1.50%	9955.3	9955.3	0.0
Transformer Loss	0.40%	2654.8	2654.8	0.0

Gross Power Output 28163.44 kJ/kg equiv to 647759.1 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg	0	0
-----------------	------	----------	---	---

Sorbent	50 kJ/kg		0	0	
Ash	50 kJ/kg		0	0	
Fan and compressor mech eff.	93%				
Oxygen Production	921 kJ/kg O2		1	3460.557	
Oxygen Compression		Value imported		2760.87	0.7 Is good nur
CO2 Compression			1	3960.87	Value imported O2 & CO2
Combustor fans (PF)	8 kJ/MJ fuel		0	0	
FGD	8 kJ/MJ fuel		0	0	
Cooling water system	7 kJ/MJ rejected		0	2.113333	Steam Cycle Condens
Misc	0.30% of gross			84.49032	
H2S Sepn				0	
CO2 Sepn				0	
Other				0	
Total Auxiliaries				10268.9 kJ/kg	
Total Input	46920.3 kJ/kg				
Total Output (Net)	17894.54 kJ/kg	=>		490000 kW	Value imported
Efficiency	45.4 %	Value imported			-173
GT Output (Generator Terminals)	663.00 MW	Value imported			0
ST Output (Generator Terminals)	0.00 MW	Value imported			-173
Direct O/P (Gross)	0 MW				
% heat available to steam cycle	0 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		86.42	1	1	147.40
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		1079.167	1	0.25	33.30
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		91.1	1	1	92.47
Gas turbine, complete	MWe	0	663	1	0.75	71.50
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		0	0	1	0.00
Steam turbine+pipes+cooling system	MWe		0	0	1	0.00
PF coal boiler	MW fuel feed LHV		0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	0	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	1	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		490	1	1	11.30
Sub-Total						355.97
Balance of plant	% of above		10			35.60
Engineering, indirects, owners cost	% of above		24			93.98
Project contingency	% of above		10			48.55
TOTAL						534.10

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ

Calculated Fuel Cost 3.0000 \$/GJ
 Fuel cost of electricity 2.3789 c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="25"/> years
Load Factor	<input type="text" value="0.85"/>

Interest during construction 80.9659 M\$
 Annual capital Charge 67.7610 M\$/y
 Capital Charges 1.8559 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/> \$/tonne
Fixed O&M cost	0.5852 c/kWh	Residue Disposal Cost	<input type="text" value="20"/> \$/tonne
Variable O&M cost	0.0000 c/kWh		

Estimated Operating Costs 4.8199 c/kWh

Multi-Criteria Analysis

This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.
 To edit the percentages allocated to different attributes scroll down the page

Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score
Fuel Consumption kJ/kW	2.203	No risk	40	42.9	APPLICABILITY	26.1
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10		
Process Conditions Temperature Pressure NB Use least well known part of process	1200K-1600K 60-150 bar but no significant technical barriers	Low risk 20	65	10	CONFIDENCE IN WHETHER IT WILL WORK	29.5
Novelty of Materials which is	Existing Special Alloys known material but in new environment	No risk 13	90	10		
Plant Complexity No. of major units No. of major recycles	4 0		80	10		
Novelty of Process with	Major modifications promising and extensive pilotscale demonstration	No risk 16	60	10	ESTIMATED COSTS	86.5
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.000		42	40		
Costs Total Operating c/kWh	4.82		64	100		
Safety Risk Control of these risks	Risk extensively demonstrated and publicly accepted	No risk 10	60	20	ACCEPTANCE	28.0
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk 5	80	20		
TOTALS						170.1
Averaged risk level		11				
Controlling risk level		20	Process conditions			

Results of Analysis

Summary

Process: **CES Process (medium term) GCL Contract 014-002**

Heat Input 1079.2 MW

Estimated Net Electricity Output	490.0 MW	NOTE GT efficiency calculated by program as ...	61.5 %
Net Efficiency	45.4 %	NOTE Steam cycle efficiency calculated as...	0.0 %
CO2 output/ kg/s	0.0 kg/s	NOTE percentage of input energy to steam cycle ..	0.0 %
CO2 output/kWh	0.000 kg/kWh		

Estimated Capital Cost 534.1 M\$
 Estimated Op Cost 4.8 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance	28.0
Applicability	26.1
Confidence	29.5
Estimated Cost	86.5
Total	170.1
Total cost only	246.5

Risk assessment

Averaged risk level	11
Controlling risk level	Process conditions 20




Comparison with Base Case CCGT

			This Case \$/ct/kWh	Base Case \$/ct/kWh	Difference \$/ct/kWh	Base rates
CO2 emission penalty	50 \$/ton					
CO2 emissions	0.000 kg/kWh		Fuel cost 2.379	1.865	-0.5136	3.0000 \$/GJ
CO2 emission cost	0.000 c/kWh		CO2 charge 0.000	1.824	1.8236	50 \$/ton
			Base capex 2.441	0.989	-1.4516	
			Extra capex 0.330	0.084	-0.2454	
			Other opex 0.000	0	0.0000	
						Total -0.3870
Factor analysis		Effect on costs of electricity	TOTAL	5.1495	4.7625	-0.3870
	Scores					
Raw materials	90	0.0244	Extra fuel		0.5136	
Process conditions	65	0.0854	Extra capex		1.6971	
Novelty of materials	90	0.0244	Total extra		2.2107	
Complexity	80	0.0488	CO2 tax benefit		1.8236	
Safety	60	0.0976				
Environmental	80	0.0488				
TOTAL		0.3295				

Base Case data

Fuel cost	1.865 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.824 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	0.989 c/kWh		
Extra Capex	0.084 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.575E-05
Mix kgC/kJ	1.575E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.347 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3465 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		CES Process (medium term)	GCL Contract
Power Out	MWe	490	
Efficiency	%	45.4	
CO2 emitted	%	0	
CO2 emitted	kg/kWh	0	
Fuel in	kg/s	23	
Fuel in	MW	1079.167	
Other in	kg/s	0	
Ash (residue) Out	kg/s	0	
CO2 to 'storage'	kg/s	62.32	
Gas Cycle Efficiency	%	0.62	
Steam Cycle Efficiency	%	0.00	
Est Capital Cost	M\$	534.10	
Est Operating Cost	ct/kWh	4.82	
Capital Cost Items			
Solids handling	'Size'	0	
	Number	0	
	Cost	0.00	
Coal pulverise+dry (gasif)	kg/s feed	0	
	Number	0	
	Cost	0.00	
Oxygen production	kg/s O2	86.42	
	Number	1	
	Cost	147.40	
Gasifier (Shell, inc hopper, cool/filt)	MW fuel feed LHV	269.7917	
	Number	1	
	Cost	33.30	
Acid gas removal (scrubbing)	kmol/s feed gas	0	
	Number	0	
	Cost	0.00	
CFBC combustor /stack	MW fuel feed	0	
	Number	0	
	Cost	0.00	
CO2 compressor (motor driven)	MWe	91.1	
	Number	1	
	Cost	92.47	
Gas turbine, complete	MWe	497.25	
	Number	1	
	Cost	71.50	
Gas turbine, compressor only	MW consumed	0	
	Number	0	
	Cost	0	
Gas turbine, turbine only	MW	0	
	Number	0	
	Cost	0	
Gas turbine, generator only	MWe	0	
	Number	0	
	Cost	0	
HRSG	MWth transferred	0	
	Number	0	
	Cost	0.00	
Steam turbine+pipes+cooling syst	MWe	0	

	Number	0
	Cost	0.00
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	490
	Number	1

	Cost	11.30
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		2
Press max		4
Process Conditions Qualifer		1
Construction Materials		3
Construction Materials Qualifier		2
No of Recycles		0
Novelty		3
Novelty Qualifer 1		2
Novelty Qualifer 2		3
Safety Risk		3
Safety Risk Qualifer		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		11
Controlling Risk Level		20
Controlling Risk is		Process conditions
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		65
Process Conditions Extra Cost	ct/kWh	0
Novelty		90
Novelty Extra Cost	ct/kWh	0
Complexity		80
Complexity Extra Cost	ct/kWh	0
Safety		60
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/kWh	2.378855
CO2 Charge	\$/kWh	0
Base Capex	\$/kWh	2.441091
Extra Capex	\$/kWh	0.329547
Other Opex	\$/kWh	0
Total	\$/kWh	5.149493
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		46920.3
Mixture LCV		46920.3
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	63.5
O2 compression power	MW	91.1
HRSG on GT	MW	0
GT power	MW	663
ST power	MW	0
Percent of heat available to Steam	MW	0
Overall electrical efficiency after lo	MW	45.4
Efficiency GT Cycle	MW	61.5
Efficiency ST cycle	MW	0
Overall power output	MW	490
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		overridden
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for gas fired CO₂ capturing power plant utilising hybrid
solid oxide fuel cell/ gas turbine power plant**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input checked="" type="checkbox"/>	Gas Turbine	10	9.3	MWe
<input type="checkbox"/>	Steam Turbine	0	0.0	MWe
<input type="checkbox"/>	Combustor	0	0.0	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input type="checkbox"/>	HRSG	0	0.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	Other major plant item	10	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input checked="" type="checkbox"/>	Fuel Cell (or Direct Generator)	10		

Fuel Type

Solid

Liquid

Gaseous

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	46920
Carbon fraction	%mass	0.62	0.86	0.74
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		46920	kJ/kg	
Combined Carbon fraction		0.74		
Combined Ash Fraction		0		

Mass & Energy Balance

This datasheet requires some details on the feed and outlet streams of the process:
Please enter data for figures shown in **blue**

Basis :	Flow kg/s	LCV kJ/kg	kg Carbon /kg	Carbon Balance kg/s
Fuel	15.47	46920	0.74	11.4478
Other Materials	0	0	0	0
Residue	0	0	0	0
% CO2 recovered =	99.0%			
CO2 recovered	41.56	0	0.273	11.33332
CO2 emitted	0.42	0	0.273	0.114478
Gross available energy		46920 kJ/kg fuel 725852.4 kJ Total		
Fuel/Energy Distribution				
Percent of Input Fuel direct to combustion or steam cycle	0%	0		
Percent of Input Fuel to gasification system	0%	0		
Heat recovered from gasifier to steam cycle	0%	0		
Heat recovered from gasifier to gas cycle	0%	0		
Percent of Input Fuel direct to Fuel Cell/MHD etc	65%	30451.08		
Percent of fuel to direct generator Converted to power	90%	27405.97		
Heat recovered from direct generation to steam cycle	0%	0		
Heat recovered from direct generation to gas cycle	0%	0		
Heat from Steam cycle lost to Process or ?	0	kW		

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1	kg/s		
Air/Fuel Ratio by Mass for Gas Turbine	56.8635	====>	Air flow of	56.86 kg/s
Air Bleed for Blade Cooling	6.27%	====>	Cooling flow of	3.57 kg/s
HRSR heat loss	1.0%			

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	7.00%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50	kJ/kg
	Sorbent	50	kJ/kg
	Ash	50	kJ/kg
Oxygen Production	950	kJ/kg O ₂	
Combustor fans (PF)	8	kJ/MJ fuel	
FGD	8	kJ/MJ fuel	
Cooling water system	7	kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	8.1 MW	Added into cell J45	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J44	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	92.92 MW	Transferred to D65	Sheet CycleAnalysis
ST power	0 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	0 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	64.62 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	35 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	0 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	469 MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	423.97 MW
Other power from GT/ST waste heat	0 MW
Energy content of fuel	725.85 MW

Losses

GT mech loss	0.46 MW
GT gen loss	1.39 MW
ST mech loss	0.00 MW
ST mech loss	0.00 MW
GT + ST transformer loss	6.50 MW
Transformer loss direct power generated	29.68 MW
Subtotal	38.04 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:		PPAP	External	<i>hidden calc</i>
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	0.00 MW	0.00	0	0.00 MW ST rejection
Misc	1.41 MW	1.41	0	0.57 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	1.41 MW			
TOTAL Losses/Auxiliaries	39.45 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	0 kJ/s from	HRSG before losses	0.00	0.0	0.000
GT loss	9989 kJ/s from	Stack	19.60	3227.5	49.930
GT Efficiency			35.00		
Total			54.60		

Gas cycle Output

Estimated GT Efficiency	0.35	Value imported		
Gross avail. energy to GT cycle	16468.92	kJ/kg		
GT Output	5764.122	kJ/kg	equiv to	89170.97 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0	Value imported		
Heat Balance				
From Combustion	0	kJ/kg		HRSG Heat available 0 kJ/kg
From Gasification	0	kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	0	kJ/kg		HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0	kJ/kg		
Export/Import	0	kJ/kg		
Heat available to steam cycle	0	kJ/kg	equiv to	0 kW
ST Output	0	kJ/kg	equiv to	0 kW

Total Potential Output 5764.122 kJ/kg equiv to 89170.97 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	445.9	445.9	0.0
Generator Loss	1.50%	1337.6	1337.6	0.0
Transformer Loss	7.00%	6242.0	6242.0	0.0

Gross Power Output 30732.9 kJ/kg equiv to 475438 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg		0	0	
	Sorbent	50 kJ/kg		0	0	
	Ash	50 kJ/kg		0	0	
Fan and compressor mech eff.		93%				
Oxygen Production		950 kJ/kg O2		0	0	
Oxygen Compression			Value imported		0	0.7 Is good nur
CO2 Compression				1	523.5941	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel		0	0	
FGD		8 kJ/MJ fuel		0	0	
Cooling water system		7 kJ/MJ rejected		0	1.815	Steam Cycle Condensate
Misc		0.30% of gross			92.19871	
H2S Sepn					0	
CO2 Sepn					0	
Other					0	
Total Auxiliaries					617.6078 kJ/kg	

Total Input	46920 kJ/kg				
Total Output (Net)	30115.3 kJ/kg	=>	469000 kW	Value imported	
Efficiency	64.62 %	Value imported			376.08
GT Output (Generator Terminals)	92.92 MW	Value imported			0
ST Output (Generator Terminals)	0.00 MW	Value imported			376.08
Direct O/P (Gross)	394.2925 MW				
% heat available to steam cycle	0 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		8.1	1	1	8.22
Gas turbine, complete	MWe	0	9.292	10	2	77.66
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		0	0	1	0.00
Steam turbine+pipes+cooling system	MWe		0	0	1	0.00
PF coal boiler	MW fuel feed LHV		0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	1	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	1	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		0	0		795.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		469	1	1	10.91
Sub-Total						891.80
Balance of plant	% of above		10			89.18
Engineering, indirects, owners cost	% of above		24			235.43
Project contingency	% of above		10			121.64
TOTAL						1338.05

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ
Calculated Fuel Cost		3.0000	\$/GJ
Fuel cost of electricity		1.6713	c/kWh

Capital Charges

Interest Rate	<input type="text" value="9%"/>	
Plant Life Span	<input type="text" value="30"/>	years
Load Factor	<input type="text" value="0.8"/>	
Interest during construction		181.7504 M\$
Annual capital Charge		147.9318 M\$/y
Capital Charges		4.4978 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.03"/>	Other Materials Cost	<input type="text" value="20"/>	\$/tonne
Fixed O&M cost		Residue Disposal Cost	<input type="text" value="20"/>	\$/tonne
Variable O&M cost				

Estimated Operating Costs **7.3896 c/kWh**

Multi-Criteria Analysis						
This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process. To edit the percentages allocated to different attributes scroll down the page						
Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score
Fuel Consumption kJ/kW	1.548	No risk	73	42.9	APPLICABILITY	40.2
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10		
Process Conditions Temperature Pressure NB Use least well known part of process	1200K-1600K <10bar needs tech breakthrough with known parallels	Low risk	34	85	CONFIDENCE IN WHETHER IT WILL WORK	21.0
Novelty of Materials which is	Exotic Ceramic newly discovered material proven in similar duty	High risk	63	20		
Plant Complexity No. of major units No. of major recycles	11 0		45	10		
Novelty of Process with	Major modifications promising industrial applications in operation	No risk	13	60	10	ESTIMATED COSTS
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.003		42	40	40	
Costs Total Operating c/kWh	7.39		12	100		35.0
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	20	ACCEPTANCE
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk	5	80	20	
TOTALS						128.1
		Averaged risk level	20			
		Controlling risk level	63	Materials		

Results of Analysis

Summary

Process: **SOFC v3.02 rerun based on 17-05-2004 flowsheet (10 streams)**

Heat Input	725.9 MW		
Estimated Net Electricity Output	469.0 MW	NOTE GT efficiency calculated by program as ...	35.0 %
Net Efficiency	64.6 %	NOTE Steam cycle efficiency calculated as...	0.0 %
CO2 output/ kg/s	0.4 kg/s	NOTE percentage of input energy to steam cycle ..	0.0 %
CO2 output/kWh	0.003 kg/kWh		

Estimated Capital Cost	1338.1 M\$
Estimated Op Cost	7.4 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance	32.0
Applicability	40.2
Confidence	21.0
Estimated Cost	35.0
	Total
	128.1
	Total cost only
	195.1

Risk assessment

Averaged risk level	20
Controlling risk level	Materials 63




Comparison with Base Case CCGT

			This Case \$/ct/kWh	Base Case \$/ct/kWh	Difference \$/ct/kWh	Base rates	
CO2 emission penalty	50 \$/ton						
CO2 emissions	0.003 kg/kWh		Fuel cost	1.671	2.097	0.4253	3.0000 \$/GJ
CO2 emission cost	0.016 c/kWh		CO2 charge	0.016	1.921	1.9049	50 \$/ton
			Base capex	5.718	2.5125	-3.2057	
			Extra capex	1.144	0	-1.1436	
			Other opex	0.000	0	0.0000	
							Total -2.0192
Factor analysis		Effect on costs of electricity	TOTAL	8.5493	6.5301	-2.0192	
	Scores		Extra fuel			-0.4253	
Raw materials	90	0.0572	Extra capex			4.3494	
Process conditions	85	0.0858	Total extra			3.9241	
Novelty of materials	20	0.4575	CO2 tax benefit			1.9049	
Complexity	45	0.3145					
Safety	80	0.1144					
Environmental	80	0.1144					
TOTAL		1.1436					

Base Case data

Fuel cost	2.0966 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.921 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	2.5125 c/kWh		
Extra Capex	0 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.577E-05
Mix kgC/kJ	1.577E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.347 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3470 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title

SOFC v3.02 rerun based on 17-05-2004 flowsheet (10 st

Power Out	MWe	469
Efficiency	%	64.62
CO2 emitted	%	1
CO2 emitted	kg/kWh	0.003222
Fuel in	kg/s	15.47
Fuel in	MW	725.8524
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	41.56
Gas Cycle Efficiency	%	0.35
Steam Cycle Efficiency	%	0.00
Est Capital Cost	M\$	1338.05
Est Operating Cost	ct/kWh	7.39
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	8.1
	Number	1
	Cost	8.22
Gas turbine, complete	MWe	18.584
	Number	10
	Cost	77.66
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	0
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	0

	Number	0
	Cost	0.00
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	795.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	469
	Number	1

	Cost	10.91
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		2
Press max		2
Process Conditions Qualifer		2
Construction Materials		5
Construction Materials Qualifier		3
No of Recycles		0
Novelty		3
Novelty Qualifer 1		2
Novelty Qualifer 2		1
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		20
Controlling Risk Level		63
Controlling Risk is	Materials	
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		85
Process Conditions Extra Cost	ct/kWh	0
Novelty		20
Novelty Extra Cost	ct/kWh	0
Complexity		45
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	1.671309
CO2 Charge	\$/ct/kWh	0.01611
Base Capex	\$/ct/kWh	5.718248
Extra Capex	\$/ct/kWh	1.14365
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	8.549316
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		46920
Mixture LCV		46920
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	8.1
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	92.92
ST power	MW	0
Percent of heat available to Steam	MW	0
Overall electrical efficiency after lo	MW	64.62
Efficiency GT Cycle	MW	35
Efficiency ST cycle	MW	0
Overall power output	MW	469
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

Worksheets for gas fired CO₂ capturing power plant utilizing circulating Dolomite CO₂ acceptor in pre-combustion decarbonisation reforming process.

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input checked="" type="checkbox"/>	Gas Turbine	1	398.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	166.0	MWe
<input checked="" type="checkbox"/>	Combustor	1	21.4	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input checked="" type="checkbox"/>	Air Separation Unit	1	27.8	kg/s O2
	O2 compression Press.		27	bar
<input checked="" type="checkbox"/>	HRSG	1	400.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	Other major plant item	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Combustor Type

PF

FBC

CFBC

PFBC

Steam Cycle Type

Sub Critical

SuperCritical

Fuel SpecificationsUser to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	48912
Carbon fraction	%mass	0.62	0.86	0.74
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		48912	kJ/kg	
Combined Carbon fraction		0.74		
Combined Ash Fraction		0		

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1 kg/s		
Air/Fuel Ratio by Mass for Gas Turbine	56.8635	====>	Air flow of 56.86 kg/s
Air Bleed for Blade Cooling	6.27%	====>	Cooling flow of 3.57 kg/s
HRSR heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	5.1 MW	Added into cell J45	Sheet CycleAnalysis
O2 compression power	13.6 MW	Added into cell J44	Sheet CycleAnalysis
HRSG on GT	400 MW	Transferred to B7	Sheet CycleAnalysis
GT power	398 MW	Transferred to D65	Sheet CycleAnalysis
ST power	166 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	25 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	47.7 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	35 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	35 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	503 MW	Transferred to G61	Sheet CycleAnalysis
Power from direct generation	0.00 MW		
Other power from GT/ST waste heat	0 MW		
Energy content of fuel	1055.03 MW		

Losses

GT mech loss	1.99 MW
GT gen loss	5.97 MW
ST mech loss	0.83 MW
ST mech loss	2.49 MW
GT + ST transformer loss	2.26 MW
Transformer loss direct power generated	0.00 MW
Subtotal	13.54 MW

Auxiliaries

NB external entries of <=0 override PPAP calculated values

Solids handling:		PPAP	External	<i>hidden calc</i>
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	26.41 MW	26.41	0	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	0.76 MW	0.76	0	107.90 MW ST rejection
Misc	1.51 MW	1.51	0	1.31 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	28.68 MW			
TOTAL Losses/Auxiliaries	42.22 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	400000	kJ/s from HRSG before losses	3791.35	18544.3	400.000
GT loss	9989	kJ/s from Stack	19.60	95.9	2.068
GT Efficiency			35.00		
Total			<u>3845.95</u>		

Gas cycle Output

Estimated GT Efficiency	0.35	Value imported		
Gross avail. energy to GT cycle	489.12	kJ/kg		
GT Output	171.192	kJ/kg	equiv to	3692.6114 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.35	Value imported		
Heat Balance				
From Combustion	48422.88	kJ/kg		HRSG Heat available 18544.27 kJ/kg
From Gasification	0	kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	18358.83	kJ/kg		HRSG to Steam Cycle 18358.83 kJ/kg
From Direct Generation	0	kJ/kg		
Export/Import	0	kJ/kg		
Heat available to steam cycle	<u>66781.71</u>	kJ/kg	equiv to	1440481.5 kW
ST Output	23259.46	kJ/kg	equiv to	501706.45 kW

Total Potential Output 23430.65 kJ/kg equiv to 505399.06 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	2527.0	18.5	2508.5
Generator Loss	1.50%	7581.0	55.4	7525.6
Transformer Loss	0.40%	2021.6	14.8	2006.8

Gross Power Output 22868.31 kJ/kg equiv to 493269.48 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg		0	0	
	Sorbent	50 kJ/kg		0	0	
	Ash	50 kJ/kg		0	0	
Fan and compressor mech eff.		93%				
Oxygen Production		950 kJ/kg O2		1	1224.386	
Oxygen Compression						0.7 Is good num
CO2 Compression				1	236.4395	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel		0	0	
FGD		8 kJ/MJ fuel		0	0	
Cooling water system		7 kJ/MJ rejected		1	305.6645	Steam Cycle Condense
Misc		0.30% of gross			68.60494	
H2S Sepn					0	
CO2 Sepn					0	
Other					0	
Total Auxiliaries					2465.6 kJ/kg	

Total Input	48912 kJ/kg					
Total Output (Net)	20402.71 kJ/kg	=>	503000 kW	Value imported		
Efficiency	47.7 %	Value imported				-61
GT Output (Generator Terminals)	398.00 MW	Value imported				2.64272
ST Output (Generator Terminals)	166.00 MW	Value imported				-58.35728
Direct O/P (Gross)	0 MW					
% heat available to steam cycle	25 %	Value imported				

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O ₂		27.8	1	1	66.63
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO ₂ compressor (motor driven)	MWe		5.1	1	1	5.18
Gas turbine, complete	MWe	0	398	1	1.3	84.52
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		400	1	1	31.96
Steam turbine+pipes+cooling system	MWe		166	1	1	58.11
PF coal boiler	MW fuel feed LHV		0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed		0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	1	0.00
PFBC combustor	MW fuel feed		1044.482	1	1.5	193.35
FBC	MW fuel feed LHV		0	0	1	0.00
CO ₂ regeneration	Kg/s CO ₂ captured		0	0	1	0.00
Gas absorption for CO ₂ capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO ₂		0	0	1	0.00
Gas shift reaction	Kg/s CO ₂ in outlet		0	0	1	0.00
Gas filters	Say		0	0		30.00
Catalyst loading/unloading	Say		0	0		10.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Electrical distribution	MWe gross		503	1	1	11.54
Sub-Total						491.28
Balance of plant	% of above		10			49.13
Engineering, indirects, owners cost	% of above		24			129.70
Project contingency	% of above		10			67.01
TOTAL						737.12

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/> \$/GJ
	Liquid	<input type="text" value="3"/> \$/GJ
	Gaseous	<input type="text" value="3"/> \$/GJ
Calculated Fuel Cost		3.0000 \$/GJ
Fuel cost of electricity		2.2642 c/kWh

Capital Charges

Interest Rate	<input type="text" value="9%"/>
Plant Life Span	<input type="text" value="30"/> years
Load Factor	<input type="text" value="0.8"/>
Interest during construction	100.1251 M\$
Annual capital Charge	81.4947 M\$/y
Capital Charges	2.3103 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.03"/>	Other Materials Cost	<input type="text" value="20"/> \$/tonne
Fixed O&M cost	0.6269 c/kWh	Residue Disposal Cost	<input type="text" value="20"/> \$/tonne
Variable O&M cost	0.0000 c/kWh		

Estimated Operating Costs **5.2014 c/kWh**

Multi-Criteria Analysis

This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.
To edit the percentages allocated to different attributes scroll down the page

Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score	
Fuel Consumption kJ/kW	2.096	No risk	45	42.9	APPLICABILITY	28.4	
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10			
Process Conditions Temperature Pressure NB Use least well known part of process	1200K-1600K 10-60 bar but no significant technical barriers	No risk	11	80	CONFIDENCE IN WHETHER IT WILL WORK	30.0	
Novelty of Materials which is	Existing Special Alloys known material in known environment	No risk	6	90			10
Plant Complexity No. of major units No. of major recycles	6 0		70	10			
<i>Raw score = 100</i> Novelty of Process with	<i>Caution - Very high risk of failure</i> Major modifications problematical credited scientific proof of concept	Unacceptable risk 100	60	10	ESTIMATED COSTS	74.8	
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.070		32	40			
Costs Total Operating c/kWh	5.2		56	100			
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	ACCEPTANCE	32.0	
Environmental Impact Management of these impacts	Benign Waste extensively demonstrated and publicly accepted	No risk	5	80			20
TOTALS						165.2	
		Averaged risk level	21				
		Controlling risk level	100	Process novelty			

Results of Analysis

Summary

Process: **CaO (+MgO) Acceptor - Subcritical**

Heat Input 1055.0 MW

Estimated Net Electricity Output 503.0 MW
 Net Efficiency 47.7 %
 CO2 output/ kg/s 9.8 kg/s
 CO2 output/kWh 0.070 kg/kWh

NOTE GT efficiency calculated by program as ... 35.0 %
 NOTE Steam cycle efficiency calculated as... 35.0 %
 NOTE percentage of input energy to steam cycle .. 25.0 %

Estimated Capital Cost 737.1 M\$
 Estimated Op Cost 5.2 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance 32.0
 Applicability 28.4
 Confidence 30.0
 Estimated Cost 74.8
 Total 165.2
 Total cost only 238.9

Risk assessment

Averaged risk level 21
 Controlling risk level **Process novelty 100**




Comparison with Base Case CCGT

			This Case \$/kWh	Base Case \$/kWh	Difference \$/kWh	Base rates
CO2 emission penalty	50 \$/ton					
CO2 emissions	0.070 kg/kWh		Fuel cost 2.264	2.097	-0.1676	3.0000 \$/GJ
CO2 emission cost	0.349 c/kWh		CO2 charge 0.349	1.921	1.5719	50 \$/ton
			Base capex 2.937	2.5125	-0.4247	
			Extra capex 0.323	0	-0.3231	
			Other opex 0.000	0	0.0000	
						Total 0.6565
Factor analysis		Effect on costs of electricity	TOTAL	5.8736	6.5301	0.6565
	Scores		Extra fuel			0.1676
Raw materials	90	0.0294	Extra capex			0.7478
Process conditions	80	0.0587	Total extra			0.9154
Novelty of materials	90	0.0294	CO2 tax benefit			1.5719
Complexity	70	0.0881				
Safety	80	0.0587				
Environmental	80	0.0587				
TOTAL		0.3231				

Base Case data

Fuel cost	2.0966 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.921 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	2.5125 c/kWh		
Extra Capex	0 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO ₂ emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.513E-05
Mix kgC/kJ	1.513E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.333 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO ₂ allowance	0.3328 kg/kWh

CaO/CaCO3 Subcrit

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		CaO (+MgO) Acceptor - Subcritical
Power Out	MWe	503
Efficiency	%	47.7
CO2 emitted	%	16.67
CO2 emitted	kg/kWh	0.069827
Fuel in	kg/s	21.57
Fuel in	MW	1055.032
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	48.77
Gas Cycle Efficiency	%	0.35
Steam Cycle Efficiency	%	0.35
Est Capital Cost	M\$	737.12
Est Operating Cost	ct/kWh	5.20
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	27.8
	Number	1
	Cost	66.63
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	5.1
	Number	1
	Cost	5.18
Gas turbine, complete	MWe	517.4
	Number	1
	Cost	84.52
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	400
	Number	1
	Cost	31.96
Steam turbine+pipes+cooling syst	MWe	166

CaO/CO₂ Subcrit

	Number	1
	Cost	58.11
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	1566.722
	Number	1
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO ₂ regeneration	Kg/s CO ₂ captured	0
	Number	0
	Cost	0.00
Gas absorption for CO ₂ capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO ₂	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO ₂ in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	30.00
Other	User Defined	0
	Number	0
	Cost	10.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	503
	Number	1

CaOCaCO3 Subcrit

	Cost	11.54
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		2
Press max		3
Process Conditions Qualifer		1
Construction Materials		3
Construction Materials Qualifier		1
No of Recycles		0
Novelty		3
Novelty Qualifer 1		3
Novelty Qualifer 2		7
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		2
Environmental Impact Qualifier		1
Average Risk Level		21
Controlling Risk Level		100
Controlling Risk is		Process novelty
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		80
Process Conditions Extra Cost	ct/kWh	0
Novelty		90
Novelty Extra Cost	ct/kWh	0
Complexity		70
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		80
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$ct/kWh	2.264151
CO2 Charge	\$ct/kWh	0.349135
Base Capex	\$ct/kWh	2.937212
Extra Capex	\$ct/kWh	0.323093
Other Opex	\$ct/kWh	0
Total	\$ct/kWh	5.873592
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		48912
Mixture LCV		48912
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

CaO/CO₂ Subcrit

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO ₂ compression power	MW	5.1
O ₂ compression power	MW	13.6
HRSG on GT	MW	400
GT power	MW	398
ST power	MW	166
Percent of heat available to Steam	MW	25
Overall electrical efficiency after lo	MW	47.7
Efficiency GT Cycle	MW	35
Efficiency ST cycle	MW	35
Overall power output	MW	503
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H ₂ S Sepn		0
CO ₂ Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for gas fired CO₂ capturing power plant utilizing
chemical looping process with recirculating barium oxides**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

	Number of Units	Nominal Size	Units
<input type="checkbox"/> Gas Turbine	0	0.0	MWe
<input checked="" type="checkbox"/> Steam Turbine	1	519.0	MWe
<input checked="" type="checkbox"/> Combustor	2	10.9	kg/s fuel
<input type="checkbox"/> Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/> Air Separation Unit	0	0	kg/s O2
<input type="checkbox"/> O2 compression Press.		1.22	bar
<input checked="" type="checkbox"/> HRSG	1	0.0	MW
<input type="checkbox"/> FGD	0		
<input type="checkbox"/> H2S Removal	0	0	ton/day
<input type="checkbox"/> Aux Power Req'd		10000	kJ/Unit size
<input checked="" type="checkbox"/> Other major plant item	1	0	
<input type="checkbox"/> Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/> CO2 Separation	0	0	
<input type="checkbox"/> Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/> CO2 Compression	1		
<input type="checkbox"/> To Pressure		110	bar
<input type="checkbox"/> Fuel Cell (or Direct Generator)	0		

Fuel Type

- Solid
 Liquid
 Gaseous

Steam Cycle Type

- Sub Critical
 SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	50013
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		50013	kJ/kg	
Combined Carbon fraction		0.75		
Combined Ash Fraction		0		

Mass & Energy Balance

This datasheet requires some details on the feed and outlet streams of the process:
Please enter data for figures shown in **blue**

Basis :	Flow kg/s	LCV kJ/kg	kg Carbon /kg	Carbon Balance kg/s
Fuel	21.88	50013	0.75	16.41
Other Materials	0	0	0	0
Residue	0	0	0	0
% CO2 recovered =	100.0%			
CO2 recovered	60.17	0	0.273	16.41
CO2 emitted	0.00	0	0.273	0
Gross available energy		50013 kJ/kg fuel 1094284 kJ Total		

Fuel/Energy Distribution

Percent of Input Fuel direct to combustion or steam cycle	100%	50013
Percent of Input Fuel to gasification system	0%	0
Heat recovered from gasifier to steam cycle	0%	0
Heat recovered from gasifier to gas cycle	0%	0
Percent of Input Fuel direct to Fuel Cell/MHD etc	0%	0
Percent of fuel to direct generation Converted to power	0%	0
Heat recovered from direct generation to steam cycle	0%	0
Heat recovered from direct generation to gas cycle	0%	0
Heat from Steam cycle lost to Process or ?	0	kW

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1 kg/s		
	40.3	====> Air flow of	40.30 kg/s
Air Bleed for Blade Cooling	6.27%	====> Cooling flow of	2.53 kg/s
HRSG heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	19 MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J45	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	0 MW	Transferred to D65	Sheet CycleAnalysis
ST power	519 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	0 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	44.3 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	0 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	46.3 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	484 MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	0.00 MW
Other power from GT/ST waste heat	0 MW
Energy content of fuel	1094.28 MW

Losses

GT mech loss	0.00 MW
GT gen loss	0.00 MW
ST mech loss	2.60 MW
ST mech loss	7.79 MW
GT + ST transformer loss	2.08 MW
Transformer loss direct power generated	0.00 MW
Subtotal	12.46 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

		PPAP	External	<i>hidden calc</i>
Solids handling:				
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	2.08 MW	2.08	0	278.70 MW ST rejection
Misc	1.45 MW	1.45	0	18.82 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	3.53 MW			

TOTAL Losses/Auxiliaries 15.99 MW

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

	Value imported		% of heat		
			I/P to GT	kJ/kg	MW
To steam	0 kJ/s from	HRSG before losses	0.00	0.0	0.000
GT loss	0 kJ/s from	Stack	0.00	0.0	0.000
GT Efficiency			0.00		
Total			<u>0.00</u>		

Gas cycle Output

Estimated GT Efficiency	0	Value imported	
Gross avail. energy to GT cycle	1E-07 kJ/kg		
GT Output	0 kJ/kg	equiv to	0 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.463	Value imported	
Heat Balance			
From Combustion	50013 kJ/kg		HRSG Heat available 0 kJ/kg
From Gasification	0 kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	0 kJ/kg		HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0 kJ/kg		
Export/Import	0 kJ/kg		
Heat available to steam cycle	50013 kJ/kg	equiv to	1094284 kW
ST Output	23070.54 kJ/kg	equiv to	504783.3 kW

Total Potential Output 23070.54 kJ/kg equiv to 504783.3 kW

Process Losses

		Total	GT	ST
Turbine Mech Loss	0.50%	2523.9	0.0	2523.9
Generator Loss	1.50%	7571.8	0.0	7571.8
Transformer Loss	0.40%	2019.1	0.0	2019.1

Gross Power Output 22516.84 kJ/kg equiv to 492668.5 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg	0	0	
	Sorbent	50 kJ/kg	0	0	
	Ash	50 kJ/kg	0	0	
Fan and compressor mech eff.	93%				
Oxygen Production	950 kJ/kg O ₂		0	0	
Oxygen Compression			Value imported	868.3729	0.7 Is good number for gasifiers kg O ₂
CO ₂ Compression			1	0	Value imported O ₂ & CO ₂
Combustor fans (PF)	8 kJ/MJ fuel		0	0	
FGD	8 kJ/MJ fuel		0	0	

Cooling water system	7 kJ/MJ rejected		1	189.8322	Steam Cycle Condenser + Allow 0.5MJ/kg CC
Misc	0.30% of gross			67.55053	
H2S Sepn				0	
CO2 Sepn				0	
Other				0	
Total Auxiliaries				1125.756 kJ/kg	
Total Input	50013 kJ/kg				
Total Output (Net)	21391.09 kJ/kg	=>		484000 kW	Value imported
Efficiency	44.3 %	Value imported			-35
GT Output (Generator Terminals)	0.00 MW	Value imported			0
ST Output (Generator Terminals)	519.00 MW	Value imported			-35
Direct O/P (Gross)	0 MW				
% heat available to steam cycle	0 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s			0	0	1 0.00
Coal pulverise+dry (gasif)	kg/s feed			0	0	1 0.00
Oxygen production	kg/s O2			0	0	1 0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV			0	0	1 0.00
Acid gas removal (scrubbing)	kmol/s feed gas			0	0	1 0.00
CFBC	MW fuel feed LHV			0	0	1 0.00
CO2 compressor (motor driven)	MWe			0	1	1 0.00
Gas turbine, complete	MWe	0		0	0	1 0.00
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred			0	1	1 0.00
Steam turbine+pipes+cooling system	MWe			519	1	1.1 150.29
PF coal boiler	MW fuel feed LHV			0	0	1 0.00
FGD (limestone gypsum)	kmol/s feed			0	0	1 0.00
Gasifier fuel gas cooler (fire tube)	MW transferred			0	0	1 0.00
Gasifier fuel gas cooler (water tube)	MW transferred			0	0	1 0.00
Candle filter (400C)	kmol/s feed			8	2	2 33.07
PFBC combustor	MW fuel feed			0	0	1 0.00
FBC	MW fuel feed LHV			0	2	0.477 0.00
CO2 regeneration	Kg/s CO2 captured			0	0	1 0.00
Gas absorption for CO2 capture	Kg/s total gas flow			0	0	1 0.00
Gas reforming	Kg/s potential CO2			0	0	1 0.00
Gas shift reaction	Kg/s CO2 in outlet			0	0	1 0.00
Other	User Defined			0	0	0.00
Other	User Defined			0	0	0.00
Other	User Defined			0	0	0.00
Other	User Defined			0	0	0.00
Other	User Defined			0	0	0.00
Other	User Defined			0	0	0.00
Electrical distribution	MWe gross			484	1	1 11.19
Sub-Total						194.55
Balance of plant	% of above			10		19.45
Engineering, indirects, owners cost	% of above			24		51.36
Project contingency	% of above			10		26.54
TOTAL						291.90

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ

Calculated Fuel Cost	3.0000	\$/GJ
Fuel cost of electricity	2.4379	c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>
Plant Life Span	<input type="text" value="25"/> years
Load Factor	<input type="text" value="0.9"/>

Interest during construction	44.2495	M\$
Annual capital Charge	37.0328	M\$/y
Capital Charges	0.9698	c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/> \$/tonne
Fixed O&M cost	0.3058	Residue Disposal Cost	<input type="text" value="20"/> \$/tonne
Variable O&M cost	0.0000		

Estimated Operating Costs	3.7135	c/kWh
----------------------------------	---------------	--------------

Multi-Criteria Analysis

This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.
To edit the percentages allocated to different attributes scroll down the page

Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score
Fuel Consumption kJ/kW	2.257	Low risk	37	42.9	APPLICABILITY	24.9
Raw Material Availability	Locally Common with some limits to availability for scale of this application	25	90	10		
Process Conditions Temperature Pressure NB Use least well known part of process	<1200K Atmospheric but no significant technical barriers	No risk 0	100	10	CONFIDENCE IN WHETHER IT WILL WORK	32.5
Novelty of Materials which is	Carbon Steel known material in known environment	No risk 0	100	10		
Plant Complexity No. of major units No. of major recycles	7 0		65	10		
<i>Raw score = 125</i> Novelty of Process with	<i>Caution - Very high risk of failure</i> Major modifications no industrial applications in operation	Unacceptable risk 100	60	10	ESTIMATED COSTS	107.9
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.000		40	40		
Costs Total Operating c/kWh	3.71		86	100		
Safety Risk Control of these risks	Major In Plant Risk NOT demonstrated, high degree of public concern existing or likely	Unacceptable risk 95	30	20	ACCEPTANCE	16.0
Environmental Impact Management of these impacts	Mildly harmful waste NOT demonstrated, high degree of public concern existing or likely	High risk 70	50	20		
Averaged risk level		48			TOTALS	181.3
Controlling risk level		100	Process novelty			

Results of Analysis

Summary

Process: **BaO/BaO2 (rerun)**

Heat Input 1094.3 MW

Estimated Net Electricity Output 484.0 MW
 Net Efficiency 44.3 %
 CO2 output/ kg/s 0.0 kg/s
 CO2 output/kWh 0.000 kg/kWh

NOTE GT efficiency calculated by program as ... 0.0 %
 NOTE Steam cycle efficiency calculated as... 46.3 %
 NOTE percentage of input energy to steam cycle .. 0.0 %

Estimated Capital Cost 291.9 M\$
 Estimated Op Cost 3.7 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance 16.0
 Applicability 24.9
 Confidence 32.5
 Estimated Cost 107.9
 Total 181.3
 Total cost only 268.7

Risk assessment

Averaged risk level 48
 Controlling risk level **Process novelty** 100



Comparison with Base Case CCGT

			This Case \$/kWh	Base Case \$/kWh	Difference \$/kWh	Base rates
CO2 emission penalty	50 \$/ton					
		Fuel cost	2.438	1.865	-0.5726	3.0000 \$/GJ
CO2 emissions	0.000 kg/kWh	CO2 charge	0.000	1.824	1.8236	50 \$/ton
		Base capex	1.276	0.989	-0.2862	
CO2 emission cost	0.000 c/kWh	Extra capex	0.210	0.094	-0.1165	
		Other opex	0.000	0	0.0000	
						Total 0.8483


Factor analysis

	Scores	Effect on costs of electricity
Raw materials	90	0.0128
Process conditions	100	0.0000
Novelty of materials	100	0.0000
Complexity	65	0.0446
Safety	30	0.0893
Environmental	50	0.0638
TOTAL		0.2105

	TOTAL	3.9240	4.7724	0.8483
Extra fuel				0.5726
Extra capex				0.4026
Total extra				0.9753
CO2 tax benefit				1.8236

Base Case data

Fuel cost	1.865 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.824 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	0.989 c/kWh		
Extra Capex	0.094 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.5E-05
Mix kgC/kJ	1.5E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.330 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3299 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title		BaO/BaO2 (rerun)
Power Out	MWe	484
Efficiency	%	44.3
CO2 emitted	%	0
CO2 emitted	kg/kWh	0
Fuel in	kg/s	21.88
Fuel in	MW	1094.284
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	60.17
Gas Cycle Efficiency	%	0.00
Steam Cycle Efficiency	%	0.46
Est Capital Cost	M\$	291.90
Est Operating Cost	ct/kWh	3.71
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	1
	Cost	0.00
Gas turbine, complete	MWe	0
	Number	0
	Cost	0.00
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	1
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	570.9

	Number	1
	Cost	150.29
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	16
	Number	2
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	2
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	484
	Number	1

	Cost	11.19
Multi Criteria		
Feed Material		2
Feed Material Qualifier		2
Temp max		1
Press max		1
Process Conditions Qualifer		1
Construction Materials		1
Construction Materials Qualifier		1
No of Recycles		0
Novelty		3
Novelty Qualifer 1		5
Novelty Qualifer 2		1
Safety Risk		4
Safety Risk Qualifer		3
Environmental Impact		3
Environmental Impact Qualifier		3
Average Risk Level		48
Controlling Risk Level		100
Controlling Risk is		Process novelty
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		100
Process Conditions Extra Cost	ct/kWh	0
Novelty		100
Novelty Extra Cost	ct/kWh	0
Complexity		65
Complexity Extra Cost	ct/kWh	0
Safety		30
Safety Extra Cost	ct/kWh	0
Environmental		50
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	2.437923
CO2 Charge	\$/ct/kWh	0
Base Capex	\$/ct/kWh	1.275608
Extra Capex	\$/ct/kWh	0.210475
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	3.924007
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		50013
Mixture LCV		50013
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	19
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	0
ST power	MW	519
Percent of heat available to Steam	MW	0
Overall electrical efficiency after lo	MW	44.3
Efficiency GT Cycle	MW	0
Efficiency ST cycle	MW	46.3
Overall power output	MW	484
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for gas fired CO₂ capturing power plant utilizing
chemical looping process with recirculating copper oxide**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

		Number of Units	Nominal Size	Units
<input type="checkbox"/>	Gas Turbine	0	0.0	MWe
<input checked="" type="checkbox"/>	Steam Turbine	1	561.0	MWe
<input checked="" type="checkbox"/>	Combustor	2	11.1	kg/s fuel
<input type="checkbox"/>	Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/>	Air Separation Unit	0	0	kg/s O2
	O2 compression Press.		1.22	bar
<input type="checkbox"/>	HRSG	0	0.0	MW
<input type="checkbox"/>	FGD	0		
<input type="checkbox"/>	H2S Removal	0	0	ton/day
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	Other major plant item	1	0	
	Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/>	CO2 Separation	0	0	
	Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/>	CO2 Compression	1		
	To Pressure		110	bar
<input type="checkbox"/>	Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Combustor Type

PF

FBC

CFBC

PFBC

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		0	0	1
LCV	kJ/kg	25000	42000	50046
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		0.00%	0.00%	100.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		50046	kJ/kg	
Combined Carbon fraction		0.75		
Combined Ash Fraction		0		

ASSUMPTIONS - Process**Gas Cycle**

Actual Fuel flow rate to Gas Turbine	1 kg/s		
	56.8635	====> Air flow of	56.86 kg/s
Air Bleed for Blade Cooling	6.27%	====> Cooling flow of	3.57 kg/s
HRSG heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%
Misc & Unaccounted Losses	0% % off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	36.5 MW	Added into cell J44	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J45	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	0 MW	Transferred to D65	Sheet CycleAnalysis
ST power	561 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	0 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	45.73 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	0 %	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	0 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	506 MW	Transferred to G61	Sheet CycleAnalysis
Power from direct generation	0.00 MW		
Other power from GT/ST waste heat	0 MW		
Energy content of fuel	1106.52 MW		

Losses

GT mech loss	0.00 MW
GT gen loss	0.00 MW
ST mech loss	2.81 MW
ST mech loss	8.42 MW
GT + ST transformer loss	2.24 MW
Transformer loss direct power generated	0.00 MW
Subtotal	13.46 MW

Auxiliaries

Solids handling:

		NB external entries of <>0 override PPAP calculated values		
		PPAP	External	hidden calc
Fuel	0 MW	0	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	0.00 MW	0.00	0	
FGD	0.00 MW	0.00	0	
Cooling water system	3.94 MW	3.94	0	561.00 MW ST rejection
Misc	1.52 MW	1.52	0	2.56 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	0 MW	0	0	
Other	0 MW	0	0	
Subtotal	5.46 MW			
TOTAL Losses/Auxiliaries	18.93 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle		% of heat		
	Value imported	I/P to GT	kJ/kg	MW
To steam	0 kJ/s from HRSG before losses	0.00	0.0	0.000
GT loss	0 kJ/s from Stack	0.00	0.0	0.000
GT Efficiency		0.00		
Total		0.00		
Gas cycle Output				
Estimated GT Efficiency	0 Value imported			
Gross avail. energy to GT cycle	1E-07 kJ/kg			
GT Output	0 kJ/kg	equiv to	0 kW	
Steam Cycle Output				
Estimated Steam Cycle Efficiency	0 Value imported			
Heat Balance				
From Combustion	50046 kJ/kg			HRSG Heat available 0 kJ/kg
From Gasification	0 kJ/kg			HRSG heat loss 1.0%
From GT HRSG etc after losses	0 kJ/kg			HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0 kJ/kg			
Export/Import	0 kJ/kg			
Heat available to steam cycle	50046 kJ/kg	equiv to	1106517 kW	
ST Output	-85.53907 kJ/kg	equiv to	-1891.269 kW	
Total Potential Output	-85.53907 kJ/kg	equiv to	-1891.269 kW	
Process Losses		Total	GT	ST
Turbine Mech Loss	0.50%	-9.5	0.0	-9.5
Generator Loss	1.50%	-28.4	0.0	-28.4
Transformer Loss	0.40%	-7.6	0.0	-7.6
Gross Power Output	-83.48613 kJ/kg	equiv to	-1845.878 kW	

Cu-CuO1


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg	0	0	
	Sorbent	50 kJ/kg	0	0	
	Ash	50 kJ/kg	0	0	
Fan and compressor mech eff.		93%			
Oxygen Production		950 kJ/kg O2	0	0	
Oxygen Compression			Value imported	1650.837	0.7 Is good nun
CO2 Compression			1	0	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel	0	0	
FGD		8 kJ/MJ fuel	0	0	
Cooling water system		7 kJ/MJ rejected	1	352.1553	Steam Cycle Condense
Misc		0.30% of gross		-0.250458	
H2S Sepn				0	
CO2 Sepn				0	
Other				0	
Total Auxiliaries				2002.742 kJ/kg	

Total Input	50046 kJ/kg				
Total Output (Net)	-2086.228 kJ/kg	=>	506000 kW	Value imported	
Efficiency	45.73 %	Value imported			-55
GT Output (Generator Terminals)	0.00 MW	Value imported			0
ST Output (Generator Terminals)	561.00 MW	Value imported			-55
Direct O/P (Gross)	0 MW				
% heat available to steam cycle	0 %	Value imported			

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$	
Solids handling	kg/s			0	0	1	0.00
Coal pulverise+dry (gasif)	kg/s feed			0	0	1	0.00
Oxygen production	kg/s O2			0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV			0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas			0	0	1	0.00
CFBC	MW fuel feed LHV			0	0	1	0.00
CO2 compressor (motor driven)	MWe			0	1	1	0.00
Gas turbine, complete	MWe	0		0	0	1	0.00
Gas turbine, compressor only	MW consumed						
Gas turbine, turbine only	MW						
Gas turbine, generator only	MWe						
HRSG	MWth transferred			0	0	1	0.00
Steam turbine+pipes+cooling system	MWe			561	1	1.1	159.33
PF coal boiler	MW fuel feed LHV			0	0	1	0.00
FGD (limestone gypsum)	kmol/s feed			0	0	1	0.00
Gasifier fuel gas cooler (fire tube)	MW transferred			0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred			0	0	1	0.00
Candle filter (400C)	kmol/s feed			8	2	2	33.07
PFBC combustor	MW fuel feed			0	0	1	0.00
FBC	MW fuel feed LHV			0	2	0.477	0.00
CO2 regeneration	Kg/s CO2 captured			0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow			0	0	1	0.00
Gas reforming	Kg/s potential CO2			0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet			0	0	1	0.00
CO2 compressor (motor driven)	User Defined			23	1		20.00
Other	User Defined			0	0		0.00
Other	User Defined			0	0		0.00
Other	User Defined			0	0		0.00
Other	User Defined			0	0		0.00
Other	User Defined			0	0		0.00
Electrical distribution	MWe gross			506	1	1	11.59
Sub-Total							223.98
Balance of plant	% of above			10			22.40
Engineering, indirects, owners cost	% of above			24			59.13
Project contingency	% of above			10			30.55
TOTAL							336.07

Operating Costs

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ
Calculated Fuel Cost		3.0000	\$/GJ
Fuel cost of electricity		2.3617	c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>	
Plant Life Span	<input type="text" value="25"/>	years
Load Factor	<input type="text" value="0.9"/>	
Interest during construction		50.9451 M\$
Annual capital Charge		42.6363 M\$/y
Capital Charges		1.0680 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/>	\$/tonne
Fixed O&M cost		Residue Disposal Cost	<input type="text" value="20"/>	\$/tonne
Variable O&M cost				

Estimated Operating Costs **3.7665 c/kWh**

Multi-Criteria Analysis

This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.
 To edit the percentages allocated to different attributes scroll down the page

Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score
Fuel Consumption kJ/kW	2.187	Low risk	41	42.9	APPLICABILITY	26.4
Raw Material Availability	Locally Common with some limits to availability for scale of this application	25	90	10		
Process Conditions Temperature Pressure NB Use least well known part of process	<1200K <10bar but no significant technical barriers	No risk	3	95	CONFIDENCE IN WHETHER IT WILL WORK	32.5
Novelty of Materials which is	Carbon Steel known material in known environment	No risk	0	100		
Plant Complexity No. of major units No. of major recycles	6 0		70	10		
<i>Raw score = 125</i> Novelty of Process with	Caution - Very high risk of failure Major modifications no industrial applications in operation	Unacceptable risk		60	ESTIMATED COSTS	106.7
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.000		40	40		
Costs Total Operating c/kWh	3.77		85	100		
Safety Risk Control of these risks	Risk demonstrated but concerns emerging in public domain	Medium risk	40	60	ACCEPTANCE	22.0
Environmental Impact Management of these impacts	Mildly harmful waste NOT demonstrated, high degree of public concern existing or likely	High risk	70	50		
TOTALS						187.6
Averaged risk level		40				
Controlling risk level		100	Process novelty			

Results of Analysis

Summary

Process: **Cu - CuO scheme preliminary based on Hysys fs 2A**

Heat Input 1106.5 MW

Estimated Net Electricity Output	506.0 MW	NOTE GT efficiency calculated by program as ...	0.0 %
Net Efficiency	45.7 %	NOTE Steam cycle efficiency calculated as...	0.0 %
CO2 output/ kg/s	0.0 kg/s	NOTE percentage of input energy to steam cycle ..	0.0 %
CO2 output/kWh	0.000 kg/kWh		

Estimated Capital Cost 336.1 M\$
 Estimated Op Cost 3.8 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance	22.0
Applicability	26.4
Confidence	32.5
Estimated Cost	106.7
Total	187.6
Total cost only	267.5

Risk assessment

Averaged risk level	40
Controlling risk level	Process novelty 100




Comparison with Base Case CCGT

			This Case \$/ct/kWh	Base Case \$/ct/kWh	Difference \$/ct/kWh	Base rates
CO2 emission penalty	50	\$/ton				
CO2 emissions	0.000	kg/kWh				3.0000 \$/GJ 50 \$/ton
CO2 emission cost	0.000	c/kWh				
Factor analysis		Effect on costs of electricity				
	Scores					
Raw materials	90	0.0140				
Process conditions	95	0.0070				
Novelty of materials	100	0.0000				
Complexity	70	0.0421				
Safety	60	0.0562				
Environmental	50	0.0702				
TOTAL		0.1896				
			TOTAL	3.9561	6.5301	2.5740
			Extra fuel			0.2651
			Extra capex			-0.9181
			Total extra			-0.6530
			CO2 tax benefit			1.9210
						Total 2.5740

Base Case data

Fuel cost	2.0966	c/kWh	Based on	3	\$/GJ
CO2 Tax	1.921	c/kWh	Based on	50	\$/tonne
Base Capex+Opex	2.5125	c/kWh			
Extra Capex	0	c/kWh			
Other Opex	0	c/kWh			



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.499E-05
Mix kgC/kJ	1.499E-05
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.330 kg/kWh
Calorific fraction of gas	1
Calorific fraction of oil	0
CO2 allowance	0.3297 kg/kWh

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title

Cu - CuO scheme preliminary based on Hysys fs 2A

Power Out	MWe	506
Efficiency	%	45.73
CO2 emitted	%	0
CO2 emitted	kg/kWh	0
Fuel in	kg/s	22.11
Fuel in	MW	1106.517
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	60.80
Gas Cycle Efficiency	%	0.00
Steam Cycle Efficiency	%	0.00
Est Capital Cost	M\$	336.07
Est Operating Cost	ct/kWh	3.77
Capital Cost Items		
Solids handling	'Size'	0
	Number	0
	Cost	0.00
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt)	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	1
	Cost	0.00
Gas turbine, complete	MWe	0
	Number	0
	Cost	0.00
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	0
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	617.1

Cu-CuO1

	Number	1
	Cost	159.33
PF coal boiler	MW fuel feed LHV	0
	Number	0
	Cost	
FGD (limestone gypsum)	kmol/s feed	0
	Number	0
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	16
	Number	2
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	2
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	1
	Cost	20.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	506
	Number	1

Cu-CuO1

	Cost	11.59
Multi Criteria		
Feed Material		2
Feed Material Qualifier		2
Temp max		1
Press max		2
Process Conditions Qualifer		1
Construction Materials		1
Construction Materials Qualifier		1
No of Recycles		0
Novelty		3
Novelty Qualifer 1		5
Novelty Qualifer 2		1
Safety Risk		3
Safety Risk Qualifer		2
Environmental Impact		3
Environmental Impact Qualifier		3
Average Risk Level		40
Controlling Risk Level		100
Controlling Risk is		Process novelty
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		95
Process Conditions Extra Cost	ct/kWh	0
Novelty		100
Novelty Extra Cost	ct/kWh	0
Complexity		70
Complexity Extra Cost	ct/kWh	0
Safety		60
Safety Extra Cost	ct/kWh	0
Environmental		50
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	2.361688
CO2 Charge	\$/ct/kWh	0
Base Capex	\$/ct/kWh	1.404772
Extra Capex	\$/ct/kWh	0.189644
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	3.956104
Fuel Mix		
Solid	frac	0
Liquid	frac	0
Gas	frac	1
Solid LCV		25000
Liquid LCV		42000
Gas LCV		50046
Mixture LCV		50046
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Cu-CuO1

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	36.5
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	0
ST power	MW	561
Percent of heat available to Steam	MW	0
Overall electrical efficiency after lo	MW	45.73
Efficiency GT Cycle	MW	0
Efficiency ST cycle	MW	0
Overall power output	MW	506
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		0
Other		0

Power Plant Assessment program

**Worksheets for coal fired power plant with CO₂ capture using
cryogenic flue gas CO₂ capture process as proposed by Israeli-
Russian Research Institute**

Plant Components

Choose the major plant components which are the closest match to the design you are assessing:

	Number of Units	Nominal Size	Units
<input type="checkbox"/> Gas Turbine	0	0.0	MWe
<input checked="" type="checkbox"/> Steam Turbine	1	812.4	MWe
<input checked="" type="checkbox"/> Combustor	1	79.3	kg/s fuel
<input type="checkbox"/> Gasifier	0	0.0	kg/s fuel
<input type="checkbox"/> Air Separation Unit	0	0	kg/s O2
O2 compression Press.		1.22	bar
<input type="checkbox"/> HRSG	0	0.0	MW
<input checked="" type="checkbox"/> FGD	1		
<input type="checkbox"/> H2S Removal	0	0	ton/day
Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/> Other major plant item	1	0	
Aux Power Req'd		0	kJ/Unit size
<input checked="" type="checkbox"/> CO2 Separation	1	0	
Aux Power Req'd		0	kJ/Unit size
<input type="checkbox"/> CO2 Compression	0		
To Pressure		110	bar
<input type="checkbox"/> Fuel Cell (or Direct Generator)	0		

Fuel Type

Solid

Liquid

Gaseous

Combustor Type

PF

FBC

CFBC

PFBC

Steam Cycle Type

Sub Critical

SuperCritical

Fuel Specifications

User to enter fuel specification figures in **blue**

		Solid	Liquid	Gas
Fuel Mass Fractions		1	0	0
LCV	kJ/kg	25000	42000	50013
Carbon fraction	%mass	0.62	0.86	0.75
Ash Fraction	%mass	0.12	0	0
% in Feed		100.00%	0.00%	0.00%
Fuel Fractions Sum (must = 1)	1			
Combined LCV		25000	kJ/kg	
Combined Carbon fraction		0.62		
Combined Ash Fraction		0.12		

Mass & Energy Balance

This datasheet requires some details on the feed and outlet streams of the process:
Please enter data for figures shown in **blue**

Basis :	Flow kg/s	LCV kJ/kg	kg Carbon /kg	Carbon Balance kg/s
Fuel	79.293	25000	0.62	49.16166
Other Materials	0	0	0	0
Residue	0	0	0	0
% CO2 recovered =	70.0%			
CO2 recovered	126.18	0	0.273	34.41316
CO2 emitted	54.08	0	0.273	14.7485
Gross available energy		25000 kJ/kg fuel 1982325 kJ Total		
Fuel/Energy Distribution				
Percent of Input Fuel				
direct to combustion or steam cycle	100%	25000		
Percent of Input Fuel				
to gasification system	0%	0		
Heat recovered from gasifier to steam cycle	0%	0		
Heat recovered from gasifier to gas cycle	0%	0		
Percent of Input Fuel				
direct to Fuel Cell/MHD etc	0%	0		
Percent of fuel to direct generati				
Converted to power	0%	0		
Heat recovered from direct generation to steam cycle	0%	0		
Heat recovered from direct generationto gas cycle	0%	0		
Heat from Steam cycle				
lost to Process or ?	0	kW		

ASSUMPTIONS - Process

Gas Cycle

Actual Fuel flow rate to Gas Turbine	1 kg/s		
	56.8635	====> Air flow of	56.86 kg/s
Air Bleed for Blade Cooling	6.27%	====> Cooling flow of	3.57 kg/s
HRSO heat loss	1.0%		

Steam Cycle

BFW Efficiency	70%	
Misc & Unaccounted Losses	0%	% off efficiency

Misc

Turbine Mechanical Loss	0.50%
Generator Loss	1.50%
Transformer Loss	0.40%
Fan and compressor mech eff.	93.00%
Misc power consumption	0.30% of gross

Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg
	Sorbent	50 kJ/kg
	Ash	50 kJ/kg
Oxygen Production	950 kJ/kg O2	
Combustor fans (PF)	8 kJ/MJ fuel	
FGD	8 kJ/MJ fuel	
Cooling water system	7 kJ/MJ rejected	

PPAP Lite

Use for direct data entry from other heat and mass balance packages

Override internal calculations

Tick box to activate input of values on this sheet.

(ie Use PPAP Lite)

CO2 compression power	25 MW	Added into cell J45	Sheet CycleAnalysis
O2 compression power	0 MW	Added into cell J44	Sheet CycleAnalysis
HRSG on GT	0 MW	Transferred to B7	Sheet CycleAnalysis
GT power	0 MW	Transferred to D65	Sheet CycleAnalysis
ST power	812.4 MW	Transferred to D66	Sheet CycleAnalysis
Percent of heat available to Steam cycle	100 %	Transferred to D69	Sheet CycleAnalysis
Overall electrical efficiency after losses	25.22 %	Transferred to D62	Sheet CycleAnalysis
Efficiency GT Cycle	%	Transferred to D13	Sheet CycleAnalysis
Efficiency ST cycle	40 %	Transferred to D18	Sheet CycleAnalysis
Overall power output	500 MW	Transferred to G61	Sheet CycleAnalysis

Power from direct generation	0.00 MW
Other power from GT/ST waste heat	0 MW
Energy content of fuel	1982.33 MW

Losses

GT mech loss	0.00 MW
GT gen loss	0.00 MW
ST mech loss	4.06 MW
ST mech loss	12.19 MW
GT + ST transformer loss	3.25 MW
Transformer loss direct power generated	0.00 MW
Subtotal	19.50 MW

Auxiliaries

NB external entries of <>0 override PPAP calculated values

Solids handling:		PPAP	External	hidden calc
Fuel	3.96465 MW	3.96465	0	
Sorbant	0 MW	0.00	0	
Residue	0 MW	0.00	0	
Oxygen Production	0 MW	0	0	
Combustor fans (PF)	15.86 MW	15.86	0	
FGD	15.86 MW	15.86	0	
Cooling water system	3.42 MW	3.42	0	487.44 MW ST rejection
Misc	1.50 MW	1.50	0	1.75 MW compression losses
H2S Sepn	0 MW	0	0	
CO2 Sepn	227 MW	0	227	
Other	0 MW	0	0	
Subtotal	267.61 MW			
TOTAL Losses/Auxiliaries	287.10 MW			

Cycle Analysis

PPAP Lite mode - Values highlighted in yellow have been imported, see PPAPLITE Sheet

The per kg figures below refer to the TOTAL fuel feed to the system (not just to the GT)

Heat Recovery/Losses in GT Cycle

			% of heat		
	Value imported		I/P to GT	kJ/kg	MW
To steam	0	kJ/s from HRSG before losses	0.00	0.0	0.000
GT loss	0	kJ/s from Stack	0.00	0.0	0.000
GT Efficiency			0.00		
Total			<u>0.00</u>		

Gas cycle Output

Estimated GT Efficiency	0	Value imported		
Gross avail. energy to GT cycle	1E-07	kJ/kg		
GT Output	0	kJ/kg	equiv to	0 kW

Steam Cycle Output

Estimated Steam Cycle Efficiency	0.4	Value imported		
Heat Balance				
From Combustion	25000	kJ/kg		HRSG Heat available 0 kJ/kg
From Gasification	0	kJ/kg		HRSG heat loss 1.0%
From GT HRSG etc after losses	0	kJ/kg		HRSG to Steam Cycle 0 kJ/kg
From Direct Generation	0	kJ/kg		
Export/Import	0	kJ/kg		
Heat available to steam cycle	25000	kJ/kg	equiv to	1982325 kW
ST Output	9957.27	kJ/kg	equiv to	789541.8 kW

Total Potential Output 9957.27 kJ/kg equiv to 789541.8 kW

Process Losses		Total	GT	ST
Turbine Mech Loss	0.50%	3947.7	0.0	3947.7
Generator Loss	1.50%	11843.1	0.0	11843.1
Transformer Loss	0.40%	3158.2	0.0	3158.2

Gross Power Output 9718.295 kJ/kg equiv to 770592.8 kW


Auxiliary Power Requirements

Solids handling	Fuel	50 kJ/kg		1	50	
	Sorbent	50 kJ/kg		1	0	
	Ash	50 kJ/kg		1	0	
Fan and compressor mech eff.		93%				
Oxygen Production		950 kJ/kg O2		0	0	
Oxygen Compression			Value imported		0	0.7 Is good nur
CO2 Compression				0	315.2863	Value imported O2 & CO2
Combustor fans (PF)		8 kJ/MJ fuel		1	200	
FGD		8 kJ/MJ fuel		1	200	
Cooling water system		7 kJ/MJ rejected		1	105	Steam Cycle Condensate
Misc		0.30% of gross			29.15489	
H2S Sepn					0	
CO2 Sepn					0	
Other					0	
Total Auxiliaries					899.4412 kJ/kg	

Total Input	25000 kJ/kg					
Total Output (Net)	8818.854 kJ/kg	=>	500000 kW	Value imported		
Efficiency	25.22 %	Value imported				-312.4
GT Output (Generator Terminals)	0.00 MW	Value imported				0
ST Output (Generator Terminals)	812.40 MW	Value imported				-312.4
Direct O/P (Gross)	0 MW					
% heat available to steam cycle	100 %	Value imported				

SIMPLIFIED ENERGY FLOW DIAGRAM

ENERGY FLOWS IN MW



Energy Flow Diagram

Process Cost Estimation

Description	Scaling parameter	User specified size	Size per unit	No of units	Cost multiplier	Predicted cost, M\$
Solids handling	kg/s		79.293	1	1	17.26
Coal pulverise+dry (gasif)	kg/s feed		0	0	1	0.00
Oxygen production	kg/s O2		0	0	1	0.00
Gasifier (Shell, inc hopper, cool/filt/scrub)	MW fuel feed LHV		0	0	1	0.00
Acid gas removal (scrubbing)	kmol/s feed gas		0	0	1	0.00
CFBC	MW fuel feed LHV		0	0	1	0.00
CO2 compressor (motor driven)	MWe		0	0	1	0.00
Gas turbine, complete	MWe	0	0	0	1	0.00
Gas turbine, compressor only	MW consumed					
Gas turbine, turbine only	MW					
Gas turbine, generator only	MWe					
HRSG	MWth transferred		0	0	1	0.00
Steam turbine+pipes+cooling system	MWe		812.4	1	1	191.21
PF coal boiler	MW fuel feed LHV		1982.325	1	1	256.51
FGD (limestone gypsum)	kmol/s feed		19.50079	1	1	68.99
Gasifier fuel gas cooler (fire tube)	MW transferred		0	0	1	0.00
Gasifier fuel gas cooler (water tube)	MW transferred		0	0	1	0.00
Candle filter (400C)	kmol/s feed		0	0	1	0.00
PFBC combustor	MW fuel feed		0	0	1	0.00
FBC	MW fuel feed LHV		0	0	1	0.00
CO2 regeneration	Kg/s CO2 captured		0	0	1	0.00
Gas absorption for CO2 capture	Kg/s total gas flow		0	0	1	0.00
Gas reforming	Kg/s potential CO2		0	0	1	0.00
Gas shift reaction	Kg/s CO2 in outlet		0	0	1	0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Other	User Defined		0	0		0.00
Equipment estimate	Equipment estimate		0	0		379.06
Electrical distribution	MWe gross		500	1	1	11.48
Sub-Total						924.52
Balance of plant	% of above		10			92.45
Engineering, indirects, owners cost	% of above		24			244.07
Project contingency	% of above		10			126.10
TOTAL						1387.14

Operating Cost Specification

Fuel Cost	Solid	<input type="text" value="1.5"/>	\$/GJ
	Liquid	<input type="text" value="3"/>	\$/GJ
	Gaseous	<input type="text" value="3"/>	\$/GJ
Calculated Fuel Cost		1.5000	\$/GJ
Fuel cost of electricity		2.1412	c/kWh

Capital Charges

Interest Rate	<input type="text" value="10%"/>	
Plant Life Span	<input type="text" value="25"/>	years
Load Factor	<input type="text" value="0.85"/>	
Interest during construction		210.2799 M\$
Annual capital Charge		175.9850 M\$/y
Capital Charges		4.7237 c/kWh

O&M Costs

O&M Factor	<input type="text" value="0.04"/>	Other Materials Cost	<input type="text" value="20"/>	\$/tonne
Fixed O&M cost		Residue Disposal Cost	<input type="text" value="20"/>	\$/tonne
Variable O&M cost				

Fixed O&M cost	1.4893	c/kWh
Variable O&M cost	0.0000	c/kWh

Estimated Operating Costs **8.3542 c/kWh**

Multi-Criteria Analysis							
<p>This page of the assessment procedure bring together data from the first two steps and allows the user to applied 'weightings' to the results to provide a ranking for the proposed power plant indicating its overall suitability as a 'green' power generation process.</p> <p>To edit the percentages allocated to different attributes scroll down the page</p>							
Multi-Criteria Analysis	Value	Risk assessment & Score%	Score %	Weighting	DECISION FACTOR	Weighted Score	
Fuel Consumption kJ/kW	3.965	No risk	-48	42.9	APPLICABILITY	-11.7	
Raw Material Availability	Locally Common with unlimited availability for scale of this application	0	90	10			
Process Conditions Temperature Pressure NB Use least well known part of process	<1200K 10-60 bar but no significant technical barriers	No risk	6	90	CONFIDENCE IN WHETHER IT WILL WORK	32.5	
Novelty of Materials which is	Stainless Steel known material but in new environment	No risk	10	95			10
Plant Complexity No. of major units No. of major recycles	4 0		80	10			
Novelty of Process with	Major modifications promising credited scientific proof of concept	High risk	63	60	10	ESTIMATED COSTS	
Greenhouse Gas Emissions CO2 emission in kg/Kwh	0.389		28	40	10.1		
Costs Total Operating c/kWh	8.35		-7	100			
Safety Risk Control of these risks	Small Risk extensively demonstrated and publicly accepted	No risk	5	80	20	ACCEPTANCE	26.0
Environmental Impact Management of these impacts	Mildly harmful waste extensively demonstrated and publicly accepted	No risk	10	50	20		
TOTALS						56.9	
		Averaged risk level	16				
		Controlling risk level	63	Process novelty			

Results of Analysis

Summary

Process: **Russian Israeli research centre cryogenic process**

Heat Input 1982.3 MW

Estimated Net Electricity Output	500.0 MW	NOTE GT efficiency calculated by program as ...	0.0 %
Net Efficiency	25.2 %	NOTE Steam cycle efficiency calculated as...	40.0 %
CO2 output/ kg/s	54.1 kg/s	NOTE percentage of input energy to steam cycle ..	100.0 %
CO2 output/kWh	0.389 kg/kWh		

Estimated Capital Cost 1387.1 M\$
 Estimated Op Cost 8.4 c/kWh


Multi-Criteria Assessment

Decision Factor Scores

Acceptance	26.0
Applicability	-11.7
Confidence	32.5
Estimated Cost	10.1
	Total
	56.9
	Total cost only
	175.9

Risk assessment

Averaged risk level	16
Controlling risk level	Process novelty 63




Comparison with Base Case CCGT

			This Case \$/kWh	Base Case \$/kWh	Difference \$/kWh	Base rates
CO2 emission penalty	50 \$/ton					
CO2 emissions	0.389 kg/kWh					1.5000 \$/GJ 50 \$/ton
CO2 emission cost	1.947 c/kWh					
		Fuel cost	2.141	1.048	-1.0929	
		CO2 charge	1.947	1.921	-0.0258	
		Base capex	6.213	2.5125	-3.7006	
		Extra capex	0.715	0	-0.7145	
		Other opex	0.000	0	0.0000	
		TOTAL	11.0155	5.4818	-5.5337	Total -5.5337
Factor analysis		Effect on costs of electricity				
	Scores					
Raw materials	90	0.0621			1.0929	
Process conditions	90	0.0621			4.4151	
Novelty of materials	95	0.0311			5.5079	
Complexity	80	0.1243			-0.0258	
Safety	80	0.1243				
Environmental	50	0.3107				
TOTAL		0.7145				

Base Case data

Fuel cost	2.0966 c/kWh	Based on	3 \$/GJ
CO2 Tax	1.921 c/kWh	Based on	50 \$/tonne
Base Capex+Opex	2.5125 c/kWh		
Extra Capex	0 c/kWh		
Other Opex	0 c/kWh		



WEIGHTINGS ANALYSIS

CO2 emission calc	
Coal kgC/kJ	0.0000248
Oil kgC/kJ	2.048E-05
Gas kgC/kJ	1.5E-05
Mix kgC/kJ	0.0000248
Standard coal efficiency	0.53
Standard oil efficiency	0.6
Standard gas efficiency	0.6
Standard coal emission	0.618 kg/kWh
Standard oil emission	0.450 kg/kWh
Standard gas emission	0.330 kg/kWh
Calorific fraction of gas	0
Calorific fraction of oil	0
CO2 allowance	0.6177 kg/kWh

Israeli-Russian cryo

Data for comparison with other processes (Used in IEA_PPC.xlt)

DO NOT EDIT

Project Title Russian Israeli research centre cryogenic process

Power Out	MWe	500
Efficiency	%	25.22
CO2 emitted	%	30
CO2 emitted	kg/kWh	0.38936
Fuel in	kg/s	79.293
Fuel in	MW	1982.325
Other in	kg/s	0
Ash (residue) Out	kg/s	0
CO2 to 'storage'	kg/s	126.18
Gas Cycle Efficiency	%	0.00
Steam Cycle Efficiency	%	0.40
Est Capital Cost	M\$	1387.14
Est Operating Cost	ct/kWh	8.35
Capital Cost Items		
Solids handling	'Size'	79.293
	Number	1
	Cost	17.26
Coal pulverise+dry (gasif)	kg/s feed	0
	Number	0
	Cost	0.00
Oxygen production	kg/s O2	0
	Number	0
	Cost	0.00
Gasifier (Shell, inc hopper, cool/filt	MW fuel feed LHV	0
	Number	0
	Cost	0.00
Acid gas removal (scrubbing)	kmol/s feed gas	0
	Number	0
	Cost	0.00
CFBC combustor /stack	MW fuel feed	0
	Number	0
	Cost	0.00
CO2 compressor (motor driven)	MWe	0
	Number	0
	Cost	0.00
Gas turbine, complete	MWe	0
	Number	0
	Cost	0.00
Gas turbine, compressor only	MW consumed	0
	Number	0
	Cost	0
Gas turbine, turbine only	MW	0
	Number	0
	Cost	0
Gas turbine, generator only	MWe	0
	Number	0
	Cost	0
HRSG	MWth transferred	0
	Number	0
	Cost	0.00
Steam turbine+pipes+cooling syst	MWe	812.4

Israeli-Russian cryo

	Number	1
	Cost	191.21
PF coal boiler	MW fuel feed LHV	1982.325
	Number	1
	Cost	
FGD (limestone gypsum)	kmol/s feed	19.50079
	Number	1
	Cost	
Gasifier fuel gas cooler (fire tube)	MW transferred	0
	Number	0
	Cost	
Gasifier fuel gas cooler (water tube)	MW transferred	0
	Number	0
	Cost	
Candle filter (400C)	kmol/s feed	0
	Number	0
	Cost	
PFBC combustor	MW fuel feed	0
	Number	0
	Cost	
FBC	MW fuel feed LHV	0
	Number	0
	Cost	0.00
CO2 regeneration	Kg/s CO2 captured	0
	Number	0
	Cost	0.00
Gas absorption for CO2 capture	Kg/s total gas flow	0
	Number	0
	Cost	0.00
Gas reforming	Kg/s potential CO2	0
	Number	0
	Cost	0.00
Gas shift reaction	Kg/s CO2 in outlet	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Other	User Defined	0
	Number	0
	Cost	0.00
Electrical distribution	MWe gross	500
	Number	1

Israeli-Russian cryo

	Cost	11.48
Multi Criteria		
Feed Material		2
Feed Material Qualifier		1
Temp max		1
Press max		3
Process Conditions Qualifer		1
Construction Materials		2
Construction Materials Qualifier		2
No of Recycles		0
Novelty		3
Novelty Qualifer 1		2
Novelty Qualifer 2		7
Safety Risk		2
Safety Risk Qualifer		1
Environmental Impact		3
Environmental Impact Qualifier		1
Average Risk Level		16
Controlling Risk Level		63
Controlling Risk is		Process novelty
Comparison		
CO2 Penalty	\$/tonne	
CO2 Emissions	kg/kWh	
CO2 Emissions Cost	ct/kWh	
Factors		
Raw Mats		90
Raw Mats Extra Cost	ct/kWh	0
Process Conditions		90
Process Conditions Extra Cost	ct/kWh	0
Novelty		95
Novelty Extra Cost	ct/kWh	0
Complexity		80
Complexity Extra Cost	ct/kWh	0
Safety		80
Safety Extra Cost	ct/kWh	0
Environmental		50
Environmental Extra Cost	ct/kWh	0
Fuel Cost	\$/ct/kWh	2.141158
CO2 Charge	\$/ct/kWh	1.946802
Base Capex	\$/ct/kWh	6.213061
Extra Capex	\$/ct/kWh	0.714502
Other Opex	\$/ct/kWh	0
Total	\$/ct/kWh	11.01552
Fuel Mix		
Solid	frac	1
Liquid	frac	0
Gas	frac	0
Solid LCV		25000
Liquid LCV		42000
Gas LCV		50013
Mixture LCV		25000
Fuel Costs		
Gas		3
Liquid		3
Solid		1.5

Israeli-Russian cryo

Other Input		20
Residue		20
PPAPLite Data		
Use PPAPLite		TRUE
CO2 compression power	MW	25
O2 compression power	MW	0
HRSG on GT	MW	0
GT power	MW	0
ST power	MW	812.4
Percent of heat available to Steam	MW	100
Overall electrical efficiency after lo	MW	25.22
Efficiency GT Cycle	MW	0
Efficiency ST cycle	MW	40
Overall power output	MW	500
Other power from GT/ST waste he	MW	0
Solids handling:		
Fuel		0
Sorbant		0
Residue		0
Oxygen Production		0
Combustor fans (PF)		0
FGD		0
Cooling water system		0
Misc		0
H2S Sepn		0
CO2 Sepn		227
Other		0