



# **CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

***Technical Study***

***Report Number: 2006/1***

***Date: January 2006***

*This document has been prepared for the Executive Committee of the IEA GHG Programme.  
It is not a publication of the Operating Agent, International Energy Agency or its Secretariat.*

## **INTERNATIONAL ENERGY AGENCY**

The International Energy Agency (IEA) was established in 1974 within the framework of the Organisation for Economic Co-operation and Development (OECD) to implement an international energy programme. The IEA fosters co-operation amongst its 26 member countries and the European Commission, and with the other countries, in order to increase energy security by improved efficiency of energy use, development of alternative energy sources and research, development and demonstration on matters of energy supply and use. This is achieved through a series of collaborative activities, organised under more than 40 Implementing Agreements. These agreements cover more than 200 individual items of research, development and demonstration. The IEA Greenhouse Gas R&D Programme is one of these Implementing Agreements.

## **DISCLAIMER**

This report was prepared as an account of work sponsored by the IEA Greenhouse Gas R&D Programme. The views and opinions of the authors expressed herein do not necessarily reflect those of the IEA Greenhouse Gas R&D Programme, its members, the International Energy Agency, the organisations listed below, nor any employee or persons acting on behalf of any of them. In addition, none of these make any warranty, express or implied, assumes any liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed or represents that its use would not infringe privately owned rights, including any party's intellectual property rights. Reference herein to any commercial product, process, service or trade name, trade mark or manufacturer does not necessarily constitute or imply an endorsement, recommendation or any favouring of such products.

## **COPYRIGHT**

Copyright © IEA Greenhouse Gas R&D Programme 2006.  
All rights reserved.

## ACKNOWLEDGEMENTS AND CITATIONS

This report describes research sponsored by the IEA Greenhouse Gas R&D Programme. This report was prepared by:

Foster Wheeler Italiana S.p.A.  
Via S. Caboto 1  
20094 Corsico (Milano)  
Italy

### **The principal researchers were:**

- Rosa Maria Domenichini
- Luca Mancuso

To ensure the quality and technical integrity of the research undertaken by the IEA Greenhouse Gas R&D Programme (IEA GHG) each study is managed by an appointed IEA GHG manager. The report is also reviewed by a panel of independent technical experts before its release.

**The IEA GHG manager for this report:** John Davison

### **The expert reviewers for this report:**

- Howard Herzog, MIT, USA
- Barry Hooper, CO2CRC, Australia
- Terry Johnson, HRL Developments Pty, Australia
- Harry Schaap, Australia
- Dale Simbeck, SFA Pacific, USA
- Louis Wibberley, CSIRO, Australia

The report should be cited in literature as follows:

IEA Greenhouse Gas R&D Programme (IEA GHG), “CO<sub>2</sub> capture in low rank coal power plants”, 2006/2, January 2006.

Further information or copies of the report can be obtained by contacting the IEA GHG Programme at:

IEA Greenhouse R&D Programme, Orchard Business Centre,  
Stoke Orchard, Cheltenham, Glos., GL52 7RZ, UK  
Tel: +44 1242 680753 Fax: +44 1242 680758  
E-mail: [mail@ieaghg.org](mailto:mail@ieaghg.org)  
[www.ieagreen.org.uk](http://www.ieagreen.org.uk)





# CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS

## Background to the Study

Until now, IEA GHG's studies on coal-based power plants with CO<sub>2</sub> capture have concentrated mainly on high rank (bituminous) coals but it is recognised that low-rank coals (sub-bituminous coal, lignite and brown coal) are important fuels for power generation in several countries. A study has therefore been carried out to estimate the performance and costs of low rank coal fired power plants with CO<sub>2</sub> capture based on various technologies. The study was carried out for IEA GHG by Foster Wheeler Italiana.

This overview written by IEA GHG summarises the results of the study and puts them in context with results from other studies carried out recently by IEA GHG. More detailed technical information is included in the Executive Summary in Foster Wheeler's report.

## Study Basis

### Low rank coal availability and analyses

Low rank coals are characterised by relatively high moisture and oxygen contents and low heating values. There is no universal system of classification for low rank coals but the lowest rank coals are normally called lignite and coals which are intermediate between lignite and high rank bituminous coals are called sub-bituminous coals. In some countries the term 'brown coal' is used for low rank coals.

Low rank coal accounts for almost half of the world's proven recoverable coal reserves on a mass basis and 30% of coal production, although in energy terms the proportions are lower because of the relatively low heating values of low rank coals. About 60% of the low rank coal reserves are sub-bituminous coal and the rest is lignite. The country with the world's largest production and proven recoverable reserves of lignite is Germany. A German coal, as shown in table 1, was selected as the basis for this study. The analysis of the standard bituminous coal used in IEA GHG's earlier studies is also shown in table 1 for comparison.

**Table 1 Coal analyses**

	German brown coal selected for this study	IEA GHG standard bituminous coal
Moisture, % as-received basis	50.70	9.5
Ash, % dry basis	7.10	13.48
Carbon, % dry basis	63.54	71.38
Hydrogen, % dry basis	4.65	4.85
Oxygen, % dry basis	23.44	7.79
Nitrogen, % dry basis	0.74	1.56
Sulphur, % dry basis	0.45	0.95
Chlorine/fluorine, % dry basis	0.08	0.03
HHV, MJ/kg as-received <sup>1</sup>	12.26	27.06
LHV, MJ/kg as-received	10.50	25.87
LHV, MJ/kg C	33.5	40.0

<sup>1</sup> There is no universally recognised relationship between the HHV and LHV of solid fuels. The relationship in this table is based on an equation from the 7<sup>th</sup> edition of "Technical Data on Fuel" by Rose and Cooper, published by the World Energy Conference. The LHV is the HHV minus the heat of vaporisation of the moisture in the coal and the moisture produced by combustion of the hydrogen in the coal. This definition is normally used in Europe. In North America the LHV is normally calculated by only subtracting the heat of vaporisation of moisture produced by combustion of hydrogen.



IEA GHG participated in a study by the CCPC<sup>2</sup> which considered CO<sub>2</sub> capture power plants based on two Canadian low rank coals; an Alberta sub-bituminous coal, and a Saskatchewan lignite. The Saskatchewan lignite has a significantly higher rank than the German brown coal shown in table 1, for example it has a moisture content of 34% and an oxygen content of 14.6%, dry basis. This study therefore extends the assessment of CO<sub>2</sub> capture to even lower rank coals.

## **Power plant performance and cost assessments**

### ***Assessment criteria***

The performances and costs of power plants with CO<sub>2</sub> capture were estimated based as far as possible on IEA GHG's standard assessment criteria. The plants were assumed to operate at base load with a load factor of 85% and the economic evaluation was based on a 10% annual discount rate and 25 year plant operating life. The reference coal price was assumed to be €1/GJ but the sensitivity of power cost to coal price was assessed, to allow for local variations. Low rank coal is traded on the open market much less than high rank coal and price information is less freely available. Further details of the assessment criteria are included in the main study report.

IEA GHG's standard criteria state that the power plant will be built at a coastal site in the Netherlands but this was not appropriate for this study because low rank coal is normally used at power plants located close to the mine. This study was therefore based on an inland mine site in Germany. The different location resulted in some changes to the plant design criteria, in particular the use of natural draught cooling towers instead of once-through sea water cooling, but in other respects the different location did not significantly affect the performance and costs.

The plant costs were estimated in Euros. Conversion of Euros to US Dollars is currently subject to significant uncertainty, because of recent large fluctuations in the exchange rate. At the start of 2005, one € had the same value as about 1.3 US\$ but the value declined to 1.17 \$ by December. Between 2001 and 2005 the value of one € has varied within the range of about 0.85 and 1.35\$.

### ***Case descriptions***

The first stage of the study involved assessment of the performances and costs of power plants with CO<sub>2</sub> capture based on a wide variety of technologies. The following plants were assessed:

1. Pulverised coal boiler with an ultra –supercritical (USC) steam cycle and post combustion CO<sub>2</sub> capture using MEA solvent scrubbing
2. Circulating Fluidised Bed (CFB) boiler with a USC steam cycle and post combustion CO<sub>2</sub> capture using MEA solvent scrubbing
3. Pressurised Circulating Fluidised Bed (PCFB) boiler with a USC steam cycle and post combustion CO<sub>2</sub> capture using MEA solvent scrubbing
4. Oxy-combustion pulverised coal boiler with a USC steam cycle
5. Gasification combined cycle using Future Energy oxygen blown, dry feed, entrained gasifiers, with water quench, sour shift conversion and CO<sub>2</sub> capture by MDEA scrubbing
6. Gasification combined cycle using Shell oxygen blown, dry feed, entrained gasifiers, with heat recovery boilers, sour shift conversion and CO<sub>2</sub> capture by MDEA scrubbing
7. Gasification combined cycle using Foster Wheeler air blown, dry feed, fluidised bed gasifiers, with heat recovery boilers, sour shift conversion and CO<sub>2</sub> capture by MDEA scrubbing

---

<sup>2</sup> Canadian Clean Power Coalition studies on CO<sub>2</sub> capture and storage, report PH4/27, March 2004.



Plants without capture were not included in the screening assessment, to limit the cost of the study. The assessment did not include the GE (formerly Texaco) gasifier, which had the lowest costs of electricity in IEA GHG's study on bituminous coal gasification combined cycle plants with capture<sup>3</sup>. That gasifier in its current form is considered to be not suitable for high moisture lignite because the water content of the slurry feed to the gasifier would be excessively high, resulting in a low efficiency and high costs.

The IGCC plants produce an impure CO<sub>2</sub> product, containing the sulphur from the coal mainly in the form of H<sub>2</sub>S. The oxyfuel plant also produces impure CO<sub>2</sub>. In that case the sulphur is mainly present as SO<sub>2</sub>. In both cases producing a high purity CO<sub>2</sub> would increase costs.

The technology with the lowest cost (CFB with post combustion capture) was selected for a more detailed assessment, which included assessment of plants with and without CO<sub>2</sub> capture. However, it should be noted that the optimum technology will depend on the fuel analysis and other local circumstances, and criteria other than the base load performance and cost of electricity, such as technology risk.

## Results and Discussion

### *Technology screening*

The performances and costs of the power plants with CO<sub>2</sub> capture, from the technology screening, are summarised in table 2.

**Table 2: Cost and performance summary, technology screening**

	Net power	Efficiency (LHV)	CO <sub>2</sub> capture	Capital cost	Electricity cost
	MW	%	%	€/kW	€/kWh
<b>Post combustion capture</b>					
Pulverised coal	761.0	35.5	85.0	1645	5.39
CFB	614.4	35.5	85.0	1552	5.34
PCFB	688.4	32.5	85.0	1788	5.55
<b>Oxy-combustion</b>					
Pulverised coal	741.3	37.5	93.0	1882	5.46
<b>Pre-combustion capture</b>					
Future Energy gasifier	665.2	34.7	85.8	1706	5.41
Shell gasifier	628.8	34.5	85.2	1917	5.94
Foster Wheeler gasifier	686.6	34.1	82.9	1795	5.64

The net power outputs of the plants are slightly different in each case because they depend on the sizes of commercially available equipment. The target percentage CO<sub>2</sub> capture is 85%, except for the oxyfuel case, which inherently achieves a higher percentage capture. The other technologies could achieve greater than 85% CO<sub>2</sub> capture if required.

The thermal efficiencies are all within the range of 32.5 - 37.5% on a lower heating value (LHV) basis and the costs of electricity are within the range of 5.34 - 5.94 c/kWh. The oxy-combustion plant has the highest efficiency and percentage CO<sub>2</sub> capture and the CFB plant with post combustion capture has the lowest electricity cost. The differences between the costs of the different technologies are within the limits of uncertainty of the assessment, particularly as none of the technologies is fully proven at commercial scale.

<sup>3</sup> Potential for improvement in gasification combined cycle power generation with CO<sub>2</sub> capture, report PH4/19, May 2003.

### Assessment of selected option


The CFB plant with post-combustion capture was assessed in more detail and a reference CFB plant without capture was also assessed for comparison. Costs of avoiding CO<sub>2</sub> emissions were calculated by comparing the plants with and without capture. The results are summarised in table 3.

**Table 3: Cost and performance summary, detailed assessment of selected case**

	Without capture	With capture	Difference due to capture
<b>Plant performance</b>			
Fuel input, MW (LHV)	1729	1729	0
Gross power output, MW	842	758	-84
Ancillary power consumption and losses, MW <sup>4</sup>	50	148	98
Net power output, MW	792	610	-182
<b>Efficiency and emissions</b>			
Thermal efficiency, % (LHV)	45.8	35.3	10.5
Increase in fuel use per kWh, %			30
CO <sub>2</sub> capture efficiency, %		85.0	
CO <sub>2</sub> emissions, g/kWh	872	170	702
CO <sub>2</sub> captured, g/kWh		962	
<b>Costs</b>			
Capital cost, €/kW net power	1006	1567	561
Electricity cost, €/kWh (excluding CO <sub>2</sub> storage)	3.46	5.39	1.93
Cost of CO <sub>2</sub> avoidance, €/tCO <sub>2</sub> (excluding storage)			27.5

The CFB plant data in table 3 differ from those in table 2 because Foster Wheeler carried out a more detailed analysis and used more data from equipment vendors, but the overall differences are small. For the technology screening, they scaled the costs of amine scrubbing units from information in Fluor's report for IEA GHG<sup>5</sup>. For the more detailed analysis of the CFB case, they obtained costs of major items of equipment in the amine scrubbing unit from vendors. The resulting costs of the amine scrubbing unit were about 10% higher than the costs obtained by scaling from Fluor's study.

Costs of low rank coal vary considerably between different locations. The relationship between fuel price and the cost of electricity, excluding CO<sub>2</sub> transportation and storage, is shown in figure 1.



**Figure 1 Sensitivity of electricity cost to fuel price**

<sup>4</sup> The auxiliary powers exclude boiler feed pumps, which are steam turbine driven, and include transformer losses.

<sup>5</sup> Improvement in power generation with post-combustion capture of CO<sub>2</sub>, report PH4/33, November 2004.

The costs in this study exclude CO<sub>2</sub> transportation and storage, which would depend strongly on local circumstances. For illustration, a cost of €10/tonne of CO<sub>2</sub> stored would add 0.96 c/kWh to the cost of electricity and €13.7/tonne to the cost of CO<sub>2</sub> avoided by the CFB plant.

#### ***Comparison with bituminous coal fired plants***

On a LHV basis, the efficiencies of the brown coal power plants with capture are similar to the efficiencies of bituminous coal plants using the same technology, as reported in other recent IEA GHG studies<sup>6</sup>, but on a HHV basis the brown coal plants are less efficient, as shown in table 4.

**Table 4: Efficiencies of brown coal and bituminous coal power plants with CO<sub>2</sub> capture**

	LHV efficiency, %		HHV efficiency, %	
	Brown coal	Bituminous coal	Brown coal	Bituminous coal
Pulverised coal, MEA scrubbing	35.5	34.8	30.4	33.3
Pulverised coal, oxy-combustion	37.5	35.4	32.1	33.8
IGCC, Shell gasifier	34.5	34.5	29.6	33.0

Low rank coal contains a large amount of moisture, which is evaporated in a drier and within a combustor or gasifier. According to the European definition of LHV (see footnote on page i), the heat of evaporation of this moisture and the moisture produced by combustion of hydrogen in the organic part of the coal has been subtracted from the heating value. Some of the coal drying is carried out using low grade heat from the power generation and CO<sub>2</sub> capture plants, so the high moisture content of the coal can actually be beneficial for the LHV efficiency.

The efficiency penalty for post-combustion CO<sub>2</sub> capture is slightly higher for the low rank coal CFB plants than for the pulverised bituminous coal plants reported in PH4/33 (10.5 compared to 9.2 percentage points). This may be because more CO<sub>2</sub> has to be captured per kWh of electricity in a low rank coal power plant, because the specific energy content of low rank coal is lower in terms of MJ/kgC, as shown in table 1.

It is more difficult to compare the costs in this study with costs from IEA GHG's earlier studies on bituminous coal fired plants, because of the different timing of the studies, varying exchange rates, different locations, different contractors and fuel price uncertainties. However, it appears that the cost of post combustion capture is similar in bituminous coal and brown coal fired plants. In the bituminous coal plant studies the cost of electricity in the optimum IGCC plant was lower than the cost in the post combustion capture and oxyfuel plants but in this study on brown coal the costs are similar for all three technologies. Post combustion capture and oxyfuel combustion appear to become more competitive compared to IGCC for lower rank coals. This is in line with results from studies by the Canadian Clean Power Coalition<sup>7</sup>

#### ***Sensitivity to coal analysis***

This study was based on a German brown coal. Low rank coal analyses vary considerably, as shown in the main study report. Important factors apart from the rank of the coal are the sulphur and ash contents and the ash composition, particularly the concentration of alkalis which can cause serious operating difficulties in some cases. Quantifying the effects of coal analysis on plant performance, costs and technology selection was outside the scope of this study. However, it is emphasised that the optimum technology for power generation with CO<sub>2</sub> capture will depend on the coal analysis.

<sup>6</sup> Report PH4/19 (IGCC), May 2003, report PH4/33 (post-combustion capture), Nov. 2004 and report 2005/11 (oxy-combustion), July 2005.

<sup>7</sup> Report PH4/27, March 2004.



## Comments from Expert Reviewers

Comments on the draft study report were received from various expert reviewers. The reviewers' comments were taken into account as far as possible in the final version of the contractor's report or in the overview. In general the reviewers thought the report was comprehensive and of high quality.

There were some specific comments about the technologies selected for the study, in particular the practicality and safety of air drying of low rank coal. Some reviewers would have liked to include assessment of other gasifiers being developed specifically for low-rank coal, in particular the HTW oxygen blown fluidised bed gasifier, the Integrated Drying Gasification Combined Cycle and the next generation ConocoPhillips E-STR gasifier, which they considered may be more competitive. Some reviewers would have liked reference cases without CO<sub>2</sub> capture to be included for all of the technologies and a more detailed assessment of a gasification case. It was also suggested that an oxyfuel CFB boiler may be attractive option. However, it was not possible to include these extra cases within the study budget.

There was some concern about technologies being evaluated by organisations which have a vested interest in them, but this concern is not unique to this study. The main sources of cost data for this and other similar studies carried out for IEA GHG and other agencies are technology and equipment vendors. These organisations have the greatest knowledge about the technologies and their costs but it has to be recognised that they also have a commercial interest in the adoption of their technologies.

## Major Conclusions

There is little difference between the costs and thermal efficiencies of low rank coal power plants with CO<sub>2</sub> capture based on post-combustion capture, oxy combustion and IGCC. The optimum technology will depend on the coal analysis and other local circumstances.

Adding post combustion CO<sub>2</sub> capture to a brown coal fired circulating fluidised bed combustion plant reduces the thermal efficiency by 10 percentage points and increases the cost of electricity by about 55%.

Post combustion capture and oxyfuel combustion appear to become more competitive compared to IGCC for lower rank coals.

## Recommendations

Criteria other than those considered in this study may influence a utility's choice of technology for power generation with CO<sub>2</sub> capture. IEA GHG is carrying out a study to assess the relative importance to utilities of different criteria.

An oxyfuel CFB case and IGCCs based on other gasifiers should be included in any future assessments of low rank coal power plants with CO<sub>2</sub> capture. Sensitivities to low rank coal analyses should also be included.



# **CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Final Report**

**November 2005**



**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 6  
**General Index**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS  
 DOCUMENT NAME : CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS REPORT

ISSUED BY : R. DOMENICHINI  
 CHECKED BY : R. DOMENICHINI  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by



**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER**  
**PLANTS REPORT**

**I N D E X**

SECTION A EXECUTIVE SUMMARY

SECTION B GENERAL INFORMATION

- 1.0 Purpose of the Study
- 2.0 Project Design Bases
- 3.0 Basic Engineering Design Data
- 4.0 Alternative Designs of Power Generation

SECTION C BASIC INFORMATION FOR LOW RANK COAL POWER PLANTS

- 1.0 Coal Handling and Storage
- 2.0 Drying of low rank coal-lignite
- 3.0 Ash Handling
- 4.0 Flue Gas Denitrification (DeNO<sub>x</sub>)
- 5.0 Flue Gas Desulphurization (FGD)
- 6.0 Mercury and Heavy Metals Removal
- 7.0 CO<sub>2</sub> Postcombustion Capture
- 8.0 CO<sub>2</sub> Precombustion Capture
- 9.0 CO<sub>2</sub> Compression and Drying
- 10.0 Utility and Offsite Units

SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE

- 1.0 Case 1 (PC Boiler with Postcombustion CO<sub>2</sub> capture)
  - 1.1 Introduction
  - 1.2 Process Description
  - 1.3 Block Flow Diagrams
  - 1.4 Heat and Material Balances
  - 1.5 Utility Consumptions
  - 1.6 Overall Performances
  - 1.7 Environmental Impact
  - 1.8 Equipment List
  
- 2.0 Case 2 (Oxyfuel PC boiler)
  - 2.1 Introduction
  - 2.2 Process Description
  - 2.3 Block Flow Diagrams
  - 2.4 Heat and Material Balances
  - 2.5 Utility Consumptions
  - 2.6 Overall Performances
  - 2.7 Environmental Impact
  - 2.8 Equipment List
  
- 3.0 Case 3 (CFB boiler with postcombustion CO<sub>2</sub> capture)
  - 3.1 Introduction
  - 3.2 Process Description
  - 3.3 Block Flow Diagrams
  - 3.4 Heat and Material Balances
  - 3.5 Utility Consumptions
  - 3.6 Overall Performances
  - 3.7 Environmental Impact
  - 3.8 Equipment List
  
- 4.0 Case 4 (PCFB boiler with postcombustion CO<sub>2</sub> capture)
  - 4.1 Introduction
  - 4.2 Process Description
  - 4.3 Block Flow Diagrams
  - 4.4 Heat and Material Balances
  - 4.5 Utility Consumptions
  - 4.6 Overall Performances
  - 4.7 Environmental Impact
  - 4.8 Equipment List

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

 Revision no.: Final  
 Date: November 2005  
 Sheet: 4 of 6

**General Index**


---

- 5.0 Case 5 (Future Energy, Entrained Flow Technology, IGCC with precombustion CO<sub>2</sub> capture)
  - 5.1 Introduction
  - 5.2 Process Description
  - 5.3 Block Flow Diagrams
  - 5.4 Heat and Material Balances
  - 5.5 Utility Consumptions
  - 5.6 Overall Performances
  - 5.7 Environmental Impact
  - 5.8 Equipment List
  
- 6.0 Case 6 (Shell, IGCC with precombustion CO<sub>2</sub> capture)
  - 6.1 Introduction
  - 6.2 Process Description
  - 6.3 Block Flow Diagrams
  - 6.4 Heat and Material Balances
  - 6.5 Utility Consumptions
  - 6.6 Overall Performances
  - 6.7 Environmental Impact
  - 6.8 Equipment List
  
- 7.0 Case 7 (FW, Fluidized Bed Technology, IGCC with precombustion CO<sub>2</sub> capture)
  - 7.1 Introduction
  - 7.2 Process Description
  - 7.3 Block Flow Diagrams
  - 7.4 Heat and Material Balances
  - 7.5 Utility Consumptions
  - 7.6 Overall Performances
  - 7.7 Environmental Impact
  - 7.8 Equipment List

**SECTION E ECONOMICS**

- 1.0 Introduction
- 2.0 Basis of Investment Cost Evaluation
- 3.0 Investment Cost of the Alternatives
- 4.0 Operation and Maintenance Costs of the Alternatives
- 5.0 Evaluation of the Electric Power Cost of the alternatives

SECTION F      COMPARISON OF ALTERNATIVES AND SELECTION OF THE  
MOST PROMISING TECHNOLOGY

- 1.0      Introduction
- 2.0      Post-combustion CO<sub>2</sub> capture alternatives (Case 1 through 4)
- 3.0      Pre-combustion CO<sub>2</sub> capture alternatives (Case 5 through 7)
- 4.0      Selection of the most promising technology

Appendix 1 – Summary of performance, cost and environmental data of all the alternatives

SECTION G      DETAILED INFORMATION FOR THE SELECTED  
TECHNOLOGY

- G.1      CFB boiler without CO<sub>2</sub> Capture
  - 1.0      Summary
  - 1.1      Process Description
  - 1.2      Process Flow Diagrams
  - 1.3      Heat and Material Balances
  - 1.4      Utility Consumption
  - 1.5      CFB Overall Performance
  - 1.6      Environmental Impact
  - 1.7      Equipment List
  
- G.2      CFB boiler with CO<sub>2</sub> Capture
  - 2.0      Summary
  - 2.1      Process Description
  - 2.2      Process Flow Diagrams
  - 2.3      Heat and Material Balances
  - 2.4      Utility Consumption
  - 2.5      CFB Overall Performance
  - 2.6      Environmental Impact
  - 2.7      Equipment List
  
- G.3      Economics
  - 3.0      Introduction
  - 3.1      Basis of investment cost evaluation
  - 3.2      Investment cost of the two alternatives

---

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
Date: November 2005  
Sheet: 6 of 6  
**General Index**

---

- 3.3 Operation and maintenance costs
- 3.4 Evaluation of the Electric Power cost and CO<sub>2</sub> removal cost

SECTION H YEAR 2020 IMPROVEMENTS

- 1.0 General Background
- 2.0 Pulverized Coal Combustion
- 3.0 Oxyfuel
- 4.0 Circulating Fluid Bed
- 5.0 Pressurized Fluid Bed
- 6.0 Integrated Gasification Combined Cycle
- 7.0 Environmental protection Technologies

SECTION I ATTACHMENTS

Attachment I.1 Analyses of low rank coals

- 1.0 Introduction
- 2.0 Classification of coal by rank
- 3.0 Worldwide distribution of coal deposits
- 4.0 Properties of low rank coals
- 5.0 Selection of the reference coal for the study

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**

**Section A Executive summary**

---

Rev. no.: Final

Date: November 2005

Sheet: 1 of 15

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
PROJECT NAME : CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS  
DOCUMENT NAME : EXECUTIVE SUMMARY

ISSUED BY : L. MANCUSO  
Checked by : G.L. FARINA  
Approved by : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

**SECTION A**  
**EXECUTIVE SUMMARY**

**I N D E X**

**SECTION A      EXECUTIVE SUMMARY**

- 1.0      Scope of the study
- 2.0      Bases of design
- 3.0      Alternative designs of power plants
- 4.0      Performance data
- 5.0      Investment cost data
- 6.0      Production costs and selection of the most promising technology
- 7.0      Detailed information of the most promising technology (CFB)
- 8.0      Summary and conclusions

## SECTION A

### 1.0 Scope of the study

The IEA Greenhouse Gas R&D Programme has retained Foster Wheeler to investigate different power plant technologies, capable to utilize low rank coal as primary fuel and make the pre-combustion or post-combustion CO<sub>2</sub> capture. The primary purpose of this study is to compare these technologies and analyze benefits and issues associated with the use of low rank coal in the power industry, optimizing efficiency, capital cost and reducing emissions to the atmosphere.

The study begins with the analysis of the distribution and characteristics of the low rank coals deposits from the major producing regions worldwide (reference to Section I, attachment I.1), showing that 47% of the quantity recoverable deposits in the world is mainly composed of lignite and sub-bituminous coal.

Germany is the world's largest brown coal producer/reserve, representing 20% of global production in 2001. This feature led to the selection of a German lignite as reference coal of the study, with a LHV equal to 10,500 kJ/kg and a moisture content of 50.7%.

The nominal capacity of the different power plants is approximately fixed to 750 MWe.

The study initially evaluates costs and performances of seven different power plant technologies, with CO<sub>2</sub> capture, in order to select the most promising process scheme.

After the determination of the most attractive technology, the study also presents a more detailed assessment of performances and costs of the selected technology, comparing the two alternatives with and without CO<sub>2</sub> capture, in order to evaluate the penalties on cost and performances related to the CO<sub>2</sub> sequestration.

Finally, the study is completed with the investigation of possible improvements to the coal firing technology, expected by year 2020.

For the preparation of the study, FWI based part of the work on the study made for IEA-GHG in 2003 ("Gasification Power Generation Study"), which was supported by different companies (Dow, General Electric, Shell, Syntex, Sud-Chemie, Texaco, UOP).



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS****Section A Executive summary**

---

Rev. no.: Final

Date: November 2005

Sheet: 4 of 15

IEA-GHG made also available previous study reports, developed by other companies, for similar plants.

For this specific study, FWI like to acknowledge the following companies for their fruitful support:

- RWE;
- FWOy;
- Future-Energy;
- Shell;
- Siemens;
- Johnson Matthey Catalysts;
- GTC;
- Sulzer;
- Koch-Glitsch;
- FWUS.

## 2.0 Bases of design

The power plants are designed to process a Western Germany lignite (Rheinbraun) coal (refer to Section B, paragraph 2.1) to produce electric energy.

For the alternatives with post-combustion CO<sub>2</sub> capture, the design capacity of the plant is fixed to approximately provide 750 MWe of power production. For the alternatives with pre-combustion CO<sub>2</sub> capture, the design capacity is fixed to match the appetite of the two gas turbines, General Electric 9FA.

The design capacity for each of the alternatives considered is summarized in paragraph 4.0.

The environmental limits set up for the power plants are outlined hereinafter.

		Post-combustion CO <sub>2</sub> CO <sub>2</sub> capture (1)		Pre-combustion CO <sub>2</sub> capture (2)
NO <sub>x</sub> (as NO <sub>2</sub> )	:	≤ 200 mg/Nm <sup>3</sup>	≤	80 mg/Nm <sup>3</sup>
SO <sub>x</sub> (as SO <sub>2</sub> )	:	≤ 200 mg/Nm <sup>3</sup>	≤	10 mg/Nm <sup>3</sup>
Particulate	:	≤ 30 mg/Nm <sup>3</sup>	≤	10 mg/Nm <sup>3</sup>
CO	:	≤ 100 mg/Nm <sup>3</sup>	≤	50 mg/Nm <sup>3</sup>

Note: (1) @ 6% O<sub>2</sub> vol dry  
(2) @ 15% O<sub>2</sub> vol dry

Characteristics of wastewater discharged from power plants shall comply with the limits stated by the current EU directives.

For the pre-combustion CO<sub>2</sub> capture alternatives (IGCC), the effluent from the wastewater treatment shall be generally recovered and recycled back to the gasification island as process water.

The other bases of design for the power plant, such as capacity, required availability, location, climatic data etc., are defined in Section B of this report.

### **3.0 Alternative designs of power plants**

Several power plant design alternatives were developed in the study. The contemplated alternatives attempt to compare the following key process aspects:

- Different coal power plant technologies for processing of a lignite coal;
- Post-combustion and pre-combustion CO<sub>2</sub> capture in different low rank coal power plants;
- Different CO<sub>2</sub> capture technologies (MEA, MDEA scrubbing or gas liquefaction).
- Performance and cost penalties, due to the CO<sub>2</sub> capture, for the most promising technology amongst the investigated alternatives.

The following alternatives were investigated:

- CASE 1 Ultra Super Critical Pulverized Coal (USC-PC) Boiler, with post-combustion CO<sub>2</sub> capture by using MEA as solvent washing.
- CASE 2 USC - PC-Oxycombustion Boiler, with post combustion CO<sub>2</sub> capture by means of Gas liquefaction.
- CASE 3 Foster Wheeler Circulating Fluidized Bed (CFB) Boiler, with post-combustion CO<sub>2</sub> capture by using MEA as solvent washing.
- CASE 4 Foster Wheeler Pressurized Circulating Fluidized Bed (PCFB) Boiler, with post-combustion CO<sub>2</sub> capture by using MDEA as solvent washing.
- CASE 5 Future Energy gasification technology, sour shift and CO<sub>2</sub> pre-combustion capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S).
- CASE 6 Shell gasification technology, sour shift and CO<sub>2</sub> pre-combustion capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S).
- CASE 7 Foster Wheeler Air gasification technology, sour shift and CO<sub>2</sub> pre-combustion capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S).

#### **4.0 Performance data**

The most important performance data of the different power plants, with CO<sub>2</sub> capture, are summarized in the following Table A.4.1.

The feature common to all the alternatives is the partial drying of the coal from the initial content of 50.7% to a range varying from 32% for the post-combustion alternatives to 10%-5% respectively for the IGCC alternatives based on Future Energy and Shell technology. The partial drying of the coal lignite is used to enhance the efficiency of the different power plants, utilizing low temperature heat available in the plant at various locations. In the IGCC alternatives, FE and Shell, it is necessary to reduce the moisture content of the lignite to a lower level to permit the operation of the pneumatic transportation system used in these technologies.

Despite the differences of the various technologies involved, the net electrical efficiency falls in a narrow range of values. The Oxycombustion USC-PC boiler is the alternative with the highest electrical efficiency and superior environmental performances.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**

Section A Executive summary

Revision Final  
 no.: November 2005  
 Date: Sheet: 8 of 15

**Table A.4.1 - Performance data.**

Case	Power plant tech.	Coal t/h	Coal moisture after drying, %wt	Acid gas removal tech.	CO <sub>2</sub> capture eff., %	Gross power output MWe (1)	Auxiliary cons. MWe	Net power output MWe (2)	Net electrical efficiency %
1	USC-PC	734.0	32	MEA	85.0	932.0	168.8	761.0	35.5
2	Oxy USC- PC	677.6	32	Gas liquefaction	93.0	1039.4	295.8	741.3	37.5
3	CFB FW	592.9	32	MEA	85.0	763.0	146.5	614.7	35.5
4	PCFB FW	727.0	32	MDEA	85.0	816.0	125.5	688.4	32.5
5	IGCC FE	653.3	10	MDEA	85.8	900.3	233.1	665.2	34.7
6	IGCC SHELL	624.2	5	MDEA	85.2	868.7	238.0	628.8	34.5
7	IGCC FW	691.0	25	MDEA	82.9	900.5	211.9	686.6	34.1

Notes: (1) At generator terminals.  
 (2) At Low Voltage side of the step-up transformers.

## **5.0 Investment cost data**

The investment cost data of the different power plants technologies, with CO<sub>2</sub> capture, are shown in Table A.5.1 and 2.

Since capacity is not the same for all the alternatives, it is better to compare these technologies, from the point of view of the investment, on the base of the specific investment (Euro/kW), rather than the total investment. From this comparison it appears that the CFB technology shows the lowest specific investment cost.

**Table A.5.1 - Investment Cost Data (Post-combustion alternatives)**

Case	Power plant technology.	MAIN POWER PLANT SECTIONS INVESTMENT										Total Investment 10 <sup>6</sup> Euro	Specific Investment Euro/kW
		Boiler Island		Process Units		CO <sub>2</sub> Compr.		Power Island		Utilities Offsites			
		10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%		
1	USC-PC	463.1	37	306.4	24	47.6	4	162.5	13	272.2	22	1251.8	1645
2	Oxy USC-PC	451.2	32	416.6 <sup>(1)</sup>	29	92.9	7	174.5	13	260.0	19	1395.2	1882
3	CFB FW	334.0	35	198.2	21	42.0	4	138.6	15	241.0	25	953.8	1552
4	PCFB FW	345.4	28	431.5	35	47.9	4	135.1	11	270.7	22	1230.6	1788

Notes: (1): Including the Air Separation Unit.

**Table A.5.2 - Investment Cost Data (Pre-combustion alternatives)**

Case	Power plant technology.	MAIN POWER PLANT SECTIONS INVESTMENT										Total Investment 10 <sup>6</sup> Euro	Specific Investment Euro/kW
		Air Separation		Process Units		CO <sub>2</sub> Compr.		Power Island		Utilities Offsites			
		10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%	10 <sup>6</sup> €	%		
5	IGCC FE	126.3	11	380.3	34	40.1	3	368.9	33	219.1	19	1134.8	1706
6	IGCC SHELL	114.0	10	472.9	39	38.5	3	367.1	30	212.7	18	1205.1	1917
7	IGCC FW	28.9 <sup>(1)</sup>	2	566.3	46	40.0	3	370.2	30	227.2	19	1232.7	1795

Notes: (1): Air Compression Unit (ASU in not required).

## 6.0 Production costs and selection of the most promising technology

The following Table A.6.1 provides the cost of electricity (C.O.E.) for the different alternatives, with the CO<sub>2</sub> capture.

The cost of electricity was calculated based on the following main assumptions:

- Cost of coal: 1.0 Euro/GJ (10.5 Euro/t);
- 7446 equivalent operating hours in normal conditions at 100% capacity;
- Total investment cost as given in para. 5.0 of this Section;
- O&M costs as evaluated in Section E;
- 10% discount rate on the investment cost over 25 operating years;
- Other financial parameters as per Section E.

**Table A.6.1 - Cost of Electric Power Production.**

Case	Power plant technology	C.O.E. (DCF= 10%) Cent/kWh
1	USC-PC	5.39
2	Oxy USC- PC	5.46
3	CFB FW	5.34
4	PCFB FW	5.55
5	IGCC FE	5.41
6	IGCC SHELL	5.94
7	IGCC FW	5.64

The cost of electricity falls in a narrow range of values and the maximum difference between the alternatives is approximately 11%. In particular, the USC-PC, CFB and IGCC-FE display the lowest cost of production of electricity. Amongst these three technologies, CFB is the one with the lowest cost and therefore it is selected for the subsequent more detailed study.



## 7.0 Detailed information of the most promising technology (CFB)

The selected technology, FW - CFB, has been analyzed with a higher level of detail. The investigation has been extended by obtaining data from critical equipment Suppliers.

CFB technology was also studied without the CO<sub>2</sub> capture, in order to evaluate the cost related to the CO<sub>2</sub> sequestration.

This evaluation is shown in the following Table A.7.1.

**Table A.7.1 – Performances of the two CFB alternatives.**

ALTERNATIVE		CFB-Boiler without CO <sub>2</sub> capture	CFB-Boiler with CO <sub>2</sub> capture
Lignite Moisture Content After Drying %wt		32	32
<b>OVERALL PERFORMANCES</b>			
Coal Flow Rate A.R.	t/h	592.9	592.9
Thermal Energy of Feedstock	MWth	1729.3	1729.3
Gross Electric Power Output <sup>(1)</sup>	MWe	841.9	758.2
Auxiliary Consumption	MWe	47.6	146.6
Net Electrical Power Output <sup>(2)</sup>	MWe	791.8	609.7
Gross Electrical Efficiency	%	48.7	43.8
Net Electrical Efficiency	%	45.8	35.3
<b>ACID GAS REMOVAL TECHNOLOGY</b>		-	MEA Scrubbing
CO <sub>2</sub> Capture Efficiency	%	-	85.0
<b>INVESTMENT COST DATA</b>			
Total Investment	10 <sup>6</sup> €	769.3	955.1
Specific Net Investment Cost	€/kW	1006	1567
<b>PRODUCTION COST DATA</b>			
C.O.E. (DCF=10%)	c€/kWh	3.46	5.39

Notes: (1) At generator terminals.

(2) At Low Voltage side of the step-up transformer.

### 7.1 Cost of avoiding CO<sub>2</sub> emissions

The cost of avoiding CO<sub>2</sub> emissions can be expressed as follows:

$$\frac{\Delta \text{ Electric Power Cost}}{\Delta \text{ Specific CO}_2 \text{ emission}} [=] \frac{\text{Euro}}{\text{t of CO}_2 \text{ captured}}$$

Where:

- $\Delta$  Electric Power Cost = Electric Power Cost of the alternative with CO<sub>2</sub> capture – Electric Power Cost of alternative w/o CO<sub>2</sub> capture. The Unit of measurement is Euro/kWh.
- $\Delta$  Specific CO<sub>2</sub> emission = Ratio of (CO<sub>2</sub> emission/Power production) of alternative with CO<sub>2</sub> capture – ratio of (CO<sub>2</sub> emission/Power production) of the alternative with CO<sub>2</sub> capture. The unit of measurement is ton CO<sub>2</sub>/kWh.

Based on the above definition, the cost of avoiding CO<sub>2</sub> emissions, at DCF=10%, is the following:


- Cost of avoiding CO<sub>2</sub> emissions: **27.5 Euro/t**

**7.2 Electrical power cost in presence of carbon tax**

Economic or regulatory mechanisms will be necessary to facilitate development and deployment of CO<sub>2</sub> capture technologies. There are various options, including a carbon tax or emission trading certificates.

The two CFB versions, with and without CO<sub>2</sub> capture, were also compared in presence of a carbon tax. Figure A.7.1 shows this comparison as function of an increasing carbon tax from 0 to 50 Euro/t of CO<sub>2</sub> emitted.

This comparison has also taken into account two different Discount Rates, 10% and 5%. For these two discount rates it appears that the Cost of production (C.O.E.) of these two versions is the same when the carbon tax is respectively 27 and 22 Euro/t of CO<sub>2</sub> emitted.



## **8.0 Summary and conclusions**

The most important conclusions of the study are:

- Partial drying of the lignite is advantageous to increase efficiency, utilizing low temperature heat sources available in the plant at various locations.
- Despite the differences of the various technologies involved, the net electrical efficiency of the various alternatives considered falls in a narrow range of values. The Oxycombustion USC-PC alternative shows the highest electrical efficiency and the superior environmental performances.
- By comparing the different power plant technologies, the specific investment cost (Euro/kW) is the lowest for the CFB technology.
- The cost of electricity of the different alternatives falls in a narrow range of values; the maximum difference between the alternatives is approximately 10%.
- CFB alternative was selected for a more detailed analysis because of its superior specific investment cost and lower C.O.E.. However, the study demonstrated that other technologies utilizing low rank coals are very close in performances and, depending on different local circumstances, may become more competitive with respect to the CFB.
- The cost of CO<sub>2</sub> capture, calculated for the CFB technology is 27.5 Euro/t of CO<sub>2</sub> captured (DCF=10%).
- In an environment with a carbon tax, the CFB with and without CO<sub>2</sub> capture show the same C.O.E. when the carbon tax is 27 and 22 Euro/t of CO<sub>2</sub> emitted, respectively for a DCF of 10% and 5%.
- In the next 15 years, significant improvements of the technologies are expected. The most important improvements are:
  - New alloys to operate in more severe supercritical conditions.
  - Demonstration of Oxyfuel technology.
  - Largest single train capacity for CFB.
  - Various improvements of the IGCC technology on the gas turbines, gasifiers and air separation unit.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**

**Section B General Information**

Revision no.: Final  
Date: November 2005  
Sheet: 1 of 25

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
PROJECT NAME : CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS  
DOCUMENT NAME : GENERAL INFORMATION

ISSUED BY : S. RIPANI  
Checked by : L. MANCUSO  
Approved by : R. DOMENICHINI

<b>Date</b>	<b>Revised Pages</b>	<b>Issued by</b>	<b>Checked by</b>	<b>Approved by</b>

---

**IEA GHG**

CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS

Section B General Information

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 25

**SECTION B**  
**GENERAL INFORMATION**

**I N D E X**

**SECTION B      GENERAL INFORMATION**

- 1.0    Purpose of the Study
- 2.0    Project Design Basis
- 3.0    Basic Engineering Design Data
- 4.0    Alternative Designs of Power Generation

## **SECTION B**

### **1.0 Purpose of the Study**

The IEA Greenhouse Gas R&D Programme has retained Foster Wheeler to investigate different Power Plant technologies, which use low rank coal as primary fuel and make the pre-combustion or post-combustion CO<sub>2</sub> capture. The primary purpose of this study is, therefore, the analysis of the benefits and issues associated with the use of low rank coal in the power industry, through the evaluation of different power plant technologies, to optimize efficiency, capital cost and reduce emissions to the atmosphere.

The study also analyzes the distribution and characteristics of the low rank coals deposits from the major producing regions worldwide, showing as almost 47% of the quantity recoverable deposits in the world is mainly composed of lignite and sub-bituminous coal (reference to Section I, attachment I.1). The analyses of the low rank coals deposits leads to the selection of a German lignite coal as feedstock for the different power plants, with a LHV equal to 10500 kJ/kg and a moisture content of 50.7%.

The nominal capacity of the different Power Plants is approximately fixed to 750 MWe.

The study evaluates costs and performances of seven different power plants technologies, with CO<sub>2</sub> capture. The description of the different power plant alternatives is made in paragraph 4.0. After the selection of the most attractive technology, the study also presents a more detailed assessment of performances and costs, comparing the alternative with and without the CO<sub>2</sub> capture, to evaluate the penalties related to the CO<sub>2</sub> capture.

Finally, the study investigates possible improvements to the screened technologies, in order to assess the likely performance of a plant in the year 2020.

## 2.0 Project Design Bases

The power plants are designed to process, in an environmentally acceptable manner, a Western Germany lignite (Rheinbraun) coal to produce electric energy to deliver to the national grid.

For the alternatives with post-combustion CO<sub>2</sub> capture, the design capacity of the plant is fixed to approximately provide 750 MWe of power production.

In case of alternatives with pre-combustion CO<sub>2</sub> capture, the design capacity is fixed to match the appetite of the two selected gas turbines, General Electric 9FA.

### 2.1 Feedstock Specification

The feedstock characteristics selected for this study (see Section I, attachment I.1) are listed hereinafter.

#### 2.1.1 Design Feedstock

##### Germany Garantie Coal

##### Proximate Analysis, wt%

Inherent moisture	50.70
Ash	3.50
Coal (dry, ash free)	45.80
Total	100.00

##### Ultimate Analysis, wt%

(dry)

Carbon	63.54
Hydrogen	4.65
Nitrogen	0.74
Oxygen	23.44
Sulphur	0.45
Ash	7.10
Chlorine	0.05
Fluorine	0.03
Total	100.00



**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**
**Section B General Information**

Revision no.: Final

 Date: November 2005  
 Sheet: 5 of 25

	Min	Max (*)
	% wt	%wt
SiO <sub>2</sub>	4.0	54.0
Al <sub>2</sub> O <sub>3</sub>	1.7	22.0
TiO <sub>2</sub>	0.2	2.5
Fe <sub>2</sub> O <sub>3</sub>	5.0	16.0
CaO	7.0	34.0
MgO	3.0	17.0
Na <sub>2</sub> O	1.0	4.0
K <sub>2</sub> O	0.4	1.5
SO <sub>3</sub>	11.0	15.0
HHV (as received), kJ/kg (*)	12000	
LHV (as received), kJ/kg (*)	10500	

(\*) Refer to Section I, attachment I.1 (paragraph 5.0) for considerations on the ash composition.

**2.1.2 Back-up Fuel**

**Natural Gas**  
**Composition, vol%**

- Nitrogen	0.4
- Methane	83.9
- Ethane	9.2
- Propane	3.3
- Butane and C5	1.4
- CO <sub>2</sub>	1.8
	100.0
- Sulphur content (as H <sub>2</sub> S), mg/Nm <sup>3</sup>	4
LHV, MJ/Nm <sup>3</sup>	40.6
Molecular weight	19.4

## 2.2 Products and by-products

The main products and by-products of the Power Plants are listed here below with their specifications.

### 2.2.1 Electric Power

Net Power Output	:	750 MWe	nominal capacity
Voltage	:	380 kV	
Frequency	:	50 Hz	
Fault duty	:	50 kA	

### 2.2.2 Carbon dioxide

The carbon dioxide characteristics at power plants B.L. are the following:

Status	:	supercritical
Pressure	:	110 bar g
Temperature	:	30 °C
Purity	:	(1)
H <sub>2</sub> S content	:	(1)
CO content	:	0.1 % wt (max)
Moisture	:	< 0.1 ppmvd
N <sub>2</sub> content	:	to be minimized (2)

- (1) Depending on the process alternative considered (see Section D – Basic information for each alternative).
- (2) High N<sub>2</sub> concentration in the product CO<sub>2</sub> stream has a negative impact for CO<sub>2</sub> storage, particularly if the CO<sub>2</sub> is used for Enhanced Oil Recovery. N<sub>2</sub> seriously degrades the performances of CO<sub>2</sub> in EOR, unlike H<sub>2</sub>S which enhances it.

Minimum Capture level :	80%
Preferred Capture level :	85%

## IEA GHG

### CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS

#### Section B General Information

Revision no.: Final

Date: November 2005

Sheet: 7 of 25

#### 2.2.3 Solid by-products

The power plants studied produce saleable solid by-products, in particular:

Case 1 (USC-PC) (1)	:	flyash bottom ash gypsum
Cases 2 – 3 – 4 (OXY-PC, CFB, PCFB) (1)	:	flyash bottom ash
Case 5 (IGCC, Future Energy technology) (1)	:	slag (40% wt approx. water content)
Case 6 (IGCC, Shell technology) (1)	:	slag (10% wt approx water content) flyash
Case 7 (IGCC, FW Tecnology)	:	char

(1) : For the description of the different alternatives, see paragraph 4.0.

### 2.3 Environmental Limits

The environmental limits set up for the study are outlined hereinafter.

#### 2.3.1 Gaseous Emissions

The overall gaseous emissions from power plants shall not exceed the following limits:

		Postcombustion CO <sub>2</sub> CO <sub>2</sub> capture (1)		Precombustion CO <sub>2</sub> capture (2)
NO <sub>x</sub> (as NO <sub>2</sub> )	:	≤ 200 mg/Nm <sup>3</sup>	≤	80 mg/Nm <sup>3</sup>
SO <sub>x</sub> (as SO <sub>2</sub> )	:	≤ 200 mg/Nm <sup>3</sup>	≤	10 mg/Nm <sup>3</sup>
Particulate	:	≤ 30 mg/Nm <sup>3</sup>	≤	10 mg/Nm <sup>3</sup>
CO	:	≤ 100 mg/Nm <sup>3</sup>	≤	50 mg/Nm <sup>3</sup>

Note: (1) @ 6% O<sub>2</sub> vol dry  
(2) @ 15% O<sub>2</sub> vol dry

### 2.3.2 Liquid Effluent

Characteristics of wastewater discharged from power plants shall comply with the limits stated by the current EU directives.

For the IGCC cases, the effluent from the wastewater treatment shall be generally recovered and recycled back to the gasification island as process water.

### 2.3.3 Solid Wastes

The process does not produce any solid wastes, except for typical industrial plant waste e.g. (sludge from waste water treatment etc.).

### 2.3.4 Noise

All the equipment of the power plants studied are designed to obtain a sound pressure level of 85 dB(A) at 1 meter from the equipment.

## **2.4 Plant Operation**

### 2.4.1 Capacity

For the alternatives with post-combustion CO<sub>2</sub> capture (conventional power station, CPS) the design capacity of the plant is fixed to approximately provide 750 MWe of power production.

For the alternatives with precombustion CO<sub>2</sub> capture (IGCC), the design capacity is fixed to match the appetite of two General Electric Frame 9FA.

A minimum availability of 85%, corresponding to 7446 hours of operation in one year at 100% capacity is expected for all the alternatives, starting from the second year of commercial operation.

### 2.4.2 Unit arrangement

Each power plant complex studied is in part a twin or multiple train facility, due to constraints on equipment size and/or to reliability reasons. The arrangement of the process units depends on the process alternative considered (reference to Section D – Basic information for each alternative).

### 2.4.3 Turndown

The power plants are designed to operate with a large degree of flexibility in terms of turndown capacity and feedstock characteristics. The multiple train configuration of each unit of the power plant (see Section D – Basic information for each alternative) allows to operate at low loads with respect to the design capacity.

This multiple configuration limits the events causing the shutdown of the entire power plant.

For the IGCC alternatives, the minimum turndown of each Gas Turbine on syngas is 20%, i.e. 10% of the design capacity. The minimum turndown of the Power Island, when all the machines are in operation (two Gas Turbines and one Steam Turbine), is about 25% of the IGCC capacity. Even if the operation of the IGCC complex at 25% load is a necessary step of the start-up procedure, its duration is to be limited, being approximately 35% load the expected turn down capacity for the entire IGCC Complex, compatible with a prolonged continuous operation.

For the post-combustion CO<sub>2</sub> capture alternatives, the possibility of turndown of the plants is limited by the capacity of the boilers to work at reduced load. Generally, each boiler can operate in the range of 40 % - 100% load, data depending on the degree of automation considered for the plant and on the equipment installed. The assumed turndown capacity of the conventional power stations is 40%.

## 2.5 **Location**

The site an inland area located in the Western Germany, in a greenfield area close the coalmine, without special civil works implications.

The proximity to the coalmine is an essential issue, due to the use of lignite case as primary fuel. In fact, lignite is not often transported long distances because its low heating value makes it relatively expensive to transport and because it often has a great tendency to spontaneously combust.

The plant area is assumed to be close to river water, which is used as make-up water.

## 2.6 Climatic and Meteorological Information

The conditions marked (\*) shall be considered reference conditions for the plant performance evaluation.

- atmospheric pressure : 1013 mbar (\*)
- relative humidity
  - average : 60 % (\*)
  - maximum : 95 %
  - minimum : 40 %
- ambient temperatures (dry bulb temperatures)
  - minimum air temperature : -10 °C
  - maximum air temperature : 30 °C
  - average air temperature : 9 °C (\*)
- wet bulb temperature at reference conditions: : 5.6 °C

## 2.7 Economic/Financial Factors

### 2.7.1 Design and Construction Period

Power plants design and construction will be completed in 34 months, starting from issue of Notice to Proceed to the EPC contractor. Overnight construction will be applied.

The curve of capital expenditure during construction is the following:

<u>Year</u>	<u>Investment Cost %</u>
1	20
2	45
3	35

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS****Section B General Information**

---

Revision no.: Final

Date: November 2005

Sheet: 11 of 25

**2.7.2 Capital Charges**

Discounted cash flow calculations will be expressed at a discount rate of 10% and to illustrate sensitivity at 5%.

**2.7.3 Contingency**

A contingency of 10% of the installed plant cost will be added to the capital cost in absence of more detailed assessment on the specific unit.

**2.7.4 Cost of Debt**

All capital requirements will be treated as debt at the same discount rate used to derive capital charges. This is equivalent to assume a 100% equity. No interest during construction is applied.

**2.7.5 Inflation**

No inflation shall be applied to the economical analysis.

**2.7.6 Commissioning**

Power plants commissioning will take a 6 month period during the last two months of the third year of construction and the first four months of first year of operation.

**2.7.7 Working Capital**

Sufficient storage for 30 days operation at rated capacity will be allowed for raw materials, products, and consumables. No allowance will be made for receipts from sales in this period.

**2.7.8 Land purchase, surveys, general site preparation**

5% of the installed plant cost is assumed.

**2.7.9 Taxation and Insurance**

1% of the installed plant cost is assumed to cover local taxation. Taxation on profits is not included. The same percentage of the installed plant cost is assumed for insurance.

**2.7.10 Fees and owner costs**

2% of the installed plant cost is assumed to cover process/patent fees, consultant services other than EPC Contractor's services, fees for agents, legal and planning costs.

**2.7.11 Operation and Maintenance**

Labour and Maintenance data used for the economical evaluation are summarized in Section E.

**2.7.12 Fuel Costs**

Cost of coal delivered to site is 1.0 \$/GJ (LHV basis).

Cost of natural gas delivered by pipeline to site is 1.7 \$/GJ (LHV basis).

**2.7.13 By-Products Price**

No selling price is attributed to CO<sub>2</sub> and other by-products.

**2.8 Software Codes**

For the development of the Study, two software codes have been mainly used:

- HYSYS v3.0.1 (by Hyprotech Ltd.): Process Simulator used for syngas treatment and for CO<sub>2</sub> capture and compression simulations, downstream the Gasification Island or Power Island.
- Gate Cycle v5.40.0 (by General Electric): Simulator of Power Island units.
- ProMax v1.2 (by BR&E): Simulator for CO<sub>2</sub> capture with amine washing (post-combustion capture)



### **3.0 Basic Engineering Design Data (BEDD)**

#### **3.0 Introduction**

Scope of the Basic Engineering Design Data is the definition of the common bases for the design of the units included in the different Power Plants to be built in an inland area of Germany.

#### **3.1 Units of Measurement**

All calculations are and shall be in SI units, with the exception of piping typical dimensions, which shall be in accordance with ANSI.

#### **3.2 Site Conditions**

- site elevation  
Power Plants complex area : 10 m above mean sea level.
- atmosphere type : Industrial.

#### **3.3 Climatic and Meteorological Information**

The reference conditions are shown in paragraph 2.6.

Other data:

- rainfall  
design : 25 mm/h  
50 mm/day
- wind  
maximum speed : 35 km/h
- snow : 50 kg/m<sup>2</sup>
- winterization  
winterization is required.

**3.4 Soil data**

- earthquake  
earthquake factor : negligible
- geology  
green field site, with no special civil works implications.

**3.5 Project Battery Limits design basis****3.5.1 Electric Power**

High voltage grid connection : 380 kV

Frequency : 50 Hz

Fault duty : 50 kA

**3.5.2 Process and Utility Fluids**

The main process and utility fluids at plants battery limits are the following:

- Coal;
- Natural Gas;
- Plant/Raw/Potable water;
- CO<sub>2</sub> rich stream;
- Limestone;
- Chemicals.

**3.6 Utility and Service fluids characteristics/conditions**

In this paragraph are listed the utilities and the service fluids distributed inside the power plants.

The conditions marked (\*) shall be considered reference conditions for the plants performance evaluation.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**

**Section B General Information**

Revision no.: Final

Date: November 2005

Sheet: 15 of 25

3.6.1 Cooling Water

Cooling Water for Condenser

Source : raw water in closed loop with cooling towers.  
 Service : steam turbine condenser.

Supply temperature:

- average supply temperature (on yearly basis) : 11 °C (\*)
- max supply temperature (average summer) : 30 °C
- max allowed temperature increase : 10 °C (\*)

Return temperature:

- average return temperature : 21 °C (\*)
- max return temperature : 40 °C

Operating pressure at Condenser inlet : 3 barg

Max allowable  $\Delta P$  for Condenser : 0.7 barg

Design pressure for Condenser (CW side) : 5.0 barg

Design temperature : 70 °C

Cleanliness Factor (for steam condenser) : 0.9

Machinery Cooling Water

Source : raw water in closed loop with cooling towers (same as per condenser)

Service : for machinery cooling (different  $\Delta P$  at users)

Supply temperature:

- average supply temperature : 11 °C (\*)
- max supply temperature : 30 °C
- max allowed temperature increase : 10 °C (\*)

Operating pressure at Users : 4.0 barg

Max allowable  $\Delta P$  for Users : 1.5 bar

Design pressure : 6.0 barg

Design temperature : 70 °C

### 3.6.2 Waters

#### Potable water

Source	: from grid
Type	: potable water
Operating pressure at grade	: 0.8 barg (min)
Operating temperature	: Ambient
Design pressure	: 5.0 barg
Design temperature	: 40 °C

#### Raw water

Source	: from river
Type	: raw water
Operating pressure at grade	: 0.8 barg (min)
Operating temperature	: Ambient
Design pressure	: 5.0 barg
Design temperature	: Ambient

#### Plant water

Source	: from storage tank of raw water
Type	: raw water after filtration
Operating pressure at grade	: 3.5 barg
Operating temperature	: Ambient
Design pressure	: 9.0 barg
Design temperature	: 40°C

#### Demineralized water

Type	: treated water (mixed bed demineralization)
Operating pressure at grade	: 5.0 barg
Operating temperature	: Ambient
Design pressure	: 9.5 barg
Design temperature	: 40 °C

## Characteristics:

- pH		6.5÷7.0
- Total dissolved solids	mg/kg	0.1 max
- Conductance at 25°C	μS	0.15 max
- Iron	mg/kg as Fe	0.01 max
- Free CO <sub>2</sub>	mg/kg as CO <sub>2</sub>	0.01 max
- Silica	mg/kg as SiO <sub>2</sub>	0.015 max

 3.6.3 Steam, Steam Condensate and BFW
Steam (IGCC alternatives)

These conditions refer to the Process Units. Inside Power Island the steam levels are different, even if there are interconnected to the Process Units.

**Table 3.1** – Process Units steam conditions.

	Pressure, barg			Temperature, °C	
	Max	Min	Design	Norm	Design
High Pressure <b>(HP)</b> Nominal Pressure: 160 barg	170	160	187	353	370
Medium High Pressure <b>(MHP)</b> Nominal Pressure: 80 barg (1)	85	80	93	300	330
Medium Pressure <b>(MP)</b> Nominal Pressure: 40 barg	43	40	47	256	270
Low Pressure <b>(LP)</b> Nominal Pressure: 6.5 barg	8.0	6.5	12	175	250
Very Low Pressure <b>(VLP)</b> Nominal Pressure: 3.2 barg	4.0	3.2	12	152	250

Notes: (1) Only for Cases 6 – 7 (see paragraph 4.0 for definition of the alternatives)

In the table above:

- The maximum value indicates the steam generation pressure to be adopted for steam generators in the Process Units.
- The minimum pressure indicates the steam pressure available for steam users.
- The normal Temperature indicates the *saturation T* corresponding to the Max Pressure indicated.

Steam (Conventional Power Station alternatives)

The only utility steam used inside the Power Plants is VLP steam, whose characteristics are the same of those shown in table 3.1.

Steam Condensate from process, utility and off site units

Steam condensate will be flashed within process units whenever possible to recover steam and piped back to the condensate collection header.

The condensate collection header shall have the following characteristics:

Operating pressure for other Units B.L.	: 1	barg
Operating temperature	: 94	°C
Design pressure	: 12.0	barg
Design temperature	: 250	°C

Boiler Feed Water (IGCC alternatives)

The main characteristics of the Boiler Feed Water at Units B.L. is shown in the following table.

**Table 3.2 – Boiler Feed Water at units B.L.**

	<b>Pressure</b>	<b>Temperature</b>
	<b>Barg</b>	<b>°C</b>
	<b>Normal</b>	<b>Normal</b>
Boiler Feed Water, Very Low Pressure <b>(BWV)</b>	15	120
Boiler Feed Water, Low Pressure <b>(BWL)</b>	15	160
Boiler Feed Water, Medium Pressure <b>(BWM)</b>	60	160
Boiler Feed Water, High Pressure <b>(BWH)</b>	195	160

### 3.6.4 Instrument and Plant Air

#### Instrument air

Operating pressure		
- normal	: 7.0	barg
- minimum	: 5.0	barg
Operating temperature	: 40	°C (max)
Design pressure	: 10.0	barg
Design temperature	: 60	°C
Dew point @ 7 barg	: -30	°C

#### Plant air

Operating pressure	: 7.0	barg
Operating temperature	: 40	°C (max)
Design pressure	: 10.0	barg
Design temperature	: 60	°C

### 3.6.5 Nitrogen (*CASES 5–6, see para. 4.0 for description of the alternatives*)

#### Low Pressure Nitrogen

Supply pressure	: 6.5	barg
Supply temperature	: 15	°C min
Design pressure	: 11.5	barg
Design temperature	: 70	°C
Min Nitrogen content	: 99.9	% vol.

#### Medium Pressure Nitrogen (Syngas dilution)

Supply pressure	: 30	barg
Supply temperature	: 210	°C
Design pressure	: 35	barg
Design temperature	: 240	°C
Min Nitrogen content	: 98	% vol.

#### Medium Pressure Nitrogen (GT injection)

Supply pressure	: 26	barg
Supply temperature	: 213	°C
Design pressure	: 35	barg
Design temperature	: 240	°C
Min Nitrogen content	: 98	% vol.

High Pressure Nitrogen

Supply pressure	:	80 barg (Case 5) 70 barg (Case 6)
Supply temperature	:	15°C (Case 5), 80° C (Case 6)
Design pressure	:	90 barg (Case 5) 80 barg (Case 6)
Design temperature	:	45°C (Case 5), 110° C (Case 6)
Min Nitrogen content	:	99.9 % vol.

3.6.6 Natural Gas

Characteristics of Natural Gas are listed in Project Design Bases (paragraph 2.0).

High Pressure

Type	:	natural gas.
Service	:	Gas turbines start-up and back-up fuel.
Operating pressure at Users	:	27.0 barg
Operating temperature at Users	:	30°C above natural gas dew point
Design pressure	:	33.0 barg
Design temperature	:	70 °C

Low Pressure

Type	:	natural gas.
Service	:	Boiler start-up and distribution.
Operating pressure at Users	:	3.5 barg
Operating temperature at Users	:	30°C above natural gas dew point
Design pressure	:	6.0 barg
Design temperature	:	60 °C



### 3.6.7 Oxygen (for IGCC and PC-Oxycombustion alternatives)

The Oxygen for the gasification unit has the following characteristics:

Supply pressure	: (*)
Supply temperature	: (*)
Design pressure	: (*)
Design temperature	: (*)

(\*) Depending on the process alternative considered (see Section D – Basic information for each alternative).

Purity	: 95.0 % mol. O <sub>2</sub> min
	3.0 % mol Ar
	2.0 % mol N <sub>2</sub>
H <sub>2</sub> O content	: 1.0 ppm max
CO <sub>2</sub> content	: 1.0 ppm max
HC as CH <sub>4</sub> (number of times the content in ambient air)	: 5 max

### 3.6.8 Electrical System Distribution

The voltage levels foreseen inside the plant area are as follows:

	<b>Voltage level (V)</b>	<b>Electric Wire</b>	<b>Frequency (Hz)</b>	<b>Fault current duty (kA)</b>
Primary distribution (1)	66000 ± 5%	3	50 ± 0.2%	31.5 kA
Primary distribution (2)	30000 ± 5%	3	50 ± 0.2%	31.5 kA
MV distribution and utilization	11000 ± 5%	3	50 ± 0.2%	31.5 kA
	6000 ± 5%	3	50 ± 0.2%	25 kA
Emergency power source	6000 ± 5%	3	50 ± 0.2%	31.5 kA
LV distribution and utilization	400/230V±5%	3+N	50 ± 0.2%	50 kA
Uninterruptible power supply	230 ± 1% (from UPS)	2	50 ± 0.2%	12.5 kA
DC control services	110 + 10%-15%	2	-	-
DC power services	220 + 10%-15%	2	-	-

Notes: (1) for IGCC Plant

(2) for Coal Power Plants other than IGCCs.

### **3.7 Plant Life**

The Plants are designed for a 25 years life, with the following considerations:

- Design life of vessels, equipment, component of equipment will be as follows:
  - 25 years for pressure containing parts;
  - 5 years for replaceable parts internal to static equipment.
- Design life of piping will be 10 years.
- For rotating machinery a service life of 25 years is to be assumed as a design criterion, taking into account that cannot be applicable to all parts of machinery for which replacement is recommended by the manufacturer during the operating life of the unit, as well as to small machinery, machines on special or corrosive/erosive service, some auxiliaries and mechanical equipment other than rotating machinery.

### **3.8 Codes and standards**

The project shall be in accordance to the International and EU Standard Codes.

#### **4.0 Alternative Designs of Power Generation**

Several power plants alternatives have been developed in the Study.

The contemplated alternatives attempt to compare the following key process aspects:

- Different coal power plant technologies for combustion of a lignite coal;
- Post-combustion and pre-combustion CO<sub>2</sub> capture in alternatives coal power plants;
- Different CO<sub>2</sub> capture technologies (MEA, MDEA scrubbing or gas liquefaction).
- Performance and cost penalties for the capture of CO<sub>2</sub>, to reduce environmental impact (only on the most promising technology amongst the investigated alternatives).

The following alternatives are investigated:

- CASE 1 Ultra Super Critical Pulverized Coal (USC-PC) Boiler with post-combustion CO<sub>2</sub> capture (using MEA as solvent washing).
- CASE 2 USC - PC-Oxycombustion Boiler, with post combustion CO<sub>2</sub> capture by means of Gas liquefaction.
- CASE 3 Foster Wheeler Circulating Fluidized Bed (CFB) Boiler, with post-combustion CO<sub>2</sub> capture (using MEA as solvent washing).
- CASE 4 Foster Wheeler Pressurized Circulating Fluidized Bed (PCFB) Boiler, with post-combustion CO<sub>2</sub> capture (using MDEA as solvent washing).
- CASE 5 Future Energy gasification technology, sour shift (2 stages) and CO<sub>2</sub> capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S)
- CASE 6 Shell gasification technology, sour shift (2 stages) and CO<sub>2</sub> capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S)
- CASE 7 Foster Wheeler Air gasification technology, sour shift (2 stages) and CO<sub>2</sub> capture (MDEA scrubbing with combined capture of CO<sub>2</sub> and H<sub>2</sub>S)

The Future Energy gasification technology is based on a dry feed gasifier, with product gas cooling by water quench. The gasifier consists of an outside pressure wall and an inside cooling screen cooled by pressurized water to protect the outside wall against chemical and thermal attacks.

The hot raw synthesis gas and the liquid slag leave the gasifier reaction chamber and flow in parallel vertically downward and discharge directly into the quench section - where the raw gas is cooled down to approximately 220°C by injection of water. Slag produced is granulated in the water bath in the bottom of the Quench system.

The raw gas is saturated with steam (approx. 60%). This water becomes gas condensate in the following cooling steps of the syngas treatment and it will be recycled back as quench water.

The Shell gasification technology is based on a dry feed gasifier, with product gas cooling in a heat recovery boiler. The gasifier consists of a pressure vessel with a gasification chamber inside. Circulating water through the membrane wall to generate saturated steam controls the inner gasifier wall temperature. The membrane wall encloses the gasification zone from which two outlets are provided. One opening at the bottom of the gasifier is used for the removal of slag. The other outlet allows hot raw gas and fly slag to exit from the top of the gasifier.

The hot raw product gas leaving the gasification zone is quenched with cooled, recycled product gas to convert any entrained molten slag to a hardened solid material, prior to entering the syngas cooler. The syngas cooler recovers high-level heat from the quenched raw gas by generating steam. The syngas cooler is water tube type.

The Foster Wheeler gasification technology is based in a CFB gasifier, with air as partial oxidation agent. The gasifier is basically a pressurized CFB unit, completely refractory lined, with no heat transfer surfaces.

The hot syngas leaving the CFB Gasifier is cooled from 930°C to approximately 390°C before filtration. The syngas cooler transfers heat to the steam cycle generating MHP steam. The industry trend for these coolers is a fire tube design, with gas flowing inside the tubes and steam or water outside, on the shell side.

Table B.4.1 provides a summary of the 7 cases with some of the most significant performance data of each alternative. From the comparison of these alternatives, the most attractive technology is selected (see section F) and a more detailed assessment of performances and costs are made for both for the case with and without CO<sub>2</sub> capture (see section G).

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS**
**Section B General Information**

Rev. no.: Final

Date: November 2005

Sheet: 25 of 25

**Table B.4.1 Most significant performance data for all the process alternatives**

<b>ALTERNATIVE</b>		<b>Case 1 USC-PC- Boiler</b>	<b>Case 2 USC-PC- Oxy Combustion</b>	<b>Case 3 FW CFB Boiler</b>	<b>Case 4 FW PCFB Boiler</b>	<b>Case 5 Future Energy Gasifier</b>	<b>Case 6 Shell Gasifier</b>	<b>Case 7 FW Gasifier</b>
<b>Coal Flow rate</b>	<b>t/h</b>	734.0	677.6	592.9	727.0	653.3	624.2	691.0
<b>Net Electric Power Output</b>	<b>MWe</b>	761.0	741.3	614.4	688.4	665.2	628.8	686.6
<b>Gross Electrical Efficiency</b>	<b>%</b>	43.5	52.6	44.1	38.5	47.2	47.7	44.7
<b>Net Electrical Efficiency</b>	<b>%</b>	35.5	37.5	35.5	32.5	34.7	34.5	34.1
<b>Acid Gas Removal Technology</b>		MEA Scrubbing	Gas Liquefaction	MEA Scrubbing	MDEA Scrubbing	MDEA Scrubbing (1)	MDEA Scrubbing (1)	MDEA Scrubbing (1)
<b>CO<sub>2</sub> capture efficiency</b>	<b>%</b>	85.0	93.0	85.0	85.0	85.8	85.2	82.9

 Note: (1): Combined removal of CO<sub>2</sub> and H<sub>2</sub>S.

**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 32

**Description of the Major Process Blocks**

**Section C**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS  
 DOCUMENT NAME : DESCRIPTION OF THE MAJOR BLOCKS COMMON TO THE POWER  
 GENERATION ALTERNATIVES

ISSUED BY : G.L. FARINA  
 CHECKED BY : G.L. FARINA  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

**SECTION C**

**DESCRIPTION OF THE MAJOR PROCESS BLOCKS COMMON TO THE  
POWER GENERATION ALTERNATIVES**

**INDEX**

**SECTION C**

- 1.0 COAL HANDLING AND STORAGE
- 2.0 DRYING OF LOW RANK COAL/LIGNITE
- 3.0 ASH HANDLING
- 4.0 FLUE GAS DENITRIFICATION (De-NO<sub>x</sub>)
- 5.0 FLUE GAS DESULPHURIZATION (FGD)
- 6.0 MERCURY AND HEAVY METALS REMOVAL
- 7.0 CO<sub>2</sub> POSTCOMBUSTION CAPTURE
- 8.0 CO<sub>2</sub> PRECOMBUSTION CAPTURE
- 9.0 CO<sub>2</sub> COMPRESSION AND DRYING
- 10.0 UTILITY AND OFFSITE UNITS

Bibliography

## **1.0 COAL HANDLING AND STORAGE**

The expected net power output from the various power generation alternatives considered in Section D is 750 MW approximately. Depending on the overall efficiency of the generation scheme this net power output corresponds to a supply of low rank coal (lignite) in the range of 800-850 t/h. The receiving, storage and handling facilities of this coal flowrate are very large and require an extended plot area.

According to the study bases of design the plant is assumed to be located close to a lignite mine to permit delivery to site by belt conveyors or alternatively by a dedicated railway.

At the plant site the coal is stored in dome, providing, a minimum of 5 days storage, which is equivalent to 100,000 ton of coal, which would require a land area of approx. 15,000 m<sup>2</sup>.

The coal from the dome is moved by enclosed belt conveyors to 4 elevated feed hoppers each sized for a capacity equivalent to 2 hours. Before the entrance to the feed hoppers a magnetic separator is provided to remove tramp iron.

Coal is discharged from the feed hoppers, at controlled rate, and transported by belt feeders to 4 parallel crushers, each sized for 50% of the full capacity. The crushers are designed to break down big lumps and deliver a coal lignite with lump size not exceeding 5 cm.

Coal lignite from the crushes is transferred by enclosed belt conveyors to 4 feed silos close to the process area, where the coal lignite size is further reduced by 4 mills to the level required by the downstream power generation plant. This can be a powder, in the 50-150 micron range, for the technologies requiring a pulverized feed, or a feed or, alternatively, a coal crushed to a maximum size of 2-3 cm for fluid bed technologies.

Enclosed belt conveyors, storage hoppers and silos, flow control feeders and other equipment handling coal lignite are potential source of air pollution due to dispersion of fine powder. To control the plant environment all this equipment are connected to a bag filters and exhaust fans that permit the capture of any coal powder generated in the coal handling area.



## 2.0 DRYING OF LOW RANK COAL-LIGNITE

The efficiency of a power generation plant can be significantly enhanced if the moisture in the feed coal lignite is reduced. But, while there are a lot of studies on low-rank coal drying, there is very limited experience of lignite drying at the level of pilot or demonstration plant.

In spite of the fact that today, there is not yet a commercially proven lignite drying technology, such a process is expected to become shortly available, as the number of users of low rank coal increases worldwide.

It is proposed in the present study to advantageously utilise some low temperature energy available in the plant at various locations, to dry and improve the quality of coal. However only a low temperature drying of coal lignite is attempted. Because when the drying temperature is increased the volatiles from the coal are liberated. As long as the coal temperature is less than 120 °C the part of volatiles that leaves the coal is insignificant. First CO<sub>2</sub> leaves the coal at more than 120 °C, later at about 180°C coal temperature H<sub>2</sub>, CO and CH<sub>4</sub>. Volatiles in coal lignite are very useful and necessary to preserve the good ignition and combustion characteristics. Once the volatiles are removed, the characteristics of coal are significantly changed, with a net loss of the energy content. Hence, in this study, we propose a low temperature drying, controlled in order to reduce moisture as much as possible, but without losing the volatile content. This means that the moisture content of the design lignite feed is lowered from 50.7% down to 30-32% for the USC PC, CFB boiler and Oxycombustion boiler alternatives, and 5-10% for the IGCC alternatives, except FW Gasifier, to allow the pneumatic transportation of the coal. For the IGCC alternative employing FW Gasifier the moisture content is lowered down to 25%. This will achieve the following advantages:

- increased overall efficiency by a few percent point;
- reduced flow of coal to the mills, by about 30%, directly reducing the power requirement of the mills by about 30%;
- reduction in the flue gas flowrate by about 6%. This has advantages in reducing the power consumption in the flue gas line and reducing the sizing of the FGD and CO<sub>2</sub> absorption plants.

The process alternatives to dry coal lignite are:

- Direct drying with flue gases at the exit of the plant.
- Indirect drying.

Drying by a direct contact of lignite with the flue gas would envisage a bubbling bed of coal, through which the flue gas is pushed. The expected pressure drop of such a system would be very high and consume substantial energy.

Further, a significant entrainment of coal fines into the flue gas should be expected. Few studies have investigated such direct contact drying, because this route appears to be costly and difficult to keep under strict control the drying temperature to prevent loss of volatiles.

For these reasons the “indirect” drying of the low rank coal is the most promising technology.

In USA EPRI is sponsoring a research and development program to dry lignite for the Great River coal program in North Dakota. The process involves the use of a bubbling fluidised bed of lignite. Heat energy to evaporate moisture is supplied by circulating hot water, which preheat air, fed to the bubbling bed and also supply additional heat to the bed by a coil submerged in the bed (see Fig. 2.1). The hot water is heated to 85°C maximum to prevent loss of volatiles contained in the lignite. Hot air carries away part of the coal moisture and, before discharge to the atmosphere, is passed through a bag filter to stop entrained coal powder, which is recycled back to the dried lignite product.

This type of drier is used for all the alternatives of the study, heating the hot water to the maximum temperature of 85°C and feeding air to the bubbling bed at 65°C maximum. Several sources of low temperature heat exist in the plant, depending on the process configuration to heat the circulating water. For the boiler options f.i. the heat recovery is performed on the cold flue gas side and interstage coolers of the CO<sub>2</sub> compressor. For the IGCC alternatives, the heat recovery is performed by using different sources: coolers of the syngas cooling section and N<sub>2</sub> compression section, interstage coolers of the CO<sub>2</sub> compressors, VLP steam generated in the syngas cooling section.

The Great River Energy is in the process of designing a demonstration fluidised bed drier of the locally produced low rank coal.

In parallel, in Germany, RWE is supporting a technology demonstration program to dry Germany lignites. Pilot scale plant of 30 t/h capacity, is in operation; a larger demonstration unit, 240 t/h, is expected to operate in the next 2-3 years, with a target to have this technology available for the design of large new power plants for the year 2008.

This process, known as WTA, is also based on a bubbling bed of fine grain lignite, fluidised by steam. The vapour living the fluidised bed of lignite is cleaned and compressed according to the heat pump principle to such an extent that its thermal energy can be used to heat the lignite bed (see Fig. 2.2).

Shell has just presented at the Gasification Technologies Conference (San Francisco, October 9-12, 2005) this new system based on a steam-fluidised

**Description of the Major Process Blocks**

**Section C**

bed, which uses a vapour electrostatic precipitator in the circulation of the vapour from/to the drier and a dry lignite cooler before going to the downstream storage.

In parallel to the above-described fluidised bed drying technologies, an alternative route, based on mechanical/thermal dewatering, is under development in Germany to reduce the lignite coal water content. Here the coal is first heated; then the water is expelled by means of a press or centrifuge. This process is tested at Rheinbraun, but appears to be not as close to commercialization as the fluid bed techniques.

Figure 2.1- Lignite Indirect Drying





Figure 2.2 - WTA Lignite Drying



### 3.0 ASH HANDLING

Power generation from coal involves the handling of two types of ash:

- Bottom ash
- Fly ash

Bottom ash is produced during the process of total or partial combustion and is the result of coal ash melting and subsequent cooling. Consequently it is a coarse product of lumps of various sizes, and is collected at the bottom of the combustion furnace or gasifier vessel.

Fly ash is also derived from the melting and cooling of the ash contained in the coal, but, due to the micron and submicron particles size, is entrained out of the combustion or gasification chamber by the flue gas or syngas and collected in downstream equipment: hoppers, electrostatic precipitators or bag filters.

Bottom ash is generally disposed in a landfill while fly ash is used in the cement industry as a valuable cement formulation component.

The bottom ash is crushed by a grinder to reduce the lump size, thus making handling and transportation easier.

The fly ash is discharged from the collecting hoppers by star valves into a dense phase, pneumatic transport, which carries the fly ash to storage silos. From the silos the fly ash is loaded by gravity to trucks for transportation. Cyclones and exhaust filter bags are used to prevent air contamination.

**4.0 FLUE GAS DENITRIFICATION (DeNO<sub>x</sub>)**

The combustion of fossil fuels produces nitrogen oxide (NO) and dioxide (NO<sub>2</sub>), collectively called NO<sub>x</sub>. The monoxide (NO) is the predominant specie. Selective catalytic reduction (SCR) is a process that catalytically reduces NO<sub>x</sub> to N<sub>2</sub> in presence of NH<sub>3</sub>.

An alternative NO<sub>x</sub> control route is proposed by BOC, LoTox, which is based on addition of ozone to the flue gas, to oxidize NO and NO<sub>2</sub> to higher nitrogen oxides (N<sub>2</sub>O<sub>3</sub> and N<sub>2</sub>O<sub>5</sub>). These are water-soluble and can be easily captured by a caustic solution to form nitrate and nitrite salts. The atmospheric oxygen is converted to ozone in an alternative generator, supplied as a package by BOC.

SCR is today the dominant technology for the control of NO<sub>x</sub> in the power generation industry.

An SCR system consists mainly of an ammonia storage, evaporation and injection by mean of a distribution grid followed by the SCR catalytic reactor schematically shown in Figure 4.1.




Figure 4.1 SCR System

The honeycomb catalyst cells are contained in square catalytic baskets. The ceramic cells support the active catalyst components, V<sub>2</sub>O<sub>5</sub>, Tl<sub>2</sub>O<sub>2</sub> and WO<sub>3</sub>. V<sub>2</sub>O<sub>5</sub> is the most active but promotes also SO<sub>2</sub> oxidation to SO<sub>3</sub> and may be the cause of catalyst sintering at high temperature. Therefore the catalyst formulation is different for different applications. Cell size varies from 4 to 8

mm. Smaller cells are used in clean gas service; larger cells in dirty gas service.

In absence of SO<sub>2</sub> SCR can operate at low temperature, as low as 200°C. When SO<sub>2</sub> is present in the flue gas also SO<sub>3</sub> is present, in small quantities, but sufficient to react with excess NH<sub>3</sub> to form ammonium sulphate and bisulfate. The first is powdery but the second is sticky and can plug catalyst and equipment. The lower the temperature the higher is the probability of sulphate/bisulphate formation. For this reason SCR in presence of SO<sub>2</sub>/SO<sub>3</sub> must operate at high temperature: minimum 320°C if SO<sub>3</sub> is less than 5 ppm; higher temperatures, 350-400°C for higher SO<sub>3</sub> concentration. To obtain these temperatures the SCR is normally located between the economizer and the air preheater (Figure 4.2).

In clean gas service the flue gas flow can be horizontal or vertical. In dirty gas service the flow is vertical downward and assisted by soot blowers between the catalyst layers to keep the catalyst clean.




Figure 4.2 SCR in conventional boilers

As shown in Figure 4.2 the catalyst temperature is kept under control at reduced capacities by bypassing a portion of the flue gas around the last economizer bank.

Two types of ammonia injection are in use. The first uses liquid ammonia, which is vaporized then mixed with air and fed to the distribution grid, inside the flue gas duct. The second system uses aqueous ammonia (25-30% NH<sub>3</sub>), which is mixed with air heated up to 300-450°C in a dedicated coil in the boiler duct. The vaporized mixture is fed to the distribution grid. This second

system is generally preferred because of the easier and safer handling and transportation of aqueous ammonia.

SCR systems are operated with a careful management of the catalyst and a close control of the NH<sub>3</sub> slip (excess NH<sub>3</sub>). At start-up only 50-70% of the catalyst is loaded and NH<sub>3</sub> slip is kept at minimum (1 ppm) to meet the required NO<sub>x</sub>. With the aging of the catalyst the NH<sub>3</sub> slip is increased progressively up to a maximum, usually 5-10 ppm. At this point, normally 5-7 years after start-up, the remaining portion of the fresh catalyst is loaded and the NH<sub>3</sub> slip can go back to 1-2 ppm and then progressively increased to compensate further catalyst aging until the end of catalyst life (normally 10 years).

In order to provide a reference for the power generation alternatives described in Section D, the performance and cost of a DeNO<sub>x</sub> system sized for a coal fired power generation with the following characteristics are given:

Bituminous coal fired	:	210 t/h
Net power output	:	660 MW
Flue gas flowrate	:	2,200,000 Nm <sup>3</sup> /h
Flue gas NO <sub>x</sub> content	:	300 ppmv (615 mg/Nm <sup>3</sup> 6% O <sub>2</sub> – dry)

NO<sub>x</sub> content of the exit flue gas is 20 ppmv (40 mg/Nm<sup>3</sup>)@ 6% O<sub>2</sub> – dry)

The investment cost of the DeNO<sub>x</sub> system is 21 million US\$.

The consumption of NH<sub>3</sub> (100%) is 400 kg/h.

The consumption of utilities is negligible.

When the plant includes downstream a CO<sub>2</sub> amine scrubbing, the residual NO<sub>x</sub> should be as low as possible to reduce the amine consumption. The 20 ppmv level is a maximum not to be exceeded, otherwise the cost of the amine loss would be too high.



## 5.0 FLUE GAS DESULPHURIZATION (FGD)

Over the last 40 years there have been several significant advancements in the design and performance of FGD systems.

Early demonstrations in USA, Japan and Europe took place in the 1960s. By the mid-1970s the technology was already wide spread in the three areas, but was plagued by a number of problems: relatively high capital and operating costs, poor reliability, scaling and fouling of equipment.

Two alternative FGD systems were proposed:

- wet FGD
- dry FGD

Wet FGD employs to capture SO<sub>2</sub>, a scrubbing process, based on a water slurry or a water solution of an alkaline reagents: lime, limestone, sodium carbonate, magnesium oxide, ammonia, dual alkali. Some proposed the use of seawater, others, such as Wellman-Lord developed a regenerable wet process based on sodium sulfite. Most of these reagents have been largely abandoned in favour of the less costly lime-limestone.

The dry FGD involves the spraying of finely atomized droplets of hydrated lime slurry in the flue gas stream, in an optimum temperature window, 150-180°C, which evaporates the water and maximize the utilization of the reagent. An alternative version of the dry FGD involves the injection of a dry sorbent powder, lime, limestone or sodium carbonate. In both cases, downstream the injection point, a bag filter captures the solid particles. The solid particle layer on the bag surface still contains some unreacted reagents, thus, providing an effective second stage of contact between the alkali and the residual SO<sub>2</sub> in the flue gas.

Wet FGD has become the dominant technology, as demonstrated by the following Table 5.1, which summarizes a database developed by the International Energy Agency, Coal Research Center in London. This Table 5.1 gives the total MW capacity in service in 1998 with FGD, divided in three categories of FGD technologies.

Table 5.1  
Total MW capacity in service with FGD in 1998

<b>Technology</b>	<b>United States</b>	<b>Abroad</b>	<b>Word Total</b>
Wet	82,859	116,374	199,233
Dry	14,836	11,008	25,394
Other	2,798	2,059	4,857
Total FGD	100,043	129,441	229,484

The following Table 5.2 gives the MW capacity in service in 1998 with wet FGD, divided by different reagents. The preference for limestone is evident from these data.

Table 5.2  
Breakdown of MW capacity in service with wet FGD in 1998

<b>Technology</b>	<b>United States</b>	<b>Abroad</b>	<b>Word Total</b>
Limestone	55,540	107,790	163,330
Lime	14,196	6,976	21,172
Dolomitic Lime	10,292	50	10,342
Sodium Carbonate	2,756	75	2,831
Seawater	75	1050	1,125
Other	-	433	433
Total FGD	82,856	116,374	199,233

Wet FGD, based on limestone-lime, is today the dominant technology. This position is the result of a number of advancements accomplished in the past 30 years. These advancements are described in the following paragraphs.

**a. Forced Oxidation**

Early calcium-based systems experienced severe scaling-fouling problems, causing an increase of capital cost (spare equipment) and maintenance cost. To resolve this problem two processes were proposed: inhibited oxidation and forced oxidation. The first attempted to reduce conversion of sulfite to sulphate, with the addition of a reducing agents (thiosulphate or sulphur). The second achieved full oxidation of SO<sub>2</sub> to SO<sub>3</sub> with the addition of air. Both processes reduced or eliminated fouling but the forced oxidation became the preferred route because the solid by-product, gypsum, was a

saleable product rather than the throwaway sulfite-sulphate mixture made by the inhibited process.

**b. Organic acids**

The addition of organic acids, adipic acid, formic acid, to the slurry was found to be an effective way to improve mass transfer and achieve higher SO<sub>2</sub> removal efficiency (95-99%) at a lower liquid to gas ratio.

**c. Contacting Trays**

Special dual flow and sieve trays have been developed for the absorber, to improve gas-liquid contact and mass transfer.

**d. Design and layout of spray nozzles and use of wall rings**

Adjusting the configuration and positioning of the spray nozzles in the absorber improved the capture of SO<sub>2</sub>. Further the use of wall rings inside the absorber redirected the gas flow along the walls toward the middle of the tower, where the spray density is higher, and redistributed the liquid along the walls back into the spray zone.

**e. Mist Eliminators**

Design of mist eliminators was improved to permit mist collection efficiency at high gas velocity.

**f. Computational fluid dynamic (CFD)**

CFD was a key tool to improve the design of FGD systems. This modelling technique permitted a better knowledge of the performance of a counter current open spray tower, which produced the following benefits:

- higher flue gas velocity; in excess of 5 m/s, vs. the 2-3 m/s of the early designs;
- Smaller absorbers;
- Single module for large power generation capacity.

**g. Hydroclones**

The gypsum-limestone slurry, leaving the absorber, in the early wet FGD systems was treated in very large thickeners to separate a solid rich mud from clean water, recycled back to the absorber. In the more recent designs the thickeners have been substituted by the more effective and less costly hydroclones. The hydroclones rely on centrifugal forces to separate solids from water; further they achieve a better separation between the larger gypsum particles, ending in the underflow, and the smaller limestone particles, ending in the overflow recycled back to the absorber. The final result is a superior gypsum quality, less contaminated with unreacted limestone, and a better utilization of limestone reagent, recycled back to the absorber.

An example of an advanced FGD design, incorporating all the improvements described above, is the single module absorber installed in the 890 MW Tampa Electric Co. Big Band Station, firing a 3.1% sulphur fuel. The main characteristics of this absorber are:

- flue gas flowrate : 4,800,000 m<sup>3</sup>/h
- gas velocity : 5 m/s
- absorber diameter : 18.3 m
- absorber height : 40 m
- SO<sub>2</sub> removal efficiency: greater than 95%

The investment cost of a today, most advanced large scale FGD design is reported to fall in the range 100-150 US\$ per kW, a dramatic drop compared to the 250-300\$ per kW of FGD designs of 10-15 years ago.

In order to provide a reference for the power generation alternatives described in Section D, we give, in the following paragraphs, the performance and cost of an FGD system sized for a coal fired power generation with the following characteristics:

Bituminous coal fired	210 t/h
Net power output	660 MW
Overall efficiency	44 %
Flue gas flowrate	2,200,000 Nm <sup>3</sup> /h
SO <sub>2</sub> flue gas content	1000 mg/Nm <sup>3</sup> (6% O <sub>2</sub> – dry)
SO <sub>3</sub> flue gas content	10 mg/Nm <sup>3</sup> (6% O <sub>2</sub> – dry)
Flue gas temp. ex. ESP	130 °C

The scrubbed flue gas SO<sub>2</sub> content is 100 mg/Nm<sup>3</sup> (6% O<sub>2</sub> – dry), which corresponds to SO<sub>2</sub> removal efficiency equal to 90%.

**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 16 of 32

**Description of the Major Process Blocks**

**Section C**

The limestone specification is:

CaCO <sub>3</sub>	% wt	95.00 min
MgO	% wt	0.15 max
Inerts	% wt	4.85 max
Average lump size		10 cm

Gypsum (calcium sulphate de-hydrate) specification, saleable as house building material, is:


CaSO <sub>4</sub> x 2H <sub>2</sub> O	% wt dry	95 min
CaSO <sub>3</sub>	% wt dry	0.25 max
CaCO <sub>3</sub>	% wt dry	1.5 max
Cl <sup>-</sup>	ppm (dry)	100 max
Mg <sup>++</sup>	ppm (dry)	100 max
Na <sup>+</sup>	ppm (dry)	600 max
Colour		white
Humidity	% wt	10 max

The wet FGD process, shown in the attached flowsheet of Fig. 5.1 is a typical configuration of a modern, large capacity module, with minimum use of spare or stand-by equipment. To overcome pressure drops a blower is installed at the unit entrance, followed by a regenerative heat exchanger (Liungstroem type) to reheat the flue gas going to the stack. This reheat is however optional. Optional is also the downstream water prescrubber, used to reduce particulates, alogens, saturate and cool the flue gas.

The limestone scrubber is a countercurrent, open spray tower, possibly with one or two contact trays. Six layers of spray nozzles are located at the top, achieving a total liquid to gas ratio of 15÷20 l per Nm<sup>3</sup> of flue gas, equivalent to a total liquid flow of approximately 40000 m<sup>3</sup>/h.

The mist separator at the top is a lamella shape bundle, periodically flushed with water. The bottom sump of the tower is divided into an oxidation zone, receiving air from a blower, and a crystallization zone to grow the size of gypsum crystals.

The overall reaction taking place is:



Every ton of SO<sub>2</sub> removed generates 0.7 ton of CO<sub>2</sub>.

The material of construction of the scrubbing tower is carbon steel lined with rubber or special alloy C-276.

The scrubber diameter is 13 m which corresponds to a flue gas, velocity inside the tower equal to 5 m/s.

The scrubber height is 40 m.

The limestone from the stockpile is crushed and milled to a 50 micron size and dispersed in a water slurry, continuously pumped to the scrubber.

The scrubber bottom slurry is dewatered in hydroclones. The overflow is recycled back to the scrubber. The underflow is dewatered in a vacuum belt filter or, alternatively, in centrifuges.

A fraction of the hydroclones overflow is discharged to remove from the circulating system dissolved salts (chlorides, fluorides, etc.) which, otherwise, would continuously grow in concentration. This blowdown, before discharge to sewer, is treated with soda and sodium sulphide, for metal precipitation, and then passed to a thickener, pressfilter and sandfilter.

The utility and chemical consumptions of this wet FGD module including all auxiliary facilities shown in Figure 5.1, are:

Electrical power	6500	kW
Make-up industrial water	110	m <sup>3</sup> /h
Limestone	4	t/h
Gypsum product	6.8	t/h

The delivered and erected investment cost is

$$85 \times 10^6 \text{ US\$}$$

It should be noticed that, if the FGD is followed by CO<sub>2</sub> amine scrubbing, the SO<sub>2</sub> content at the FGD outlet should be as low as possible, close to 10 ppmv or 30 mg/Nm<sup>3</sup> to reduce amine consumption. This is a challenge for today available FGD technology, but probably not an impossible target for the cases considered in this study in view of the low S content of the design coal lignite.

The particulate leaving the electrostatic separator is predominantly in the submicron range, which does not result in any significant abatement by the wet limestone scrubbing. If the fuel used contains heavy metals (Ni, V, etc.) unfortunately these, after combustion, are in the submicron range, so the electrostatic precipitator and FGD do not stop them effectively. The only way to capture the heavy metals is by active carbon injection followed by bag filtration (see paragraph 6.0).

Description of the Major Process Blocks

Section C




Figure 5.1 FGD Flow Scheme

## 6.0 MERCURY AND HEAVY METALS REMOVAL

The removal of mercury and heavy metals (Ni, V, etc.) from flue gas is a relatively recent requirement to improve the environmental performance of the power generation industry.

The industrial experience accumulated so far is limited with respect to other emissions control technologies. Even legislation is not well established in many countries or still waiting for a final assessment of the status of the technologies.

EPRI has been active in this area and have participated to development and testing of the most promising technology that is based on the use of active carbon injection followed by a fabric bag filter. The best processing scheme is an electrostatic precipitation to remove 99% of particulate (micron range) followed by active carbon injection and pulse jet fabric filter, capturing the submicron particulate, where heavy metals are concentrated. Mercury is absorbed on the active carbon injected and trapped by the fabric filter. Mercury removal rates as high as 90% has been demonstrated, with the residual Hg in the flue gas in the 1÷3 µg/Nm<sup>3</sup> range. Oxidized forms of Hg are hardly captured.

The investment cost of this type of treatment facilities is not available but it falls in the range of the cost of a bag filter house, sized for the flue gas rate.



## 7.0 CO<sub>2</sub> POSTCOMBUSTION CAPTURE

The CO<sub>2</sub> capture technology is mainly used today to purify syngas used in the chemical industry (ammonia, hydrogen), to remove CO<sub>2</sub> from natural gas, to supply CO<sub>2</sub> to the merchant market (beverage, dry-ice, etc.) and for use in enhanced oil recovery (EOR). There is as yet no commercial market for its use in the power industry for the post combustion capture of CO<sub>2</sub>.

Several technologies are available for the capture of CO<sub>2</sub>:

- Solvent absorption
- Pressure swing adsorption on molecular sieve
- Selective membrane
- Cryogenic processing.

Should the power industry be obliged to remove CO<sub>2</sub> from flue gas the most likely route is the use of solvent absorption, better suited for the large capacities involved.

Several solvents can be used: physical, chemical, and intermediate. The chemical solvents (amine) seem to be the best candidate because the CO<sub>2</sub> partial pressure in the flue gas is extremely low and chemical solvents, contrary to physical solvents, are less dependent on CO<sub>2</sub> partial pressure to achieve a satisfactory solvent CO<sub>2</sub> loading (see also para. 8.0).

On the other side chemical solvents require, during solvent regeneration, more energy (steam) to break the relatively strong chemical link between CO<sub>2</sub> and the solvent. Intermediate solvents could offer an interesting compromise, lowering the consumption of regeneration steam. This is the case of sterically hindered amines, which display a weaker link with CO<sub>2</sub>, intermediate between a standard amine, like MEA and a physical solvent, like methanol.

Because of the advanced state of development of amine absorption it is likely that the first generation of CO<sub>2</sub> post combustion capture will be based on amine. However the flue gas amine scrubbing is confronted with the problem of the presence of oxygen, which causes solvent degradation and equipment corrosion. This requires incorporation in the solvent of inhibitors to counteract O<sub>2</sub> activity. The solvent formulation with special inhibitors is the basic know-how offered for licence by 3 companies:

- Fluor : formulated MEA
- ABB Lummus: formulated MEA
- MHI : formulated sterically hindered amine.

The process scheme and equipment used by these three processes are standard and do not have any novel or proprietary know-how content.

Transferring the formulated amine scrubbing process to the power industry, for CO<sub>2</sub> capture from the flue gas, involves an important scale up issue. However this is not considered to be a big problem because the equipment used permit large scale up in capacity without great risk. Two 12 m diameter absorbers and one regenerator can be designed comfortably and could accommodate a flue gas flow of 2,200,000 Nm<sup>3</sup>/h containing 12% CO<sub>2</sub>, which corresponds to a coal fired station with a net power generation of 660 MW.

The energy consumption of the amine CO<sub>2</sub> recovery is very high. Energy is consumed by flue gas blowers to overcome the system pressure drop; additionally energy is lost in making available LP steam for amine regeneration by extraction from the steam turbine. Another indirect cost, involved by the amine CO<sub>2</sub> removal, is the additional expenditure in the upstream de-NO<sub>x</sub> and FGD facilities, to meet the extremely low levels of residual NO<sub>x</sub> and SO<sub>x</sub> in the flue gas, before entering the amine scrubbing. In fact, SO<sub>x</sub> and NO<sub>x</sub> form with amine stable, non regenerable, salts, thus causing a continuous loss of solvent. For this reason the flue gas fed to amine scrubbing should not exceed the following limits:

NO <sub>x</sub>	20 ppmv	(40 mg/Nm <sup>3</sup> ) @ 6% O <sub>2</sub> vol dry
SO <sub>x</sub>	10 ppmv	(30 mg/Nm <sup>3</sup> ) @ 6% O <sub>2</sub> vol dry

The use of low NO<sub>x</sub> burners together with SCR generally permit to meet the required NO<sub>x</sub> specification, but the SO<sub>x</sub> limit (10 ppm) is a serious challenge for today FGD technology.

Another risk issue of post combustion CO<sub>2</sub> removal is the effect on amine solution of other types of impurity (alogens, metals etc.), which may be present in coal fired plant flue gas. Despite the fact that technical solutions for the removal of all these impurities can be found, the demonstration of their effectiveness is an important step stop before investing in a large capacity plant.

As a reference for the power generation alternatives of Section D a CO<sub>2</sub> postcombustion amine scrubbing is presented for a coal fired power generation with the following characteristics as above specified.

The process flowsheet of the CO<sub>2</sub> amine removal is shown in Figure 7.1.

**Description of the Major Process Blocks**

**Section C**




Fig 7.1 – CO<sub>2</sub> postcombustion capture; typical flow scheme

Treated flue gas from FGD flows to the direct quench tower where it is contacted with circulating water. The flue gas is cooled and cleaned and then flows to the MEA absorber.

In the absorber the flue gas is first contacted with a semi-lean MEA solution, in the lower section of the tower, and with a fully stripped lean solution in the upper part of the tower.

The scrubbed syngas is then washed and cooled in the tower top section with a stream of circulating water, cooled in an external heat exchanger. Reaction heat between MEA and CO<sub>2</sub> is removed by the top and bottom pump-around.

Make-up water scrubbing in the demister, at the top of the tower, captures any MEA entrainment. The flue gas leaves the top of the tower at 55°C and goes directly to the stack, which can be mounted on the absorber top.

Rich amine from the bottom is pumped to the regeneration section. After heat exchange with the stripped, hot, amine from the stripper, rich MEA flows in part to the stripper and in part to the flash drum. The flashed MEA becomes the semi-lean solution used in the absorber bottom section, while the MEA stripped in the regenerator is the lean MEA used in the absorber top section.

A slip stream of the amine circulation is sent to the reclaimer (not shown) where, after addition of sodium carbonate, the amine is distilled with the use of MP steam, to separate the heat stable salts and impurities which are pumped away for disposal.

One module made up by two absorber and one regenerator can process the flue gas of the coal fired power station indicated above. The estimated demand of

---

**IEA GHG R&D PROGRAMME**

Revision no.:

Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date:

November 2005

Sheet:

23 of 32

**Description of the Major Process Blocks****Section C**

---

LP steam for regeneration, assuming a CO<sub>2</sub> recovery equal to 85%, is 670 t/h.

Power required to drive pumps and blower is 8 MW.

The estimated consumption of MEA plus inhibitor is 1000-1200 kg/h.

## 8.0 CO<sub>2</sub> PRECOMBUSTION CAPTURE

The CO<sub>2</sub> precombustion capture is applicable to those power generation alternatives (Section D) based on coal lignite gasification. In these processes schemes, after the gasification and sour shift steps, the syngas, before going to combustion in the gas turbine, must be treated for the removal of acid gases, CO<sub>2</sub> and H<sub>2</sub>S. This syngas purification is favoured by the fact that syngas is under pressure, which enhances the capture capability of the solvent used in the acid gas removal.

Several different solvents are commercially available for acid gas removal. They can be grouped in three categories. The physical solvents, such as methanol or Selexol, capture the acid gas in accordance with the Henry's law; the chemical solvents, such as amine, capture the acid gas with a chemical reaction; the mixed solvents, such as sterically hindered amine (MDEA) display both types of capture, physical and chemical. The first group is obviously favoured by a high partial pressure of the acid gas in the syngas, while the second group is less sensitive to the acid gas partial pressure. On the other side physical solvents can be regenerated with minimum energy consumption; usually the bulk of the regeneration duty is done by a simple flashing (pressure reduction). On the contrary chemical solvents require substantial energy (LP steam) for regeneration, because the chemical link between the acid gases and the solvent must be broken. The mixed solvents display a performance that is a compromise between the first two categories.

The use, for this study, of physical solvent could be attractive because the syngas is under pressure. Further physical solvents display, in general, a better selectivity than chemical solvents, which would permit to separate H<sub>2</sub>S from CO<sub>2</sub>. This separation permits to convert H<sub>2</sub>S to sulphur (Claus process) and to obtain a pure CO<sub>2</sub> by-product.

However a selective acid gas removal, separating H<sub>2</sub>S from CO<sub>2</sub>, requires higher capital and operating costs than a combined removal of CO<sub>2</sub> and H<sub>2</sub>S. An additional important benefit of the combined removal is the elimination of the sulphur recover plant (Claus) and tail gas treatment. On the other side the combined removal produces a CO<sub>2</sub> by-product contaminated with H<sub>2</sub>S.

Whether or not it would be acceptable and advantageous to transport and store H<sub>2</sub>S along with CO<sub>2</sub> would depend on local circumstances. It may be more expensive to transport and inject CO<sub>2</sub> containing significant concentrations of H<sub>2</sub>S and if the CO<sub>2</sub> had to transport long distances, these extra costs may be greater than the reductions in capture costs. It may also be more difficult to obtain permits to transport CO<sub>2</sub>, containing H<sub>2</sub>S. On the other hand, H<sub>2</sub>S can be advantageous for CO<sub>2</sub> enhanced oil recovery (EOR), as it enhances the

**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 25 of 32

**Description of the Major Process Blocks**

**Section C**

miscibility of CO<sub>2</sub>. Some of the H<sub>2</sub>S injected with the CO<sub>2</sub> would pass through the oil output; if the oil filled is already sour, the additional oil processing costs and environmental impacts may not be significant, but if the oil field is not sour, the H<sub>2</sub>S could be a problem. Underground injection of mixtures of CO<sub>2</sub> and H<sub>2</sub>S is an established practise.

About 1 million tonnes/year of such gases, separated from natural gas, are injected in western Canada, as described in IEA GHG report PH4/15. In addition, CO<sub>2</sub> containing about 2% H<sub>2</sub>S and other sulphur compounds such as mercaptans is used for EOR at the Weyburn oil field in Canada. This gas is transported by pipeline from the Great Plains gasification plant in USA. If the CO<sub>2</sub> was to be fed into a transmission grid supplying many different users and storage reservoirs, it may be required to have a low impurity concentration, to meet the most stringent requirements of any of the users of CO<sub>2</sub>. In this circumstance, combined capture would not be acceptable.

In this study the sulphur content of the selected design feedstock, coal lignite, is rather low, 0.48% wt dry-ash free basis. As a consequence, choosing a combined acid gas removal, the CO<sub>2</sub> by-product would contain approximately 0.28% vol. H<sub>2</sub>S. This low concentration encourages the use of combined removal and consequent savings in capital and operating costs, as demonstrated in the previous (2002) study made by FW for IEA GHG R&D Programme.

The use of a combined acid gas removal makes less attractive the use of a physical solvent since selectivity is no longer a requirement. Further physical solvents require in a combined removal process a larger solvent circulation and plant investment cost than chemical solvents; although the latter require more energy for solvent regeneration.

For this study we propose the use of MDEA, a sterically hindered amine, which has been selected for several IGCC projects. MDEA requires a lower solvent circulation rate than physical solvents and the steam consumption for regeneration is lower than the consumption of a true chemical solvent as MEA.

In order to provide a reference for the power generation alternatives of Section D, based on gasification, we provide herebelow a description of a typical H<sub>2</sub>S+CO<sub>2</sub> removal plant sized for a coal based IGCC with the following characteristics:

**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 26 of 32

**Description of the Major Process Blocks**

**Section C**

Bituminous coal	270	t/h
Raw syngas (dry)	29,000	kmol/h
Syngas CO <sub>2</sub> content (dry)	60	% vol.
Syngas H <sub>2</sub> S content (dry)	0.2	% vol.
Pressure	35	bar

After scrubbing the purified syngas contains less than 3 ppm H<sub>2</sub>S because the high solvent circulation required by the simultaneous CO<sub>2</sub> removal, assures an almost total capture of H<sub>2</sub>S. The removal efficiency of CO<sub>2</sub> is 90%.

Some H<sub>2</sub> is lost with the CO<sub>2</sub> by-product, equivalent to approximately 0.2-0.3% of the net power output.

The MDEA process is described in the attached process flowsheet shown in Fig. 8.1.

The raw syngas flows to the absorber where it is washed, counter currently, with a water solution of formulated MDEA. The clean solvent is fed to the top tray of the absorber which is equipped with valve trays.

The purified syngas from the top of the absorber is routed to preheating and combustion in the gas turbines.

Rich MDEA from the absorber bottom at 35 bar is expanded to 6-7 bar in an hydraulic turbine for power recovery. The hydraulic turbine supplies power to the lean solvent booster pump. Expanded MDEA flows to a flash drum. The flashed gases join the main acid gas stream leaving the top of the regenerator.

The flashed rich solvent is preheated to about 100°C, by heat exchange with the hot regenerated MDEA, and then enters the regenerator, which is a 3 packing beds tower.

CO<sub>2</sub> and H<sub>2</sub>S are stripped by the rising steam, generated in two reboilers, at the bottom of the regenerator, using LP steam as heat source.

Stripping steam containing H<sub>2</sub>S and CO<sub>2</sub> flows from the top of the main section of the regenerator tower through a total trap out chimney tray and into the single packed bed direct contact cooling/condensing section that constitutes the upper part of the regenerator. Condensate withdrawn from the chimney tray is pumped firstly through the reflux condensers, to be cooled against cooling water down to 35°C at which temperature it is re-introduced in to the cooling/condensing section of regenerator.

The cooled CO<sub>2</sub>+H<sub>2</sub>S stream flows to battery limits for transfer to the compression unit.

NH<sub>3</sub> co-absorbed from the raw gas scrubbed in the absorber is also regenerated from the MDEA solvent in the main section and accumulates in the direct cooling/condensing section. The NH<sub>3</sub> is removed from the circulating condensate loop, in the net reflux condensate stream and is passed to the small, single packed bed ammonia stripper. Low pressure steam is injected directly into the base to strip the condensate. The stripped condensate is pumped from



**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 27 of 32

**Description of the Major Process Blocks**

**Section C**

the bottom of tower back to the main section of the MDEA regenerator as reflux.

The overhead vapour, containing ammonia, from ammonia stripper is sent back to the cooling/condensing section of the MDEA regenerator.

The hot regenerated lean MDEA solvent leaving the reboilers is cooled in the lean/rich solvent exchangers then raised in pressure to about 18 bar(a) by means of the lean solvent pumps and passed through the lean solvent coolers, where it is cooled to a maximum of 35°C by heat exchange with cooling water. A 10% slipstream of this cooled lean MDEA solvent is then drawn-off and filtered firstly in a 10 µ mechanical filter, secondly in a carbon filter, and finally in a 5 µ mechanical filter.

In addition 5% of the total lean MDEA solvent circulation of the cooled lean MDEA solvent, following the above filtration/adsorption steps is letdown in pressure and sent to solvent reclaiming package (ion exchange), for removal of the heat stable salts which can otherwise gradually build-up in concentration in the solution.

This reclaimed 5% of the lean MDEA solvent circulation is returned at low pressure to the main suction line of lean solvent pumps.

Finally the cooled lean MDEA solvent is pumped back to the absorber. The unit is also equipped with two solvent storage tanks each capable of storing the entire MDEA solvent inventory. Solvent make-up pumps, withdraw stored solvent and reintroduce it into the main solvent circuit at the suction of lean solvent pumps; a slop drum, fitted with a slop pump receives drains from MDEA containing equipment.

The expected utility consumptions of the MDEA system described above are:

LP steam	150	t/h
Electric Power	12.5	MW
Cooling Water ( $\Delta T= 12^{\circ}\text{C}$ )	5300	m <sup>3</sup> /h

The expected solvent make-up is 62 t/year

The estimated investment cost is: 48 MM US\$



**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: November 2005  
 Sheet: 28 of 32

**Description of the Major Process Blocks**

**Section C**




Figure 8.1 CO<sub>2</sub> precombustion capture flow scheme

## 9.0 CO<sub>2</sub> COMPRESSION AND DRYING

CO<sub>2</sub>, as produced in the various power generation alternatives described in Section D, must be compressed up to 110 bar g, prior to export for sequestration, as per the battery limit definition.

CO<sub>2</sub>, at these conditions is a supercritical fluid (critical point: 31°C-74 bar).

The process configuration of the CO<sub>2</sub> compression and drying depends on the alternative considered (reference to Section D, basic information for each alternative). All the equipment involved in the process are proven technology, amply demonstrated also for the capacity required by this study.

As a general description, incoming CO<sub>2</sub> at low pressure is saturated with water at temperature close to atmospheric temperature. After separation of possible liquid entrainments, the CO<sub>2</sub> stream is compressed in the first and second stage of a centrifugal compressor. Interstage cooling and water separation are provided at the outlet of the first two stages of compression. Cooling is obtained by preheating of cold condensate and/or water used for lignite drying followed by air or water trim cooling.

Compressed CO<sub>2</sub> after the 2<sup>nd</sup> stage is dried in a molecular sieve multi-bed drier. Regeneration of the drier beds is done by electric energy. Dried CO<sub>2</sub> water content is lower than 1 ppm.

CO<sub>2</sub> is then further compressed in a two stages compressor equipped with intercoolers between stages. Supercritical CO<sub>2</sub> at 74 bar is pumped by the CO<sub>2</sub> pump at 110 bar to the pipeline for delivery to the sequestration site.

The adopted centrifugal compressors operate at high speed (9600 r.p.m.), requiring a gearbox. Two 50% capacity compression lines, operating in parallel, are provided with a common multibed drier.

**10.0 UTILITY AND OFFSITE UNITS**

**10.1 Cooling water system (Unit 4100)**

The cooling water system consists of raw water in closed loop with natural draught evaporative towers. Natural draught hyperbolic towers find application because large water quantities are required from the alternative power plants of the study.

In the natural draught cooling towers, air flow through the tower is due to the chimney effect created by the difference in density between the external cold air and the internal warm and humid air. The main advantages of these towers are that there are no problems of fogging and recirculation of air, due to the elevated air discharge, and there is a reduction of windage losses. As a consequence, hyperbolic towers can be located adjacent to users, with a considerable saving in cost of piping for water distribution. Operating and maintenance cost are minimum and service life can be expected to span many years. Investment cost required by hyperbolic towers is higher than mechanical draught towers because of their elevated dimensions.

This system permits to have low water losses limited to evaporation and blowdown. The blowdown is necessary to prevent the concentration of dissolved solids from increasing to the point where it may precipitate and scale up heat exchangers and the cooling tower fill. The best way to reduce water consumption is to reduce evaporation. Evaporation depends on a large number of factors. Some are related to the air ambient conditions on which there is no control (ambient dry bulb temperature, ambient air relative humidity, barometric pressure). Others are related to towers design and operating conditions that can be controlled. In this study the evaporation losses have been calculated taking into account that they are a function of ambient air wet bulb temperature and relative humidity. For the average ambient conditions considered in the study the evaporation losses are 0.285 kg/MJ. The cooling water in closed loop is directly used to condensate steam in the steam turbine condenser of power plants, as cooling medium for the ASU, where this unit is present, and CO<sub>2</sub> capture and compression units, as well as for the cooling of the machinery.

The max allowed cooling water temperature increase is 10°C.

The number of electric driven circulation pumps provided to keep the machinery cooling water circulation depends on the specific alternative.

**10.2 Demi Water (Unit 4200)**

Raw water from the nearby river is generally used as make up water for the power plant. Raw water is also used to produce demineralized water. Raw water flows through the Demineralized Water Package that supplies make up water with adequate physical-chemical characteristics to the thermal cycle.

Multiple lines work alternatively to allow periodic resin regeneration. Adequate demi water storage is provided by means of a dedicated Demineralized Water Tank.

The demineralized water make-up supplies the make-up water to the thermal cycle, whilst the demineralized water distribution pump supplies demineralized water to the other plant users or to the plant circuits for first filling.

**10.3 Natural Gas system (Unit 4300)**

Natural gas is derived from an external network and fed to a metering station, before distribution.

From the metering station, natural gas is distributed to the boilers, gasifiers or gas turbines as start-up/back-up fuel.

In the IGCC plants, the pilots of the flare stacks also use natural gas.

**10.4 Plant and Instrument air system (Unit 4400)**

The air compression system supplies air to the plant. Air is directly taken from the ambient and compressed by means of two air compressors, one in operation and the other one in stand-by.

Compressed air is stored in an air receiver in order to guarantee the hold-up required for emergency shutdown.

Plant air is directly taken from the air receiver, whilst air from instrumentation is previously sent to the air dryer where air is dried up to ensure an adequate dew point (- 40 °C at 7 barg).

**10.5 Fire fighting system (Unit 4600)**

This unit consists of all the systems able to locate possible fire and all the equipments necessary to its extinction. The Fire Detection and Extinguishing System shall essentially include the automatic and manual fire detection facilities, as well as the detection devices with relevant alarm system. Appropriate fire detection and suppression system shall be installed in each fire hazard area according to the applicable protection requirements. The fire fighting water is supplied by water pumping station via looping piping network consisting in a perimetrical circuit fed by water pumped from cooling tower basin.

---

**IEA GHG R&D PROGRAMME**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
Date: November 2005  
Sheet: 32 of 32

**Description of the Major Process Blocks**

**Section C**

---

**Bibliography**

While many published literature site studies on drying of coal, the most recent references for such studies are listed below:

- [1] Lehigh Energy Update, Energy Research Center for Great River Energy, Aug. 2002, Vol. 20(2)
- [2] Great River Energy, "Lignite Fuel Enhancement" at Coal Creek Station, Underwood, North Dakota, USA. (546 MW Demonstration Plant)
- [3] RWE Rheinbraun, Vattenfall Europe Generation, The Development of Coal-Fired Power Plant Technology in the Light of Preventive Climate Protection, Cologne, Berlin, April, 2003
- [4] World Energy Council, Publications, Tech. Papers, 17<sup>th</sup> Congress, Extensions of Conventional Energy Resources Through Advanced Technology Employed for Lignite Mining and Utilization", Hans-W Schiffer, Rheinbraun AG, Germany.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 21  
**CASE 1**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 1 – PC BOILER WITH POST COMBUSTION CO<sub>2</sub> CAPTURE

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 21

**CASE 1**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 1.0 Case 1
- 1.1 Introduction
- 1.2 Process Description
- 1.3 Block Flow Diagrams
- 1.4 Heat and Material Balances
- 1.5 Utility Consumption
- 1.6 USC PC Overall Performance
- 1.7 Environmental Impact
- 1.8 Equipment List

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 3 of 21

**CASE 1**

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

**1.0 Case 1 PC Boiler with Postcombustion CO<sub>2</sub> Capture**

**Summary**

Pulverised Coal fuel Ultra SuperCritical (PC -USC) boiler with SCR + FGD based on wet limestone + Amine wash for CO<sub>2</sub> Absorption + CO<sub>2</sub> compression unit.

- The size of the plant considered for this configuration is based on the size required to provide nearly the same net output for all the other configurations taking into account the additional steam and power requirements of all the equipment in the plant.
- A pre-drying of the coal from a moisture level of 50.7% in as-received coal to about 32% is considered, before it is fed to the boiler plant. Drying of coal using low temperature waste heat is used for this alternative (Reference to Section C).
- The boiler technology for firing coal considered in this study is commercially available in the market. The boiler is a tower type boiler. The essential features of the firing system are the flue gas extraction from the furnace and integral fan beater mills for combined drying and grinding of coal, as well as tangential firing system with coal-specific jet burners. The flue gas line of the boiler includes a special plastic heat exchanger to maximise heat recovery between the ESP and the FGD systems, without suffering from corrosion resistance. Such heat exchangers are also commercially used for low temperature heat recovery in similar plants.
- The limits of NO<sub>x</sub> emission can be met with just the firing system of the boiler with staged combustion and low temperature at furnace exit. However, an SCR system based on ammonia injection is adopted in the boiler to reduce the NO<sub>x</sub> levels to about 20 ppmv, a requirement of the downstream CO<sub>2</sub> capture plant.
- A wet limestone based FGD system is selected for this plant. The downstream amine based CO<sub>2</sub> absorption system, again requires a very low level of SO<sub>2</sub> in the flue gas (much lower than the emission limits). This calls for a high SO<sub>2</sub> capture efficiency in the FGD to reach 10 ppm levels of SO<sub>2</sub> at the exit. Such high efficiencies are not presently met in FGD systems, though it can be achieved in the existing plants, with a further level of washing with the reagents. It would be a technical challenge, which needs to be further demonstrated in a large size plant.



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 4 of 21  
**CASE 1**

---

- Following the study performed by Fluor, a carbon dioxide capture plant based on solvent scrubbing of flue gas with amine solvents is considered. This is followed by steam stripping and recycle of the solvent and then drying and compression of the captured carbon dioxide. This is a technology commercially available for post combustion capture of carbon dioxide, from more than one supplier, albeit with an acceptable commercial risk for scaling to the size required for this plant. ( Reference to Section C para. 7.0).
- The possible effect of any other impurities in the flue gas, even at small concentrations, on the CO<sub>2</sub> capture plant has to be studied further, both theoretically and in pilot operation plants.
- The configuration of the plant considered provides for a good heat integration of the various systems.
- All the heat required for the CO<sub>2</sub> capture plant is provided from the low temperature steam extracted from the turbines. This results in a significant loss of power in the turbine generator. Further, a significant optimisation of heat within the CO<sub>2</sub> capture plant is also considered with adequate heat exchanges between various streams within the plant.
- CO<sub>2</sub> is dried and compressed up to supercritical phase at 110 bar for use in EOR or for geological disposal.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 5 of 21  
**CASE 1**

---

**1.1 Introduction**

The Case-1 of the study is a Pulverised Coal (PC) fired Ultra-Super Critical (USC) steam plant fitted with Post-combustion carbon dioxide capture and compression units.


The configuration of the PC USC complex is based on a once through steam generator with superheating and single steam reheating. The boiler has a staged low NO<sub>x</sub> burner system with the most advanced gas treatment systems.

Reference is made to the attached Block Flow Diagram of the PC USC plant. The arrangement of the process units is :

**Unit**

- 1000 Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- 2000 Boiler Island with SCR based De NO<sub>x</sub>  
and Electro Static Precipitators (ESP)
- 2100 FGD system and Gypsum handling plant
- 3000 Power Island consisting of  
Steam Turbine and Preheating Line
- 4000 CO<sub>2</sub> Capture Plant (Amine Scrubbing)
- 5000 CO<sub>2</sub> Compression and Drying

# Case: USC – PF Block Flow Diagram



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 6 of 21  
**CASE 1**

**1.2 Process Description**

*Note:* ‘Coal’ referred to in all the following sections means ‘low rank coal’ as defined in the BEDD document.

Unit 1000: Coal and Ash Handling

Please refer to Section C para. 1.0 for a process description of this unit.

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the boiler plant.

Coal Pre-Drying:

This scheme is described in Section C (Basic information for Low Rank Coal Power Plants) para. 2.0 (Drying of low rank coal lignite). A specific block flow diagram showing the main heating sources of this alternative is attached to paragraph 1.3.

The split of the heating sources required for the drying of the lignite is reported in the following table:

<b>Heat source</b>	<b>Duty, MWth</b>
Flue gas cooling from Boiler Island	34
CO <sub>2</sub> capture unit	88
CO <sub>2</sub> compression	32
<b>TOTAL HEAT</b>	<b>154</b>

Ash Handling Plant:

The ash handling system, takes care of conveying the ash generated in the boiler plant: both the furnace bottom ash and the fly ash from the various hoppers. (Reference to Section C).

Unit 2000: Boiler Island

This Unit is treated as a package supplied by specialised Vendors. USC-PC boilers firing coal of the size proposed for this study are commercially available and have gained a lot of operational experience.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 7 of 21  
**CASE 1**

---

Pulverisation Plant:

Final drying and pulverisation would be performed in the beater mills (fan mills) envisaged in the boiler island due to the soft nature of coal. The Fan Mills create the necessary suction pressure (draft) needed to draw the hot flue gases from near the exit of the furnace into the mills. The coal feed is done into this inlet duct to the mills. The coal and flue gas mixture enters the fan mills and the coal is pulverised by the impact action of the mill impellers. Classifiers at the mill exhausts control the size of the particles by returning larger particles to the mills. The flue gases help transport the pulverised fuel to the burner. Due to the negative pressure in the mills, ambient air from the atmosphere is used as tempering air to control the temperature required in the pulveriser system.

Tower Type Boiler:

The boiler would be a single pass tower-type ultra super critical boiler, with tangential firing system typical for these type of coals. For reduction of the NO<sub>x</sub> emission level, the firing system is provided with air staging in the furnace, incorporating multi-stage supply of combustion air. The integral lower firing temperatures used for this type of coal, further has a tendency to reduce the total NO<sub>x</sub> formed in the boiler.

The boiler heating surfaces are arranged in the tower at the exit of the furnace. The second pass of the boiler is only a flue gas duct in which is located the Selective Catalytic Reduction (SCR) based DeNO<sub>x</sub>.

The flue gases at the exit of the SCR, pass through to the air heater to preheat the incoming combustion air and an Electro Static Precipitator (ESP) to remove the carried over ash particles in the flue gas.

Further, a part of the flue gas at the exit of boiler is re-circulated to maintain the necessary mass flow rates required at the exit of the furnace for good convective heat recovery.

De-NO<sub>x</sub> System

An SCR system is provided to reduce the NO<sub>x</sub> produced by the combustion to a level which does not exceed the inlet requirement of the carbon dioxide capture plant, which corresponds to less than 20 ppmv of NO<sub>2</sub>. The catalytic De NO<sub>x</sub> reactor is situated in the gas stream between the boiler outlet and the air heaters. This offers a temperature range required for good functioning of the SCR system without the formation of ammonium sulphates. Gaseous ammonia is added to air supplied from a fan in a mixer as the reagent and injected into

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	8 of 21
<b>CASE 1</b>	

---

the flue gas. In the presence of the catalyst, ammonia reacts with nitrogen oxides to reduce it to nitrogen.

An SCR based De-NO<sub>x</sub> system is required for this configuration to reduce the NO<sub>x</sub> to less than 20 ppmv.

For Process Description of the De-NO<sub>x</sub> system, refer to Section C para 4.0.

Flue Gas Coolers:

The flue gas needs to be cooled to about 80°C, as an operational requirement for the downstream FGD system. It is proposed that a part of this heat be recovered for further use in the plant, including heat for drying the coal.

In the first stage, the flue gases are cooled in a plastic heat exchanger to generate hot condensate for further use. Such heat exchangers have been used in commercial coal fired power plants for low temperature heat recovery.

The flue gas needs to be cooled to about 30-35°C, as an operational requirement for the downstream CO<sub>2</sub> capture plant. The flue gas leaves the FGD system at 50 °C and then it passes in a Direct Contact Cooler, performing an adiabatic quench, where it is cooled to 35° C, before entering absorption columns of the CO<sub>2</sub> Capture Plant.

Unit 2100: FGD System

For further description, reference is to be made to Section C para. 5.0 for Wet limestone based FGD system.

The function of the FGD System is to scrub the boiler exhaust gases to remove most of the SO<sub>2</sub> content prior to enter the CO<sub>2</sub> Capture plant. The sulphur dioxide level in the flue gas must be reduced to 10 ppm necessary for efficient operation of the CO<sub>2</sub> capture plant.

Unit 4000: CO<sub>2</sub> Capture Plant

Clean flue gas with NO<sub>x</sub> less than 20 ppmv and SO<sub>x</sub> less than 10 ppm is now sent to the CO<sub>2</sub> absorption tower.

Refer to Section C para. 7.0 for this section.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	9 of 21
<b>CASE 1</b>	

---

Consequent to the detailed study presented by Fluor in its report for a similar technology study, an identical plant is considered for CO<sub>2</sub> capture; a commercial amine (MEA) scrubbing technology. The block flow diagram of this section is attached to paragraph 1.3.

In this study a 85% capture of CO<sub>2</sub> from the flue gas is considered.

Unit 5000: CO<sub>2</sub> Compression and Drying

Refer to Section C, para. 9.0 for the general description of the Unit. The block flow diagram of this section is attached to paragraph 1.3.

CO<sub>2</sub> can be handled as a liquid in pipe lines at conditions beyond its critical point ( $P_{CR}=73.8$  bar;  $T_{CR}=31^{\circ}\text{C}$ ). The present configuration studied, assumes, CO<sub>2</sub> to be delivered as a liquid at a pressure of around 110 bara.

Unit 3000: Steam Turbine and Preheating Line

The turbine consists of HP, IP and LP sections all connected to the generator on a single shaft. Main steam from the boiler passes through the stop valves and control valves and enter the turbine at 290 bar, 600°C. Steam from the exhaust of the HP turbine is returned to the boiler gas path for reheating and is then throttled into the double flow IP turbine at 60 bar, 620°C. Exhaust steam from IP flows into a double flow LP turbine and then downward into the condenser at 0.032 bar, 25°C. The LP steam is also extracted for the use in the reboiler and stripping unit in the CO<sub>2</sub> capture plant.

The block flow diagram of this section is attached to paragraph 1.3.

Recycled condensate from the condenser is pumped to the carbon dioxide capture plant and preheated in the amine stripper overhead condenser and the carbon dioxide compressor intercoolers. An optimisation of the integration between power plant and CO<sub>2</sub> capture plant allows to maximize the efficiency of the process. This also avoids the necessity of LP steam extractions to preheat condensate in LP preheating line. The preheated feed water stream is routed to the deaerator, along with condensate returned from the amine stripper reboiler. After deaeration the feed-water is heated in HP feed water heaters to 295°C prior to entering the boiler.

Integration Between The Process Units And The Power Island.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 10 of 21  
**CASE 1**

---

The plant configuration studied considers the following integrations between the Process Units and the Power Island:

- The heat required for the drying of coal is generated by producing hot water in the flue gas line, before the FGD section, in CO<sub>2</sub> compression unit and in CO<sub>2</sub> capture plant.
- A part of the heat recovered in the CO<sub>2</sub> capture plant (overhead stripper condenser) and in the compression line is recovered by preheating the condensate, totally avoiding the use of LP feed water heaters.
- All the LP steam required for the CO<sub>2</sub> absorption plant is provided by extraction from the LP stage of the steam turbine.



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 11 of 21  
**CASE 1**


---

**1.3 Block Flow Diagrams**


The Block Flow Diagrams of the following process units are attached to this paragraph:

- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 2000/2100: Boiler Island with SCR based De NO<sub>x</sub>  
Electro Static Precipitators (ESP)  
FGD System
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Capture Plant (Amine Scrubbing)
- UNIT 5000: CO<sub>2</sub> Compression and Drying


# UNIT 1000 - Coal and Ash Handling




# UNITS 2000/2100 – Boiler Island and FGD System




# UNIT 3000 - Steam Turbine & Preheating Line



# UNIT 4000 - CO<sub>2</sub> Capture Plant



# UNIT 5000 - CO<sub>2</sub> Compression & Drying



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 12 of 21  
**CASE 1**


---

**1.4 Heat and Material Balances**


The Heat & Material Balances of the following process units are attached to this section:

- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 2000: Boiler Island with SCR based De NO<sub>x</sub>  
and Electro Static Precipitators (ESP)
- UNIT 2100: FGD System
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Capture Plant (Amine Scrubbing)
- UNIT 5000: CO<sub>2</sub> Compression and Drying


Stream numbers are as shown on the Block Flow Diagrams attached to paragraph 1.3 of this Section.

 <b>FOSTER WHEELER</b>	PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 1</b>						APPROVED	LM		
	<b>UNIT : 1000 Coal &amp; Ash Handling</b>						DATE	Feb-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Coal to Plant	Coal to Boiler Island	Fly Ash	Bottom Ash	Air from Lignite Dryer					
Temperature (°C)	AMB	AMB	AMB	AMB	50					
Pressure (bar)	ATM	ATM	ATM	ATM	ATM					
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	733991	532143	20554	5138	1326973					
Molar flow (kgmole/h)										
	Moisture 50.70%	Moisture 32%	0	0						
Composition wt%										
Carbon	31.33%	43.21%								
Hydrogen	2.29%	3.16%								
Oxygen	11.56%	15.94%								
Sulfur	0.22%	0.31%								
Nitrogen	0.37%	0.51%								
Chlorine	0.03%	0.05%								
Moisture	50.70%	32.00%								
Ash	3.50%	4.83%								



 <b>FOSTER WHEELER</b>	PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b> <b>CASE : CASE 1</b> <b>UNITS : 2000 Boiler Island 2100 FGD System</b>						PREP.	SR		
							APPROVED	LM		
							DATE	Feb-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Coal from Coal Dryer	Air intake from Atmosphere	Flue Gas From Boiler	Flue Gas to FGD System	Feed Water from Preheating line UNIT 3000	HP Steam to Steam Turbine	IP Steam from Preheating Line UNIT 3000	IP Reheated Steam to Steam Turbine	Flue Gas to CO2 Capture Plant	Make up Water
Temperature (°C)	AMB	15	130	80	295	600	358	620	50	30
Pressure (bar)	AMB	1.013	1.01	1.05	337.9	290.0	64.5	60.0	1.12	2.0
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	532143	3436652	3957176	3957176	2760000	2760000	2417870	2417870	3911817	137300
Molar flow (kgmole/h)			136570	136570		153248	134252	134252	133986	
<b>LIQUID PHASE</b>										
Mass flow (kg/h)		0	0	0	2760000	0	0	0	0	137300
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)		3436652	3957176	3957176	0	2760000	2417870	2417870	3911817	
Molar flow (kgmole/h)		560649	136570	136570	0	153248	134252	134252	133986	
Molecular Weight		6.13	28.98	28.98	18.01	18.01	18.01	18.01	29.20	
Composition (vol %)	See UNIT 1000									
N <sub>2</sub>		77.57%	69.12%	69.12%	0.00%	0.00%	0.00%	0.00%	70.51%	0.00
CO <sub>2</sub>		0.00%	13.93%	13.93%	0.00%	0.00%	0.00%	0.00%	14.24%	0.00
H <sub>2</sub> O		0.68%	13.88%	13.88%	100.00%	100.00%	100.00%	100%	12.17%	1.00
O <sub>2</sub>		20.86%	3.02%	3.02%	0.00%	0.00%	0.00%	0.00%	3.08%	0.00
Ar		0.89%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00
NO <sub>x</sub>		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00
SO <sub>x</sub>		0.00%	0.04%	0.04%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00
CO		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0%	0.00%	0.00

Sheet 1 of 2

 <b>FOSTER WHEELER</b>	PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 1</b>						APPROVED	LM		
	<b>UNIT : 2100 FGD System</b>						DATE	Feb-05		
STREAM	11	12	13	14	15	16	17	18	19	20
	Product Gypsum	Limestone <sup>(1)</sup>								
<b>Temperature (°C)</b>	AMB	AMB								
<b>Pressure (bar)</b>	ATM	ATM								
<b>TOTAL FLOW</b>	Solid									
Mass flow (kg/h)	8370	5080								
Molar flow (kgmole/h)										
<b>LIQUID PHASE</b>										
Mass flow (kg/h)										
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)										
Molar flow (kgmole/h)										
Molecular Weight										
Composition (vol %)										
N <sub>2</sub>										
CO <sub>2</sub>										
H <sub>2</sub> O										
O <sub>2</sub>										
Ar										
NO <sub>x</sub>										
SO <sub>x</sub>										
CO										

Note (1): Limestone Analysis (wt %) CaCO<sub>3</sub> = 95% - MgCO<sub>3</sub> = 3.4% - Inert = 1.6%



## PC-USC HEAT AND MATERIAL BALANCE


CLIENT : IEA GREEN HOUSE R & D PROGRAMME


CASE : CASE 1

UNIT : 3000 Steam Turbine & Preheating Line

Sheet 1 of 1

Stream	Description	Flowrate t/h	Temperature °C	Pressure bar a	Entalphy kJ/kg
1	HP Water to Boiler Island	2760	295	338	1298
2	HP Steam from Boiler	2760	600	290	3456
3	IP Steam to Boiler	2418	358	65	3056
4	IP hot reheated steam to Steam Turbine	2418	620	60	3706
5	IP Steam Turbine exhaust	1849	226	3.6	2916
6	LP Steam to Reboiler	1058	146	3.6	2747
7	Hot Condensate returned from Reboiler	1058	134	3	566
8	LP Steam to Steam Turbine	866	226	3.6	2916
9	Condensate	1038	25	0.032	106
10	LP Preheated Condensate	1038	130	12	544
11	Condensate to HP FWH	2760	176	340	765
12	Cooling Water Inlet	53524	11	3	47
13	Cooling Water Outlet	53524	21	2	88

 <b>FOSTER WHEELER</b>	PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 1</b>						APPROVED	LM		
	<b>UNIT : 4000 CO<sub>2</sub> Capture Plant</b>						DATE	Feb-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Flue Gas from FGD System	Flue Gas to Atmosphere	Carbon Dioxide to Compression	LP Steam From Turbine Extraction	Condensate from Reboiler to Power Island	Make up Water				
Temperature (°C)	50	46	38	146	134	30				
Pressure (bar)	1.12	1.01	1.6	3.6	3.2	2.0				
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	3911817	3114001	726204	1058060	1058060	190692				
Molar flow (kgmole/h)	133986	113099	16912	58748	58748					
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	0	0	0	1058060	1058060	190692				
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	3911817	3114001	726204	0	0					
Molar flow (kgmole/h)	133986	113099	16912	0	0					
Molecular Weight	29.20	27.53	42.94	18.01	18.01					
Composition (vol %)										
N <sub>2</sub>	70.51%	83.52%	0.01%	0.00%	0.00%	0.00%				
CO <sub>2</sub>	14.24%	2.53%	95.88%	0.00%	0.00%	0.00%				
H <sub>2</sub> O	12.17%	10.30%	4.11%	100.00%	100.00%	100.00%				
O <sub>2</sub>	3.08%	3.65%	0.00%	0.00%	0.00%	0.00%				
Ar	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%				
NO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%				
SO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%				
CO	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%				

 <b>FOSTER WHEELER</b>	PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 1</b>						APPROVED	LM		
	<b>UNIT : 5000 CO<sub>2</sub> Compression &amp; Drying</b>						DATE	Feb-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	CO <sub>2</sub> from Stripper	CO <sub>2</sub> to long term Storage	Condensate from Stripper Condenser	Preheated Condensate to Power Island						
Temperature (°C)	38	30	107	130						
Pressure (bar)	1.5	110	12	11						
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	726204	713673	1038012	1038012						
Molar flow (kgmole/h)	16912	16216	57635	57635						
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	0	713673	1038012	1038012						
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	726204	0	0	0						
Molar flow (kgmole/h)	16912	0	0	0						
Molecular Weight	42.94	44.01	18.01	18.01						
Composition (vol %)										
N <sub>2</sub>	0.008%	0.008%	0.00%	0.00%						
CO <sub>2</sub>	95.88%	99.99%	0.00%	0.00%						
H <sub>2</sub> O	4.11%	0.00%	100.00%	100.00%						
O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%						
Ar	0.00%	0.00%	0.00%	0.00%						
NO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%						
SO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%						
CO	0.00%	0.00%	0.00%	0.00%						

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005


Sheet: 13 of 21

**CASE 1**

---

## **1.5 Utility Consumption**

The utility consumption of the process / utility and offsite units are shown in the attached Tables.

		CLIENT: IEA GHG	Rev Final
		PROJECT: GASIFICATION POWER GENERATION STUDY	Nov 05
		LOCATION: Germany	ISSUED BY: SR.
		FWI N°:	CHECKED BY: L.M. APPR. BY: R.D.
<b>ELECTRICAL CONSUMPTION SUMMARY - CASE 1 - PC - USC</b>			
UNIT	DESCRIPTION UNIT	Absorbed Electric Power [kW]	
<b>PROCESS UNITS</b>			
1000	Coal - Ash Storage and Handling	343	
1050	Coal Drying (Air fan consumption)	691	
2000	Boiler Island	19200	
2100	FGD System	8100	
4000	CO <sub>2</sub> Capture Plant	31202	
5000	CO <sub>2</sub> Compression and Drying	78400	
<b>POWER ISLANDS UNITS</b>			
3000	Steam Turbine and Preheating line	1370	
<b>UTILITY and OFFSITE UNITS</b>			
	Cooling Towers	20715	
	Others	8750	
<b>BALANCE</b>		<b>168771</b>	







**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 14 of 21  
**CASE 1**

**1.6 PC-USC Overall Performance**

The following Table shows the overall performance of the PC-USC Complex.

<b>PC-USC</b>		
<b>Case 1</b>		
<b>OVERALL PERFORMANCES OF THE PC-USC COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	734.0
Coal LHV (A.R.)	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>2140.8</b>
Steam turbine power output (@ gen. terminals)	MWe	932.0
<b>GROSS ELECTRIC POWER OUTPUT OF PC - USC COMPLEX (D)</b>	<b>MWe</b>	<b>932.0</b>
Coal Storage / Handling / Drying	MWe	1.0
Boiler Island	MWe	19.2
FGD	MWe	8.1
CO <sub>2</sub> Plant incl. Blowers	MWe	31.2
CO <sub>2</sub> Compression	MWe	78.4
Power Island (1)	MWe	1.4
Utilities	MWe	29.5
<b>ELECTRIC POWER CONSUMPTION OF PC-USC COMPLEX</b>	<b>MWe</b>	<b>168.8</b>
<b>NET ELECTRIC POWER OUTPUT OF PC-USC (C)</b> Step-Up Transformer Efficiency (0.997)	<b>MWe</b>	<b>761.0</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>43.5%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>35.5%</b>

Notes: (1) Boiler Feed Water pumps are steam turbine driven.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 15 of 21  
**CASE 1**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the IGCC Complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 43.21%wt)	19144
Limestone	51
Slag	118
<b>Net Carbon flowing to Process Units (A)</b>	<b>19077</b>
Liquid Storage	
CO	0.0
CO <sub>2</sub>	<u>16215</u>
<b>Total to storage (B)</b>	<b>16215</b>
Emission	
CO	0.0
CO <sub>2</sub>	<u>2862</u>
<b>Total Emission</b>	<b>2862</b>
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85.0</b>

## 1.7 Environmental Impact

The PC-USC Complex is designed to process coal, whose characteristics are defined in the Basic Engineering Design Data and produce electric power. The advanced technology allows to reach a high efficiency and to minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the PC-USC Complex are summarised in this section.

### 1.7.1 Gaseous Emissions

#### Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases leaving the absorber unit of the CO<sub>2</sub> capture plant.

Table 1.1 summarises expected flow rate and concentration of the combustion flue gas after CO<sub>2</sub> capture treatment.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 16 of 21  
**CASE 1**

**Table 1.1** – Expected gaseous emissions from PC-USC plant integrated with CO<sub>2</sub> capture.

	Normal Operation
Wet gas flow rate, kg/s	865
Flow, Nm <sup>3</sup> /h	2535000
Temperature, °C	46
<b>Composition</b>	<b>(%vol)</b>
N <sub>2</sub>	83.52
O <sub>2</sub>	3.65
CO <sub>2</sub>	2.53
H <sub>2</sub> O	10.30
<b>Emissions</b>	<b>mg/Nm<sup>3</sup><sup>(1)</sup></b>
NO <sub>x</sub>	40
SO <sub>x</sub>	29 <sup>(2)</sup>
CO	Less than 150
Particulate	Less than 30
NH <sub>3</sub>	5 <sup>(3)</sup>

(1) Dry gas, O<sub>2</sub> Content 6% vol

(2) SO<sub>x</sub> Emissions upstream AGR unit; after solvent washing, emissions are expected close to zero

(3) Due to ammonia slippage into the flue gas downstream the SCR

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Flow rate : 1327 t/h  
 Particulate : 27.6 kg/h

#### Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by proper design and operation.

#### **1.7.2 Liquid Effluent**

The plant would be designed for zero liquid effluents.

#### **1.7.3 Solid Effluent**

No solid waste other than those produced by a real industrial activity.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 17 of 21  
**CASE 1**

The power plant is expected to produce the following solid by-products:

Fly Ash

Flow rate : 20.6 t/h

Bottom Ash

Flow rate : 5.1 t/h

Fly and bottom ash can be dispatched to cement industries.

Solid Gypsum

Flow rate : 8.4 t/h

Solid gypsum keeping Euro Gypsum restrictions can be delivered to the market.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 18 of 21

**CASE 1**

---

## **1.8 Equipment List**

The list of the main equipment and process packages are included in this section.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 19 of 21  
**CASE 1**

**UNIT 1000 – Coal handling and storage – Ash and Solid removal**

Coal Unloading train including:

- Hopper systems
- Coal conveying
- Stacker reclaimer
- Coal delivery equipment

Coal Pre-drying train including:

- Fluid Bed Dryer
- Air fan
- Hot Water based Air Heater
- Filters for exhaust air

Fly ash handling System including:

- Pneumatic Conveying system
- Storage Silo
- Dust suppression System

Bottom ash systems

- Conveying System
- Clinker Crusher

Miscellaneous equipment

**UNIT 2000 – Boiler Island with SCR based De NOx – Electro Static Precipitators (ESP)**

Tower type boiler including:

- Fresh Air Fans
- Fan Beater Mills
- SCR DeNOx System
- Air Heaters
- Electro Static Precipitator
- Induced Draft Fans
- Flue Gas Recirculation Fans
- Hot Water Generator
- Miscellaneous equipment

Auxiliary boiler

Structures

Control System

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 20 of 21  
**CASE 1**

---

### **UNIT 2100 – FGD system and Gypsum handling plant**

Limestone storage  
Limestone feeder  
Absorber Tower  
Oxydation air blower  
Make up water system  
Gypsum handling & storage  
Reagent feed pumps  
Miscellaneous equipment

### **UNIT 3000 – Power Island consisting of Steam Turbine and Preheating Line**

Steam turbine and generator package  
Deaerator  
HP feedwaterheaters  
Condenser Package  
Condensate pumps  
Steam turbine driven BFW pump  
LP pumps

### **UNIT 4000 – CO<sub>2</sub> Capture Plant**

Flue gas blower  
Absorption towers  
Packing  
Stripper tower  
Packing for stripper  
Stripper reboiler  
Overhead stripper condenser  
Water wash cooler  
Cross exchangers  
Lean solvent cooler  
Flash preheater  
Reclaimer  
Soda ash dosing  
Amine filter package  
MEA storage tank  
MEA circulation pumps  
Wash water pumps



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 21 of 21  
**CASE 1**

---

Surplus water pumps  
Reflux pump  
Surplus water tankage

**UNIT 5000 – CO<sub>2</sub> Compression and Drying**

Compression package  
Drying package  
CO<sub>2</sub> pumps  
KO drums  
Intercooling heat exchangers  
Intercooling Water circulation pumps

**Utility and Offsite Units**

Cooling Water / Machinery cooling water systems (Unit 4100)  
Demineralized, Plant and Potable Water System (Unit 4200)  
Natural Gas System (Unit 4300)  
Plant / Instrument Air Systems (Unit 4400)  
Waste Water Treatment (Unit 4600)  
Fire Fighting System (Unit 4700)  
Chemicals (Unit 4900)  
Interconnecting (Instrumentation, DCS, Piping, Electrical, 400 KV Substation)  
(Unit 6000)

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 1 of 25  
**CASE 2**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 2 – OXYFUEL PC BOILER

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: Nov. 2005

Sheet: 2 of 25

**CASE 2**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 2.0 Case 2
- 2.1 Introduction
- 2.2 Process Description
- 2.3 Block Flow Diagrams
- 2.4 Heat and Material Balances
- 2.5 Utility Consumption
- 2.6 PC - Oxyfuel Overall Performance
- 2.7 Environmental Impact
- 2.8 Equipment List

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**
**2.0 Case 2 - Oxyfuel**
**Summary**

Pulverised Coal Ultra SuperCritical (PC -USC) boiler modified to allow oxycombustion and CO<sub>2</sub> capture and storage.

- The size of the plant considered for this configuration is based on the size required to provide nearly the same net output for all the other configurations.
- A pre-drying of the coal from a moisture level of 50.7% in as-received coal to about 32% is considered, before it is fed to the boiler plant. Drying of coal using low temperature waste heat is used for this alternative (Reference to Section C para. 2.0). In this case waste Nitrogen from ASU is used to fluidize the lignite dryer, instead of ambient air. The Nitrogen pressure allows to fluidize the bed without the insertion of a blower.
- The use of oxy-combustion (fossil fuel combusted with near pure oxygen and recycled flue gas or CO<sub>2</sub> and water/steam) to produce a flue gas consisting essentially of CO<sub>2</sub> and water is seen as having potential as a means of disposing of combustion related CO<sub>2</sub>. The advantage is that the flue gas is not diluted with nitrogen as when air is used for firing and therefore, can be disposed of with minimal further downstream processing.
- The amount of oxygen required for the plant under study is very high and a single train air separation plant cannot supply the same. Multiple trains of ASU are proposed to supply the required oxygen for combustion. However, the cryogenic technology for separation of oxygen from air is a very well established commercial technology.
- The boiler technology considered in this study with oxygen is an extrapolation of the existing air fired technology. To ensure nearly same conditions of operation, the pure oxygen is mixed with a part of the recycle gas to reach nearly same conditions of the flue gas in the boiler. These effects have to be further understood in detail in a big size plant operation. It is expected that a 500MW boiler using this technology would be demonstrated in the next few years, to understand and establish the design changes required for this boiler.
- The configuration of the boiler considered is a tower type boiler, as with air fired PC boiler considered in the other case of study. The essential features of the firing system are the flue gas extraction from the furnace and integral fan

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 4 of 25  
**CASE 2**

---

beater mills for combined drying and grinding of coal, as well as tangential firing system with coal-specific jet burners.

- The limits of NO<sub>x</sub> emission (European Emission Limits) can be met with just the firing system of the boiler with staged combustion and low temperature at furnace exit. Hence, no SCR system is considered for the boiler. Further, the nitrogen oxides are expected to be condensed into the CO<sub>2</sub> stream in the downstream CO<sub>2</sub> capture and processing plant. Hence, there are no emissions of nitrogen oxides into the atmosphere.
- No FGD system is required for this scheme. All the sulphur oxides are expected to be condensed into the CO<sub>2</sub> stream during the chilling and separation process, and end up in the product CO<sub>2</sub> stream.
- CO<sub>2</sub> plant: The flue gas at the exit of the boiler consists only of the CO<sub>2</sub> and some leakage nitrogen and oxygen. The configuration for CO<sub>2</sub> separation follows the study performed by Mitsui; the flue gases at the exit of the boiler are chilled to separate out the CO<sub>2</sub>. The duty for chilling is obtained by partly expanding the compressed CO<sub>2</sub> in the intermediate stages of the plant. CO<sub>2</sub> is eventually compressed to a liquid at 110 bar for final disposal. Present also alternative to clean CO<sub>2</sub> and discuss pros. and cons.
- The possible effect of any other impurities in the flue gas, even at small concentrations, on the CO<sub>2</sub> capture plant has to be studied further, both theoretically and in pilot operation plants.
- The configuration of the plant considered provides for a good heat integration of the various systems.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**


---

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 5 of 25  
**CASE 2**

**2.1 Introduction**

The Case-2 of the study is a Pulverised Coal (PC) fired Ultra-Super Critical (USC) steam plant modified to allow oxycombustion and CO<sub>2</sub> capture.

The configuration of the PC USC complex is based on once through steam generator with superheating and a single reheating of steam. The boiler has a staged low NO<sub>x</sub> burner system with the most advanced gas treatment systems including ESP (Electrostatic Precipitators) to capture particulates.

The downstream systems include:

- CO<sub>2</sub> Separation Plant
- CO<sub>2</sub> Compression train.


Previous work from a number of authors as well as pilot and laboratory scale studies have indicated that retrofit of oxy-combustion based technology to existing fossil fuel fired plant is feasible, with more often than not, little or no changes to the existing boiler pressure parts. In case of a new plant, the same philosophy of design as for existing plants can be adopted to ensure ease of design and understanding of the operating principles of the boiler.

Reference is made to the attached Block Flow Diagram of the PC plant. The arrangement of the process units are :

**Unit**

- |      |  |
|------|--|
| 1000 | Coal handling and storage<br>Ash and Solid removal<br>Coal Drying System |
| 1100 | Air Separation Unit (ASU)  |
| 2000 | Boiler Island with Electro Static Precipitators (ESP)                    |
| 3000 | Power Island consisting of<br>Steam Turbine and Preheating Line          |
| 4000 | CO <sub>2</sub> Separation Unit  |

# Case 2: Oxyfuel PC - USC Block Flow Diagram



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 6 of 25  
**CASE 2**

**2.2 Process Description**

*Note:* ‘Coal’ referred to in all the following sections means ‘low rank coal’ as defined in the BEDD document.

Unit 1000: Coal and Ash Handling

Please refer to Section C para. 1.0 for a process description of this unit.

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the boiler plant.

Coal Pre-Drying:

This scheme is described in Section C (Basic information for Low Rank Coal Power Plants) para. 2.0 (Drying of low rank coal lignite). The block flow diagram of the Unit is also attached to paragraph 1.3 of this Section.

The split of the heating sources required for the drying of the lignite is reported in the following table:

<b>Heat source</b>	<b>Duty, MWth</b>
ASU	46
Flue gas treatment	96
<b>TOTAL HEAT</b>	<b>142</b>

Ash Handling Plant:

The ash handling system, takes care of conveying the ash generated in the boiler plant: both the furnace bottom ash and the fly ash from the various hoppers. (Reference to Section C).

Unit 1100: Air Separation Unit (ASU)

The ASU is considered as a typical Package supplied by vendors with clearly defined limits of supply and interfaces.

The configuration selected for the ASU, is a tested and well commercialised cryogenic distillation of air. Considering that the pressure of oxygen required is only at very low pressure to the boiler plant, a low-pressure distillation column is selected.

The typical train of ASU includes:



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**


---

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 7 of 25  
**CASE 2**

- (1) Air filtration and compression
- (2) Cryogenic Heat Exchangers (Cold Boxes)
- (3) Cryogenic Distillation Column.

Size of ASU:

The total quantity of oxygen required for this study is much in excess of a single train capacity presently installed. Hence, multiple trains of ASU are considered; three trains in all. The size of each train shall be about 5000 tonnes O<sub>2</sub> per day, which is already about 20% larger than the largest plant presently installed and close to maximum capacity which can be commercially offered nowadays. The limitations of air compressor size and the distillation column size for a single train can be met for larger sizes of ASU.

Purity of Oxygen:

The purity of oxygen affects the downstream CO<sub>2</sub> separation plant, as any impurity in the oxygen gets carried over, along with combustion gases to this plant. However, the combustion gases are also mixed with unavoidable impurities of Nitrogen from air leakage into the boiler, etc.

Consequently, a high purity of oxygen is not an absolute requirement, as the downstream CO<sub>2</sub> separation plant will have to deal with these sources of impurities.

Purity levels of 95% of oxygen are easily generated in the ASU plant. A higher purity level for oxygen imposes a penalty on the energy requirement on the ASU plant.

Hence, the purity level of oxygen requirement defined for the ASU plant is limited to 95%.

Waste Nitrogen:

The ASU also generates a nitrogen stream, which is available at a low pressure (approx. 1.6 bar) and is relatively dry. This is usually vented to the atmosphere as waste gases.

In the present study, this stream is used as the fluidising and drying medium for the lignite drying plant to improve the overall efficiency of the plant.

Unit 2000: Boiler Island

The block flow diagram of the Unit is attached to paragraph 1.3 of this Section.

This Unit is treated as a package supplied by specialised Vendors. Supercritical PC boilers firing coal, of the size proposed for this study, using oxygen are not

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 8 of 25  
**CASE 2**

---

developed commercially. However, from a characteristics study, it is expected that the behaviour and design aspects of the boiler would not be different from those of air fired plants.

As pure oxygen is used for combustion, there is a deficient mass flow rate in the boiler due to absence of inert nitrogen present in air fired plants. To make up for this loss in mass flow rates and to reach similar characteristics, a part of the flue gas at the exit of the boiler, is recirculated back through the furnace and convective pass.

At the present level of development of this technology, it is preferable to reach a combustion gas composition whose properties are similar to those for an air fed boiler plant. It is assumed in this study that this can be achieved and hence, the design of an air fired boiler can be extrapolated to those for an oxygen fired boiler. For example, it would be preferable to maintain an oxygen level of about 20% in the gases fed to the boiler. However, it is also understood that the properties of the flue gases and the design of the furnace would be considerably different due to the presence of high level of CO<sub>2</sub> in the gases.

These have been studied by various people and it is expected that a new boiler using O<sub>2</sub>/CO<sub>2</sub> mixture can be designed and will perform similar to an air fired boiler.

Pulverisation Plant:

Final drying and pulverisation would be performed in the beater mills (fan mills) envisaged in the boiler island due to the soft nature of coal. The Fan Mills create the necessary suction pressure (draft) needed to draw the hot flue gases from near the exit of the furnace into the mills. The coal feed is done into this inlet duct to the mills. The coal and flue gas mixture enters the fan mills and the coal is pulverised by the impact action of the mill impellers. Classifiers at the mill exhausts control the size of the particles by returning larger particles to the mills. The flue gases help transport the pulverised fuel to the burner.

Tower Type Boiler:

The boiler would be a single pass tower-type super critical boiler, with tangential firing system. For reduction of the NO<sub>x</sub> emission level, the firing system is provided with staging in the furnace, incorporating multi-stage supply of combustion oxygen and flue gas. The integral lower firing temperatures used for this type of coal, further has a tendency to reduce the total NO<sub>x</sub> formed in the boiler.

The boiler heating surfaces are arranged in the tower at the exit of the furnace. The second pass of the boiler is only a flue gas duct through which the flue gases pass through to the gas heater (to preheat the incoming mixture of

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 9 of 25  
**CASE 2**

---

oxygen and recycled flue gas) and an Electro Static Precipitator (ESP) to remove the carried over ash particles in the flue gas.

Further, a part of the flue gas at the exit of boiler is re-circulated (secondary recycle) to maintain the necessary mass flow rates required at the exit of the furnace for good convective heat recovery.

*Flue gas Recirculation (Secondary Recycle):*

In comparison with air fired PC fired boilers, the flue gases generated in the boilers are not diluted with the inert nitrogen present in air. To arrive at a similar situation and to provide for adequate mass flow rates for heat pick up and transfer to steam, a part of the product gases at the outlet of the boiler are recirculated into the boiler (secondary recycle). Required adjustments are made in the flow rates to account for the revised composition of the gases and their changed heat capacities of the gases.

As in conventional lignite fired boiler, there is no requirement for air or any other gas to be heated and supplied to the pulveriser plants. A part of the flue gas at the furnace exit is used as the primary recycle stream for final drying and conveying the pulverised fuel to the boiler. Hence, there is only one stream of recycle gas from the boiler exit (in comparison to those for the high rank coal boilers described by Mitsui).

*Secondary Recycle Gas location:*

In conventional air fired plants, the secondary recycle can be taken at the exit of the ESP, with the temperature of the gases being nearly 130 – 140°C. However, in the case with oxycombustion, the quantity of moisture in the flue gas at the exit of the boiler is very high for conveniently handling this flue gas. Hence, the flue gases are cooled by a water wash to remove the inherent moisture, before recycle back to the boiler. On the way, it is re-heated using the flue gas cooling stream to efficiently return a part of the heat back to the boiler.

Some studies have suggested to recycle the flue gases at the exit of the boilers, before the ESP. This could be disadvantageous, as the gas is still laden with significant dust levels, which could lead to severe erosion of recirculation gas fans. Further, as the ratio of recycle gases is very high (almost 70%), it could lead to a quick build-up of impurities in the boiler.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 10 of 25  
**CASE 2**

Excess Oxygen level:

In present day pulverised coal fired boilers, excess air levels of 20% are maintained. There is a continuous effort by boiler designers to reduce this level with a good distribution to about 15% to improve the overall efficiency of the boiler. In any case in the present study is considered an excess oxygen level of 20% at the burner, from all sources (recycle and added oxygen).

Air Leakage into the boiler:

Conventionally, the boilers are operated at a slight vacuum to prevent leakage of hot flue gases at any level, out of the system, for safety reasons. Some smaller boilers are operated at positive pressures, but for big size boilers, maintaining a pressure tight situation is nearly impossible. This leads to unavoidable ambient air leakage into the boiler, affecting the efficiency of the boiler.

This is more harmful for oxy-combustion boilers, as this leakage air effects the downstream equipment and affects the purity of the gases generated in the boiler. This is a big source of nitrogen in the product gases, which is to be removed in the final CO<sub>2</sub> product.

Typically in the design of air fired plants, a 1-2% stoichiometric air leakage into the boiler is considered. A similar air leakage is considered in evaluating the mass flow rates for this study.

De-NO<sub>x</sub> System

It is expected that all the nitrogen oxides in the flue gases will be condensed along with the CO<sub>2</sub> in the product carbon stream. Hence, no further De-NO<sub>x</sub> system is required for this option.

Flue Gas Coolers:

The flue gas needs to be cooled to about 30°C, as an operational requirement for the downstream CO<sub>2</sub> system. It is proposed that a part of this heat be recovered for further use in the plant, including heat for drying the coal.

A gas/gas heat exchanger is located in the flue gas path for preheating the flue gases returning to the boiler from the CO<sub>2</sub> plant.

Adequate precaution will be made in the selection of the material of construction of this plant.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 11 of 25  
**CASE 2**

As a finish cooler, a direct contact cooler with water is employed to reach the required flue gas temperature for the CO<sub>2</sub> system.

### FGD System

All the sulphur oxides will be condensed in the CO<sub>2</sub> plant and end up in the product CO<sub>2</sub> stream. The recycle flue gases to the boiler are re-heated and sent directly to the boiler. As the flue gases do not go through the milling plant, where usually low temperature is encountered, no associated dew point corrosion problems are expected.

Hence, no desulphurisation plant is provided for this case.

### Unit 4000: CO<sub>2</sub> Separation Plant

The purpose of this system is to process the flue gas stream leaving the Oxygen Fired Boiler Island to provide a liquid CO<sub>2</sub> product stream for a long term storage.

In this study a minimum of 85% capture of CO<sub>2</sub> from the flue gas is considered.

CO<sub>2</sub> can be handled as a liquid in pipe lines at conditions beyond its critical point ( $P_{CR}=73.8$  bar;  $T_{CR}=31^{\circ}\text{C}$ ). The present configuration studied, assumes, CO<sub>2</sub> to be delivered as a liquid at a pressure of around 110 bar a.

The gas at the exit of the boiler, is a CO<sub>2</sub> rich flue gas along with impurities like nitrogen that is present in the feed oxygen and air leakage, moisture of combustion and Oxygen due to the excess of O<sub>2</sub> for combustion and air leakage. These impurities affect the pumping and transport of the product CO<sub>2</sub> streams. Hence, the CO<sub>2</sub> separation section basically consists of a scheme to remove these components to enhance the product CO<sub>2</sub> from the plant.

Different schemes can be used in order to reach the correct CO<sub>2</sub> purity with different costs and electrical consumption. If CO<sub>2</sub> captured is used for EOR it is necessary to have an high purity CO<sub>2</sub> stream (>95%). In case of simple sequestration, it is not important to reach a stringent specification of the CO<sub>2</sub>, so the treatment unit can be cheaper and less complicate.

One could look at three possible options for the gas treatment with their own advantages and limitations.

Alternative CO<sub>2</sub> cleaning processes:

- Option 1: Scrubbing of flue gas with amine:

This option can be interesting due to the higher partial pressure of CO<sub>2</sub> in the flue gas, when compared with traditional air fired boiler.

Specific advantages of this scheme could be:

- Smaller towers due to lower volume of flue gas in comparison to air fired boiler.
- Established process of amine wash
- High purity of CO<sub>2</sub> captured stream is possible

However this scheme could have the following limitations

- High cost of amine washing plant
- Need for large steam flow rate to regenerate the amine
- Consequent loss of power

Considering that the final CO<sub>2</sub> product has to be compressed / pumped to a high pressure, this scheme could add additional equipment with consequent loss of power generation and efficiency.

- Option 2: Compression of the gas at high pressure:

Pure CO<sub>2</sub> condenses at 20 °C at about 58 bara and the CO<sub>2</sub> concentration in the flue gas after moisture removal is 78%, to reach the corresponding partial pressure of CO<sub>2</sub> for condensation, it has to be compressed to about 80 bara and cooled till ambient temperature, with cooling water. At this conditions some of the Nitrogen and Oxygen also condense into the CO<sub>2</sub> stream, making it less than 90% purity: a concentration that is not adequate for EOR.

In the case where the final CO<sub>2</sub> is sent for sequestration, this solution is very attractive due to the simple scheme that can be used. The flue gas is only compressed, dried and stored without any stringent specifications required for this case.

A major requirement is that the oxygen concentration should be minimized to meet the current pipelines operating practise, due to the high corrosive nature of oxygen. With this scheme is not possible to reach a low concentration of O<sub>2</sub>. Hence corrosion could be a serious problem for pipelines and it could be uneconomic to use special materials.

The effect of other impurities are not fully known.

However it should be emphasized that this treatment would guarantee zero gaseous emissions from the boiler.

- Option 3: Chilling of flue gas, compression and cryogenic separation

This is a modification of Option 2, in that the gases are compressed and chilled to cryogenic temperatures (-60 °C) before separating of product CO<sub>2</sub> and other impurities. At this conditions the solubility of N<sub>2</sub>, O<sub>2</sub> and other gases in the

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**


---

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 13 of 25  
**CASE 2**

CO<sub>2</sub> stream are low. Hence the product stream of CO<sub>2</sub> is more than 95 % pure. No upstream treatment plant is required. Of course, the scheme calls for big heat exchangers constructed with special material to handle condensed gases in cryogenic conditions and high energy requirements of chilling.

However considering that the product gases anyway have to be compressed to a high pressure, a part of this compressed gases are expanded to generate the required refrigeration.

Optimization with the respect to purity and temperature requirement for separation can be performed to evaluate this process further.

Description of the scheme:

The block flow diagram of the Unit is attached to paragraph 1.3 of this Section.

In the first stage, the flue gases from boiler at 80°C are scrubbed with water in a direct contact scrubber tank. Most of the moisture will be condensed out from the gases. Any carried over particulates in the flue gas is also scrubbed out. A set of moisture separators at the top of this scrubber ensure that the gases leaving the top of the scrubber are almost dry.

A major part of this dry cool gas is recycled back to the boiler to maintain the required mass flow rates by the suction action of the gas recirculation fans. The recycled gases are heated in the flue gas line of the boiler, against the cooling flue gases.

The remaining part of the flue gases is further cooled in a trim cooler before it is sent to the CO<sub>2</sub> separation (purification) section.

The gases are now compressed in multiple stages with inter-stage cooling. The heat of compression is advantageously used to preheat the condensate water to the boiler and also the HP feed water allowing a consistent reduction in size of the preheating line of the power island. Trim coolers are used to further cool the gases at the inlet of each compression stage. The gases are compressed to about 30 bar.

After compression the high pressure gases are dried in a desiccant dryer to reach a low dew point (-60°C) and then they enter the cold box, without problem of ice formation. In the double cold box takes place the inerts removal. The system uses two flash separators tanks, the first at (-26°C) and the second at temperature very close to the freezing temperature of CO<sub>2</sub> (-55°C) by the principle of phase separation between the condensed liquid CO<sub>2</sub> and the insoluble inert gases. The conditions of separation (CO<sub>2</sub> partial pressure and temperature) are set to ensure the required CO<sub>2</sub> purity levels corresponding to at least 85% CO<sub>2</sub> capture overall with a purity higher than



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 14 of 25  
**CASE 2**

---

95%. The condensed CO<sub>2</sub> liquid is now evaporated to generate the required refrigeration for the plant operation.

The cold box heat exchanges are optimised by use of reflex heat exchangers. The product CO<sub>2</sub> gases are again compressed to the required pressure of 110 bar. The gases are cooled and condensed to ambient temperature to produce the final product CO<sub>2</sub> liquid for transport in pipelines.

The inert gases leaving the separation tanks are still at a high pressure. These are vented to atmosphere after passing them through an expander to recover some electrical energy from the process.

This section has a huge duty for both compression and cryogenic cooling. The heat exchangers must be constructed in special material due to the problems of corrosion and the very low temperature. An appropriate selection of material of construction is an important issue to be evaluated to guarantee a good operation of the plant.

Unit 3000: Steam Turbine and Preheating Line

The block flow diagram of the Unit is attached to paragraph 1.3 of this Section.

The turbine consists of a HP, IP and LP sections all connected to the generator on a single shaft. Main steam from the boiler passes through the stop valves and control valves and enter the turbine at 290 bar, 600°C. Steam from the exhaust of the HP turbine is returned to the boiler gas path for reheating and is then throttled into the double flow IP turbine at 60 bar, 620°C. Exhaust steam from IP flows into a double flow LP turbine and then downward into the condenser at 0.032 bar, 25°C.

Waste heat from carbon dioxide compressor intercoolers is recovered to preheat boiler feedwater and the condensate from the condenser.

This integration between power plant and CO<sub>2</sub> capture plant allows to maximize the efficiency of the process. This also reduces the MP/LP steam extractions to preheat condensate and BFW in the LP/HP preheating line. The feed-water is finally heated in HP feed water heaters to 295°C prior to entering the boiler.



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 15 of 25  
**CASE 2**

Integration Between The Various Units Of The Plant.

The plant configuration studied considers the following integrations between the various Units:

- The heat required for the drying of coal is partially generated by producing hot water in the Air Separation Unit from the inter-stage cooling in the compressors. The missing heat is recovered from CO<sub>2</sub> compression line.
- The ASU also generates a stream of nitrogen at 1.7 bar. This pressure is more than adequate for the inert medium for fluidising and drying of the input coal. Hence, this stream shall be used for lignite drying process, saving on the power requirements for an independent air blower.
- A part of the heat generated in the CO<sub>2</sub> compression line is recovered by preheating BFW and the condensate, reducing the duty of the HP/LP feed water heaters.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---


Revision no.: Final  
Date: Nov. 2005  
Sheet: 16 of 25  
**CASE 2**

**2.3 Block Flow Diagrams**


The Block Flow Diagrams of the following process units are attached to this paragraph:

- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 1100: Air Separation Unit (ASU)
- UNIT 2000: Boiler Island with Electro Static Precipitators (ESP)
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Separation Unit


# UNIT 1000 - Coal and Ash Handling




# UNIT 1100 - Air Separation Unit ASU




# UNIT 2000 - Boiler Island



# UNIT 3000 - Steam Turbine & Preheating Line



# UNIT 4000 – CO<sub>2</sub> Separation Unit



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 17 of 25  
**CASE 2**


**2.4 Heat and Material Balances**


The Heat & Material Balances of the following process units are attached to this section:


- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 1100: Air Separation Unit (ASU)
- UNIT 2000: Boiler Island with Electro Static Precipitators (ESP)
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Separation Unit

Stream numbers are as shown on the Block Flow Diagrams attached to Chapter 2.3 of this Section.



 <b>FOSTER WHEELER</b>	Oxyfuel PC-USC HEAT AND MATERIAL BALANCE					REVISION	0	1		
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME					PREP.	SR			
	CASE : CASE 2					APPROVED	LM			
	UNIT : 1000 Coal & Ash Handling					DATE	Feb 05			
STREAM	1	2	3	4	5		6	7	8	9
	Coal to Plant	Coal to Boiler Island	Fly Ash	Bottom Ash	Nitrogen Vent from Lignite Dryer					
Temperature (°C)	AMB	AMB	AMB	AMB	60					
Pressure (bar)	ATM	ATM	ATM	ATM	ATM					
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	677589	491252	18970	4740	1221542					
Molar flow (kgmole/h)										
<b>LIQUID PHASE</b>										
Moisture	Moisture	Moisture								
Mass flow (kg/h)	50.70%	32.0%								
Composition wt% with moisture										
Carbon	31.33%	43.21%			77.31%	Nitrogen				
Hydrogen	2.29%	3.16%			0.27%	Argon				
Oxygen	11.56%	15.94%			0.47%	Oxygen				
Sulfur	0.22%	0.31%			21.94%	Water				
Nitrogen	0.37%	0.51%								
Chlorine	0.03%	0.05%								
Moisture	50.70%	32.00%								
Ash	3.50%	4.83%								

 <b>FOSTER WHEELER</b>	Oxyfuel PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME						PREP.	SR		
	CASE : CASE 2						APPROVED	LM		
	UNIT : 1100 Air Separation Unit ASU <span style="float: right;">Sheet 1 of 1</span>						DATE	Feb 05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Ambient Air Inlet	Oxygen	Nitrogen to Drying							
Temperature (°C)	6	16	16							
Pressure (bar)	1.01	1.6	1.4							
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	2830242	677418	1035205							
Molar flow (kgmole/h)	97932	21064	36858							
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	0	0								
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	2830242	677418	1035205							
Molar flow (kgmole/h)	97932	21064	36858							
Molecular Weight	28.90	32.16	28.09							
Composition (vol %)										
N <sub>2</sub>	77.31%	1.98%	99.04%							
CO <sub>2</sub>	0.04%	0.00%	0.00%							
H <sub>2</sub> O	1.00%	0.00%	0.00%							
O <sub>2</sub>	20.73%	94.98%	0.61%							
Ar	0.92%	3.04%	0.35%							
NO <sub>x</sub>	0.00%	0.00%	0.00%							
SO <sub>x</sub>	0.00%	0.00%	0.00%							
CO	0.00%	0.00%	0.00%							

 <b>FOSTER WHEELER</b>	Oxyfuel PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 2</b>						APPROVED	LM		
	<b>UNIT : 2000 Boiler Island</b>						DATE	Feb 05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Coal from Coal Dryer	Oxygen from ASU	Exhaust Flue Gas from Boiler	Flue Gas to Processing System	Flue Gas Recirculation	Feed Water from Preheating line UNIT 3000	HP Steam to Steam Turbine	IP Steam from Preheating Line UNIT 3000	IP Reheated Steam to Steam Turbine	
Temperature (°C)	AMB	16	135	30	30	295	600.00	358	620	
Pressure (bar)	AMB	1.6	1.04	1.02	1.02	339	290	65	60	
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	491252	677418	3529800	907000	1787600	2610000	2610000	2313600	2313600	
Molar flow (kgmole/h)		21064	113129	22604	44551					
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	0	0	0	0	0	2610000	2610000	2313600	2313600	
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	491252	677418	3529800	907000	1787600					
Molar flow (kgmole/h)		21064	113129	22604	44551					
Molecular Weight		32.16	31.20	40.13	40.13					
Composition (vol %)	See UNIT 1000									
N <sub>2</sub>		1.98%	7.66%	12.90%	12.90%	0.00%	0.00%	0.00%	0.00%	
CO <sub>2</sub>		0.00%	45.51%	76.29%	76.29%	0.00%	0.00%	0.00%	0.00%	
H <sub>2</sub> O		0.00%	42.91%	4.21%	4.21%	100.00%	100.00%	100.00%	100.00%	
O <sub>2</sub>		94.98%	3.80%	6.40%	6.40%	0.00%	0.00%	0.00%	0.00%	
Ar		3.03%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
NO <sub>x</sub>		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
SO <sub>x</sub>		0.00%	0.12%	0.20%	0.20%	0.00%	0.00%	0.00%	0.00%	
CO		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	



## Oxyfuel PC-USC HEAT AND MATERIAL BALANCE


CLIENT : IEA GREEN HOUSE R & D PROGRAMME

CASE : CASE 2

UNIT : 3000 Steam Turbine & Preheating Line

Sheet 1 of 1

Stream	Description	Flowrate t/h	Temperature °C	Pressure bar a	Entalphy kJ/kg
1	HP Water to Boiler Island	2610	295	339	1303
2	HP Steam from Boiler	2610	600	290	3456
3	IP Steam to Boiler	2314	358	65	3056
4	IP hot reheated steam to Steam Turbine	2314	620	60	3706
5	IP Steam Turbine exhaust	1886	283	6	3026
6	Condensate	1994	25	0.032	106
7	LP Preheated Condensate	2516	164	12	703
8	Condensate to HP FWH	2610	189	343	823
9	Cooling Water Inlet	85585	11	2	47
10	Cooling Water Outlet	85585	21	2	88

 <b>FOSTER WHEELER</b>	Oxyfuel PC-USC HEAT AND MATERIAL BALANCE						REVISION	0	1	
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME						PREP.	SR		
	CASE : CASE 2						APPROVED	LM		
	UNIT : 4000 CO <sub>2</sub> Separation Unit						DATE	Feb 05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Flue Gas from Boiler Island	Flue Gas Recirculation	Carbon Dioxide to Storage	Flue Gas vented to Atmosphere						
Temperature (°C)	30	30	35	56						
Pressure (bar)	1.02	1.02	110	1.01						
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	907000	1787600	725320	164500						
Molar flow (kgmole/h)	22604	44551	16642	5011						
<b>LIQUID PHASE</b>										
Mass flow (kg/h)			725320							
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	907000	1787600	725320	164500						
Molar flow (kgmole/h)	22604	44551	16642	5011						
Molecular Weight	40.13	40.13	43.58	32.83						
Composition (vol %)										
N <sub>2</sub>	12.90%	12.90%	1.99%	51.60%						
CO <sub>2</sub>	76.29%	76.29%	96.40%	24.00%						
H <sub>2</sub> O	4.21%	4.21%	0.00%	0.00%						
O <sub>2</sub>	6.40%	6.40%	1.34%	24.41%						
Ar	0.00%	0.00%	0.00%	0.00%						
NO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%						
SO <sub>x</sub>	0.20%	0.20%	0.27%	0.00%						
CO	0.00%	0.00%	0.00%	0.00%						

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 18 of 25  
**CASE 2**

**2.5 Utility Consumption**

The utility consumption of the process / utility and offsite units are shown in the attached Table.



CLIENT: IEA GHG  
 PROJECT: GASIFICATION POWER GENERATION STUDY  
 LOCATION: Germany  
 FWI N°:

Rev Final  
 Nov 05  
 ISSUED BY: SR.  
 CHECKED BY: LM  
 APPR. BY: RD

**ELECTRICAL CONSUMPTION SUMMARY - CASE 2 - PC - USC Oxyfuel**

UNIT	DESCRIPTION UNIT	Absorbed Electric Power [kW]
<b>PROCESS UNITS</b>		
1000	Coal - Ash Storage and Handling	340
1050	Coal Drying (Air fan consumption)	638
1100	Air Separation Unit	132000
2000	Boiler Island	11980
4000	CO <sub>2</sub> Separation Unit	112000
<b>POWER ISLANDS UNITS</b>		
3000	Steam Turbines and Preheating Line	2080
<b>UTILITY and OFFSITE UNITS 3000 - 4000 - 5000</b>		
	Cooling Towers	25600
	Others	9770
	<b>BALANCE</b>	294408





**2.6 PC-USC Overall Performance**

The following Table shows the overall performance of the PC-USC Complex.

<b>PC-USC Oxyfuel Combustion</b>		
<b>Case 2</b>		
<b>OVERALL PERFORMANCES</b>		
Coal Flowrate A.R.	t/h	677.6
Coal LHV A.R.	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>1976.3</b>
Steam turbine power output (@ gen. terminals)	MWe	1027.7
Expander power output	MWe	11.7
<b>GROSS ELECTRIC POWER OUTPUT OF PC - USC COMPLEX (D)</b>	<b>MWe</b>	<b>1039.4</b>
Coal Storage / Handling / Drying	MWe	1.0
Air Separation Unit	MWe	132.8
Boiler Island	MWe	12.0
CO <sub>2</sub> Separation Unit	MWe	112.6
Power Island (1)	MWe	2.1
Utilities	MWe	35.4
<b>ELECTRIC POWER CONSUMPTION OF PC-USC COMPLEX</b>	<b>MWe</b>	<b>295.8</b>
<b>NET ELECTRIC POWER OUTPUT OF PC-USC (C)</b>		
Step-up transformer efficiency (0.997)	<b>MWe</b>	<b>741.3</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>52.6%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>37.5%</b>

Notes: (1) Boiler Feed Water pumps are steam turbine driven.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: Nov. 2005

Sheet: 20 of 25

**CASE 2**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the PC-Oxycombustion Complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 43.21%wt)	17674
Slag	426
Net Carbon flowing to Process Units (A)	17248
Liquid Storage	
CO	0.0
CO <sub>2</sub>	<u>16044</u>
Total to storage (B)	16044
Emission	
CO	0.0
CO <sub>2</sub>	<u>1204</u>
Total Emission	1204
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>93</b>

## 2.7 Environmental Impact

The Oxyfuel PC-USC Complex is designed to process coal, whose characteristics are defined in the Basic Engineering Design Data and produce electric power. The advanced technology allows to reach a high efficiency and to minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the Oxyfuel PC-USC Complex are summarised in this section.

### 2.7.1 Gaseous Emissions

#### Main Emissions

In normal operation at full load, the main continuous emission is the gas leaving the CO<sub>2</sub> processing plant.

Table 1.1 summarises expected flow rate and concentration of the combustion flue gas after CO<sub>2</sub> capture treatment.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 21 of 25  
**CASE 2**

**Table 1.1 – Expected gaseous emissions from Oxyfuel PC-USC plant.**

	Normal Operation
Wet gas flow rate, kg/s	45.68
Flow, Nm <sup>3</sup> /h	112302
Temperature, °C	56
Composition	(%vol)
N <sub>2</sub>	51.60
O <sub>2</sub>	24.41
CO <sub>2</sub>	24.00
H <sub>2</sub> O	0
Emissions	kg/h
NO <sub>x</sub>	0
SO <sub>x</sub>	0.95
CO	0
Particulate	NIL

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Air with moisture : 1222 t/h  
 Particulate : 16.1 kg/h

Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by proper design and operation.

**2.7.2 Liquid Effluent**

The plant is designed for zero liquid effluents

**2.7.3 Solid Effluent**

Solid waste produced by the process units are typical for these plants  
 The power plant is expected to produce the following solid by-products:

Fly Ash

Flow rate : 19 t/h

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 22 of 25  
**CASE 2**

Bottom Ash

Flow rate : 4.7 t/h

Fly and bottom ash can be dispatched to cement industries.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: Nov. 2005

Sheet: 23 of 25

**CASE 2**

---

## **2.8 Equipment List**

The duty specifications of the main equipment and process packages are included in this paragraph.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: Nov. 2005  
Sheet: 24 of 25  
CASE 2

**UNIT 1000 – Coal handling and storage – Ash and Solid removal**

Coal Unloading train including:

- Hopper systems
- Coal conveying
- Stacker reclaimer
- Coal delivery equipment

Coal Pre-drying train including:

- Fluid Bed Dryer
- Hot Water based Gas Heater
- Filters for exhaust Gas

Fly ash handling System including:

- Pneumatic Conveying system
- Storage Silo
- Dust suppression System

Bottom ash systems

- Conveying System
- Clinker Crusher

Miscellaneous equipment

**UNIT 1100 – Air Separation Unit ASU**

Air Filter

Air Compressors

Air Coolers

Air Purification System

Main Exchanger Line

ASU Cold Box

Backup Storage Vessel

Pumps

**UNIT 2000 – Boiler Island with – Electro Static Precipitators (ESP)**

Tower type boiler including:

- Fresh Air Fans
- Fan Beater Mills
- Gas/Gas Heaters
- Electro Static Precipitator
- Induced Draft Fans
- Flue Gas Recirculation Fans
- Recycle Gas Preheater
- Miscellaneous equipment

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 25 of 25  
**CASE 2**

Auxiliary boiler  
Structures  
Control System

**UNIT 3000 – Power Island consisting of Steam Turbine and Preheating Line**

Steam turbine and generator package  
LP feedwaterheaters  
Deaerator  
HP feedwaterheaters  
Condenser Package  
Condensate pumps  
Steam turbine driven BFW pump  
LP pumps

**UNIT 4000 – CO<sub>2</sub> Separation Unit**

Direct Contact Flue Gas Cooler  
Compressors  
CO<sub>2</sub> pumps  
Drums and Vessels  
Heat Exchangers  
Water pumps  
Flue Gas Expander

**Utility and Offsite Units**

Cooling Water / Machinery cooling water systems (Unit 4100)  
Demineralized, Plant and Potable Water System (Unit 4200)  
Natural Gas System (Unit 4300)  
Plant / Instrument Air Systems (Unit 4400)  
Waste Water Treatment (Unit 4600)  
Fire Fighting System (Unit 4700)  
Chemicals (Unit 4900)  
Interconnecting (Instrumentation, DCS, Piping, Electrical, 400 KV Substation)  
(Unit 6000)

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 20  
**CASE 3**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 3 – FW CFB BOILER WITH POST COMBUSTION CO<sub>2</sub>  
 CAPTURE

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 2 of 20

**CASE 3**

---

**SECTION D**

**BASIC INFORMATION FOR EACH ALTERNATIVE**

**I N D E X**

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 3.0 Case 3 Circulating Fluidized Bed (CFB)
- 3.1 Introduction
- 3.2 Process Description
- 3.3 Block Flow Diagrams
- 3.4 Heat and Material Balances
- 3.5 Utility Consumption
- 3.6 CFB Overall Performance
- 3.7 Environmental Impact
- 3.8 Equipment List

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**
**3.0 Case 3 Foster Wheeler Circulating Fluidized Bed (CFB) Boiler with Postcombustion CO<sub>2</sub> Capture**
**Summary**

SuperCritical CFB boiler with SCR + Amine wash for CO<sub>2</sub> Absorption + CO<sub>2</sub> compression unit.

- The size of the plant considered for this configuration is based on the actual commercial size of CFB boilers. To provide a net power output consistent with other plants studied, two CFB boilers in parallel are employed, taking into account the additional steam and power requirements of all the equipment in the plant.
- The largest CFB boilers are still small in comparison to the largest pulverized coal (PC) boilers, which can be substantially larger than 1000 MWe. However, because CFB boilers are very similar to PC boilers in mechanical design and construction, much of what was learned in scaling up PC boilers can be and is being applied to CFB boiler scale-up. CFB boilers of bigger size are under investigation during these years and they will represent a commercially available technology in the next few years.
- The Boiler technology for firing coal considered in this study is a commercially available unit in the market.
- A pre-drying of the coal from a moisture level of 50.7% in as-received coal to about 32% is considered, before it is fed to the boiler plant. Drying of coal using low temperature waste heat is used for this alternative (Reference to Section C).
- CFB Technology is a modern way to burn coals with different characteristics, specifically developed to address today's needs for fuel flexibility and low emissions. The low furnace temperature provide for low NO<sub>x</sub> emissions, low SO<sub>x</sub> emissions via simple furnace limestone injection and the ability to fire a range of fuels, in particular low rank coals with high moisture content.
- The limits of NO<sub>x</sub> emissions can be met with just the firing system of the boiler with low temperature at furnace exit. However, an SCR system based on direct ammonia injection is considered in the boiler to reduce the NO<sub>x</sub> levels to about 20 ppmv, a requirement of the downstream CO<sub>2</sub> capture plant.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 4 of 20

**CASE 3**


---

- Downstream flue gas desulphurization is not required to meet SO<sub>x</sub> emission limits. SO<sub>x</sub> are captured by a limestone injection in the combustion chamber. The limestone reacts with the sulphur released from the fuel. The amount of limestone that is required is dependent on a number of factors such as the amount of sulphur in the fuel, the temperature of the bed and physical and chemical characteristics of the limestone. The ideal reaction temperature range is 840 – 900 °C. The downstream amine based CO<sub>2</sub> absorption system, again requires a very low level of SO<sub>2</sub> in the flue gas (much lower than the emission limits). This calls for a high SO<sub>2</sub> capture efficiency to reach the limit of 10 ppm of SO<sub>2</sub> at the exit of the boiler. With actual technology this limit can't be reached with the only limestone injection. Presently in CFB Boilers the minimum level obtainable is 15 ppm. In any case one of the main advantages of the CFB technology is the possibility to completely avoid the presence of the expensive FGD unit, so 15 ppm of SO<sub>2</sub> in the flue gas are considered acceptable for the CO<sub>2</sub> capture plant. An higher amine degradation in the CO<sub>2</sub> capture plant is also considered. The big advantage of completely avoid the FGD unit, in term of auxiliary power consumption and cost reduction, more than compensate the major amine degradation.
- Following the study performed by Fluor, a carbon dioxide capture plant based on solvent scrubbing of flue gas with amine solvents is considered. This is followed by steam stripping and recycle of the solvent and then drying and compression of the captured carbon dioxide. This is a technology commercially available for post combustion capture of carbon dioxide, from more than one supplier, albeit with an acceptable commercial risk for scaling to the size required for this plant. (Reference to Section C para. 7.0).
- The possible effect of any other impurities in the flue gas, even at small concentrations, on the CO<sub>2</sub> capture plant has to be studied further, both theoretically and in pilot operation plants.
- The configuration of the plant considered provides for a good heat integration of the various systems.
- All the heat required for the CO<sub>2</sub> capture plant is provided from the low temperature steam extracted from the turbine. This results in a significant loss of power in the turbine generator. Further, a significant optimisation of heat within the CO<sub>2</sub> capture plant is also considered with adequate heat exchangers between various streams within the plant.
- CO<sub>2</sub> is dried and compressed up to supercritical phase at 110 bar for use in EOR or for geological disposal.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 5 of 20  
**CASE 3**

---

**3.1 Introduction**

The Case-3 of the study is a Super Critical CFB steam plant fitted with Post-combustion carbon dioxide capture and compression units.


The configuration of the CFB complex is based on once through steam generator with superheating and a single steam reheating.

Reference is made to the attached Block Flow Diagram of the CFB power plant. The arrangement of the process units is:

**Unit**

1000	Coal handling and storage Ash and Solid removal Coal Drying System
2000	Boiler Island with SCR based De NO <sub>x</sub> , Limestone Injection and Electro Static Precipitators (ESP)
3000	Power Island consisting of Steam Turbine and Preheating Line
4000	CO <sub>2</sub> Capture Plant
5000	CO <sub>2</sub> Compression and Drying

# Case 3: CFB Block Flow Diagram



### 3.2 Process Description

*Note:* ‘Coal’ referred to in all the following sections means ‘low rank coal’ as defined in the BEDD document.

#### Unit 1000: Coal and Ash Handling

Please refer to Section C para. 1.0 for process description of this unit.

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the boiler plant.

#### Coal Pre-Drying:

This Scheme is described in Section C (Basic information for Low Rank Coal Power Plants) para. 2.0 (Drying of low rank coal lignite). A specific block flow diagram showing the main heating sources of this alternative is attached to paragraph 3.3.

The split of the heating sources required for the drying of the lignite is reported in the following table:

<b>Heat source</b>	<b>Duty, MWth</b>
Flue gas cooling from Boiler Island	26
CO <sub>2</sub> capture unit	72
CO <sub>2</sub> compression	26
<b>TOTAL HEAT</b>	<b>124</b>

#### Ash Handling Plant:

The ash handling system, takes care of conveying the ash generated in the boiler plant: both the furnace bottom ash and the fly ash from the various hoppers. (Reference to Section C).

#### Unit 2000: Boiler Island

This Unit is treated as a package supplied by Foster Wheeler. Supercritical CFB boilers firing coal of the size proposed for this study are commercially available and have gained a lot of operational experience.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 7 of 20  
**CASE 3**

---

The CFB Island consists of the boiler proper (furnace, solid separator, back pass), plus the material handling, air handling and other auxiliary equipment.

Milling Plant:

After drying process, the coal is delivered by conveyor belts to the boiler. In this case it is not necessary the pulverisation of coal and the final milling can be avoided. The particles size after drying (<8mm) is already suitable for the CFB boiler operation. The dried lignite is transferred to hoppers for boiler feeding. This system works in pressure to avoid back flow of flue gases from combustion chamber.

Tower Type Boiler:

The boiler would be a tower-type super critical boiler. The main distinguishing feature of a CFB boiler is the separator device at the furnace gas outlet which collect bed material entrained in the flue gas for recycle back to the furnace. The bed material contains fuel ash, unburned fuel, spent limestone and unutilized limestone. Collection and recirculation of this material back to the furnace results in excellent fuel burnout and limestone utilization.

The boiler heating surfaces are arranged in the tower at the exit of the furnace. The flue gases at the exit of the SCR, pass through to the air heater to preheat the incoming combustion air and an Electro Static Precipitator (ESP) to remove the carried over ash particles in the flue gas.

De-NO<sub>x</sub> System

An SCR system is provided to reduce the NO<sub>x</sub> produced by the combustion to a level which does not exceed the inlet requirement of the carbon dioxide capture plant, which corresponds to less than 20 ppmv of NO<sub>2</sub>. The catalytic De NO<sub>x</sub> reactor is situated in the gas stream between the boiler outlet and the air heaters. This offers a temperature range required for good functioning of the SCR system without the formation of ammonium sulfates. Gaseous ammonia is added to air supplied from a fan in a mixer as the reagent and injected into the flue gas. In the presence of the catalyst, ammonia reacts with nitrogen oxides to reduce it to nitrogen.

For Process Description of the De-NO<sub>x</sub> system, refer to Section C para. 4.0.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	8 of 20
<b>CASE 3</b>	

---

Flue Gas Coolers:

The flue gas needs to be cooled to about 30-35°C, as an operational requirement for the downstream CO<sub>2</sub> capture plant. The flue gas leaves the boiler at 128 °C and then is cooled till 85 °C recovering heat for combustion air preheating. Then it passes in a Direct Contact Cooler, performing an adiabatic quench, where it is cooled to 35° C, before entering absorption columns of the CO<sub>2</sub> Capture Plant.

Unit 4000: CO<sub>2</sub> Capture Plant

Clean flue gas with NO<sub>2</sub> less than 20 ppmv and SO<sub>x</sub> less than 15 ppm is now sent to the CO<sub>2</sub> absorption tower.

Refer to Section C para. 7.0 for this section.

Consequent to the detailed study presented by Fluor in its report for a similar technology study, an identical plant is considered for CO<sub>2</sub> capture; a commercial amine (MEA) scrubbing technology.

The Block Flow Diagram of this section is attached to paragraph 3.3.

In this study a 85% capture of CO<sub>2</sub> from the flue gas is considered.

Unit 5000: CO<sub>2</sub> Compression and Drying

Refer to Section C, para. 9.0 for the general description of the Unit.

The block flow diagram of this section is attached to paragraph 3.3.

CO<sub>2</sub> can be handled as a liquid in pipe lines at conditions beyond its critical point (P<sub>CR</sub>=73.8 bar; T<sub>CR</sub>=31°C). The present configuration studied, assumes, CO<sub>2</sub> to be delivered as a liquid at a pressure of around 110 bara.

Unit 3000: Steam Turbine and Preheating Line

The turbine consists of a HP, IP and LP sections all connected to the generator on a single shaft. Main steam from the boiler passes through the stop valves and control valves and enter the turbine at 283 bar, 584°C. Steam from the exhaust of the HP turbine is returned to the boiler gas path for reheating and is then throttled into the double flow IP turbine at 48 bar, 602°C. Exhaust steam from IP flows into a double flow LP turbine and then downward into the condenser at 0.032 bar, 25°C. The LP steam is also extracted for the use in the reboiler and stripping unit in the CO<sub>2</sub> capture plant.



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
 Date: November 2005  
 Sheet: 9 of 20  
**CASE 3**

The block flow diagram of this section is attached to paragraph 3.3.

Recycled condensate from the condenser is pumped to the carbon dioxide capture plant and preheated in the amine stripper overhead condenser and in the carbon dioxide compressor intercoolers. An optimisation of the integration between power plant and CO<sub>2</sub> capture plant allows to maximize the efficiency of the process. This also avoids the necessity of LP steam extractions to preheat condensate in LP preheating line. The preheated feed water stream is routed to the deaerator, along with condensate returned from the amine stripper reboiler. After deaeration the feed-water is heated in HP feed water heaters to 272°C prior to entering the boiler.

Integration Between The Process Units And The Power Island.

The plant configuration studied considers the following integrations between the Process Units and the Power Island:

- The heat required for the drying of coal is generated by producing hot water in the flue gas line, in CO<sub>2</sub> compression unit and in CO<sub>2</sub> capture plant.
- A part of the heat recovered in the CO<sub>2</sub> compression line is recovered by preheating the condensate, totally avoiding the use of LP feed water heaters.
- All the LP steam required for the CO<sub>2</sub> absorption plant is provided by extraction from the LP stage of the steam turbine.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 10 of 20  
**CASE 3**


---

### **3.3 Block Flow Diagrams**


The Block Flow Diagrams of the following process units are attached to this paragraph:

- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 2000: Boiler Island with SCR based De-NO<sub>x</sub>  
Electro Static Precipitators (ESP)  
Limestone Injection
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Capture Plant (Amine Scrubbing)
- UNIT 5000: CO<sub>2</sub> Compression and Drying


# UNIT 1000 - Coal and Ash Handling




# UNIT 2000 – Boiler Island




# UNIT 3000 - Steam Turbine & Preheating Line



# UNIT 4000 - CO<sub>2</sub> Capture Plant



# UNIT 5000 - CO<sub>2</sub> Compression & Drying



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 11 of 20  
**CASE 3**

---


**3.4 Heat and Material Balances**


The Heat & Material Balances of the following process units are attached to this section:

- UNIT 1000: Coal handling and storage  
Ash and Solid removal  
Coal Drying System
- UNIT 2000: Boiler Island with SCR based De-NO<sub>x</sub>  
Electro Static Precipitators (ESP)  
Limestone Injection
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line
- UNIT 4000: CO<sub>2</sub> Capture Plant (Amine Scrubbing)
- UNIT 5000: CO<sub>2</sub> Compression and Drying

Stream numbers are as shown on the Block Flow Diagrams attached to paragraph 3.3 of this Section.



CFB HEAT AND MATERIAL BALANCE						REVISION	0	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>					PREP.	SR	
	<b>CASE : CASE 3</b>					APPROVED	LM	
	<b>UNIT : 1000 Coal &amp; Ash Handling</b>					DATE	Feb-05	
						Sheet 1 of 1		
STREAM	1	2	3	4	5	6	7	8
	Coal to Plant	Coal to Boiler Island	Fly Ash	Bottom Ash	Air from Lignite Dryer			
Temperature (°C)	AMB	AMB	AMB	AMB	65			
Pressure (bar)	ATM	ATM	ATM	ATM	ATM			
<b>TOTAL FLOW</b>								
Mass flow (kg/h)	592883	429840	28800	12240	1071865			
Molar flow (kgmole/h)								
	Moisture 50.70%	Moisture 32%						
Composition wt% with moisture								
Carbon	31.33%	43.20%						
Hydrogen	2.29%	3.16%						
Oxygen	11.56%	15.94%						
Sulfur	0.22%	0.31%						
Nyrogen	0.37%	0.51%						
Chlorine	0.03%	0.05%						
Moisture	50.70%	32.00%						
Ash	3.50%	4.83%						

CFB HEAT AND MATERIAL BALANCE							REVISION	0
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR
	<b>CASE : CASE 3</b>						APPROVED	LM
	<b>UNIT : 2000 Boiler Island</b>						DATE	Feb-05
							Sheet 1 of 1	
STREAM	1	2	3	4	5	6	7	8
	Coal from Coal Dryer	Air intake from Atmosphere	Flue Gas From Boiler	Feed Water from Preheating line UNIT 3000	HP Steam to Steam Turbine	IP Steam from Preheating Line UNIT 3000	IP Reheated Steam to Steam Turbine	Limestone
Temperature (°C)	AMB	15	85	272	584	319	602	AMB
Pressure (bar)	AMB	1.013	1.03	313	283	51	48	ATM
<b>TOTAL FLOW</b>								
Mass flow (kg/h)	429840	2793374	3361176	2182000	2182000	2016000	2016000	27360
Molar flow (kgmole/h)		96690	116023	121155	121155	111938	111938	
<b>LIQUID PHASE</b>								
Mass flow (kg/h)		0		2182000	0	0	0	
<b>GASEOUS PHASE</b>								
Mass flow (kg/h)		2793374	3361176	0	2182000	2016000	2016000	
Molar flow (kgmole/h)		96690	116023	0	121155	111938	111938	
Molecular Weight		28.89	28.97	18.01	18.01	18.01	18.01	
Composition (vol %)	See UNIT 1000							
N <sub>2</sub>		77.57%	68.91%	0.00%	0.00%	0.00%	0.00%	
CO <sub>2</sub>		0.00%	13.51%	0.00%	0.00%	0.00%	0.00%	
H <sub>2</sub> O		0.68%	13.70%	100.00%	100.00%	100.00%	100.00%	
O <sub>2</sub>		20.86%	3.88%	0.00%	0.00%	0.00%	0.00%	
Ar		0.89%	0.00%	0.00%	0.00%	0.00%	0.00%	
NO <sub>x</sub>		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
SO <sub>x</sub>		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
CO		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	

Note (1): Limestone Analysis (wt %) CaCO<sub>3</sub> = 95% - MgCO<sub>3</sub> = 3.4% - Inert = 1.6%

# CFB HEAT AND MATERIAL BALANCE



CLIENT : IEA GREEN HOUSE R & D PROGRAMME


CASE : CASE 3

UNIT : 3000 Steam Turbine & Preheating Line

Sheet 1 of 1

Stream	Description	Flowrate t/h	Temperature °C	Pressure bar a	Entalphy kJ/kg
1	HP Water to Boiler Island	2182	272	313	1191
2	HP Steam from Boiler	2182	584	283	3413
3	IP Steam to Boiler	2016	319	51	2978
4	IP hot reheated steam to Steam Turbine	2016	602	48	3673
5	IP Steam Turbine exhaust	1563	239	3.6	2943
6	LP Steam to Reboiler	873	146	3.6	2747
7	Hot Condensate returned from Reboiler	873	135	3	566
8	LP Steam to Steam Turbine	761	239	3.6	2943
9	Condensate	884	25	0.032	105
10	LP Preheated Condensate	1194	143	9	600
11	Condensate to HP FWH	2182	176	316	762
12	Cooling Water Inlet	45850	11	3	47
13	Cooling Water Outlet	45850	21	3	88



CFB HEAT AND MATERIAL BALANCE							REVISION	0	1	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CASE 3</b>						APPROVED	LM		
	<b>UNIT : 5000 CO<sub>2</sub> Compression &amp; Drying</b>						DATE	Feb-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	CO <sub>2</sub> from Stripper	CO <sub>2</sub> to long term Storage	Condensate from Stripper Condenser	Preheated Condensate to Power Island						
Temperature (°C)	38	30	75	124						
Pressure (bar)	1.6	110	12	10						
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	596737	586433	884000	884000						
Molar flow (kgmole/h)	13897	13325	49084	49084						
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	0	586433	884000	884000						
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	596737	0	0	0						
Molar flow (kgmole/h)	13897	0	0	0						
Molecular Weight	42.94	44.01	18.01	18.01						
Composition (vol %)										
N <sub>2</sub>	0.01%	0.01%	0.00%	0.00%						
CO <sub>2</sub>	95.88%	99.99%	0.00%	0.00%						
H <sub>2</sub> O	4.11%	0.00%	100.00%	100.00%						
O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%						
Ar	0.00%	0.00%	0.00%	0.00%						
NO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%						
SO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%						
CO	0.00%	0.00%	0.00%	0.00%						

Sheet 1 of 1

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 12 of 20

**CASE 3**

---

### **3.5 Utility Consumption**

The utility consumption of the process / utility and offsite units are shown in the attached Table.









### 3.6 CFB Technology Overall Performance

The following Table shows the overall performance of the CFB Complex.

<b>CFB</b>		
<b>Case 3</b>		
<b>OVERALL PERFORMANCES OF THE CFB COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	592.9
Coal LHV (A.R.)	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>1729.3</b>
Steam turbine power output (@gen. Terminals)	MWe	763.0
<b>GROSS ELECTRIC POWER OUTPUT OF CFB COMPLEX (D)</b>	<b>MWe</b>	<b>763.0</b>
Coal Storage / Handling / Drying	MWe	1.9
Boiler Island	MWe	28.1
CO <sub>2</sub> Plant incl. Blowers	MWe	25.4
CO <sub>2</sub> Compression	MWe	64.6
Power Island (1)	MWe	1.1
Utilities	MWe	25.5
<b>ELECTRIC POWER CONSUMPTION OF CFB COMPLEX</b>	<b>MWe</b>	<b>146.6</b>
<b>NET ELECTRIC POWER OUTPUT OF CFB (C)</b>		
<b>Step-Up Transformer Efficiency (0.997)</b>	<b>MWe</b>	<b>614.6</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>44.1%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>35.5%</b>

Notes: (1) Boiler Feed Water pumps are steam turbine driven.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 14 of 20  
**CASE 3**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the CFB Complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 43.21%wt)	15466
Limestone	259.7
Slag	50.7
<b>Net Carbon flowing to Process Units (A)</b>	<b>15675</b>
Liquid Storage	
CO	0.0
CO <sub>2</sub>	<u>13324</u>
<b>Total to storage (B)</b>	<b>13324</b>
Emission	
CO	0.0
CO <sub>2</sub>	<u>2351</u>
<b>Total Emission</b>	<b>2351</b>
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85.0</b>

### 3.7 Environmental Impact

The CFB Complex is designed to process coal, whose characteristics are defined in the Basic Engineering Design Data and produce electric power. The advanced technology allows to reach an high efficiency and to minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the CFB Complex are summarised in this section.

#### 3.7.1 Gaseous Emissions

##### Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases leaving the absorber unit of the CO<sub>2</sub> capture plant.

Table 3.1 summarises expected flow rate and concentration of the combustion flue gas after CO<sub>2</sub> capture treatment.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 15 of 20

**CASE 3**
**Table 3.1** – Expected gaseous emissions from CFB plant integrated with CO<sub>2</sub> capture.

	Normal Operation
Wet gas flow rate, kg/s	741
Flow, Nm <sup>3</sup> /h	2169430
Temperature, °C	46
Composition	(%vol)
N <sub>2</sub>	82.60
O <sub>2</sub>	4.65
CO <sub>2</sub>	2.43
H <sub>2</sub> O	10.31
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NO <sub>x</sub>	40
SO <sub>x</sub>	43 <sup>(2)</sup>
CO	Less than 150
Particulate	Less than 30
NH <sub>3</sub>	5 <sup>(3)</sup>

 (1) Dry gas, O<sub>2</sub> Content 6% vol

 (2) SO<sub>x</sub> Emissions upstream AGR unit; after solvent washing, emissions are expected close to zero

(3) Due to ammonia slippage into the flue gas downstream the SCR

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 16 of 20  
**CASE 3**

---

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Flow rate : 1072 t/h  
 Particulate : 21 kg/h

Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by routing all vents to a bag filter.

**3.7.2 Liquid Effluent**

The plant would be designed for zero liquid effluents

**3.7.3 Solid Effluent**

The power plant is expected to produce the following solid by-products:

Fly Ash

Flow rate : 28,8 t/h

Bottom Ash

Flow rate : 12,2 t/h

The amount of ash produced in a CFB boiler is slightly higher than in a traditional PC boiler because besides the ash in the coal there is also the ash due to the injection of limestone for SO<sub>x</sub> removal. This ash consists of Calcium Sulfate, Calcium Oxide not reacted and the inerts included in limestone.

Fly and bottom ash are used as bed filling and/or dispatched to cement industries.

The Calcium Sulfate is not a pure product as in the case of PC boiler and can't be sold as pure gypsum.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 17 of 20

**CASE 3**

---

### **3.8 Equipment List**

The list of the main equipment and process packages are included in this section.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 18 of 20  
**CASE 3**

**UNIT 1000 – Coal handling and storage – Ash and Solid removal**

Coal Unloading train including:

- Hopper systems
- Coal conveying
- Stacker reclaimer
- Coal delivery equipment

Coal Pre-drying train including:

- Fluid Bed Dryer
- Air fan
- Hot Water based Air Heater
- Filters for exhaust air

Fly ash handling System including:

- Pneumatic Conveying system
- Storage Silo
- Dust suppression System

Bottom ash systems

- Conveying System
- Clinker Crusher

Miscellaneous equipment

**UNIT 2000 – Boiler Island with SCR based De NOx – Electro Static Precipitators (ESP)**

CFB boiler including:

- Coal and Limestone Silos
- Fresh Air Fans - Primary air fan
- Secondary air fan
- Fluidizing Air Blower
- SCR DeNOx System
- Air Heaters
- Electro Static Precipitator
- Hot Water Generator
- Ash Cooler
- Miscellaneous equipment

Auxiliary boiler

Structures

Control System

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 19 of 20  
**CASE 3**

### **UNIT 3000 – Power Island consisting of Steam Turbine and Preheating Line**

Steam turbine and generator package  
Deaerator  
HP feedwaterheaters  
Condenser Package  
Condensate pumps  
Steam turbine driven BFW pump  
LP pumps

### **UNIT 4000 – CO<sub>2</sub> Capture Plant**

Flue gas blower  
Absorption towers  
Packing  
Stripper tower  
Packing for stripper  
Stripper reboiler  
Overhead stripper condenser  
Water wash cooler  
Cross exchangers  
Lean solvent cooler  
Flash preheater  
Reclaimer  
Soda ash dosing  
Amine filter package  
MEA storage tank  
MEA circulation pumps  
Wash water pumps  
Surplus water pumps  
Reflux pump  
Surplus water tankage



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 20 of 20

**CASE 3**

---

## **UNIT 5000 – CO<sub>2</sub> Compression and Drying**

Compression package

Drying package

CO<sub>2</sub> pumps

KO drums

Intercooling heat exchangers

Intercooling Water circulation pumps

### **Utility and Offsite Units**

Cooling Water / Machinery cooling water systems (Unit 4100)

Demineralized water system (Unit 4200)

Natural Gas System (Unit 4300)

Plant / Instrument Air Systems (Unit 4400)

Raw-Service-Potable water system (Unit 4500)

Fire Fighting System (Unit 4600)

Chemicals

Interconnecting (Instrumentation, DCS, Piping, Electrical, 400 KV Substation) (Unit 6000)

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 22  
**CASE 4**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 4 –FW PRESSURIZED CIRCULATING FLUID BED BOILER  
 (PCFB) WITH POSTCOMBUSTION CO<sub>2</sub> CAPTURE

ISSUED BY : G.L. FARINA  
 CHECKED BY : R. DOMENICHINI  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 2 of 22

**CASE 4**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

##### **4.0 Case 4 Pressurized Circulating Fluid Bed Boiler (PCFB)**

- 4.1 Introduction
- 4.2 Process Description
- 4.3 Block Flow Diagrams
- 4.4 Heat and Material Balances
- 4.5 Utility Consumptions
- 4.6 PCFB Overall Performance
- 4.7 Environmental Impact
- 4.8 Equipment List

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**
**4.0 CASE 4 Foster Wheeler Pressurized Circulating Fluid Bed Boiler (PCFB) with Postcombustion CO<sub>2</sub> Capture**
**Summary**

Pressurized Circulating Fluid Bed Boiler (PCFB) with Amine wash for CO<sub>2</sub> Absorption + CO<sub>2</sub> Compression Unit.

- The size of the plant considered for this configuration is based on the size required to provide nearly the same net output for all the other configurations taking into account the additional steam and power requirements of all the equipment in the plant.
- A pre-drying of the coal from a moisture level of 50.7% in as-received coal to about 32% is considered, before it is fed to the boiler plant. Drying of coal using low temperature waste heat is used for this alternative (Reference to Section C).
- The boiler technology for firing coal considered in this study is commercially in operation. The boiler is a Pressurized Circulating Fluid Bed type boiler. Limestone is added to the coal, which provides for a 97% sulphur capture and an SO<sub>2</sub> level in the flue gas equal to 38 mg/Nm<sup>3</sup> (dry-6% O<sub>2</sub>). After amine scrubbing the SO<sub>2</sub> is further reduced to less than 20 mg/Nm<sup>3</sup> (dry – 6% O<sub>2</sub>).
- NO<sub>x</sub> in the flue gas is kept under control by the combined effect of the low combustion temperature of the fluid bed (870°C) and the use of SNCR to keep in the flue gas 40 mg/Nm<sup>3</sup> (dry – 6% O<sub>2</sub>).
- CO<sub>2</sub> is captured by solvent scrubbing of the flue gas with 50% MDEA solution (amine Guard FS). MDEA is a sterically hindered amine, which is effective for CO<sub>2</sub> absorption under pressure. The main advantage with respect a MEA washing is the reduction of the solvent stripping steam consumption.
- The configuration of the plant considered provides a heat integration of the various systems.
- All the heat required for the CO<sub>2</sub> capture plant is provided from the low temperature steam extracted from the turbines of a steam cycle based on operation at supercritical conditions.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 4 of 22

**CASE 4**

---

- CO<sub>2</sub> is dried and compressed up to a supercritical phase at 110 bar for use in EOR or for geological dispose.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 5 of 22  
**CASE 4**

---

**4.1 Introduction**

The Case-4 of this study is a Pressurized Circulating Fluidized Boiler (PCFB) steam plant fitted with Post-Combustion carbon dioxide capture and compression units.

The configuration of the Power Plant is based on a PCFB boiler island with steam generator at supercritical conditions with superheating and single steam reheating.

Reference is made to the Process Flow Diagram attached to paragraph 4.3.

The PCFB Complex is divided in the following process units:

**Unit**

- |      |  |
|------|--|
| 1000 | Coal and limestone handling and storage<br>Coal crushing and drying<br>Ash Removal (Multiple modules in parallel)  |
| 2000 | PCFB boiler island<br>Recuperative exchangers<br>Candle Filter<br>Three modules, each with 33% capacity            |
| 3000 | Turboexpander and air compression<br>BFW Heater<br>Three modules, each with 33% capacity                           |
| 4000 | Steam power island<br>Two modules, each with 50% capacity  |
| 5000 | Flue gas water quench<br>CO <sub>2</sub> removal<br>Three modules except amine regenerator which is single module. |
| 6000 | CO <sub>2</sub> compression and drying single module   |

## 4.2 Process Description

Note: “Coal” referred to in all the following sections means “low rank coal” as defined in the BEDD document.

The technology used in this Case-4 is a circulating fluid bed boiler operating at 16.3 bar (a), thus permitting the capture of CO<sub>2</sub> by scrubbing the flue gas under pressure. The main features of this Case 4 are presented in the following sub paragraphs, to be read in conjunction with the flowsheet (Fig. 1), attached to paragraph 4.3.

a. the net power output of this case is consistent with the capacities of the other cases studied. To achieve this goal the following factors have been taken into account:

- maximum demonstrated capacity of PCFB boiler. The 360 MW Karita no. 1 plant (Japan), in commercial operation, is the reference point.
- capacity of Dresser Rand Turboset used in the expansion of the pressurized flue gas.

The structure of the power plant selected for CASE 4 takes into account the capacities of these two key components and, for an expected net power output of approximately 700 MW, is based on the following number of key-items:

- 3 PCFB boilers.
- 3 Dresser Rand Turbosets, each consisting of 2 expanders, 2 low pressure and 1 high pressure air compressors.
- 3 boiler feedwater heaters, each connected to a D.R. Turboset.
- 2 x 50% capacity steam turbines
- 3 CO<sub>2</sub> absorbers and one common amine regenerator
- 1 CO<sub>2</sub> compression set.

b. Lignite fed to the PCFB boilers needs not to be pulverized, as in PC boilers, but must be reduced to a maximum size of 6 mm, to match the requirements of fluid bed operation. After crushing the lignite is dried to improve the power plant efficiency. A fluid bed drier is used to reduce the moisture from 50.7 to 32%. Low temperature waste heat is the drier energy input, according to the technology described in Section C, paragraph 2, but the

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 7 of 22  
**CASE 4**

flue gas from the expander, after heat recovery, is used instead of air, as stripping medium.

The split of the heating sources required for the drying of the lignite is reported in the following table:

<b>Heat source</b>	<b>Duty, MWth</b>
Flue gas from turboset	76.5
Condensate from quench	75.5
<b>TOTAL HEAT</b>	<b>152</b>

Limestone is added to the sized coal to achieve a molar ratio Ca/S equal to 2, which provides for a 97% sulphur capture and an SO<sub>2</sub> level in the flue gas equal to 38 mg/Nm<sup>3</sup> (dry – 6%O<sub>2</sub>). After amine scrubbing the SO<sub>2</sub> is further reduced to less than 20 mg/Nm<sup>3</sup> (dry – 6%O<sub>2</sub>).

Coal and sorbent (limestone) are fed to PCFB boilers by lock-hoppers and screw feeders, pressurized with air at 35 bar.

NO<sub>x</sub> in the flue gas is kept under control by the combined effect of the low combustion temperature of the fluid bed (870°C) and the use of SNCR (injection of NH<sub>3</sub>). NO<sub>x</sub> in the flue gas is kept below 40 mg/Nm<sup>3</sup> (dry – 6%O<sub>2</sub>).

The PCFB boilers combustion air is supplied by the compressor sets driven by the flue gas expanders.

Excess air is 15% vol., achieving a combustion efficiency in excess of 99%. The boilers heat loss is less than 0.2 % of the coal heat input.

- c. The PCFB boiler, in essence, is a conventional, atmospheric pressure, circulating fluidized bed boiler, placed inside a pressure vessel. It consists of a vertical riser, two refractory lined cyclones and 3 Intrex™ fluid bed exchangers (see Fig. 2). The enclosure walls of the riser and the 3 Intrex™ fluid bed exchangers are water cooled tube membrane, containing both evaporative and primary superheat surface.

To minimize the pressure vessel diameter the Intrex™ fluid bed exchangers are stacked vertically. Each exchanger is formed by a tube bundle, submerged in a slow moving fluid bed (0.3-0.4 m/sec), thus minimizing erosion. The top two exchangers superheat HP steam, while the bottom one reheats MP steam. The recirculating bed material from the cyclone is cooled down from 870°C to approximately 700°C by the fluid bed exchangers and then returns to the riser bottom where it mixes with the incoming fresh coal feed. Non mechanical Y valves control the solid flow from the cyclones and from the exchangers to the riser.

The PCFB boiler is approximately 55-60 m tall, with a diameter of 12 m.



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 8 of 22  
**CASE 4**

Compressed air, 17.3 bar (a) and 232°C, enters at the top of the vessel and flows down through the annular space between the vessel and the internals. Dampers control the distribution of air among the multiple injection points to achieve a staged combustion which minimizes the formation of NO<sub>x</sub>.

- d. The raw flue gas exits from the top of the PCFB boiler at 870°C and 16,3 bar (a) and is cooled down to 343°C in the no. 1 Recuperative Exchanger. This is a pressure vessel which contains two tube bundles; the first bundle reheats the CO<sub>2</sub> free flue gas from 290°C to 700°C; the second tube bundle partially superheats the HP steam to 510°C. Raw flue gas at 343°C is filtered in a porous metal candle filter to separate entrained ash. Entrained fly ash is approximately 75% of total ash while the remaining 25% is bottom ash collected in the bottom hopper of the PCFB boiler.

The flue gas exiting the filter, is further cooled to 104°C in the Recuperative Exchanger no. 2, which reheats to 290°C the CO<sub>2</sub> free flue gas from the CO<sub>2</sub> absorbers.

The flue gas is further cooled to 38°C by direct contact with cooling water in the quench tower. Hot water (102°) from the quench tower is used as heating medium in a coil inside the lignite fluid bed drier.

Particulate free flue gas, at 38°C and 15.5 bar(a), is contacted with 50% MDEA solution (amine Guard FS). MDEA is a sterically hindered amine, which is an effective solvent for CO<sub>2</sub> absorption under pressure. The main advantage is a reduction of the solvent stripping steam consumption, because a fraction of the CO<sub>2</sub> is dissolved in the solvent under the effect of pressure, and can be released by a pressure reduction, in the flash drum, with no steam demand. The saving of stripping steam is reflected by the expected specific energy consumptions of MEA, operating at pressure close to atmospheric (100% chemical absorption) and MDEA, operating at 15 bar (a) pressure (chemical and physical absorption):

MEA	800-850 kcal/kg of CO <sub>2</sub>
MDEA	650-700 kcal/kg of CO <sub>2</sub>

The MDEA wash is designed to remove 85% of the CO<sub>2</sub> in the raw flue gas. The rich solvent from the absorbers is first flashed at an intermediate pressure, to release the gas dissolved under the effect of pressure, and then stripped in a common regenerator, which recycles back the lean solvent to the absorber. The CO<sub>2</sub> rich gas from the flash drum and from the regenerator is processed in the CO<sub>2</sub> compression section; a description of this section is given in Section C, paragraph 9. The purity of compressed CO<sub>2</sub> is 99.3% vol.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 9 of 22  
**CASE 4**

The CO<sub>2</sub> free flue gas from the absorbers is recycled back to the Recuperative Exchangers no. 1 and no. 2 to recover heat from the raw flue gas. After the Recuperative Exchanger no. 2 some preheated BFW is added to the CO<sub>2</sub> free flue gas stream, to solve pinch point problems in the subsequent exchanger.

The CO<sub>2</sub> free flue gas, at 700°C and 14.8 bar (a) is expanded in the turboset expanders, driving the air combustion compressors and producing, in addition 82,15 MWe. Additional energy could be recovered by increasing the CO<sub>2</sub> free flue gas temperature to 750-800°C. This could be accomplished passing the flue gas from the Recuperative Exchanger no. 1 in a tube bundle in the bed of an Intrex™ exchanger, inside the PCFB boiler. However this possible upgrade of the technology was not used to avoid the recourse to sophisticated alloys and valving in the expander feed line.

The presence of alkali traces in the flue gas could be taken care by spraying in the boiler cyclones exit a water slurry of pulverized emathelyte, which captures alkali vapours. However this is not necessary because the chances of finding alkali vapours in the hot flue gas going to the expander are nil. In fact the flue gas, before reheating, is cooled down to ambient temperature for amine scrubbing and all alkali vapours disappear below 530°C, by condensation on the particulate. Further in this design flue gas is filtered in porous metal candle filter, thus supplying to the expander a clean flue gas, particle free. In this situation the operation of the expander is expected to be easy and problem free.

The expanded flue gas, after heat recovery to preheat the boiler feed water, is compressed by a blower to be used as stripping medium in the lignite fluid bed drier. The flue gas emerging from the fluid bed drier, at 65°C, is filtered in a bag house filter to stop any entrained carbon particle and then routed to the stack.

- e. Steam cycle, shown in Fig. 1, is based on operation at supercritical conditions. HP steam is delivered to the steam turbine at:

290 bar (a)  
585 °C

Intermediate pressure, 50 bar (a), IP steam is reheated to 600°C. Substantial amounts of low pressure steam is used to drive, with a steam turbine, the HP BFW pump and to feed the MDEA reboiler:

HP BFW Pumps :	131 t/h	8 bar steam
MDEA Reboiler :	817 t/h	3.5 bar steam

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 10 of 22

**CASE 4**

---

The plant has a large excess of low temperature heat which cannot be reused. The following low grade heat sources are rejected to cooling water or air:

- CO<sub>2</sub> compression interstage coolers (part of the heat that is not recovered for lignite drying)
- MDEA stripper off-gas
- Lean MDEA solvent cooling
- Ash cooling

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 11 of 22

**CASE 4**

---

### **4.3 Block Flow Diagrams**

The Process Flow Scheme of the plant is attached to this paragraph (Fig. 1).

The General arrangement of the PCFB Boiler is shown in Fig. 2.




Figure 1 - Plant Process Flow Scheme

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
Date: November 2005  
Sheet: 12 of 22  
**CASE 4**




Figure 2 PCFB Boiler General Arrangement

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005


Sheet: 13 of 22

**CASE 4**

---


#### **4.4 Heat And Material Balances**


The Heat & Material Balances are shown in the following Tables. The stream numbers are those indicated in the process flowsheet of Fig.1, attached to paragraph 4.3. The flowrates shown in the Material Balance are for the entire plant and not for the single modules.

	HEAT AND MATERIAL BALANCE						REVISION	0
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME						PREP.	GLF
	CASE : CASE 4 - PCFB						APPROVED	RD
	Sheet 1 of 4						DATE	Feb '05
STREAM (Solid)	1	2	3	4	7			
	Raw Lignite	Dry Lignite 32% H2O	Limestone	PCFB Solid Feed	ASH			
Temperature (°C)	9	65	9	38	340			
Pressure (bar a)	1	1	1	24.4	1			
<b>COAL</b>								
Flow (t/h)	727.0	527.1		537.1				
Comp. (% wt)								
C	31.33	43.23		42.43				
H <sub>2</sub>	2.29	3.15		3.09				
O <sub>2</sub>	11.56	15.94		15.64				
S	0.22	0.30		0.30				
N <sub>2</sub>	0.37	0.51		0.50				
Cl	0.03	0.04		0.04				
H <sub>2</sub> O	50.70	32.00		31.40				
Ash	3.50	4.83		4.74				
LHV (kcal/kg)	2508	3460						
<b>SORBENT</b>								
Flow (t/h)			10					
Comp. (% wt)								
CaCO <sub>3</sub>			98.4	1.83				
MgCO <sub>3</sub>			0.1					
Inerts			1.5	0.03				
<b>ASH</b>								
Flow (t/h)					38			
Flyash (t/h)					28			
Bottom Ash (t/h)					10			





	HEAT AND MATERIAL BALANCE						REVISION	0	
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME						PREP.	GLF	
	CASE : CASE 4 - PCFB						APPROVED	RD	
	Sheet 3 of 4						DATE	Feb '05	
STREAM (Gas and Liquid)	14	15	16	17	18	19	20	21	
	FLUE GAS FROM EXPANDER	FLUE GAS TO STACK	COMPRES. CO2	LEAN MDEA	LP BFW	STEAM TO MDEA REB.	HP BFW TO HRSG	HP BFW TO HP HEATER	
Temperature (°C)	285	65	60	40	25	240	170	170	
Pressure (bar a)	1.04	1.03	110	19	21	3,6	323	323	
<b>FLOWRATE</b>									
t/h	2943	3146	710	9005	944	817	840	1160	
10 <sup>6</sup> x Nm <sup>3</sup> /h	2.403	2.656	-	-	-	-	-	-	
Comp. (% vol.)									
H <sub>2</sub> O	12.06	20.36	0.40						
O <sub>2</sub>	2.84	2.57							
N <sub>2</sub>	81.54	73.85	0.10						
Ar	0.92	0.83	0.20						
CO <sub>2</sub>	2.64	2.39	99.30						
SO <sub>2</sub>	Neg.	Neg.							
NO	Neg.	Neg.							
MW <sub>AVE</sub>	27.45	26.55	43.90						

	HEAT AND MATERIAL BALANCE						REVISION	0	
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME						PREP.	GLF	
	CASE : CASE 4 - PCFB						APPROVED	RD	
	Sheet 4 of 4						DATE	Feb '05	
STREAM (Gas and Liquid)	22	23	24	25	26				
	HP BFW TO PCFB	HP STEAM FROM RECUP EX. 1	HP STEAM TO HP TURB.	IP STEAM TO REHEATER	IP STEAM FROM REHEATER				
Temperature (°C)	261	510	585	319	600				
Pressure (bar a)	318	312	290	52.5	50				
<b>FLOWRATE</b>									
t/h	2000	2000	1990	1905	1905				
10 <sup>6</sup> x Nm <sup>3</sup> /h	-	-	-	-	-				

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 14 of 22

**CASE 4**

---

#### **4.5 Utility consumption**

The utility consumption of the process/utility and offsite units are shown in the attached Tables.



CLIENT: IEA GHG  
 PROJECT: GASIFICATION POWER GENERATION STUDY  
 LOCATION: Germany  
 FWI N°:

Rev Final  
 Nov 05  
 ISSUED BY: SR.  
 CHECKED BY: LM  
 APPR. BY: RD

**ELECTRICAL CONSUMPTION SUMMARY - CASE 4 - PCFB**

UNIT	DESCRIPTION UNIT	Absorbed Electric Power [kW]
<b>PROCESS UNITS</b>		
1000	Coal - Ash Storage and Handling	336
1050	Coal Drying (Air fan consumption)	684
2000/3000	Boiler Island & Turboset	11500
5000	CO <sub>2</sub> Capture Plant	7000
6000	CO <sub>2</sub> Compression and Drying	79000
<b>POWER ISLANDS UNITS</b>		
4000	Steam Turbine and Preheating line	1500
<b>UTILITY and OFFSITE UNITS</b>		
	Cooling Towers	20500
	Others	5000
<b>BALANCE</b>		<b>125520</b>





#### 4.6 PCFB Overall Performance

The following Table shows the overall performance of the PCFB Complex.

Coal Flowrate (A.R.)	t/h	727.0
Coal LHV (A.R.)	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>2120.4</b>
Steam turbine power output (@gen. Terminals)	MWe	733.86
Turboset Power Output	MWe	82.15
<b>GROSS ELECTRIC POWER OUTPUT OF PC - USC COMPLEX (D)</b>	<b>MWe</b>	<b>816.0</b>
Coal Storage / Handling / Drying	MWe	1.0
Boiler Island & Turboset	MWe	11.5
Steam Turbine and Preheating Line (1)	MWe	1.5
CO <sub>2</sub> Capture Plant	MWe	7.0
CO <sub>2</sub> Compression	MWe	79.0
Utilities/Offsites	MWe	25.5
<b>ELECTRIC POWER CONSUMPTION OF PC-USC COMPLEX</b>	<b>MWe</b>	<b>125.5</b>
<b>NET ELECTRIC POWER OUTPUT OF PC-USC (C)</b>		
<b>Step-Up Transformer Efficiency (0.997)</b>	<b>MWe</b>	<b>688.4</b>
<b>Gross electrical efficiency (D/A*100) (based on coal LHV)</b>	<b>%</b>	<b>38.5%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>32.5%</b>

Notes: (1) Boiler Feed Water pumps are steam turbine driven.



**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 16 of 22  
**CASE 4**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the IGCC Complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 57.19%wt)	18973
Limestone	98
Slag	190
<b>Net Carbon flowing to Process Units (A)</b>	<b>18881</b>
Liquid Storage	
CO	0.0
CO <sub>2</sub>	<u>16050</u>
<b>Total to storage (B)</b>	<b>16050</b>
Emission	
CO	0.0
CO <sub>2</sub>	<u>2831</u>
<b>Total Emission</b>	<b>2831</b>
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85</b>

#### 4.7 Environmental Impact

The PCFB Complex is designed to process coal, whose characteristics are defined in the Basic Engineering Design Data and produce electric power. The advanced technology allows to reach high efficiency and minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the PCFB Complex are summarised in this section.

##### 4.7.1 Gaseous Emissions

###### Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases leaving the lignite fluid bed drier.

Table 1 summarises the expected flow rate and composition of the combustion flue gas.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 17 of 22

**CASE 4**
**Table 1 – Expected gaseous emissions from PCFB plant integrated with CO<sub>2</sub> capture.**

	Normal Operation
Wet gas flow rate, kg/s	874
Flow, Nm <sup>3</sup> /h	2656000
Temperature, °C	65
Composition	(%vol)
N <sub>2</sub>	73,85
O <sub>2</sub>	2,57
CO <sub>2</sub>	2,39
H <sub>2</sub> O	20,36
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NO <sub>x</sub>	<40
SO <sub>x</sub>	<38 <sup>(2)</sup>
CO	Less than 150
Particulate	Less than 30
NH <sub>3</sub>	5 <sup>(3)</sup>

 (1) Dry gas, O<sub>2</sub> content 6% vol

 (2) SO<sub>x</sub> Emissions upstream AGR unit; after solvent washing, emissions are expected close to zero

(3) Due to ammonia slippage into the flue gas downstream the SNCR

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 18 of 22  
**CASE 4**

---

Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by routing all vents to a bag filter.

**4.7.2 Liquid Effluent**

The plant is designed to achieve zero liquid effluents

**4.7.3 Solid Effluent**

The power plant is expected to produce the following solid by-products:

Fly Ash

Flow rate : 28 t/h

Bottom Ash

Flow rate : 10 t/h

The amount of ash produced is slightly higher than in a traditional PC boiler because besides the ash in the coal there is also the ash due to the injection of limestone for SO<sub>x</sub> removal. This ash consists of Calcium Sulfate, Calcium Oxide not reacted and the inerts included in limestone.

Fly and bottom ash are used as bed filling and/or dispatched to cement industries.

The Calcium Sulfate is not a pure product as in the case of PC boiler and can't be sold as pure gypsum.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 19 of 22

**CASE 4**

---

#### **4.8 Equipment List**

The list of the main equipment and process packages are included in this section.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 20 of 22  
**CASE 4**

**UNIT 1000 – Coal and limestone handling and storage**

Coal Unloading train including:

- Hopper systems
- Coal conveying
- Stacker reclaimer
- Coal delivery equipment

Coal Pre-drying train including:

- Fluid Bed Dryer
- Air fan
- Hot Water based Air Heater
- Filters for exhaust air

Fly ash handling System including:

- Pneumatic Conveying system
- Storage Silo
- Dust suppression System

Bottom ash systems

- Conveying System
- Clinker Crusher

Miscellaneous equipment

**UNIT 2000/3000 – Boiler Island & Turboset**

3 Pulverized Coal Fluidized Bed boiler including:

- Vertical raiser
- 2 refractory lined cyclone separators
- 3 Intrex fluid bed exchangers
- Air Distributors
- Miscellaneous equipment

3 Dresser Rand Turbosets (2 expanders, 2 low pressure and 1 high pressure air compressors)

3 Boiler Feed Water Heaters

Structures

Control System

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 21 of 22  
**CASE 4**

---

### **UNIT 4000 – Steam Power Island consisting of Steam Turbine and Preheating Line**

Steam turbine and generator package  
Deaerator  
HP feedwaterheaters  
Condenser Package  
Condensate pumps  
Steam turbine driven BFW pump

### **UNIT 5000 – CO<sub>2</sub> Capture Plant**

Quench Tower  
Water pump  
Absorption towers  
Packing  
Flash Drum  
Stripper tower  
Packing for stripper  
Stripper reboiler  
Overhead stripper condenser  
Cross exchangers  
Lean solvent cooler  
Reflux Pump

### **UNIT 6000 – CO<sub>2</sub> Compression and Drying**

Compression package  
Drying package  
CO<sub>2</sub> pumps  
KO drums  
Intercooling heat exchangers  
Intercooling Water circulation pumps

### **Utility and Offsite Units**

Cooling Water / Machinery cooling water systems (Unit 4100)  
Deminerlized, Plant and Potable Water System (Unit 4200)  
Natural Gas System (Unit 4300)

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 22 of 22

**CASE 4**

Plant / Instrument Air Systems (Unit 4400)

Waste Water Treatment (Unit 4600)

Fire Fighting System (Unit 4700)

Chemicals (Unit 4900)

Interconnecting (Instrumentation, DCS, Piping, Electrical, 400 KV Substation)  
(Unit 7000)

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 28  
**Case 5**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 5-IGCC BASED ON FUTURE ENERGY GASIFICATION  
 WITH PRECOMBUSTION CO<sub>2</sub> CAPTURE

ISSUED BY : P. COTONE  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 28

**Case 5**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 5.0 Case 5: IGCC based on Future Energy gasification
- 5.1 Introduction
- 5.2 Process Description
- 5.3 Process Flow Diagrams
- 5.4 Heat and Material Balances
- 5.5 Utility Consumption
- 5.6 IGCC Overall Performance
- 5.7 Environmental Impact
- 5.8 Equipment List

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 3 of 28

**Case 5**

## **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

### **5.0 Case 5 IGCC Based on Future Energy gasification**

#### **5.1 Introduction**

The IGCC Complex of the study is a very large power production facility, converting coal to electric energy with a minimum impact to the environment. The key process step of the IGCC Complex is the gasification of coal. Gasification is the partial oxidation of coal, or any other fossil fuel, to a gas, often identified as syngas, in which the major components are hydrogen and carbon monoxide.

The partial oxidation agent used is oxygen, or air, supplemented usually by steam. The choice of oxygen or air depends on the type of gasifier, the final use of the syngas and the reactivity of the feed material. For this study the gasification technology selected is based on oxygen blown gasifier. For Future Energy Gasifier in case of Lignite Gasification, due to the high moisture content, a supplementation of steam is not necessary.

The syngas generated by gasification can be cleaned and then used in a combined cycle that is today the most efficient thermal cycle for power generation. The gasification therefore acts as a bridge between a low quality fossil fuel, coal, and the gas turbine with the target of high-energy efficiency and minimum emissions to the environment.

The gross production capacity of the IGCC Complex of the study is 900 MWe.

The IGCC Complex is a combination of several process units. The main process blocks of the Complex are:

- Coal milling and gasifier feed preparation;
- Air separation;
- Gasification;
- Syngas treatment and conditioning;
- Combined Cycle power generation;
- CO<sub>2</sub> Compression and Drying.

These basic blocks may be supported by other ancillary units, such as Sulphur recovery, Tail gas treatment, and a number of utility and offsite units, such as cooling water, flare, plant/instrument air, machinery cooling water, demineralised water, auxiliary fuels, etc.

Each process unit of the Complex may be a single train for the total capacity or split in two, three or more parallel trains, depending on the maximum capacity

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 4 of 28  
**Case 5**


of the equipment involved or on the necessity to assure, through the use of multiple parallel trains, a superior degree of reliability.

The arrangement of the main process units is:

<u><b>Unit</b></u>	<u><b>Trains</b></u>
1000 Gasification	4 x 33%
Waste Water Pre-treatment	1 x 100%
2100 ASU	2 x 50%
2200 Syngas Treatment and Conditioning Line	2 x 50%
2300 AGR	3 x 33%
2500 CO <sub>2</sub> Compression and Drying	2 x 50%
3000 Gas Turbine (PG 9351 – FA)	2 x 50%
HRSG	2 x 50%
Steam Turbine	1 x 100%

Reference is made to the attached overall Block Flow Diagram of the IGCC Complex.

## Case 5 – FUTURE ENERGY – IGCC COMPLEX BLOCK FLOW DIAGRAM




**5.2 Process Description**

*Coal Handling and Storage*

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the plant. For more details see section C, paragraph 1.

*Coal Drying:*

The basic features of this process are shown in Section C, para 2.0. The process scheme used for this specific alternative is shown in the following scheme.



The indirect Lignite Drying method has been used for this alternative.

This system could be specifically advantageous for the ICGG case, as a lot of source of low temperature heat exists in the plant design that can be used.

For Future Energy gasification the required moisture content in the feedstock is 10%.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 7 of 28  
**Case 5**

The split of the heating sources required for the drying of the lignite is reported in the following table:

Heat source	Duty, MWth
Syngas cooling	63
CO <sub>2</sub> compression	38
VLP steam (3.2 barg)	112
N <sub>2</sub> compression	12
<b>TOTAL HEAT</b>	<b>225</b>

Unit 1000: Gasification Island
*Feeding system:*

The coal feeding system consists of four coal silos, four mills and conveyor systems and four dosing unit, one for each gasifier.

The mills reduce the coal lignite size to a fine powder (>55% <100 μm; >99% <500 μm).

By means of conveyor systems the pulverized coal is passed to a dense-flow feeding system consisting of a sequence of an atmospheric fuel bunker, three lock hoppers and a feeder vessel.

The pulverized fuel settles in the fuel bunker, and the carrier gas and purging gas are vented over the bunker top. The full lock hopper is pressurized with purge gas (nitrogen).

The fuel in the feeder vessel is partially fluidised by means of a carrier gas (nitrogen) in the vortex shaft of the feeder vessel, in which the fuel conveying lines are immersed. Finally the fuel is pneumatically transported in a dense flow to the gasifier burners.

*Gasifier:*

The feedstock is gasified in a patented “Cooling Screen” design gasifier, highly suitable for high-ash containing feedstock. This design lowers the risk of slag attack to a refractory lining and offers long lifetime and low maintenance cost operation. For safe capture of slag and solids a full-quench system is proposed.

The gasifier consists of an outside pressure wall and an inside cooling screen cooled by pressurized water to protect the outside wall against chemical and thermal attacks.

The reactants, pulverized fuel and oxygen are fed into the reaction chamber in parallel flow through the combination burners at gasifier top. The latter are

converted in a heterogeneous flame reaction in entrained flow at a pressure of approximately 40 bar and temperatures exceeding slag melting temperatures.

At the top of the reactor one pilot burner and three main burners are arranged. Each main burner is equipped with one feed line. Nitrogen is used to maintain the circuit pressure at 1 bar above the reactor pressure to prevent migration of syngas into the cooling circuit in the event of a leak in the cooling coils or in the cooling shroud of the burner.

In the start-up phase the pilot burner is first run on Natural gas/N<sub>2</sub>-mixture.

Once the pilot burner for the ignition of the fuel is in temperature maintenance operation, the gasifier can be brought on line within minutes.

The partial oxidation reaction converts the coal lignite into hydrogen and carbon monoxide. The inert components in the feed are forming a slag.

*Quench:*

The hot raw synthesis gas and the liquid slag leave the gasifier reaction chamber and flow in parallel vertically downward and discharge directly into the quench section - where the raw gas is cooled down to approximately 220°C by injection of water. Slag produced is granulated in the water bath in the bottom of the Quench system.

The raw gas is saturated with steam (approx. 60%). This water becomes gas condensate in the following cooling steps of the syngas treatment and it will be recycled back as quench water.

The water of the quench, which is not vaporized, is flashed together with suspended solids (slag, fine ash, coke, soot and salts) and sent to the waste water pre-treatment.

*Slag Handling:*

The slag discharged from the Quench sump falls into a water-filled pressurized lock hopper. When the lock hopper is filled with slag, is cooled, depressurised and the slag and any water remaining in the hopper are discharged into a slag-receiving tank.

The major portion of the slag settles in the slag-receiving tank from where it is discharged by means of a drag chain conveyor. The slag is then washed on a slag wash conveyor to remove fines and quench water and is passed to a conveyor that transports the slag to a slag storage bin/container.

Waters carried out of the slag discharge system are collected in a conveyor overflow wet well and pumped to the waste water treatment plant via a hydro

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	9 of 28
<b>Case 5</b>	

---

cyclone. Water that is needed in the slag discharge system is recycled from the waste water treatment plant.

*Gas Scrubbing:*

The wet raw gas from the quench is cleaned in a venturi scrubber, where fine ash and soot particles are removed from the raw gas by water. Scrubber water is directed to the waste water treatment. Remaining solid particles in the raw syngas are separated from the gas in the course of gas cooling and water condensation.

*Waste Water Pre-Treatment:*

The liquid effluents from the quench systems, water from the slag separation and overflow of scrubbing water from the venturi scrubbers as well as process condensate, contaminated with fine particulate matter, soot and salts are treated in this section. Waste water from the quench circuit is first pre-treated mechanically by means of a cyclone and filter systems. Most of the pre-cleaned quench water is returned to the quench system.

The remaining part of the pressurized waste water is first sent to a flash vessel to remove all gas components, and then it is routed to the cyanide oxidation after passing a first cooling and neutralization.

During the next step the pre-treated water passes to the precipitation and flocculation tank, where flocculants are added to stimulate the coagulation and settlement of soot and fines. Fine slag and precipitate are removed and further dewatered using a fabric filter to separate the precipitate from the wastewater. The washed and dried filter cake is containerized for appropriate off-site disposal.

The cleared effluent of the thickener and the filtrate of the waste water filter are fed after a neutralisation, to the NH<sub>3</sub> stripping column. The stripped waste water is removed from the column and pumped via a cooler to a waste water tank. Finally the cleaned waste water is recycled to the slag discharge systems and to the quench. The stripper overheads are condensed and the ammonia water is recycled to the NH<sub>3</sub> stripper.

The vapour phase of the flash is cooled and sent together with the remaining gas of the NH<sub>3</sub> stripping column to the CO<sub>2</sub> compression and drying Unit.



**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 10 of 28  
**Case 5**

The main process streams of the Gasification Island relevant to this alternative are summarised in following table:

STREAM	FUEL FEED (COAL)	HP OXYGEN (95% purity)	HP NITROGEN	LP NITROGEN	SATURATED SYNGAS
Temperature (°C)	AMB.	21	21	21	180
Pressure (bar)		48	55	7.5	39
<b>TOTAL FLOW</b>					
Mass flow (kg/h)	357,900	257,600	74,350	17,570	1,268,500
Molar flow (kmol/h)					64,080
Composition (% vol)					
H <sub>2</sub>					10,0
CO					23,9
CO <sub>2</sub>					2,7
N <sub>2</sub> /Ar					2,7
O <sub>2</sub>					-
H <sub>2</sub> S + COS					0,07
H <sub>2</sub> O					60,50
Others					0,13

Note: Figures referred to the total flowrates

Unit 2100: Air Separation Unit (ASU)

This Unit is treated as a package unit supplied by specialised Vendors. The Air Separation Unit (ASU, Unit 2100) is installed to produce oxygen and nitrogen through cryogenic distillation of atmospheric air.

The oxygen produced is delivered to the Gasification Island to be used as reaction oxidant.

As a by-product nitrogen is obtained and is used for the pneumatic transport of dried pulverized coal to the gasifiers; the excess is routed to the syngas dilution and to the gas turbines for power augmentation and NO<sub>x</sub> control.

The Plant consists of two air separation trains and at the same time is able to produce additional oxygen and nitrogen products to maintain the desired

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 11 of 28  
**Case 5**

inventories in the storage systems of liquid and gaseous products used as back-up; these systems are common to both trains.

ASU is partially integrated with the gas turbines. When the gasification operates at full load, approx 30% of the air required by the ASU to obtain the design oxygen production is derived from both gas turbine compressors; the integration between the gas turbines operation and the ASU is achieved at a level where approx 70% of the atmospheric air is compressed with a dedicated air compressor and the difference comes already pressurized from the compressors of the gas turbines in the combined cycle. The air extracted from the gas turbine at high temperature is cooled by exchanging heat with nitrogen for syngas dilution before being fed to the Air Separation Unit.

The main process stream of the Air Separation Unit relevant to this alternative are summarised in following table:

STREAM	TOTAL AIR (1)	OXYGEN TO GASIFIERS (2)	HP NITROGEN (3)	LP NITROGEN (4)	TOTAL NITROGEN TO SYNGAS & GT
Temperature (°C)		21	21	21	100
Pressure (bar)		48	55	7.5	23
<b>TOTAL FLOW</b>					
Mass flow (kg/h)	1,143,000	257,600	74,350	17,570	574,000

Unit 2200: Syngas Treatment and Conditioning Line

This Unit receives the raw syngas from the gasification section, which is hot, humid and contaminated with acid gases, CO<sub>2</sub> and H<sub>2</sub>S, and other chemicals, like COS, HCN and NH<sub>3</sub>.

Before using this syngas as fuel in the gas turbines it is necessary to remove all the contaminants and prepare the syngas at the proper conditions of temperature, pressure and water content in order to achieve in the combustion process of the gas turbine the desired environmental performance and stability of operation.

Saturated raw syngas from wet scrubbing in Unit 1000, at approximately 40 bar and 180°C, enters Unit 2200. The syngas is first heated by the hot shift effluent and then enters the first stage of Shift Reactor, where CO is shifted to H<sub>2</sub> and CO<sub>2</sub> and COS is converted to H<sub>2</sub>S. The exothermic shift reaction brings the syngas temperature up to 419°C.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 12 of 28  
**Case 5**

---

In order to meet the required degree of CO<sub>2</sub> removal, a double stage shift containing sulphur tolerant shift catalyst (dirty shift) is used. The hot shifted syngas outlet from the first stage is cooled in a series of heat exchangers:

Shift feed product exchanger  
 HP Steam Generator  
 MP Steam Generator

Inlet temperature to the second stage shift is controlled to 263 °C. Outlet temperature from second shift is 324°C. The hot shifted syngas outlet from the second stage is cooled in a series of heat exchangers:

MP Steam Generator  
 LP Steam Generator  
 VLP Steam Generator  
 Condensate Preheater A/B

The final cooling step of the syngas takes place in a final cooler, where syngas is cooled with cooling water.

The condensate recovered from the Separator Drums is recycled back to the Gasification Unit.

The first and second stage of the shift reactor is split in two parallel trains, as the remaining equipment of Unit 2200, because of the size limitation of the exchangers involved.

Cold syngas, after CO<sub>2</sub> and H<sub>2</sub>S removal, is diluted with Nitrogen in order to achieve 65% max Hydrogen content and then sent to the gas turbines, Unit 3000.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 13 of 28  
**Case 5**

The main process streams of the Syngas treatment and conditioning line relevant to this alternative are summarised in following table:

STREAM	SAT SYNGAS (1)	HP GENERATED STEAM (2)	MP GENERATED STEAM (3a+3b)	LP GENERATED STEAM (4)	VLP GENERATED STEAM (5)	SYNGAS TO GT (6)
Temperature (°C)	221	352	256	175	152	75
Pressure (bar)	39	171	44	9	5	28,5
<b>TOTAL FLOW</b>						
Mass flow (kg/h)	1,268,500	36,000	171,900	160,800	207,000	185,442
Molar flow (kmol/h)	64,080					15,734
Composition (% vol)						
H <sub>2</sub>	10,0					65,0
CO	23,9					3,7
CO <sub>2</sub>	2,7					4,3
N <sub>2</sub>	2,7					26,4
Ar	-					-
O <sub>2</sub>	-					0,3
H <sub>2</sub> S + COS	0,07					-
H <sub>2</sub> O	60,50					0,3
Others	0,13					-

**Unit 2300: Acid Gas Removal (AGR)**

The removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub> is an important step of the IGCC operation. In fact this unit is not only capital intensive and a large consumer of energy, but also is a key factor for the control of the environmental performance of the IGCC. The right selection of the process and of the solvent used to capture the acid gases is important for the performance of the complex.

Unit 2300 is characterised by a medium syngas pressure (29.7 bar g) and an extremely high CO<sub>2</sub>/H<sub>2</sub>S ratio (365/1).

Based on considerations on section C, paragraph 8.0, the combined removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub>, based on the Amine Guard FS process has been selected.

The product of this process is a single stream to be compressed and delivered to plant B.L.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**


Revision no.: Final  
 Date: November 2005  
 Sheet: 14 of 28  
**Case 5**

Entering Streams

1. Untreated Gas from Syngas Treatment & Conditioning Line

Exit Streams

2. Treated Gas to Gas Turbines
3. CO<sub>2</sub> to compression



The Amine Guard FS solvent consumption, to make-up losses, is 64 m<sup>3</sup>/year.

The proposed process matches the process specification with reference to H<sub>2</sub>S+CO<sub>2</sub> concentration of the treated gas exiting the Unit (H<sub>2</sub>S+CO<sub>2</sub> concentration is less than 3 ppm). This is due to the integration of CO<sub>2</sub> removal with the H<sub>2</sub>S removal, which makes available a large circulation of the solvent.

The CO<sub>2</sub> removal rate is 91,6% as required, allowing reaching an overall CO<sub>2</sub> capture of 85% with respect to the carbon entering the IGCC.

These performances for the H<sub>2</sub>S removal and CO<sub>2</sub> capture are achieved with large steam consumption.

Together with CO<sub>2</sub>/H<sub>2</sub>S exiting the Unit, the following quantity of hydrogen is lost:

- 97 kmol/h of Hydrogen, corresponding to 0.62% vol and to an overall thermal power of approx 6.6 MWth, i.e. more than 2 MWe.

The feasibility to separate and recover H<sub>2</sub> during the CO<sub>2</sub> compression was investigated. Due to the similar equilibrium constants of CO<sub>2</sub> and H<sub>2</sub> at super-critical CO<sub>2</sub> conditions, this separation is unfeasible.

The main process streams of the AGR Unit relevant to this alternative are summarised in following table:

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 15 of 28  
**Case 5**

STREAM	RAW SYNGAS (1)	TREATED SYNGAS (2)	CO <sub>2</sub> RICH STREAM (3)
Temperature (°C)	38	38	49
Pressure (bar)	30.7	29.5	1.8
<b>TOTAL FLOW</b>			
Molar flow (kmol/h)	39,500	24,800	15,600
Composition (% vol)			
H <sub>2</sub>	52.1	82.6	0.6
CO	3.0	4.7	
CO <sub>2</sub>	40.2	5.4	93.3
H <sub>2</sub> S + COS	0.1	3 ppm	0.3
Others	4.6	7.3	5.8

Unit 2500: CO<sub>2</sub> Compression and Drying

This Unit is a Package Unit supplied by specialised Vendor. For more details see section C, paragraph 9.0.

The product stream sent to final storage is mainly composed of CO<sub>2</sub> and CO. The main properties of the stream are as follows:

- Product stream : 647 t/h.
  - Product stream : 110 bar
  - Composition :
- |                  |            |
|------------------|------------|
|                  | %vol       |
| CO <sub>2</sub>  | 99.0       |
| H <sub>2</sub> S | 0.3        |
| Others           | <u>0.7</u> |
| TOTAL            | 100.0      |

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	16 of 28
<b>Case 5</b>	

---

Unit 3000: Power Island

The power island is based on two General Electric gas turbines, frame 9001 FA, two Heat Recovery Steam Generators (HRSG), generating steam at 3 levels of pressure, and one steam turbine common to the two HRSGs.

The power island configuration is described referring to the Process Flow Diagrams attached to the end of this paragraph.

During normal operation, the clean syngas, coming from Unit 2200 - Syngas Treatment and Conditioning Line, is heated up to 170°C against MP BFW in the syngas final heater dedicated to each Gas Turbine.

Finally, the hot syngas is burnt inside the Gas Turbine to produce electric power; the resulting stream of hot exhaust gas is conveyed to the Heat Recovery Steam Generator located downstream each Gas Turbine.

Compressed air is extracted from the Gas Turbines and delivered to ASU. MP nitrogen coming from ASU is injected into the Gas Turbines for NO<sub>x</sub> abatement and power output augmentation.

The flue gas stream at a temperature of about 570°C flows through the coils inside the HRSG generating steam at three different pressure levels, is cooled down to about 129°C and then discharged to the atmosphere through a stack common to the two HRSG Units.

The turbine consists of HP, IP and LP sections all connected to the generator on a single shaft. HP steam from the HRSG HP section enters the turbine at approx. 156 bar, 550°C. Steam from the exhaust of the HP turbine is returned to the HRSG for reheating after mixing with MP steam, and is then throttled into the IP turbine at approx. 36 bar, 530°C. Exhaust steam from IP flows into a LP turbine after mixing with superheated LP steam from HRSG and then downward into the condenser at 0.032 bar, 25°C.

When the clean syngas production is not sufficient to satisfy the appetite of both Gas Turbines it is possible to cofire natural gas or to switch to natural gas one or both Gas Turbines.

This could happen in case of partial or total failure of the Gasification/Gas Treatment units of the IGCC and during start-up.

The selected machines are suitable to co-fire syngas and natural gas from 20% to 100% load.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 17 of 28

**Section D: Basic Information for Each Alternative**
**Case 5**


---

During Natural Gas Operation no air extraction is foreseen, while a stream of MP Steam has to be injected into the combustion chambers of the Gas Turbines to reduce the NO<sub>x</sub> emissions.

During normal operation on Natural Gas, the Power Island does not export/import to/from IGCC Process Units any steam/water stream and no low temperature heat can be recovered in Process Units. Then all cold condensate coming from Steam Condenser can be directly sent to the deaerator after polishing. In this situation, the degassing steam demand of the deaerator is very high, more than VLP steam produced by HRSG's that needs to be integrated with steam coming from LP and MP headers.

The interfaces considered (during normal operating case) between the power island and the rest of the plant are as follow:

- Compressed Air : Air sent to Unit 2100 – Air Separation Unit;
- MP nitrogen : Nitrogen coming from ASU injected into the Gas Turbines for NO<sub>x</sub> abatement and power output augmentation.
- HP steam (160 barg): steam imported from Syngas Treatment and Conditioning Line.
- MP steam (40 barg): steam imported from Syngas Treatment and Conditioning Line.
- MP steam (40 barg): steam exported to the Gasification Island users.
- LP steam (6,5 barg): steam imported from Syngas Treatment and Conditioning Line. The steam is also exported to the following Process Units: ASU, Utility and Offsite Unit.
- VLP steam (3,2 barg): the total steam generated in Syngas Treatment and Conditioning Line is used in the Lignite drying section.
- BFW : HP, MP, LP, VLP Boiler Feed Water is exported to the Process Units to generate the above mentioned steam production.
- Process Condensate : All the condensate recovered from the condensation of the steam utilised in the Process Unit is recycled back to the HRSG after polishing in Unit 4200, Demi Water/Condensate Recovery.
- Condensate from ST : All the Condensate from the Condenser is exported to the polishing unit (Unit 4200), pre-heated in the Syngas Cooling and Conditioning Line partially cooled in the Lignite drying section and recycled back to the HRSG.



**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 18 of 28  
**Case 5**

Flow rate of the steam/water interfaces of the Plant are shown in table attached to para 5.5, Utilities Consumption.

The main process data of the Power Island relevant to this alternative are summarised in following table:

STREAM	SYNGAS (1)	AIR TO ASU (2)	NOX CONTROL N <sub>2</sub> (3)	LP STEAM TO ST (4)	HP STEAM TO ST (5)
Temperature (°C)	170	396	213	236	552
Pressure (bar)	26	14,2	22	5,7	156
<b>TOTAL FLOW</b>					
Mass flow (t/h)	185,4 (1)	147,7 (1)	193,0 (1)	92,7	456,4

STREAM	RH MP STEAM TO ST (6)	COND. FROM ST (7)	COOLING WATER TO CND (8)	COOLING WATER FROM CND (9)	FLUE GAS AT STACK (10)
Temperature (°C)	527	25	11	21	129
Pressure (bar)	36	0,03	3	2,3	Amb
<b>TOTAL FLOW</b>					
Mass flow (kg/h)	780,8	873,4	45163	45163	2511,5 (1)

(1): For each GT

Unit 4600: Waste Water Treatment

The part of waste water from the NH<sub>3</sub> stripper that is not recycled back to the quench, flows to the anaerobic section, where a phosphoric acid solution is added to the waste water to support the bacterial growth.

In the Anaerobic Reactor the organic pollutants are biodegraded with production of biological gas and biological sludge. The biogas produced in the reactor is routed to the local flare to be burned.

The biological mass exits the anaerobic reactor and enters the Anaerobic Clarifier where the biomass is separated by gravity from the supernatant.

Effluent from anaerobic section is subject to a further aerobic treatment for the complete removal of ammonia and organic contaminants. The effluent from the anaerobic clarifier is pumped to the denitrification/oxidation tanks where is

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 19 of 28  
**Case 5**

---

mixed with the rainwater bleed-off and drainage coming from the deoiling section.

In this deoiling section, the oily drainage mixed with contaminated rainwater is fed by means of pumps from the oil water storage tank to the primary deoiling section, consisting of a Corrugate Plate Interceptor, which provides gravity separation of free oil and suspended solids carried in the waste water.

The effluent from the separator cells is dosed with polyelectrolyte and is routed by gravity to a secondary deoiling step, consisting of Induced Air Flotation. Air induced by motors driven self-aerating rotors mechanism removes the oil and suspended solids, which are collected in a dense froth to be recycled back to the CPI.

The deoiled water is then pumped to the denitrification/oxidation tanks, where it is mixed with the anaerobic treatment effluent and where the organic contaminants are removed and ammonia is oxidized to nitrates which are further reduced to nitrogen gas in the denitrification section.

The effluent from the oxidation tank enters the aerobic clarifier, where the biomass separates by gravity from the supernatant. The sludge from the bottom of the clarifier is recycled to the anaerobic reactor by the Sludge Pump.

The supernatant from the clarifier is dosed with polyelectrolyte and pumped into Dual Media Filter, which uses sand and anthracite as filter media for the removal of residual hydrocarbons and suspended solids, and into Activated Carbon Filters, for the complete removal of organic contaminants

From the filters the water is recovered back to the Gasification Island as make-up water.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 20 of 28

**Case 5**


---

### **5.3 Process Flow Diagrams**

The Process Flow Diagrams of the following main process units are attached to this paragraph:

- UNIT 2100: Air Separation Unit (PFD n° BD0237A-3-50-2100);
- UNIT 2200: Syngas Treatment and Conditioning Line (PFD n° BD0237A-3-50-2200);
- UNIT 2300: Acid Gas Removal (PFD n° BD0237A-3-50-2300);
- UNIT 3000: Power Island (PFD n° BD0237A-3-50-3000; sheet 1 and 2).






REVISIONS		DATE	BY	APP'D
1	ISSUE FOR CONSTRUCTION			
2	CONSTRUCTION			

EA GREEN HOUSE ROAD PROGRAMME CO2 CAPTURE BELOW FIRM COAL POWER PLANTS		SCALE:	DATE:
FUTURE ENERGY - CASE 5 UNIT 2200 - SYNGAS TREATMENT AND CONDITIONING LINE		AREA:	DESIGNER:
PROJECT NO: 0002337A SHEET NO: 0002337A-01		DATE:	SCALE:
PROJECT NO: 0002337-0-00-2300 SHEET NO: 0002337-0-00-2300-01		DATE:	SCALE:






LEGEND

◇ STREAM NUMBER

REVISIONS		DATE	BY	APP'D
1	ISSUE FOR ISSUES			
2	ISSUE FOR ISSUES			

EA GREEN HOUSE RAD PROGRAM		SCALE	DATE
CO <sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS		AREA	
FUTURE ENERGY - CASE 5		PROJECT	
UNIT 3000-POWER PLANT		CONTRACT NO.	
DESIGNED BY: M. J. HARRIS		PROJECT NO.	
DRAWN BY: M. J. HARRIS		DATE	
CHECKED BY: M. J. HARRIS		SCALE	
APPROVED BY: M. J. HARRIS		PROJECT NO.	
DATE: 5-20-2000		SCALE	
SHEET NO. 1 OF 1			



REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973

REVISIONS		DATE	
NO.	DESCRIPTION	BY	CHKD.
1	ISSUE FOR SERVICES	LP	APR 1973
2	CONNECTIONS	BY	DEC 1973



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 21 of 28

**Case 5**

---

#### **5.4 Heat and Material Balances**

For Heat and Material Balances refer to tables attached in paragraph 5.2.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 22 of 28

**Case 5**

---

## **5.5 Utility Consumption**

The Utility Consumption of the process / utility and offsite units are shown in the attached Tables.



CLIENT: IEA GHG  
 PROJECT: CO2 capture in low-rank coal power plants  
 LOCATION: Germany  
 FWI N°:

REVISION	Rev.0	Rev.1	Rev.2	Rev.3
DATE	Feb-05			
ISSUED BY	P.C.			
CHECKED BY	L.M.			
APPROVED BY	R.D.			

**UTILITIES CONSUMPTION SUMMARY - CASE 5 - FUTURE ENERGY LOW PRESSURE GASSIFICATION - MDEA**

UNIT	DESCRIPTION UNIT	HP Steam 160 barg [t/h]	MP Steam 40 barg [t/h]	LP Steam 6.5 barg [t/h]	LP Steam ST extr. 4.7 barg [t/h]	VLP Steam 3.2 barg [t/h]	HP BFW [t/h]	MP BFW [t/h]	LP BFW [t/h]	VLP BFW [t/h]	condensate recovery [t/h]	Losses [t/h]
<b>PROCESS UNITS</b>												
900	Lignite Handling, Milling and Drying					207.0					207.0	
1000	Gasification Section			-30.8				44.7			13.9	
2100	Air Separation Unit			20.1							20.1	
2200	Syngas Treatment and Conditioning line	-36.0	-171.9	-160.8		-207.0	36.0	171.9	160.8	207.0		
2300	Acid Gas Removal			157.2							157.2	
<b>POWER ISLANDS UNITS</b>												
3000		36.0	171.9	4.9	0.0		-36.0	-216.6	-160.8	-207.0		
<b>UTILITY and OFFSITE UNITS</b>												
4100 to 5300				9.4							9.4	
<b>BALANCE</b>												
		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	407.6	0.0

Note: Minus prior to figure means figure is generated





**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 23 of 28  
**Case 5**

**5.6 IGCC Overall Performance**

The following Table shows the overall performance of the IGCC Complex.

<b>FUTURE ENERGY</b>		
Low pressure Gasification - MDEA Alternative		
<b>OVERALL PERFORMANCES OF THE IGCC COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	653.3
Coal LHV (A.R.)	kJ/kg	10500.0
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV)</b>		
<b>MWt 1905.5</b>		
Natural Gas to gasifiers	kg/h	640.1
NG LHV	kJ/kg	50053.4
<b>TOTAL THERMAL INPUT (A)</b>		
<b>MWt 1914.4</b>		
Thermal Power of Raw Syngas exit Scrubber (based on LHV)	MWt	1641.7
Thermal Power of Clean Syngas to Gas Turbines (based on LHV)	MWt	1467.2
Syngas treatment efficiency	%	89.4
Gas turbines total power output (@ gen terminals)	MWe	572.0
Steam turbine power output (@ gen terminals)	MWe	328.3
<b>GROSS ELECTRIC POWER OUTPUT OF IGCC COMPLEX (D)</b>		
<b>MWe 900.3</b>		
ASU power consumption	MWe	129.7
Process Units consumption	MWe	18.4
Utility Units consumption	MWe	17.0
Offsite Units consumption (including cooling tower system)	MWe	0.5
Power Islands consumption	MWe	7.3
CO <sub>2</sub> Compression and Drying	MWe	60.2
<b>ELECTRIC POWER CONSUMPTION OF IGCC COMPLEX</b>		
<b>MWe 233.1</b>		
<b>NET ELECTRIC POWER OUTPUT OF IGCC (C)</b>		
<b>(Step Up transformer efficiency = 0.997%)</b>		
<b>MWe 665.2</b>		
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>		
<b>% 47.2</b>		
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>		
<b>% 34.7</b>		

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 24 of 28  
**Case 5**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the IGCC Complex.

	<b>Equivalent flow of CO<sub>2</sub>, kmol/h</b>
Carbon incoming (Coal carbon = 57.19%wt)	17,055.8
Carbon incoming (Natural gas)	34
Slag	42.8
<b>Net Carbon Flowing to Process Units (A)</b>	<b>17,047</b>
Liquid Storage	
CO	49
CO <sub>2</sub>	<u>14,584</u>
Total to storage (B)	14,633
Emission	
CO	6
CO <sub>2</sub>	<u>2,408</u>
Total Emission	2,414
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85.8</b>

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 25 of 28  
**Case 5**

**5.7 Environmental Impact**

The IGCC Complex is designed to process coal, whose characteristic are shown at Section B - para 2.0, and produce electric power. The advanced technology allows to reach a high efficiency and to minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the IGCC Complex are summarised in this section.

**5.7.1 Gaseous Emissions**
Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases of the two trains of the Power Island, proceeding from the combustion of the Syngas in the two gas turbines, and emission from the coal Drying process.

Table 5.1 summarises expected flow rate and concentration of the combustion flue gas from one train of the Power Island.

**Table 5.1** – Expected gaseous emissions from one train of the Power Island.

	Normal Operation
Wet gas flow rate, kg/s	697.6
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	2,500,200
Temperature, °C	129
Composition	(%vol)
Ar	0.91
N <sub>2</sub>	74.83
O <sub>2</sub>	11.17
CO <sub>2</sub>	1.32
H <sub>2</sub> O	11.77
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NOx	74
SOx	1.2
CO	31.3
Particulate	5

(1) Dry gas, O<sub>2</sub> content 15%vol

Both the Combined Cycle Units have the same flue gas composition and flow rate. The total gaseous emissions of the Power Island are given in Table 5.2.



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 26 of 28  
**Case 5**

**Table 5.2 – Expected total gaseous emissions of the Power Island.**

	Normal Operation
Wet gas flow rate, kg/s	1,395.2
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	5,000,400
Temperature, °C	129
<b>Emissions</b>	<b>kg/h</b>
NOx	370.0
SOx	6.0
CO	156.5
Particulate	25.0

(1) Dry gas, O<sub>2</sub> content 15%vol

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Flow rate : 1996.7 t/h  
 Particulate : <10 mg/Nm<sup>3</sup>, wet basis.

Minor Emissions

Other minor gaseous emissions are the process vents and fugitive emissions. Some of the vent points emit continuously; others during process upsets or emergency conditions only. All vent streams containing, potentially, undesirable gaseous components are sent to a flare system. Venting via the flare will be minimal during normal operation, but will be significant during emergencies, process upsets, start up and shutdown.

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). Proper design and operation reduce these emissions to a very low level.

**5.7.2 Liquid Effluent**

Cooling Water System

Raw water is used for the cooling towers make up. Main characteristics of the Cooling Towers blowdown are listed in the following:

- Maximum flow rate : 250 m<sup>3</sup>/h
- Temperature : 11 °C
- Cooling Tower Concentration factor : 5

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**


---

Revision no.: Final  
 Date: November 2005  
 Sheet: 27 of 28  
**Case 5**

---

**5.7.3 Solid Effluent**

The plant is expected to produce the following solid by-products:

Slag

Flow rate	:	26	m <sup>3</sup> /h
Water content	:	40	%wt

Sludge

Flow rate	:	3,5	m <sup>3</sup> /h
Water content	:	80	%wt

Only slag can be sold to be commercially used as major components in concrete mixtures to make road, pads, storage bins. The generated sludge from the waste water cleaning is a waste material and it is necessary to be deposited.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 28 of 28

**Case 5**

---

## **5.8 Equipment List**

The list of main equipment and process packages are included in this section.





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisys - Future Energy -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>						Shell/tube	Shell/tube		
1		Feed/ Product Exchanger	Shell & Tube						
2		Feed/ Product Exchanger	Shell & Tube						
1		HP Steam Generator	Kettle						
2		HP Steam Generator	Kettle						
1		MP Steam Generator	Kettle						
2		MP Steam Generator	Kettle						
1		MP Steam Generator	Kettle						
2		MP Steam Generator	Kettle						
1		LP Steam Generator	Kettle						
2		LP Steam Generator	Kettle						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisis - Future Energy -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS (Continued)</b>				Shell/tube	Shell/tube		
1		VLP Steam Generator	Kettle						
2		VLP Steam Generator	Kettle						
1		Condensate Preheater	Shell & Tube						
2		Condensate Preheater	Shell & Tube						
1		Final Cooler	Shell & Tube						
2		Final Cooler	Shell & Tube						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisys - Future Energy -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>DRUMS</b>									
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolysis - Future Energy -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>REACTOR</b>									
1		Shift Catalyst Reactor - 1st Bed	vertical						
2		Shift Catalyst Reactor - 1st Bed	vertical						
1		Shift Catalyst Reactor - 2nd Bed	vertical						
2		Shift Catalyst Reactor - 2nd Bed	vertical						
<b>PACKAGE UNITS</b>									
		Catalyst Loading System							
		Shift Catalyst							





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3100 - Gas Turbine - Future Enrgy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>									
						Shell/tube	Shell/tube		
1		Syngas Final Heater	Shell & Tube						
2		Syngas Final Heater	Shell & Tube						
<b>DRUMS</b>									
1		Syngas Final Separator	vertical						
2		Syngas Final Separator	vertical						
<b>PACKAGES</b>									
1		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	286 MW					
2		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	286 MW					



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - Future Energy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PUMPS</b>									
1		LP BFW Pumps	centrifugal						One operating, one spare
2		LP BFW Pumps	centrifugal						One operating, one spare
1		MP BFW Pumps	centrifugal						One operating, one spare
2		MP BFW Pumps	centrifugal						One operating, one spare
1		HP BFW Pumps	centrifugal						One operating, one spare
2		HP BFW Pumps	centrifugal						One operating, one spare
1		VLP BFW Pumps	centrifugal						One operating, one spare
2		VLP BFW Pumps	centrifugal						One operating, one spare
<b>MISCELLANEA</b>									
1		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
2		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
1		CCU Stack							
2		CCU Stack							
1		Stack Silencer							
2		Stack Silencer							
1		MP Steam Desuperheater							Included in 1-HRSG-3201
2		MP Steam Desuperheater							Included in 2-HRSG-3201
1		HP Steam Desuperheater							Included in 1-HRSG-3201
2		HP Steam Desuperheater							Included in 2-HRSG-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - Future Energy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
		<b>Fluid Sampling Package</b>							
		<b>Phosphate Injection Package</b> Phosphate storage tank Phosphate dosage pumps							Included in Z - 3202 Included in Z - 3202 One operating , one spare
		<b>Oxygen Scavanger Injection Package</b> Oxygen scavanger storage tank Oxygen scavanger dosage pumps							Included in Z - 3203 Included in Z - 3203 One operating , one spare
		<b>Amines Injection Package</b> Amines Storage tank Amines Dosage pumps							Included in Z - 3204 Included in Z - 3204 One operating , one spare



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - Future Energy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT RECOVERY STEAMGENERATOR</b>							
1		<b>Heat Recovery Steam Generator</b>	Horizontal, Natural Circulated, 4 Pressure Levels, Simple Recovery, Reheated.						
1		<b>HP steam Drum</b>							Included in 1-HRS-3201
1		<b>MP steam drum</b>							Included in 1-HRS-3201
1		<b>LP steam drum</b>							Included in 1-HRS-3201
1		<b>VLP steam drum with degassing section</b>							Included in 1-HRS-3201
1		<b>HP Superheater 2nd section</b>							Included in 1-HRS-3201
1		<b>MP Reheater 2nd section</b>							Included in 1-HRS-3201
1		<b>HP Superheater 1st section</b>							Included in 1-HRS-3201
1		<b>MP Reheater 1st section</b>							Included in 1-HRS-3201
1		<b>HP Evaporator</b>							Included in 1-HRS-3201
1		<b>HP Economizer 3rd section</b>							Included in 1-HRS-3201
1		<b>MP Evaporator</b>							Included in 1-HRS-3201
1		<b>LP Superheater</b>							Included in 1-HRS-3201
1		<b>MP Economizer 2nd section</b>							Included in 1-HRS-3201
1		<b>HP Economizer 2nd section</b>							Included in 1-HRS-3201
1		<b>LP Evaporator</b>							Included in 1-HRS-3201
1		<b>LP Economizer</b>							Included in 1-HRS-3201
1		<b>MP Economizer 1st section</b>							Included in 1-HRS-3201
1		<b>HP Economizer 1st section</b>							Included in 1-HRS-3201
1		<b>VLP Evaporator</b>							Included in 1-HRS-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

### EQUIPMENT LIST

Unit 3200 - Heat Recovery Steam Generator - Future Energy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT RECOVERY STEAM GENERATOR</b>							
2		Heat Recovery Steam Generator	Horizontal, Natural Circulated, 4 Pressure Levels, Simple Recovery, Reheated.						
2		HP steam Drum							Included in 2-HRS-3201
2		MP steam drum							Included in 2-HRS-3201
2		LP steam drum							Included in 2-HRS-3201
2		VLP steam drum with degassing section							Included in 2-HRS-3201
2		HP Superheater 2nd section							Included in 2-HRS-3201
2		MP Reheater 2nd section							Included in 2-HRS-3201
2		HP Superheater 1st section							Included in 2-HRS-3201
2		MP Reheater 1st section							Included in 2-HRS-3201
2		HP Evaporator							Included in 2-HRS-3201
2		HP Economizer 3rd section							Included in 2-HRS-3201
2		MP Evaporator							Included in 2-HRS-3201
2		LP Superheater							Included in 2-HRS-3201
2		MP Economizer 2nd section							Included in 2-HRS-3201
2		HP Economizer 2nd section							Included in 2-HRS-3201
2		LP Evaporator							Included in 2-HRS-3201
2		LP Economizer							Included in 2-HRS-3201
2		MP Economizer 1st section							Included in 2-HRS-3201
2		HP Economizer 1st section							Included in 2-HRS-3201
2		VLP Evaporator							Included in 2-HRS-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

Unit 3300 - Steam Turbine and Blow Down System - Future Energy - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS</b>				shell / tube	shell / tube		
		Blow-Down Cooler	Shell & Tube						
		<b>DRUMS</b>							
		Flash Drum	vertical						
		Continuous Blow-down Drum	vertical						
		Discontinuous Blow-down Drum	vertical						
		<b>PACKAGES</b>							
		<b>Steam Turbine &amp; Condenser Package</b>		328 MW					
		Steam Turbine							Included in Z - 3201
		Inter/After condenser							
		Gland Condenser							Included in Z - 3201
		Steam Condenser							Included in Z - 3201
		Steam Turbine Generator							Included in Z - 3201
		Start-up Ejector							Included in Z - 3201
		Holding Ejector 1st Stage							Included in Z - 3201
		Holding Ejector 2nd Stage							Included in Z - 3201
		Condensate Pumps	Centrifugal						Included in Z - 3201 Two operating, one spare
		Start-up Ejector Silencer							Included in Z - 3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3400 - Electric Power Generation - Future Energy - with CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
		Gas Turbine Generator							Included in 1 -Z- 3101
		Gas Turbine Generator							Included in 2 -Z- 3101
		Steam Turbine Generator							Included in Z- 3301



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Utility and Offsite Units - Future Energy - with CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
	Unit 4100	Cooling Water System Machinery Cooling Water System							
	Unit 4200	Demineralized Water System Plant and Potable Water System							
	Unit 4300	Natural Gas System							
	Unit 4400	Plant and Instrument Air System							
	Unit 4600	Waste Water Treatment							
	Unit 4700	Fire Fighting System							
	Unit 4900	Chemicals							
	Unit 6000	Interconnecting Instrumentation DCS Piping Electrical 400 KV Substation							



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 29  
**Case 6**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 6-IGCC BASED ON SHELL GASIFICATION  
 WITH PRECOMBUSTION CO<sub>2</sub> CAPTURE

ISSUED BY : P. COTONE  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 29

**Case 6**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 6.0 Case 6: IGCC based on Shell gasification
- 6.1 Introduction
- 6.2 Process Description
- 6.3 Process Flow Diagrams
- 6.4 Heat and Material Balances
- 6.5 Utility Consumption
- 6.6 IGCC Overall Performance
- 6.7 Environmental Impact
- 6.8 Equipment List

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 3 of 29  
**Case 6**

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**
**6.0 Case 6**
**6.1 Introduction**

The main features of the Case 6 configuration of the IGCC Complex are:

- Low pressure (40 bar g) Shell Gasification;
- Coal Nitrogen Dry Feed;
- Gasifier Heat Recovery Type;
- Double stage dirty shift;
- Combined removal of H<sub>2</sub>S and CO<sub>2</sub>.

The combined removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub>, is based on the Amine Guard FS process. The product of this process is a single stream to be compressed and delivered to plant B.L.

The degree of integration between the Air Separation Unit (ASU) and the Gas Turbines is approx 30%.

Gas Turbine power augmentation and syngas dilution, for NO<sub>x</sub> control, is achieved with injection of compressed N<sub>2</sub> from ASU to the gas turbines.

The arrangement of the main process units is:

<u>Unit</u>		<u>Trains</u>
1000	Coal pressurization/feeding	6 x 18.3 %
	Gasification heat recovery	2 x 50 %
	Slag removal	2 x 50 %
	Dry solids removal	2 x 50 %
	Wet scrubbing	2 x 50 %
	Sour slurry and sour water stripper	2 x 50 %
2100	ASU	2 x 50%
2200	Syngas Treatment and Conditioning Line	2 x 50%
2300	AGR	3 x 33%
2500	CO <sub>2</sub> Compression and Drying	2 x 50%

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**


**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 4 of 29  
**Case 6**

3000	Gas Turbine (PG 9351 – FA)	2 x 50%
	HRSG	2 x 50%
	Steam Turbine	1 x 100%

Reference is made to the attached overall Block Flow Diagram of the IGCC Complex.

## Case 6 – SHELL – IGCC COMPLEX BLOCK FLOW DIAGRAM




**6.2 Process Description**

*Coal Handling and Storage*

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the plant. For more details see section C, paragraph 1.

*Coal Drying*

The basic features of this process are shown in Section C, para 2.0. The process scheme used for this specific alternative is shown in the following scheme:



The indirect Lignite Drying method has been used for this alternative.

This system could be specifically advantageous for the ICGG case, as a lot of source of low temperature heat exists in the plant design that can be used.

For Shell gasification the required moisture content in the feedstock is 5%.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 7 of 29  
**Case 6**

The split of the heating sources required for the drying of the lignite is reported in the following table:

Heat source	Duty, MWth
Syngas cooling	68
CO <sub>2</sub> compression	38.5
LP steam (5.7 barg)	110
N <sub>2</sub> compression	12
<b>TOTAL HEAT</b>	<b>228.5</b>

Unit 1000: Gasification Island
*Feeding system*

Milled and dried coal is pneumatically transported to the coal pressurisation and feeding system. This system consists of lock hoppers and feed hoppers. Once a lock hopper has been charged with coal, it is pressurised with nitrogen and its contents discharged into a feed hopper.

Pressurised coal is withdrawn from the feed hoppers and pneumatically conveyed with nitrogen to the gasifier's coal burners.

Lock hoppers are widely utilised in materials handling applications. They have proven to be a safe and reliable method for transferring solids under pressure.

The valves required for commercial scale lock hopper systems have been extensively demonstrated.

The coal feeding system consists of four coal silos, four mills and conveyor systems and four dosing unit, one for each gasifier.

*Gasifier*

The gasifier consists of a pressure vessel with a gasification chamber inside. Circulating water through the membrane wall to generate saturated steam controls the inner gasifier wall temperature. The membrane wall encloses the gasification zone from which two outlets are provided. One opening at the bottom of the gasifier is used for the removal of slag. The other outlet allows hot raw gas and fly slag to exit from the top of the gasifier.

In the top part of the gasifier, a solid-free cold syngas stream is injected to the hot product syngas, so that the product syngas is quenched to a temperature at which the fly ash solidifies. The recycle quench gas is withdrawn from downstream of the dry solids removal unit. A recycle gas compressor is applied for this service.

At the bottom of the gasifier, as the molten slag contacts the water bath, the

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	8 of 29
<b>Case 6</b>	

---

slag solidifies into dense, glassy granules. These slag granules fall into a collecting vessel located beneath the slag bath and are transferred to a lock hopper which operates on a timed cycle to receive the slag. After the lock hopper is filled, the slag is washed with clean make-up water to remove entrained gas and any surface impurities. After washing, the lock hopper is depressurised and the slag is fed to a de-watering bin. Commercially sized slag sluicing valves have been applied for this service.

The dewatering bin is equipped with a mechanical conveyor (drag chain) to lift the settled solids off the bottom of the vessel and deposit them on a conveyor belt for delivery to intermediate.

#### *High Temperature Gas Cooling*

The hot raw product gas leaving the gasification zone is quenched with cooled, recycled product gas to convert any entrained molten slag to a hardened solid material prior to entering the syngas cooler. The syngas cooler recovers high-level heat from the quenched raw gas by generating steam. The gasifier is a water wall membrane type, while the downstream syngas cooler is water tube type.

Each gasifier is coupled with a syngas cooler to maximise the heat recovery while maintaining operability. The steam system has been designed bearing efficiency and intrinsic safety in mind. The choice for two steam levels (HP and MP) ensures a high efficiency. The MP steam pressure level has been selected as high as the HP in order to maximise the overall efficiency.

#### *Dry Solids Removal*

The bulk of the flyash contained in the raw gas leaving the syngas cooler is removed from the gas using a commercially demonstrated high pressure, high temperature (HPHT) filter (approx. 350°C). The flyash leaving the process is conveyed to a flyash lock hopper. After the lock hopper is filled, the flyash is purged with high-pressure nitrogen to remove any entrained raw gas; this effluent is disposed to a blow down flare system. After purging the lock hopper, the flyash is pneumatically conveyed to a silo for intermediate storage. All vent gases from the flyash lock hopper and the storage silo are filtered of particles. Flyash is recycled and added to the coal feed.

#### *Wet Scrubbing*

The gas leaving the dry solids removal is further purified by passing through a wet scrubbing unit where any residual flyash is removed to a level of less than 1 ppm. This wet scrubbing system also removes other minor contaminants such



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	9 of 29
<b>Case 6</b>	

---

as soluble alkali salts and hydrogen halides.

Make-up water is continuously added to the wet scrubbing unit to control the concentration of contaminants. To minimise the water use for the plant, recycle water from the sour water stripper unit is used for this make-up and this comprises the majority of the make-up water stream. A small bleed flow of the contaminated water is sent to the sour slurry-stripping unit to recover the contaminants.

A scrubber outlet temperature of 180 °C has been selected, which corresponds to a 26% water molar content in the syngas.

*Sour Slurry Stripper (Waste Water Pre-treatment)*

The blow-down water from the wet scrubbing unit and a bleed from the slag bath are fed to a stripper for the removal of hydrogen sulphide, dissolved raw gases and to reduce the ammonia level in the water to an environmentally acceptable level. In this unit, low-pressure steam provides the necessary heat and stripping medium. A large portion of the effluent water from the stripper is recycled after clarification to the slag bath as make-up water. Only a small effluent water stream is sent to the Waste Water Treatment. In this way, the consumption of process water has been minimised.

*Sour Water Stripper*

Sour water streams from several streams are stripped in this unit. Since the column operates under non-fouling conditions, the necessary stripping steam is supplied via a LP steam reboiler. The vapour leaving the SWS column is sent to an overhead system. In this overhead system the overhead vapours are condensed and the sour gases are separated from the condensate in the gas/liquid separator. The condensed water is routed back to the SWS column as reflux, above the rectifying bed. The sour gases are routed to the battery limit. The SWS effluent has been used as make-up water in the wet scrubbing systems.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 10 of 29  
**Case 6**

The main process streams of the Gasification Island relevant to this alternative are summarised in following table:

STREAM	FUEL FEED (COAL)	HP O <sub>2</sub> (95% purity)	HP N <sub>2</sub>	LP N <sub>2</sub>	HP Steam	MP Steam	SATURATED SYNGAS
Temperature (°C)	AMB.	180	80	70	290	290	180
Pressure (bar)		45	71	7.5	71	71	41
<b>TOTAL FLOW</b>							
Mass flow (kg/h)	323,920	219,800	105,960	41,100	353,200	33,860	711,640
Molar flow (kmol/h)							33,450
Composition (% vol)							
H <sub>2</sub>							21,2
CO							42,1
CO <sub>2</sub>							5,0
N <sub>2</sub>							5,6
Ar							-
O <sub>2</sub>							-
H <sub>2</sub> S + COS							0,1
H <sub>2</sub> O							26,0
Others							-

Note: Figures referred to the total flowrates

Unit 2100: Air Separation Unit (ASU)

This Unit is treated as a package unit supplied by specialised Vendors. The Air Separation Unit (ASU, Unit 2100) is installed to produce oxygen and nitrogen through cryogenic distillation of atmospheric air.

The oxygen produced is delivered to the Gasification Island to be used as reaction oxidant.

As a by-product nitrogen is obtained and is used for the pneumatic transport of dried pulverized coal to the gasifiers; the excess is routed to the syngas dilution and to the gas turbines for power augmentation and NO<sub>x</sub> control.

The Plant consists of two air separation trains and at the same time is able to produce additional oxygen and nitrogen products to maintain the desired inventories in the storage systems of liquid and gaseous products used as back-up; these systems are common to both trains.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 11 of 29  
**Case 6**

ASU is partially integrated with the gas turbines. When the gasification operates at full load, approx 30% of the air required by the ASU to obtain the design oxygen production is derived from both gas turbine compressors; the integration between the gas turbines operation and the ASU is achieved at a level where approx 70% of the atmospheric air is compressed with a dedicated air compressor and the difference comes already pressurized from the compressors of the gas turbines in the combined cycle. The air extracted from the gas turbine at high temperature is cooled by exchanging heat with nitrogen for syngas dilution before being fed to the Air Separation Unit.

The main process stream of the Air Separation Unit relevant to this alternative are summarised in following table:

STREAM	TOTAL AIR (1)	OXYGEN TO GASIFIERS (2)	HP NITROGEN (3)	LP NITROGEN (4)	TOTAL NITROGEN TO SYNGAS & GT
Temperature (°C)		180	80	70	95
Pressure (bar)		45	71	7.5	23
<b>TOTAL FLOW</b>					
Mass flow (kg/h)	975,220	219,800	105,960	41,100	573,100

Unit 2200: Syngas Treatment and Conditioning Line

This Unit receives the raw syngas from the gasification section, which is hot, humid and contaminated with acid gases, CO<sub>2</sub> and H<sub>2</sub>S, and other chemicals, mainly COS, HCN and NH<sub>3</sub>.

Before using this syngas as fuel in the gas turbines it is necessary to remove all the contaminants and prepare the syngas at the proper conditions of temperature, pressure and water content in order to achieve in the combustion process of the gas turbine the desired environmental performance and stability of operation.

Saturated raw syngas from wet scrubbing in Unit 1000, at approximately 39 bar and 180°C, enters Unit 2200. The syngas is first heated by the hot shift effluent and then enters the first stage of Shift Reactor, where CO is shifted to H<sub>2</sub> and CO<sub>2</sub> and COS is converted to H<sub>2</sub>S. The exothermic shift reaction brings the syngas temperature up to 496°C.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 12 of 29  
**Case 6**

---

In order to meet the required degree of CO<sub>2</sub> removal, a double stage shift containing sulphur tolerant shift catalyst (dirty shift) is used. In addition, a large amount of MP steam (290 t/h) shall be added to the syngas, coming from the scrubber, to allow reaching the required conversion of the shift reaction. This is a limitation of the gasification technology with waste heat boiler because the water content of the syngas is low if compared to the content of the syngas coming from the quench technology. The large amount of steam added to the syngas corresponds to a loss on the Plant Power production

The hot shifted syngas outlet from the first stage is cooled in a series of heat exchangers:

- Shift feed product exchanger
- HP Steam Generator
- MP Steam Generator

Inlet temperature to the second stage shift is controlled to 263 °C. Outlet temperature from second shift is 297°C. The hot shifted syngas outlet from the second stage is cooled in a series of heat exchangers:

- MP Steam Generator
- LP Steam Generator
- VLP Steam Generator
- Condensate Preheater A/B

The syngas exiting from the Condensate Preheater is already at the required temperature (38°C) for the AGR section. Even though a final cooling step of the syngas in a cooling water cooler is foreseen in case of necessity.

Process condensate separated in Separator Drums is recycled back to the Sour Water Stripper of the Gasification Island.

The first and second stage of the shift reactor is split in two parallel trains, as the remaining equipment of Unit 2200, because of the size limitation of the exchangers involved.

Cold syngas, after combined CO<sub>2</sub> and H<sub>2</sub>S removal, is diluted with Nitrogen in order to achieve 65% max Hydrogen content, preheated with VLP steam and then sent to the gas turbines, Unit 3000.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 13 of 29  
**Case 6**

The main process streams of the Syngas treatment and conditioning line relevant to this alternative are summarised in following table:

STREAM	SAT SYNGAS (1)	HP GENERATED STEAM (2)	MP GENERATED STEAM (3a+3b)	LP GENERATED STEAM (4)	VLP GENERATED STEAM (5)	SYNGAS TO GT (6)
Temperature (°C)	180	352	256	175	152	135
Pressure (bar)	39	171	44	9	5	28,5
<b>TOTAL FLOW</b>						
Mass flow (kg/h)	711,640	91,800	110,500	69,500	62,500	185,400
Molar flow (kmol/h)	33,450					15,785
Composition (% vol)						
H <sub>2</sub>	21,2					65,0
CO	42,1					3,5
CO <sub>2</sub>	5,0					4,0
N <sub>2</sub>	5,6					26,8
Ar	-					-
O <sub>2</sub>	-					0,4
H <sub>2</sub> S + COS	0,1					-
H <sub>2</sub> O	26,0					0,3
Others	-					-

Unit 2300: Acid Gas Removal (AGR)

The removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub> is an important step of the IGCC operation. In fact this unit is not only capital intensive and a large consumer of energy, but also is a key factor for the control of the environmental performance of the IGCC. The right selection of the process and of the solvent used to capture the acid gases is important for the performance of the complex.

Unit 2300 is characterised by a medium syngas pressure (30 bar g) and an extremely high CO<sub>2</sub>/H<sub>2</sub>S ratio (387/1).

Based on considerations on section C, paragraph 8.0, the combined removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub>, based on the Amine Guard FS process has been selected.

The product of this process is a single stream to be compressed and delivered to plant B.L.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**


Revision no.: Final  
 Date: November 2005  
 Sheet: 14 of 29  
**Case 6**

Entering Streams

1. Untreated Gas from Syngas Treatment & Conditioning Line

Exit Streams

2. Treated Gas to Gas Turbines
3. CO<sub>2</sub> to compression



The Amine Guard FS solvent consumption, to make-up losses, is 63,5 m<sup>3</sup>/year.

The proposed process matches the process specification with reference to H<sub>2</sub>S+CO<sub>2</sub> concentration of the treated gas exiting the Unit (H<sub>2</sub>S+CO<sub>2</sub> concentration is less than 3 ppm). This is due to the integration of CO<sub>2</sub> removal with the H<sub>2</sub>S removal, which makes available a large circulation of the solvent.

The CO<sub>2</sub> removal rate is 91,6% as required, allowing reaching an overall CO<sub>2</sub> capture of approx 85% with respect to the carbon entering the IGCC.

These performances for the H<sub>2</sub>S removal and CO<sub>2</sub> capture are achieved with large steam consumption.

Together with CO<sub>2</sub>/H<sub>2</sub>S exiting the Unit, the following quantity of hydrogen is lost:

- 97 kmol/h of Hydrogen, corresponding to 0.66% vol and to an overall thermal power of approx 6.6 MWth, i.e. more than 2 MWe.

The feasibility to separate and recover H<sub>2</sub> during the CO<sub>2</sub> compression was investigated. Due to the similar equilibrium constants of CO<sub>2</sub> and H<sub>2</sub> at super-critical CO<sub>2</sub> conditions, this separation is unfeasible.

The main process streams of the AGR Unit relevant to this alternative are summarised in following table:

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 15 of 29  
**Case 6**

STREAM	RAW SYNGAS (1)	TREATED SYNGAS (2)	CO <sub>2</sub> RICH STREAM (3)
Temperature (°C)	38	38	49
Pressure (bar)	30.7	29.5	1.8
<b>TOTAL FLOW</b>			
Molar flow (kmol/h)	38,870	24,900	14,800
Composition (% vol)			
H <sub>2</sub>	53.1	82.4	0.7
CO	2.9	4.5	-
CO <sub>2</sub>	38.7	5.1	93.3
H <sub>2</sub> S + COS	0.1	3 ppm	0.3
Others	5.2	8.0	5.7

Unit 2500: CO<sub>2</sub> Compression and Drying

This Unit is a Package Unit supplied by specialised Vendor. For more details see section C, paragraph 9.0.

The product stream sent to final storage is mainly composed of CO<sub>2</sub> and CO. The main properties of the stream are as follows:

- Product stream : 609 t/h.
  - Product stream : 110 bar
  - Composition :
- |                  |            |
|------------------|------------|
|                  | %vol       |
| CO <sub>2</sub>  | 99.0       |
| H <sub>2</sub> S | 0.3        |
| Others           | <u>0.7</u> |
| TOTAL            | 100.0      |

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 16 of 29

**Section D: Basic Information for Each Alternative**
**Case 6**


---

Unit 3000: Power Island

The power island is based on two General Electric gas turbines, frame 9001 FA, two Heat Recovery Steam Generators (HRSG), generating steam at 3 levels of pressure, and one steam turbine common to the two HRSGs.

The power island configuration is described referring to the Process Flow Diagrams attached to the end of this paragraph.

During normal operation, the clean syngas, coming from Unit 2200 - Syngas Treatment and Conditioning Line, is heated up to 170°C against MP BFW in the syngas final heater dedicated to each Gas Turbine.

Finally, the hot syngas is burnt inside the Gas Turbine to produce electric power; the resulting stream of hot exhaust gas is conveyed to the Heat Recovery Steam Generator located downstream each Gas Turbine.

Compressed air is extracted from the Gas Turbines and delivered to ASU. MP nitrogen coming from ASU is injected into the Gas Turbines for NO<sub>x</sub> abatement and power output augmentation.

The flue gas stream at a temperature of about 570°C flows through the coils inside the HRSG generating steam at three different pressure levels, is cooled down to about 129°C and then discharged through a stack common to the two HRSG Units.

The turbine consists of HP, IP and LP sections all connected to the generator on a single shaft. HP steam from the HRSG HP section enters the turbine at approx. 156 bar, 550°C. Steam from the exhaust of the HP turbine is returned to the HRSG for reheating after mixing with MP steam, and is then throttled into the IP turbine at approx. 36 bar, 530°C. Exhaust steam from IP flows into a LP turbine after mixing with superheated LP steam from HRSG and then downward into the condenser at 0.032 bar, 25°C.

The MHP saturated steam at 70 bar from the gasification island, is superheated in a dedicated coil and sent to a dedicated ST section where is expanded to 5.7 bar. The exhaust steam is mixed with the exhaust steam from the ST IP section and flows to the ST LP main section. This steam turbine is coupled to the same generator of the main steam turbine. A dedicated clutch allows isolating the smaller steam turbine during the start-up of the plant.



---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 17 of 29  
**Case 6**

---

When the clean syngas production is not sufficient to satisfy the appetite of both Gas Turbines it is possible to cofire natural gas or to switch to natural gas one or both Gas Turbines.

This could happen in case of partial or total failure of the Gasification/Gas Treatment units of the IGCC and during start-up.

The selected machines are suitable to co-fire syngas and natural gas from 20% to 100% load.

During Natural Gas Operation no air extraction is foreseen, while a stream of MP Steam has to be injected into the combustion chambers of the Gas Turbines to reduce the NO<sub>x</sub> emissions.

During normal operation on Natural Gas, the Power Island does not export/import to/from IGCC Process Units any steam/water stream and no low temperature heat can be recovered in Process Units. Then all cold condensate coming from Steam Condenser can be directly sent to the deaerator after polishing. In this situation, the degassing steam demand of the deaerator is very high, more than VLP steam produced by HRSG's that needs to be integrated with steam coming from LP and MP headers.

The interfaces considered (during normal operating case) between the power island and the rest of the plant are as follow:

- Compressed Air : Air sent to Unit 2100 – Air Separation Unit;
- MP nitrogen : Nitrogen coming from ASU injected into the Gas Turbines for NO<sub>x</sub> abatement and power output augmentation.
- HP steam (160 barg): steam imported from Syngas Treatment and Conditioning Line.
- MHP steam (70 barg): steam imported from Gasification Island.
- MP steam (40 barg): steam imported from Syngas Treatment and Conditioning Line.
- MP steam (40 barg): steam exported from the steam turbine to Syngas Treatment and Conditioning Line to meet the water requirement of the shift reaction.
- LP steam (6,5 barg): steam imported from Syngas Treatment and Conditioning Line. The steam is also exported to the following Process Units: ASU, Utility and Offsite Unit.
- LP steam (6,5 barg): steam exported from the steam turbine to AGR and Lignite Drying section.
- VLP steam (3,2 barg): steam imported from Syngas Treatment and Conditioning Line.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 18 of 29  
**Case 6**

- BFW : HP, MP, LP, VLP Boiler Feed Water is exported to the Process Units to generate the above mentioned steam production.
- Process Condensate : All the condensate recovered from the condensation of the steam utilised in the Process Unit is recycled back to the HRSG after polishing in Unit 4200, Demi Water/Condensate Recovery.
- Condensate from ST : All the Condensate from the Condenser is exported to the polishing unit (Unit 4200), pre-heated in the Syngas Cooling and Conditioning Line partially cooled in the Lignite drying section and recycled back to the HRSG.

Flow rate of the steam/water interfaces of the Plant are shown in table attached to para 6.5, Utilities Consumption.

The main process data of the Power Island relevant to this alternative are summarised in following table:

STREAM	SYNGAS (1)	AIR TO ASU (2)	NOX CONTROL N <sub>2</sub> (3)	LP STEAM TO ST (4)	HP STEAM TO ST (5)	RH MP STEAM TO ST (6)	COND. FROM ST (7)
Temperature (°C)	170	396	213	246	552	527	25
Pressure (bar)	26	14,2	22	5,7	156	36	0,03
<b>TOTAL FLOW</b>							
Mass flow (t/h)	185,4 (1)	147,7 (1)	193,0 (1)	144,4	432,9	456,1	970,5

STREAM	COOLING WATER TO CND (8)	COOLING WATER FROM CND (9)	FLUE GAS AT STACK (10)	MP STEAM FROM ST (11)	LP STEAM FROM ST (12)	MHP STEAM TO ST (13)
Temperature (°C)	11	21	129	273	173	507
Pressure (bar)	3	2,3	Amb	40	5,7	69
<b>TOTAL FLOW</b>						
Mass flow (kg/h)	33271	33271	2511,5 (1)	289,1	352,2	387,0

(1): For each GT

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	19 of 29
<b>Case 6</b>	

---

Unit 4600: Waste Water Treatment

The effluents from the Gasification Island – Sour water stripper are split in two parts. The flowrate needed as Gasification make-up is recycled back directly to the gasification. The excess part flows to the anaerobic treatment, where a phosphoric acid solution is added to the waste water to support the bacterial growth.

In the Anaerobic Reactor the organic pollutants are biodegraded with production of biological gas and biological sludge. The biogas produced in the reactor is routed to the local flare to be burned.

The biological mass exits the anaerobic reactor and enters the Anaerobic Clarifier where the biomass is separated by gravity from the supernatant.

Effluent from anaerobic section is subject to a further aerobic treatment for the complete removal of ammonia and organic contaminants. The effluent from the anaerobic clarifier is pumped to the denitrification/oxidation tanks where is mixed with the rainwater bleed-off and drainage coming from the deoiling section.

In this deoiling section, the oily drainage mixed with contaminated rainwater is fed by means of pumps from the oil water storage tank to the primary deoiling section, consisting of a Corrugate Plate Interceptor, which provides gravity separation of free oil and suspended solids carried in the waste water.

The effluent from the separator cells is dosed with polyelectrolyte and is routed by gravity to a secondary deoiling step, consisting of Induced Air Flotation. Air induced by motors driven self-aerating rotors mechanism removes the oil and suspended solids, which are collected in a dense froth to be recycled back to the CPI.

The deoiled water is then pumped to the denitrification/oxidation tanks, where it is mixed with the anaerobic treatment effluent and where the organic contaminants are removed and ammonia is oxidized to nitrates which are further reduced to nitrogen gas in the denitrification section.

The effluent from the oxidation tank enters the aerobic clarifier, where the biomass separates by gravity from the supernatant. The sludge from the bottom of the clarifier is recycled to the anaerobic reactor by the Sludge Pump.

The supernatant from the clarifier is dosed with polyelectrolyte and pumped into Dual Media Filter, which uses sand and anthracite as filter media for the

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 20 of 29  
**Case 6**

removal of residual hydrocarbons and suspended solids, and into Activated Carbon Filters, for the complete removal of organic contaminants

From the filters the water is sent to a dedicated treatment where the reverse osmosis process allows recovering almost 60% of the treated water. This recovered water is recycled back to the Demi Water System, Unit 4200, and used as raw water for the Demineralised water plant. The remaining 40% of water is discharged together with the cooling towers blowdown.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 21 of 29


**Case 6**

---


### **6.3 Process Flow Diagrams**

The Process Flow Diagrams of the following main process units are attached to this paragraph:

- UNIT 2100: Air Separation Unit (PFD n° BD0237A-3-50-2100);
- UNIT 2200: Syngas Treatment and Conditioning Line (PFD n° BD0237A-3-50-2200);
- UNIT 2300: Acid Gas Removal (PFD n° BD0237A-3-50-2300);
- UNIT 3000: Power Island (PFD n° BD0237A-3-50-3000; sheet 1 and 2).




NO.	REV.	DATE	BY	CHK.	APP.	DESCRIPTION
PROJECT NAME			SCALE		SHEET NO. OF TOTAL SHEETS	
EA GREEN HOUSE BLDG PROGRAM			1/4" = 1' - 0"		10	
CO2 CAPTURE IN LOW RANK COAL POWER PLANTS						
SHELL - CASE 6						
UNIT 200 AIR SEPARATOR UNIT						
DESIGNED BY: [Signature]			CHECKED BY: [Signature]		DATE: 10/20/11	
DRAWN BY: [Signature]			APPROVED BY: [Signature]		DATE: 10/20/11	
PROJECT NO. 10000000000000000000			SHEET NO. 10		OF TOTAL SHEETS 10	
DATE: 10/20/11			SCALE: 1/4" = 1' - 0"		SHEET NO. 10	



REVISIONS		DATE	BY	APP'D.
1	ISSUE FOR ISSUES			
2	REVISIONS			

PROJECT	EA GREEN HOUSE ROAD PROGRAMME	SCALE	AS SH.
SUBJECT	CO2 CAPTURE AT LOW RANK COAL POWER PLANTS	DRAWN	
UNIT	SHELL - CASE 6	DESIGNED BY	
DESCRIPTION	UNIT 2200 - SYNGAS TREATMENT AND CONDITIONING LINE	ENGINEER	0202337A
DATE	17/03/2010	DATE	
SCALE	AS SH.	DATE	
PROJECT	EA GREEN HOUSE ROAD PROGRAMME	SCALE	AS SH.
SUBJECT	CO2 CAPTURE AT LOW RANK COAL POWER PLANTS	DRAWN	
UNIT	SHELL - CASE 6	DESIGNED BY	
DESCRIPTION	UNIT 2200 - SYNGAS TREATMENT AND CONDITIONING LINE	ENGINEER	0202337A
DATE	17/03/2010	DATE	
SCALE	AS SH.	DATE	



RAW SYNGAS FROM UNIT 2200  
(STRONG COOLING)

P1

P2

ADD GAS REMOVAL  
PACKAGE  
(NMEA PROCESS)

CO2 TO COMPRESSION

PURGED SYNGAS TO UNIT 2200  
(STRONG HEAT/COOLING AND  
CONDENSING UNIT)


LEGEND	
	STREAM NUMBER

REV		DESCRIPTION				DATE			
NO.	BY	DATE	DESCRIPTION	REV	DATE	BY	DESCRIPTION	REV	DATE
		REVISIONS							
		PROJECT INFORMATION							
		CLIENT							
		SHEET INFORMATION							
		SHEET NO.							
		TOTAL SHEETS							

<b>EA GREEN HOUSE ROAD PROGRAMME</b> CO2 CAPTURE IN 100 MW COAL POWER PLANTS		SHEET NO. <b>10002337A</b> UNIT 2200-MS CO2 REMOVAL	
PROJECT NO. <b>10002337A</b> SHEET NO. <b>10002337A</b>		DATE: <b>10/2013</b> SCALE: <b>AS SHOWN</b>	
		PROJECT NO. <b>10002337A</b> SHEET NO. <b>10002337A</b>	






**LEGEND**

◇ STREAM NUMBER

NO.	SIZE FOR SERVICES	RETRIEVING				UNIT
		LP	MP	HP	ST	
EA GREEN HOUSE ROAD PROGRAMME						
CO2 CAPTURE IN LON BANK COAL POWER PLANTS						
SHELL - CASE 8						
UNIT 3000 POWER PLANT						
PROJECT NO. 41002337A						
DATE: 11/01/2008						
DRAWN: S-30-3000						
PAGE: 2 OF 2						



REVISIONS		REVISIONS	
NO.	DATE	BY	CHK
1			
2			

PROJECT INFORMATION		DRAWING INFORMATION	
NO.	DATE	BY	CHK
1			
2			

PROJECT INFORMATION		DRAWING INFORMATION	
NO.	DATE	BY	CHK
1			
2			

PROJECT INFORMATION		DRAWING INFORMATION	
NO.	DATE	BY	CHK
1			
2			

PROJECT INFORMATION		DRAWING INFORMATION	
NO.	DATE	BY	CHK
1			
2			

PROJECT INFORMATION		DRAWING INFORMATION	
NO.	DATE	BY	CHK
1			
2			

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 22 of 29

**Case 6**

---

#### **6.4 Heat and Material Balances**

For Heat and Material Balances refer to tables attached in paragraph 6.2.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 23 of 29

**Case 6**

---

## **6.5 Utility Consumption**

The Utility Consumption of the process / utility and offsite units are shown in the attached Tables.



CLIENT: IEA GHG  
 PROJECT: CO2 capture in low-rank coal power plants  
 LOCATION: Germany  
 FWI N°:

REVISION	Rev.0	Rev.1	Rev.2	Rev.3
DATE	Feb-05			
ISSUED BY	P.C.			
CHECKED BY	L.M.			
APPROVED BY	R.D.			

**UTILITIES CONSUMPTION SUMMARY - CASE 6 - SHELL LOW PRESSURE GASSIFICATION - MDEA**

UNIT	DESCRIPTION UNIT	HP Steam 160 barg [t/h]	MHP Steam 70 barg [t/h]	MP Steam 40 barg sat [t/h]	MP Steam 40 barg SH [t/h]	LP Steam 6.5 barg [t/h]	LP Steam ST extr. 4.7 barg [t/h]	VLP Steam 3.2 barg [t/h]	HP BFW [t/h]	MP BFW [t/h]	LP BFW [t/h]	VLP BFW [t/h]	condensate recovery [t/h]	Losses [t/h]
	<b>PROCESS UNITS</b>													
900	Lignite Handling, Milling and Drying						202.0						202.0	
1000	Gasification Section		-387.0						463.1				64.5	11.6
2100	Air Separation Unit					17.1							17.1	
2200	Syngas Treatment and Conditioning line	-91.8		-110.5	289.1	-69.5		-36.2	91.8	110.5	69.5	62.5	26.3	289.1
2300	Acid Gas Removal						150.2						150.2	
3000	<b>POWER ISLANDS UNITS</b>	91.8	387.0	110.5	-289.1	42.9	-352.2	36.2	-554.9	-110.5	-69.5	-62.5		
4100 to 5300	<b>UTILITY and OFFSITE UNITS</b>					9.4							9.4	
	<b>BALANCE</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>469.5</b>	<b>300.7</b>

Note: Minus prior to figure means figure is generated





**6.6 IGCC Overall Performance**

The following Table shows the overall performance of the IGCC Complex.

<b>SHELL</b>		
Low pressure Gasification - MDEA Alternative		
<b>OVERALL PERFORMANCES OF THE IGCC COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	624.2
Coal LHV (A.R.)	kJ/kg	10500.0
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>		
	<b>MWt</b>	<b>1820.5</b>
Thermal Power of Raw Syngas exit Scrubber (based on LHV)	MWt	1648.5
Thermal Power of Clean Syngas to Gas Turbines (based on LHV)	MWt	1467.5
Syngas treatment efficiency	%	89.0
<b>GROSS ELECTRIC POWER OUTPUT OF IGCC COMPLEX (D)</b>		
	<b>MWe</b>	<b>868.7</b>
ASU power consumption	MWe	117.8
Process Units consumption	MWe	32.7
Utility Units consumption	MWe	20.1
Offsite Units consumption (including cooling tower system)	MWe	0.6
Power Islands consumption	MWe	10.3
CO <sub>2</sub> Compression and Drying	MWe	56.5
<b>ELECTRIC POWER CONSUMPTION OF IGCC COMPLEX</b>		
	<b>MWe</b>	<b>238.0</b>
<b>NET ELECTRIC POWER OUTPUT OF IGCC (C)</b>		
(Step Up transformer efficiency = 0.997%)	<b>MWe</b>	<b>628.8</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>		
	<b>%</b>	<b>47.7</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>		
	<b>%</b>	<b>34.5</b>



**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 25 of 29

**Case 6**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the IGCC Complex.

	<b>Equivalent flow of CO<sub>2</sub>, kg/h</b>
Carbon incoming (Coal carbon = 57.19%wt)	16,297
Slag	100
<b>Net Carbon Flowing to Process Units (A)</b>	<b>16,197</b>
Liquid Storage	
CO	4
CO <sub>2</sub>	<u>13,792</u>
Total to storage (B)	13,796
Emission	
CO	6
CO <sub>2</sub>	<u>2,395</u>
Total Emission	2,401
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85.2</b>

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 26 of 29  
**Case 6**

**6.7 Environmental Impact**

The IGCC Complex is designed to process coal, whose characteristic are shown at Section B - para 2.0, and produce electric power. The advanced technology allows to reach a high efficiency and to minimise environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the IGCC Complex are summarised in this section.

**6.7.1 Gaseous Emissions**
Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases of the two trains of the Power Island, proceeding from the combustion of the Syngas in the two gas turbines, and emission from the coal Drying process.

Table 6.1 summarises expected flow rate and concentration of the combustion flue gas from one train of the Power Island.

**Table 6.1** – Expected gaseous emissions from one train of the Power Island.

	Normal Operation
Wet gas flow rate, kg/s	697.6
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	2,500,215
Temperature, °C	129
Composition	(%vol)
Ar	0.91
N <sub>2</sub>	74.84
O <sub>2</sub>	11.17
CO <sub>2</sub>	1.31
H <sub>2</sub> O	11.77
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NOx	74
SOx	1.2
CO	31.3
Particulate	5

(1) Dry gas, O<sub>2</sub> content 15%vol

Both the Combined Cycle Units have the same flue gas composition and flow rate. The total gaseous emissions of the Power Island are given in Table 6.2.

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 27 of 29  
**Case 6**

**Table 6.2** – Expected total gaseous emissions of the Power Island.

	Normal Operation
Wet gas flow rate, kg/s	1,395.2
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	5,000,430
Temperature, °C	129
<b>Emissions</b>	<b>kg/h</b>
NOx	375.0
SOx	6.0
CO	156.5
Particulate	25.0

(1) Dry gas, O<sub>2</sub> content 15%vol

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Flow rate : 2029.9 t/h  
 Particulate : <10 mg/Nm<sup>3</sup>, wet basis.

Minor Emissions

Other minor gaseous emissions are the process vents and fugitive emissions. Some of the vent points emit continuously; others during process upsets or emergency conditions only. All vent streams containing, potentially, undesirable gaseous components are sent to a flare system. Venting via the flare will be minimal during normal operation, but will be significant during emergencies, process upsets, start up and shutdown.

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). Proper design and operation reduce these emissions to a very low level.

**6.7.2 Liquid Effluent**

Waste Water Treatment (Unit 4600)

The expected flow rate, from the Reverse Osmosis, discharged together with the cooling towers blowdown, is as follows:

- Flow rate : 48 m<sup>3</sup>/h

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 28 of 29  
**Case 6**

Cooling Water System

Raw water is used for the cooling towers make up.  
 Main characteristics of the Cooling Towers blowdown are listed in the following:

- Maximum flow rate : 300 m<sup>3</sup>/h
- Temperature : 11 °C
- Cooling Tower Concentration factor : 5

**6.7.3 Solid Effluent**

The plant is expected to produce the following solid by-products:

Slag

- Flow rate : 10.8 t/h (dry flow rate)
- Water content : 10 %wt

Slag product can be sold to be commercially used as major components in concrete mixtures to make road, pads, storage bins.

Fly ash

- Flow rate : 12.3 t/h

Fly ash can be dispatched to cement industries.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 29 of 29

**Case 6**

---

## **6.8 Equipment List**

The list of main equipment and process packages are included in this section.



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.:

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

Unit 2100 - Air Separation Unit - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>									
						shell / tube	shell / tube		
1		1st Nitrogen heater	Shell & Tube						
2		1st Nitrogen heater	Shell & Tube						
1		2nd Nitrogen heater	Shell & Tube						
2		2nd Nitrogen heater	Shell & Tube						
<b>PACKAGES</b>									
		<b>Air Separation Unit Package</b> (two parallel trains, each sized for 50% of the capacity)							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisys - SHELL -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>						Shell/tube	Shell/tube		
1		Feed/ Product Exchanger	Shell & Tube						
2		Feed/ Product Exchanger	Shell & Tube						
1		HP Steam Generator	Kettle						
2		HP Steam Generator	Kettle						
1		MP Steam Generator	Kettle						
2		MP Steam Generator	Kettle						
1		MP Steam Generator	Kettle						
2		MP Steam Generator	Kettle						
1		LP Steam Generator	Kettle						
2		LP Steam Generator	Kettle						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisys - SHELL -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS (Continued)</b>				Shell/tube	Shell/tube		
1		VLP Steam Generator	Kettle						
2		VLP Steam Generator	Kettle						
1		Condensate Preheater	Shell & Tube						
2		Condensate Preheater	Shell & Tube						
1		Final Cooler	Shell & Tube						
2		Final Cooler	Shell & Tube						





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolisys - SHELL -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>DRUMS</b>							
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Cooling and COS Hydrolysis - SHELL -CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>REACTOR</b>									
1		Shift Catalyst Reactor - 1st Bed	vertical						
2		Shift Catalyst Reactor - 1st Bed	vertical						
1		Shift Catalyst Reactor - 2nd Bed	vertical						
2		Shift Catalyst Reactor - 2nd Bed	vertical						
<b>PACKAGE UNITS</b>									
		Catalyst Loading System							
		Shift Catalyst							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3100 - Gas Turbine - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>									
						Shell/tube	Shell/tube		
1		Syngas Final Heater	Shell & Tube						
2		Syngas Final Heater	Shell & Tube						
<b>DRUMS</b>									
1		Syngas Final Separator	vertical						
2		Syngas Final Separator	vertical						
<b>PACKAGES</b>									
1		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	286 MW					
2		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	286 MW					



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

Unit 3200 - Heat Recovery Steam Generator - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PUMPS</b>									
1		LP BFW Pumps	centrifugal						One operating, one spare
2		LP BFW Pumps	centrifugal						One operating, one spare
1		MP BFW Pumps	centrifugal						One operating, one spare
2		MP BFW Pumps	centrifugal						One operating, one spare
1		HP BFW Pumps	centrifugal						One operating, one spare
2		HP BFW Pumps	centrifugal						One operating, one spare
1		VLP BFW Pumps	centrifugal						One operating, one spare
2		VLP BFW Pumps	centrifugal						One operating, one spare
<b>MISCELLANEA</b>									
1		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
2		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
1		CCU Stack							
2		CCU Stack							
1		Stack Silencer							
2		Stack Silencer							
1		MP Steam Desuperheater							Included in 1-HRSG-3201
2		MP Steam Desuperheater							Included in 2-HRSG-3201
1		HP Steam Desuperheater							Included in 1-HRSG-3201
2		HP Steam Desuperheater							Included in 2-HRSG-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
		<b>Fluid Sampling Package</b>							
		<b>Phosphate Injection Package</b> Phosphate storage tank Phosphate dosage pumps							Included in Z - 3202 Included in Z - 3202 One operating , one spare
		<b>Oxygen Scavanger Injection Package</b> Oxygen scavanger storage tank Oxygen scavanger dosage pumps							Included in Z - 3203 Included in Z - 3203 One operating , one spare
		<b>Amines Injection Package</b> Amines Storage tank Amines Dosage pumps							Included in Z - 3204 Included in Z - 3204 One operating , one spare



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT RECOVERY STEAMGENERATOR</b>							
1		<b>Heat Recovery Steam Generator</b>	Horizontal, Natural Circulated, 4 Pressure Levels, Simple Recovery, Reheated.						
1		<b>HP steam Drum</b>							Included in 1-HRS-3201
1		<b>MP steam drum</b>							Included in 1-HRS-3201
1		<b>LP steam drum</b>							Included in 1-HRS-3201
1		<b>VLP steam drum with degassing section</b>							Included in 1-HRS-3201
1		<b>HP Superheater 2nd section</b>							Included in 1-HRS-3201
1		<b>MP Reheater 2nd section</b>							Included in 1-HRS-3201
1		<b>MHP Superheater</b>							Included in 1-HRS-3201
1		<b>HP Superheater 1st section</b>							Included in 1-HRS-3201
1		<b>MP Reheater 1st section</b>							Included in 1-HRS-3201
1		<b>HP Evaporator</b>							Included in 1-HRS-3201
1		<b>HP Economizer 3rd section</b>							Included in 1-HRS-3201
1		<b>MP Superheater</b>							Included in 1-HRS-3201
1		<b>MP Evaporator</b>							Included in 1-HRS-3201
1		<b>LP Superheater</b>							Included in 1-HRS-3201
1		<b>MP Economizer 2nd section</b>							Included in 1-HRS-3201
1		<b>HP Economizer 2nd section</b>							Included in 1-HRS-3201
1		<b>LP Evaporator</b>							Included in 1-HRS-3201
1		<b>LP Economizer</b>							Included in 1-HRS-3201
1		<b>MP Economizer 1st section</b>							Included in 1-HRS-3201
1		<b>HP Economizer 1st section</b>							Included in 1-HRS-3201
1		<b>VLP Evaporator</b>							Included in 1-HRS-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

### EQUIPMENT LIST

Unit 3200 - Heat Recovery Steam Generator - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT RECOVERY STEAM GENERATOR</b>							
2		<b>Heat Recovery Steam Generator</b>	Horizontal, Natural Circulated, 4 Pressure Levels, Simple Recovery, Reheated.						
2		<b>HP steam Drum</b>							Included in 1-HRS-3201
2		<b>MP steam drum</b>							Included in 1-HRS-3201
2		<b>LP steam drum</b>							Included in 1-HRS-3201
2		<b>VLP steam drum with degassing section</b>							Included in 1-HRS-3201
2		<b>HP Superheater 2nd section</b>							Included in 1-HRS-3201
2		<b>MP Reheater 2nd section</b>							Included in 1-HRS-3201
2		<b>MHP Superheater</b>							Included in 1-HRS-3201
2		<b>HP Superheater 1st section</b>							Included in 1-HRS-3201
2		<b>MP Reheater 1st section</b>							Included in 1-HRS-3201
2		<b>HP Evaporator</b>							Included in 1-HRS-3201
2		<b>HP Economizer 3rd section</b>							Included in 1-HRS-3201
2		<b>MP Superheater</b>							Included in 1-HRS-3201
2		<b>MP Evaporator</b>							Included in 1-HRS-3201
2		<b>LP Superheater</b>							Included in 1-HRS-3201
2		<b>MP Economizer 2nd section</b>							Included in 1-HRS-3201
2		<b>HP Economizer 2nd section</b>							Included in 1-HRS-3201
2		<b>LP Evaporator</b>							Included in 1-HRS-3201
2		<b>LP Economizer</b>							Included in 1-HRS-3201
2		<b>MP Economizer 1st section</b>							Included in 1-HRS-3201
2		<b>HP Economizer 1st section</b>							Included in 1-HRS-3201
2		<b>VLP Evaporator</b>							Included in 1-HRS-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3300 - Steam Turbine and Blow Down System - SHELL - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS</b>				shell / tube	shell / tube		
		Blow-Down Cooler	Shell & Tube						
		<b>DRUMS</b>							
		Flash Drum	vertical						
		Continuous Blow-down Drum	vertical						
		Discontinuous Blow-down Drum	vertical						
		<b>PACKAGES</b>							
		Steam Turbine & Condenser Package		300 MW					
		Steam Turbine							Included in Z - 3201
		Inter/After condenser							
		Gland Condenser							Included in Z - 3201
		Steam Condenser							Included in Z - 3201
		Steam Turbine Generator							Included in Z - 3201
		Start-up Ejector							Included in Z - 3201
		Holding Ejector 1st Stage							Included in Z - 3201
		Holding Ejector 2nd Stage							Included in Z - 3201
		Condensate Pumps	Centrifugal						Included in Z - 3201 Two operating, one spare
		Start-up Ejector Silencer							Included in Z - 3201
		<b>MISCELLANEA</b>							
	1	LP Steam from ST Desuperheater							
	1	MP Steam from ST Desuperheater							





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
LOCATION:  
PROJ. NAME: CO2 Capture in Low-rank coal Power Plants  
CONTRACT N.

REVISION	Rev.0	
DATE	Feb. 05	
ISSUED BY	P.C.	
CHECKED BY	L.M.	
APPROVED BY	R.D.	

**EQUIPMENT LIST**  
Unit 3400 - Electric Power Generation - SHELL - with CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
1		Gas Turbine Generator							Included in 1 -Z- 3101
2		Gas Turbine Generator							Included in 2 -Z- 3101
		Steam Turbine Generator							Included in Z- 3301



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION:  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	P.C.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Utility and Offsite Units - SHELL - with CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
	Unit 4100	Cooling Water System Machinery Cooling Water System							
	Unit 4200	Demineralized Water System Plant and Potable Water System							
	Unit 4300	Natural Gas System							
	Unit 4400	Plant and Instrument Air System							
	Unit 4600	Waste Water Treatment							
	Unit 4700	Fire Fighting System							
	Unit 4900	Chemicals							
	Unit 6000	Interconnecting Instrumentation DCS Piping Electrical 400 KV Substation							

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 28  
**Case 7**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : CASE 7 - IGCC BASED ON FOSTER WHEELER GASIFICATION  
 WITH PRECOMBUSTION CO<sub>2</sub> CAPTURE

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 28

**Case 7**

---

## **SECTION D**

### **BASIC INFORMATION FOR EACH ALTERNATIVE**

#### **I N D E X**

#### **SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

- 7.0 Case 7: IGCC based on Foster Wheeler gasification
- 7.1 Introduction
- 7.2 Process Description
- 7.3 Process Flow Diagrams
- 7.4 Heat and Material Balances
- 7.5 Utility Consumption
- 7.6 IGCC Overall Performance
- 7.7 Environmental Impact
- 7.8 Equipment List

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 3 of 28  
**Case 7**

**SECTION D BASIC INFORMATION FOR EACH ALTERNATIVE**

**7.0 Case 7 IGCC Based on Foster Wheeler gasification**

**7.1 Introduction**

The main features of this alternative for the precombustion CO<sub>2</sub> capture are:

- Low pressure (36.5 barg) FW Gasifier with air as partial oxidation agent;
- CFB Gasifier, Heat Recovery Type;
- Double stage sour Shift;
- Combined removal of H<sub>2</sub>S and CO<sub>2</sub>, based on the Amine Guard FS process.

The gross production capacity of the IGCC Complex of the study is 900 MWe.

The degree of integration between Air Compression Unit and the Gas Turbines is 30%. The use of air as partial oxidation agent allows the gas turbines working without further syngas dilution with nitrogen, for NO<sub>x</sub> control.

The arrangement of the main process units of the IGCC Complex is as follows:

<u>Unit</u>	<u>Trains</u>
1000 Gasification & Heat Recovery Waste Water Pre-treatment	4 x 33% 1 x 100%
2100 Air Compression Unit	2 x 50%
2200 Syngas Treatment and Conditioning Line	3 x 33%
2300 AGR (H <sub>2</sub> S and CO <sub>2</sub> Removal)	3 x 33%
2500 CO <sub>2</sub> Compression and Drying	2 x 50%
3000 Gas Turbine (PG 9351 – FA) HRSG Steam Turbine	2 x 50% 2 x 50% 1 x 100%

Reference is made to the attached overall Block Flow Diagram of the IGCC Complex.

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 4 of 28


**Case 7**

---

These basic blocks are supported by other ancillary units and a number of utility and offsite units, such as cooling water, flare, plant/instrument air, machinery cooling water, demineralised water, auxiliary fuels, etc.

Each process unit of the Complex may be a single train for the total capacity or split in two, three or more parallel trains, depending on the maximum capacity of the equipment involved or on the necessity to assure, through the use of multiple parallel trains, a superior degree of reliability.

## Case 7: FW Gasifier - IGCC COMPLEX Block Flow Diagram



**7.2 Process Description**


*Coal Handling and Storage:*

This unit is made up of standard equipment in use, to receive the coal from outside the plant boundary, store the coal, reclaim the same and transport to the plant. For more details see section C, paragraph 1.

*Coal Drying:*

The FW Gasification technology requires 25% moisture content in the feedstock to the gasifiers. As a lot of low temperature sources exist in plant, the indirect lignite drying method is used for this alternative.

The basic features of this process are shown in Section C, para 2.0. The process scheme used for this specific alternative is shown in the following scheme.





**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 7 of 28  
**Case 7**

The split of the heating sources required for the drying of the lignite is reported in the following table:

<b>Heat source</b>	<b>Duty, MWth</b>
Syngas cooling	91
CO <sub>2</sub> compression	38
VLP steam (3.2 barg)	16
Air compression	35.5
<b>TOTAL HEAT</b>	<b>180.5</b>

Unit 1000: Gasification Island

*Feeding system:*

The coal feeding system of the CFB Gasifier, operating at pressures ranging between 35 – 40 bara, consists of four coal silos, four mills and conveyor systems and four dosing unit, one for each gasifier.

The recommended particle size is in the range of 1000-2000 µm as larger particle size feed may reduce the carbon conversion and affect the right temperature profile.

By means of conveyor systems, the pulverized coal is passed to a dense-flow feeding system consisting of a sequence of an atmospheric fuel bunker, three lock hoppers and a feeder vessel.

The pulverized fuel settles in the fuel bunker, and the carrier gas and purging gas are vented over the bunker top.

The fuel is pneumatically transported by air in a dense flow to the gasifier burners.

*Gasifier:*

The feedstock is gasified in a CFB gasifier with air as partial oxidation agent, operating in a temperature range of 900-1000°C. The gasifier is basically a pressurized CFB unit, completely refractory lined, with no heat transfer surfaces. This design lowers the risk of slag attack to a refractory lining and offers long lifetime and low maintenance cost operation. The carbon conversion efficiency is around 97%, lower than the others technologies, thus resulting in a disadvantage of the process. The residual carbon rich char from the gasifier is cooled to approximately 250°C, to avoid auto ignition, depressurized and stored in a dedicated containment vessel. The char residue from the gasifier is suitable for combustion in a PC or CFB boiler; alternatively, the char could also be suitable for landfill disposal, as it is not

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	8 of 28
<b>Case 7</b>	

---

classified as a hazardous material. For the development of the present study, it is assumed that char is sent outside for further combustion in a PC or CFB boiler.

CFB gasifiers with 100% carbon conversion efficiency are under investigation and could be patented shortly.

*High Temperature Syngas Cooling:*

The hot syngas leaving the CFB Gasifier is cooled from 930°C to approximately 390°C before filtration. The syngas cooler transfers heat to the steam cycle generating MHP steam at 80 barg. The industry trend for these coolers is a fire tube design, with gas flowing inside the tubes and steam or water outside, on the shell side. Appropriate design ensures minimum fouling on the gas side, without the need of soot blowing systems.

Downstream the steam generation system, the syngas passes in a cyclone that removes solid particles, then in a ceramic candle filter for the removal of particulate of smaller size. Filtered syngas is used to preheat combustion air up to 316°C, as required by the gasifier, and is further sent to the gas scrubbing at 330°C.

*Gas Scrubbing:*

Syngas leaving the high temperature cooling section is scrubbed in a wet scrubbing unit to lower the residual fly ash content to a very low level. This system also removes other minor contaminants such as soluble alkali salts and hydrogen halides. To reduce the water consumption of the plant, recycle water from the sour water stripper unit is used. However, make-up water is continuously added to the wet scrubbing unit to control the concentration of the contaminants. The scrubber outlet temperature is lowered down to 160°C, to increase the water content in the syngas (approximately 20%) and reduce the injection of steam for the downstream shift reaction.

*Sour Water Stripper:*

The Sour Water Stripper separates the sour gases contained in the blow-down water from the Wet Scrubbing unit, as well as other sour water streams like the water condensed from the cooling of the syngas in Unit 2200. Since the column operates under non-fouling conditions, the necessary stripping steam is supplied via a LP steam re-boiler. The vapour leaving the SWS column is sent to an overhead system. In this overhead system the overhead vapours are condensed and the sour gases are separated from the condensate in the

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 9 of 28  
**Case 7**

gas/liquid separator. The condensed water is routed back to the SWS column, as reflux, above the rectifying bed. The sour gases are routed to Unit 2500 and compressed together with CO<sub>2</sub> captured in the downstream process units. The effluents from the Sour water stripper are split in two parts: the flowrate needed as Gasification make-up is recycled back directly to the gasification, whilst the remaining part flows to the wastewater treatment (Unit 4600).

The main process streams of the Gasification Island relevant to this alternative are summarised in following table:

STREAM	FUEL FEED COAL (25%Moisture)	AIR	STEAM	SORBENT	SATURATED SYNGAS	MHP STEAM GENERATED
Temperature (°C)	AMB.	316	246	15	927	296
Pressure (bar)	38	38	38	38	37	80
<b>TOTAL FLOW</b>						
Mass flow (kg/h)	454200	1064734	32497	8511	1528010	504500
Molar flow (kmol/h)		36868			61458	
Composition (% vol)						
H <sub>2</sub>					14.64	
CO					16.65	
CO <sub>2</sub>					10.53	
N <sub>2</sub>					46.82	
CH <sub>4</sub>					1.25	
Ar					0.57	
O <sub>2</sub>					0.00	
H <sub>2</sub> S + COS					0.05	
H <sub>2</sub> O					9.41	
Others					0.08	

Note: Figures referred to the total flowrates.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 10 of 28  
**Case 7**

Unit 2100: Air Compression Unit (ACU)

Compressed air is required by the Gasification Island for the partial oxidation of the coal in the gasifiers. Part of the airflow is also used for the pneumatic transport of dried pulverized coal to the gasifiers.

The Air Compression Unit (Unit 2100) produces air to satisfy the above requirements.

The Plant mainly consists of two air compression trains, integrated with the gas turbines compressors.

When the gasification operates at full load, approx 30% of the air required by the gasifiers is derived from the gas turbine compressors, i.e. the integration between the gas turbines operation and the ACU is achieved at a level where approx 70% of the atmospheric air is compressed with self standing units, being the remaining part coming already pressurized from the compressors of the gas turbines (approx. 14 bars). A second compression stage finally compresses air coming from GTs and first stage up to the required pressure of the gasification island (38 bars).

The air extracted from the gas turbines at high temperature is cooled by exchanging heat with the total airflow rate coming from the last stage of compression, which must be heated to 316°C prior entering the gasifiers.

To reduce the power demand of the compression unit, intercooled stages are used and the heat is recovered for subsequent drying of the lignite.

The main process streams of the Air Compression Unit are summarised in following table:

<b>STREAM</b>	<b>AIR INTAKE FROM ATM (1)</b>	<b>AIR FROM GTs (2)</b>	<b>TOTAL AIR TO GASIFIERS (3)</b>
<b>Temperature (°C)</b>	9	366	316
<b>Pressure (bar)</b>	ATM	14.2	38
<b>TOTAL FLOW</b>			
Mass flow (kg/h)	745314	319420	1064734

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.:	Final
Date:	November 2005
Sheet:	11 of 28
<b>Case 7</b>	

---

Unit 2200: Syngas Treatment and Conditioning Line

This Unit receives the raw syngas from the gasification section, which is contaminated with acid gases, CO<sub>2</sub> and H<sub>2</sub>S, and other chemicals, like COS, HCN and NH<sub>3</sub>.

Before using this syngas as fuel in the gas turbines it is necessary to remove all the contaminants and prepare the syngas at the proper conditions of temperature, pressure and water content in order to achieve, in the combustion process of the gas turbine, the desired environmental performance and stability of operation.

Saturated raw syngas from wet scrubbing in Unit 1000, at approximately 36 bars and 160°C, enters Unit 2200. The syngas is first heated by the hot shift effluent and then enters the first stage of Shift Reactor, where CO is shifted to H<sub>2</sub> and CO<sub>2</sub>, whilst COS is converted to H<sub>2</sub>S. In order to meet the required degree of CO<sub>2</sub> removal, a double stage shift containing sulphur tolerant shift catalyst (dirty shift) is used. A large amount of MP steam shall be added to the syngas (227 t/h), before entering the reactors, to allow reaching the required degree of CO conversion. This is a limitation coming from the gasification technology involved, as the air gasification leads to a high nitrogen content in the syngas outlet from the gasification island, thus resulting in a very diluted CO concentration and in a high dry syngas flow rate. In fact, to reach a good CO removal efficiency, a minimum Water on Dry Syngas ratio of approx 0.3 shall be ensured at the outlet of the shift reactors, thus resulting in a high additional steam requirement that corresponds to a considerable loss of power production.

The shift efficiency is 91.4% with respect to the incoming CO and is similar to the other alternatives, but the correspondent CO<sub>2</sub> capture rate of the Plant is less because of the characteristics of the gasification technology involved, being the degree of carbon conversion approximately 97%, instead of more than 99% for the other technologies, and because of the presence of CH<sub>4</sub> in the syngas due to the relatively low combustion temperature.

The exothermic shift reaction brings the syngas temperature outlet from the first stage of the shift reactor up to 350°C. Inlet temperature to the second stage shift is controlled to 275 °C. Outlet temperature from second shift is 305°C. The hot shifted syngas outlet from the second stage is cooled in a series of heat exchangers:

- MP Steam Generator
- LP Steam Generator
- VLP Steam Generator

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 12 of 28  
**Case 7**

## Condensate Preheater A/B

The final cooling step of the syngas takes place in a cooler, where syngas is cooled with cooling water.

Process condensate collected during the cooling of the condensate is recycled back to the Sour Water Stripper of the Gasification Island.

Unit 2200 is entirely split in three parallel trains, both for the shift reactors and the cooling section, because of the size limitation of the equipment involved.

The main process streams of the Syngas treatment and conditioning line are summarised in following table:

<b>STREAM</b>	<b>SAT SYNGAS (1)</b>	<b>MP GENERATED STEAM (2)</b>	<b>LP GENERATED STEAM (3)</b>	<b>VLP GENERATED STEAM (4)</b>	<b>SYNGAS TO GTs (5)</b>
<b>Temperature (°C)</b>	159	256	175	152	49
<b>Pressure (bar)</b>	36.3	44	9	5	28.5
<b>TOTAL FLOW</b>					
Mass flow (kg/h)	1657187	56300	107800	33060	952848
Molar flow (kmol/h)	68635				50418
<b>Composition (% vol)</b>					
H <sub>2</sub>	13.11				36.20
CO	14.90				1.74
CO <sub>2</sub>	9.42				2.65
N <sub>2</sub>	41.92				56.95
CH <sub>4</sub>	1.12				1.52
Ar	0.51				0.69
O <sub>2</sub>	0.00				0.00
H <sub>2</sub> S + COS	0.05				0.00
H <sub>2</sub> O	18.90				0.25
Others	0.07				0.00

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 13 of 28  
**Case 7**

Unit 2300: Acid Gas Removal (AGR)

The removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub> is an important step of the IGCC operation. In fact, this unit is not only capital intensive and a large consumer of energy, but also is a key factor for the control of the environmental performance of the IGCC. The right selection of the process and of the solvent used to capture the acid gases is important for the performance of the complex.


Unit 2300 is characterised by a medium syngas pressure (29 bar g). Based on considerations of section C, paragraph 8.0, the combined removal of acid gases, H<sub>2</sub>S and CO<sub>2</sub>, based on the Amine Guard FS process has been selected. The product of this process is a single stream to be compressed and delivered to plant B.L.

Entering Streams

1. Untreated Gas from Syngas Treatment & Conditioning Line

Exit Streams

2. Treated Gas to Gas Turbines
3. CO<sub>2</sub> to compression



The Amine Guard FS solvent consumption, to make-up losses, is 93 m<sup>3</sup>/year.

The proposed process matches the process specification with reference to H<sub>2</sub>S+CO<sub>2</sub> concentration of the treated gas exiting the Unit (H<sub>2</sub>S+CO<sub>2</sub> concentration is less than 3 ppm). This is due to the integration of CO<sub>2</sub> removal with the H<sub>2</sub>S removal, which makes available a large circulation of the solvent.

The CO<sub>2</sub> removal rate is 91.5% as required, allowing reaching an overall CO<sub>2</sub> capture of 82.9% with respect to the carbon entering the Process Units.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 14 of 28  
**Case 7**

These performances for the H<sub>2</sub>S removal and CO<sub>2</sub> capture are achieved with large LP steam consumption.

Together with CO<sub>2</sub>/H<sub>2</sub>S exiting the Unit, the following quantity of hydrogen is lost:

- 86 kmol/h of Hydrogen, corresponding to 0.55% vol and to an overall thermal power of approx 5.8 MWth, i.e. more than 1.8 MWe.

The feasibility to separate and recover H<sub>2</sub> during the CO<sub>2</sub> compression was investigated. Due to the similar equilibrium constants of CO<sub>2</sub> and H<sub>2</sub> at super-critical CO<sub>2</sub> conditions, this separation is unfeasible.

The main process streams of the AGR Unit are summarised in following table:

<b>STREAM</b>	<b>RAW SYNGAS (1)</b>	<b>TREATED SYNGAS (2)</b>	<b>CO<sub>2</sub> RICH STREAM (3)</b>
<b>Temperature (°C)</b>	38	38	49
<b>Pressure (bar)</b>	30	29	1.8
<b>TOTAL FLOW</b>			
Molar flow (kmol/h)	65143	50418	15766
<b>Composition (% vol)</b>			
H <sub>2</sub>	28.16	36.20	0.55
CO	1.36	1.74	0.02
CO <sub>2</sub>	24.26	2.65	91.77
CH <sub>4</sub>	1.18	1.52	0.00
N <sub>2</sub>	44.17	56.95	0.74
H <sub>2</sub> S + COS	0.05	0.00	0.20
Others	0.82	0.94	6.72

Unit 2500: CO<sub>2</sub> Compression and Drying

This Unit is a Package Unit supplied by specialised Vendors. For more details see section C, paragraph 9.0.

The product stream sent to final storage is mainly composed of CO<sub>2</sub> and CO. The main properties of the stream are as follows:



**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 15 of 28  
**Case 7**

- Product stream : 641.4 t/h.
- Product stream : 110 bar
- Composition :

	%vol
CO <sub>2</sub>	98.41
H <sub>2</sub> S	0.22
Others	1.37
TOTAL	100.0

Unit 3000: Power Island

The Power Island is based on two General Electric gas turbines, frame 9001 FA, two Heat Recovery Steam Generators (HRSG), generating steam at 3 pressure levels, and one steam turbine common to the two HRSGs.

The power island configuration is described referring to the Process Flow Diagrams attached to paragraph 7.3.

During normal operation, the clean syngas, coming from Unit 2100 - Syngas Treatment and Conditioning Line, is heated up to 170°C against MP BFW in the syngas final heater dedicated to each Gas Turbine.

Finally, the hot syngas is burnt inside the Gas Turbine to produce electric power; the resulting stream of hot exhaust gas is conveyed to the Heat Recovery Steam Generator, located downstream each Gas Turbine.

Compressed air is extracted from the Gas Turbines and delivered to Air Compression Unit, reaching 30% of integration.

The flue gas stream at a temperature of about 570°C flows through the coils inside the HRSG, generating steam at three different pressure levels, cooled down to about 129°C and then discharged to the atmosphere through a stack common to the 2 HRSG Units.

The turbine consists of HP, IP and LP sections all connected to the generator on a single shaft. HP steam from the HRSG HP section enters the turbine at approx. 156 bar, 550°C. Steam from the exhaust of the HP turbine is returned to the HRSG for reheating, after mixing with MP steam, and is then throttled into the IP turbine at approx. 36 bar, 530°C. Exhaust steam from IP flows into a LP turbine after mixing with superheated LP steam from HRSG and then downward into the condenser at 0.032 bar (25°C).

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 16 of 28  
**Case 7**

---

The MHP saturated steam (80 bars) from the gasification island is superheated in a dedicated coil and sent to a dedicated ST section where is expanded to 5.7 bar. The exhaust steam is mixed with the exhaust steam from the ST IP section and flows to the ST LP main section. This Steam Turbine is coupled to the same generator of the main steam turbine. A dedicated clutch allows isolating the smaller steam turbine during the start-up of the plant.

When the clean syngas production is not sufficient to satisfy the appetite of both Gas Turbines it is possible to co-fire natural gas or to switch to natural gas one or both Gas Turbines.

This could happen in case of partial or total failure of the Gasification/Gas Treatment units of the IGCC and during start-up.

The selected machines are suitable to co-fire syngas and natural gas from 20% to 100% load.

During Natural Gas Operation no air extraction is foreseen, while a stream of MP Steam has to be injected into the combustion chambers of the Gas Turbines to reduce the NO<sub>x</sub> emissions.

During normal operation on Natural Gas, the Power Island does not export/import to/from IGCC Process Units any steam/water stream and no low temperature heat can be recovered in Process Units. Then all cold condensate coming from Steam Condenser can be directly sent to the deaerator after polishing. In this situation, the degassing steam demand of the deaerator is very high, more than VLP steam produced by HRSG's that needs to be integrated with steam coming from LP and MP heaters.

The interfaces considered (during normal operating case) between the power island and the rest of the plant are as follow:

- Compressed Air : Air sent to Unit 2100 – Air Compression Unit.
- MHP steam (80 barg) : Steam imported from Gasification Island.
- MP steam (40 barg) : Saturated Steam imported from Syngas Treatment and Conditioning Line.
- SHMP steam (40 barg): Superheated Steam from the Steam Turbine exported to Syngas Treatment and Conditioning Line to meet the water requirement of the shift reaction.
- LP steam (6,5 barg): Steam imported from Syngas Treatment and Conditioning Line. Steam is also exported to the Utility and Offsite Units.
- LP steam (4.7 barg): Steam exported from the Steam Turbine to the Acid Gas Removal Unit.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 17 of 28  
**Case 7**

- VLP steam (3,2 barg): The total steam generated in Syngas Treatment and Conditioning Line is used in the Lignite drying section.
- BFW : HP, MP, LP, VLP Boiler Feed Water is exported to the Process Units to generate the above mentioned steam production.
- Process Condensate : All the condensate recovered from the condensation of the steam utilised in the Process Unit is recycled back to the HRSG after polishing in Unit 4200, Demi Water/Condensate Recovery.
- Condensate from ST : All the Condensate from the Condenser is exported to the polishing unit (Unit 4200), pre-heated in the Syngas Cooling and Conditioning Line, partially cooled in the Lignite drying section and recycled back to the HRSG.

Flow rate of the steam/water interfaces of the Plant are shown in table attached to para 7.5, Utilities Consumption.

The main process data of the Power Island relevant to this alternative are summarised in following table:

STREAM	SYNGAS (1)	AIR TO ACU (2)	LP STEAM TO ST (3)	MP STEAM TO ST (4)	HP STEAM TO ST (5)	MHP STEAM TO ST (6)
Temperature (°C)	170	396	238	527	550	517
Pressure (bar)	28	14,2	5,7	36	156	77
<b>TOTAL FLOW</b>						
Mass flow (t/h)	476.4 (1)	159.7 (1)	114.4	363.0	377.1	504.5

STREAM	MP STEAM TO SHIFT REACTOR (7)	LP STEAM TO AGR (8)	COND. FROM ST (9)	COOLING WATER TO CND (10)	COOLING WATER FROM CND (11)	FLUE GAS AT STACK (12)
Temperature (°C)	270	170	25	11	21	129
Pressure (bar)	40	5.7	0,03	3	2,3	Amb
<b>TOTAL FLOW</b>						
Mass flow (kg/h)	227.3	222.4	1042.6	38774	38774	2474.7 (1)

(1): For each GT

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

---

Revision no.: Final  
Date: November 2005  
Sheet: 18 of 28  
Case 7

---

Unit 4600: Waste Water Treatment

The part of wastewater from the Sour Water stripper, that is not recycled back to the gasification island, flows to the anaerobic treatment, where a phosphoric acid solution is added to the wastewater to support the bacterial growth.

In the Anaerobic Reactor the organic pollutants are biodegraded with production of biological gas and biological sludge. The biogas produced in the reactor is routed to the local flare to be burned.

The biological mass exits the anaerobic reactor and enters the Anaerobic Clarifier where the biomass is separated by gravity from the supernatant.

Effluent from anaerobic section is subject to a further aerobic treatment for the complete removal of ammonia and organic contaminants. The effluent from the anaerobic clarifier is pumped to the denitrification/oxidation tanks where is mixed with the rainwater bleed-off and drainage coming from the deoiling section.

In this deoiling section, the oily drainage mixed with contaminated rainwater is fed by means of pumps from the oil water storage tank to the primary deoiling section, consisting of a Corrugate Plate Interceptor, which provides gravity separation of free oil and suspended solids carried in the waste water.

The effluent from the separator cells is dosed with polyelectrolyte and is routed by gravity to a secondary deoiling step, consisting of Induced Air Flotation. Air induced by motors driven self-aerating rotors mechanism removes the oil and suspended solids, which are collected in a dense froth to be recycled back to the CPI.

The deoiled water is then pumped to the denitrification/oxidation tanks, where it is mixed with the anaerobic treatment effluent and where the organic contaminants are removed and ammonia is oxidized to nitrates that are further reduced to nitrogen gas in the denitrification section.

The effluent from the oxidation tank enters the aerobic clarifier, where the biomass separates by gravity from the supernatant. The sludge from the bottom of the clarifier is recycled to the anaerobic reactor by the Sludge Pump.

The supernatant from the clarifier is dosed with polyelectrolyte and pumped into Dual Media Filter, which uses sand and anthracite as filter media for the removal of residual hydrocarbons and suspended solids, and into Activated Carbon Filters, for the complete removal of organic contaminants

---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 19 of 28

**Case 7**

---

From the filters the water is sent to a dedicated treatment where the reverse osmosis process allows recovering almost 60% of the treated water. This recovered water is recycled back to the Demi Water System, Unit 4200, and used as raw water for the Demineralised water plant. The remaining 40% of water is discharged together with the cooling towers blowdown.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 20 of 28


**Case 7**

---

### **7.3 Process Flow Diagrams**

The Process Flow Diagrams of the following main process units are attached to this paragraph:

- UNIT 2100: Air Compression Unit (PFD n° BD0237A-3-50-2100)
- UNIT 2200: Syngas Treatment and Conditioning Line (PFD n° BD0237A-3-50-2200);
- UNIT 2300: Acid Gas Removal (PFD n° BD0237A-3-50-2300);
- UNIT 3000: Power Island (PFD n° BD0237A-3-50-3000; sheet 1 and 2).




**LEGEND**

◇	STREAM NUMBER
---	---------------

REV		REVISIONS				REVISIONS			
NO.	DATE	BY	CHK	DESCRIPTION	DATE	BY	CHK	DESCRIPTION	DATE

<b>E.A. GREEN HOUSE ROAD PROGRAMME</b> <b>CO2 CAPTURE IN 100 MW COAL POWER PLANTS</b>		SCALE	MFC
<b>P.W. CASHER - CASE 7</b> <b>UNIT 700-A6 COMPRESSION UNIT</b>		AREA	UNIT
PROJECT NO. <b>9000337A</b> SHEET NO. <b>4</b> OF <b>10</b>		DATE	

	DRAWING APPROVED BY: <b>TEJASWANI</b> DESIGNED BY: <b>TEJASWANI</b> CHECKED BY: <b>TEJASWANI</b> PROJECT ENGINEER: <b>TEJASWANI</b> PROJECT MANAGER: <b>TEJASWANI</b>	DATE: <b>08/03/2017</b> TIME: <b>11:50:20</b> SHEET: <b>4</b>
--	---	---



REVISIONS		DATE		BY	


  

EA GREEN HOUSE R&D PROGRAM CO2 CAPTURE ALLOW FIRM COAL POWER PLANTS		SHEET NO. 104
F.W. Gooden - CASK 7		AREA:
UNIT 2200- SYNGAS TREATMENT AND CONDITIONING LINE		DRAWING NO. 1000237A
PROJECT NO. 1000237		SHEET NO. 104
DATE: 10/11/01		SCALE:
DRAWN BY:		CHECKED BY:
APPROVED BY:		DATE:


	F.W. Gooden 1000237-1-10-2300
--	----------------------------------





**LEGEND**  
 ◊ STREAM NUMBER


UNIT		UNIT FLOW SHEETS		UNIT FLOW SHEETS		UNIT FLOW SHEETS	
UNIT	NO.	UNIT	NO.	UNIT	NO.	UNIT	NO.
<b>REVISIONS</b>							
NO.	DATE	DESCRIPTION	BY	CHK.	DATE	BY	CHK.
<b>EA GREEN HOUSE ROAD PROGRAMME</b> <b>CO2 CAPTURE IN 100 RAW COAL POWER PLANTS</b> <b>FW GASIFIER - CASE 7</b> <b>UNIT 2200-MSR GAS REMOVAL</b>							
<b>PROJECT INFORMATION</b> PROJECT NO.: 10002337A PROJECT NAME: FW GASIFIER - CASE 7 PROJECT LOCATION: 10002337A				<b>SCALE</b> SHEET NO.: 1 TOTAL SHEETS: 1			
<b>DESIGN INFORMATION</b> DESIGNER: [Name] CHECKER: [Name] DATE: 2010-10-20				<b>APPROVAL</b> APPROVED BY: [Signature] DATE: 2010-10-20			



**LEGEND**

◇ STEAM NUMBER

NO.	SIZE FOR SERVICES	REHEATING			NO.
		HP	MP	LP	
EA GREEN HOUSE ROAD PROGRAMME					
CO <sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS					
FW CASHER - CASE 7					
UNIT 3000 POWER PLANT					
AREA:					
PROJECT:					
CONTRACT NO. 11002337A					
DATE:					
CONSULTANT:					
DESIGN & 3-D MODEL:					
SHEET NO. 3000-001					



REVISIONS		REVISIONS	
NO.	DATE	BY	CHK.
1			
2			

E.A. GREEN HOUSE ROAD PROGRAMME		SCALE	1:1
CO2 CAPTURE IN 100 MW COAL POWER PLANTS		AREA	
FW CASHER - CASE 7		DATE	
100 MW COAL POWER PLANT		DESIGNED BY	MOHAMED A. EL-SAYED
		CHECKED BY	
		DATE	
		PROJECT NO.	1000337A
		REV.	1
		DATE	10/10/2007
		SCALE	1:1

		100 MW COAL POWER PLANT CO2 CAPTURE IN 100 MW COAL POWER PLANTS FW CASHER - CASE 7 100 MW COAL POWER PLANT
--	--	---

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 21 of 28

**Case 7**

---

#### **7.4 Heat and Material Balances**

For Heat and Material Balances refer to tables attached in paragraph 7.2.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final

Date: November 2005

Sheet: 22 of 28

**Case 7**

---

## **7.5 Utility Consumption**

The Utility Consumption of the process / utility and offsite units are shown in the attached Tables.









## 7.6 IGCC Overall Performance

The following Table shows the overall performance of the IGCC Complex.

<b>FW GASIFIER</b>		
<b>Case 7</b>		
<b>OVERALL PERFORMANCES OF THE IGCC COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	691.0
Coal LHV (A.R.)	kJ/kg	10500.0
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>2015.4</b>
Thermal Power of Raw Syngas exit Scrubber (based on LHV)	MWt	1585.4
Thermal Power of Clean Syngas to Gas Turbines (based on LHV)	MWt	1467.2
Syngas treatment efficiency	%	92.5
Gas turbines total power output (@ gen terminals)	MWe	580.0
Steam turbine power output (@ gen terminals)	MWe	320.5
<b>GROSS ELECTRIC POWER OUTPUT OF IGCC COMPLEX (D)</b>	<b>MWe</b>	<b>900.5</b>
Air Compression for Gasification	MWe	106
Process Units consumption	MWe	21.9
Utility Units consumption	MWe	14.9
Offsite Units consumption (including cooling tower system)	MWe	0.5
Power Islands consumption	MWe	8.3
CO <sub>2</sub> Compression and Drying	MWe	59.9
<b>ELECTRIC POWER CONSUMPTION OF IGCC COMPLEX</b>	<b>MWe</b>	<b>211.9</b>
<b>NET ELECTRIC POWER OUTPUT OF IGCC (C)</b> (Step Up transformer efficiency = 0.997%)	<b>MWe</b>	<b>686.6</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>44.7</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>34.1</b>

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 24 of 28  
**Case 7**

The following Table shows the overall CO<sub>2</sub> removal efficiency of the IGCC Complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 47.66%wt)	18038
Limestone	84
Slag	661
<b>Net Carbon flowing to Process Units (A)</b>	<b>17461</b>
Liquid Storage	
CO	3.5
CO <sub>2</sub>	<u>14471.0</u>
<b>Total to storage (B)</b>	<b>14474.5</b>
Emission	
CO <sub>2</sub>	2986.5
CO	<u>0.0</u>
<b>Total Emission</b>	<b>2986.5</b>
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>82.9</b>

The removal efficiency of 82.9% of the incoming carbon is lower than the other IGCC technologies, where approx. 85% has been considered. The reasons of this lower efficiency are attributable to the gasification technology of the alternative and are mainly listed in the following:

- Lower carbon conversion of the CFB Gasifier (approx. 97%), compared to more than 99% of the other technologies (see also paragraph 7.2, Unit 1000), which reduces the amount of carbon entering the downstream process units.
- Presence of CH<sub>4</sub> in the syngas generated in the gasifier, because of the low gasification temperature (<1000°C); methane is not affected by the shift reaction and is not captured by the downstream Acid Gas Removal Section.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 25 of 28  
**Case 7**

**7.7 Environmental Impact**

The IGCC Complex is designed to process coals, whose characteristic are shown at Section B - para 2.0, and produce electric power. The advanced technology allows reaching a high efficiency and minimising environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the IGCC Complex are summarised in this section.

**7.7.1 Gaseous Emissions**
Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases of the two trains of the Power Island, proceeding from the combustion of the Syngas in the two gas turbines, and emission from the coal Drying process.

Table 7.1 summarises expected flow rate and concentration of the combustion flue gas from one train of the Power Island.

**Table 7.1** – Expected gaseous emissions from one train of the Power Island.

	Normal Operation
Wet gas flow rate, kg/s	687.4
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	2,847,775
Temperature, °C	129
Composition	(%vol)
Ar	0.88
N <sub>2</sub>	76.02
O <sub>2</sub>	10.09
CO <sub>2</sub>	1.67
H <sub>2</sub> O	11.34
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NOx	74
SOx	1.2
CO	31.4
Particulate	5

(1) Dry gas, O<sub>2</sub> content 15%vol

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

Revision no.: Final  
 Date: November 2005  
 Sheet: 26 of 28  
**Case 7**

Both the Combined Cycle Units have the same flue gas composition and flow rate. The total gaseous emissions of the Power Island are given in Table 7.2.

**Table 7.2** – Expected total gaseous emissions of the Power Island.

	Normal Operation
Wet gas flow rate, kg/s	1,395.2
Flow, Nm <sup>3</sup> /h <sup>(1)</sup>	5,695,550
Temperature, °C	129
Emissions	kg/h
NO <sub>x</sub>	421.5
SO <sub>x</sub>	6.8
CO	178.8
Particulate	28.5

(1) Dry gas, O<sub>2</sub> content 15%vol

In normal operation at full load, the following emission to the atmosphere is foreseen from the Coal Drying Process:

Flow rate : 1601 t/h  
 Particulate : <10 mg/Nm<sup>3</sup>, wet basis.

Minor Emissions

Other minor gaseous emissions are the process vents and fugitive emissions. Some of the vent points emit continuously; others during process upsets or emergency conditions only. All vent streams containing, potentially, undesirable gaseous components are sent to a flare system. Venting via the flare will be minimal during normal operation, but will be significant during emergencies, process upsets, start up and shutdown.

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). Proper design and operation reduce these emissions to a very low level.

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section D: Basic Information for Each Alternative**


---

Revision no.: Final  
 Date: November 2005  
 Sheet: 27 of 28  
**Case 7**

**7.7.2 Liquid Effluent**
Waste Water Treatment (Unit 4600)

The expected flow rate, from the Reverse Osmosis, discharged together with the cooling towers blowdown, is as follows:

- Flow rate : 268.4 m<sup>3</sup>/h

Cooling Water System

Raw water is used for the cooling towers make up.

Main characteristics of the Cooling Towers blowdown are listed in the following:

- Maximum flow rate : 209 m<sup>3</sup>/h
- Temperature : 11 °C
- Cooling Tower Concentration factor : 5

**7.7.3 Solid Effluent**

The plant is expected to produce the following solid by-products:

Char

Flow rate : 40 t/h (dry flow, including 6.8 t/h of unreacted carbon).

The char sorbent residue from the gasifier is sent to an outside plant for further combustion in a PC or CFB boiler.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section D: Basic Information for Each Alternative**

---

Revision no.: Final

Date: November 2005

Sheet: 28 of 28

**Case 7**

---

## **7.8 Equipment List**

The list of main equipment and process packages are included in this section.



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2100 - Air Compression Unit - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS</b>				shell / tube	shell / tube		
		<b>PACKAGES</b>							
		Air Compression Unit Package (two parallel trains, each sized for 50% of the capacity)							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Treatment & Conditioning Line - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>									
						Shell/tube	Shell/tube		
1		Feed/ Product Exchanger	Shell & Tube						
2		Feed/ Product Exchanger	Shell & Tube						
3		Feed/ Product Exchanger	Shell & Tube						
1		MP Steam Generator	Kettle						
2		MP Steam Generator	Kettle						
3		MP Steam Generator	Kettle						
1		LP Steam Generator	Kettle						
2		LP Steam Generator	Kettle						
3		LP Steam Generator	Kettle						





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Treatment & Conditioning Line - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS (Continued)</b>				Shell/tube	Shell/tube		
1		VLP Steam Generator	Kettle						
2		VLP Steam Generator	Kettle						
3		VLP Steam Generator	Kettle						
1		Condensate Preheater	Shell & Tube						
2		Condensate Preheater	Shell & Tube						
3		Condensate Preheater	Shell & Tube						
1		Final Cooler	Shell & Tube						
2		Final Cooler	Shell & Tube						
3		Final Cooler	Shell & Tube						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Treatment & Conditioning Line - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>DRUMS</b>							
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
3		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
3		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
3		Condensate Separator	Vertical						
1		Condensate Separator	Vertical						
2		Condensate Separator	Vertical						
3		Condensate Separator	Vertical						



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 2200 - Syngas Treatment & Conditioning Line - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>REACTOR</b>									
1		Shift Catalyst Reactor - 1st Bed	vertical						
2		Shift Catalyst Reactor - 1st Bed	vertical						
3		Shift Catalyst Reactor - 1st Bed	vertical						
1		Shift Catalyst Reactor - 2nd Bed	vertical						
2		Shift Catalyst Reactor - 2nd Bed	vertical						
3		Shift Catalyst Reactor - 2nd Bed	vertical						
<b>PACKAGE UNITS</b>									
		Catalyst Loading System							
		Shift Catalyst							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3100 - Gas Turbine - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>HEAT EXCHANGERS</b>									
						Shell/tube	Shell/tube		
1		Syngas Final Heater	Shell & Tube						
2		Syngas Final Heater	Shell & Tube						
<b>DRUMS</b>									
1		Syngas Final Separator	vertical						
2		Syngas Final Separator	vertical						
<b>PACKAGES</b>									
1		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	290 MW					
2		<b>Gas Turbine &amp; Generator Package</b> Gas turbine Gas turbine Generator	PG 9531 (FA)	290 MW					



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

### EQUIPMENT LIST

Unit 3200 - Heat Recovery Steam Generator - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PUMPS</b>									
1		LP BFW Pumps	centrifugal						One operating, one spare
2		LP BFW Pumps	centrifugal						One operating, one spare
1		MP BFW Pumps	centrifugal						One operating, one spare
2		MP BFW Pumps	centrifugal						One operating, one spare
1		HP BFW Pumps	centrifugal						One operating, one spare
2		HP BFW Pumps	centrifugal						One operating, one spare
1		VLP BFW Pumps	centrifugal						One operating, one spare
2		VLP BFW Pumps	centrifugal						One operating, one spare
<b>MISCELLANEA</b>									
1		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
2		Flue Gas Monitoring System							NOx, CO, SO <sub>2</sub> , particulate, H <sub>2</sub> O, O <sub>2</sub>
1		CCU Stack							
2		CCU Stack							
1		Stack Silencer							
2		Stack Silencer							
1		MP Steam Desuperheater							Included in 1-HRSG-3201
2		MP Steam Desuperheater							Included in 2-HRSG-3201
1		HP Steam Desuperheater							Included in 1-HRSG-3201
2		HP Steam Desuperheater							Included in 2-HRSG-3201



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>PACKAGES</b>							
		<b>Fluid Sampling Package</b>							
		<b>Phosphate Injection Package</b> Phosphate storage tank Phosphate dosage pumps							Included in Z - 3202 Included in Z - 3202 One operating , one spare
		<b>Oxygen Scavanger Injection Package</b> Oxygen scavanger storage tank Oxygen scavanger dosage pumps							Included in Z - 3203 Included in Z - 3203 One operating , one spare
		<b>Amines Injection Package</b> Amines Storage tank Amines Dosage pumps							Included in Z - 3204 Included in Z - 3204 One operating , one spare





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0	Rev.2	Rev.3
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 3200 - Heat Recovery Steam Generator - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT RECOVERY STEAM GENERATOR</b>							
2		Heat Recovery Steam Generator	Horizontal, Natural Circulated, 4 Pressure Levels, Simple Recovery, Reheated.						
2		HP steam Drum							Included in 2-HRS-3201
2		MP steam drum							Included in 2-HRS-3201
2		LP steam drum							Included in 2-HRS-3201
2		VLP steam drum with degassing section							Included in 2-HRS-3201
2		HP Superheater 2nd section							Included in 2-HRS-3201
2		MP Reheater 2nd section							Included in 2-HRS-3201
2		MHP Superheater							Included in 2-HRS-3201
2		HP Superheater 1st section							Included in 2-HRS-3201
2		MP Reheater 1st section							Included in 2-HRS-3201
2		HP Evaporator							Included in 2-HRS-3201
2		HP Economizer 3rd section							Included in 2-HRS-3201
2		MP Evaporator							Included in 2-HRS-3201
2		MP Superheater							Included in 2-HRS-3201
2		LP Superheater							Included in 2-HRS-3201
2		MP Economizer 2nd section							Included in 2-HRS-3201
2		HP Economizer 2nd section							Included in 2-HRS-3201
2		LP Evaporator							Included in 2-HRS-3201
2		LP Economizer							Included in 2-HRS-3201
2		MP Economizer 1st section							Included in 2-HRS-3201
2		HP Economizer 1st section							Included in 2-HRS-3201
2		VLP Evaporator							Included in 2-HRS-3201





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1-BD-0237A

REVISION	Rev.0		
DATE	Feb. 05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

Unit 3300 - Steam Turbine and Blow Down System - FW Gasifier - CO<sub>2</sub> capture, dirty shift reaction, combined removal of H<sub>2</sub>S and CO<sub>2</sub>

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
		<b>HEAT EXCHANGERS</b>				shell / tube	shell / tube		
		Blow-Down Cooler	Shell & Tube						
		<b>DRUMS</b>							
		Flash Drum	vertical						
		Continuous Blow-down Drum	vertical						
		Discontinuous Blow-down Drum	vertical						
		<b>PACKAGES</b>							
		Steam Turbine & Condenser Package		320 MW					
		Steam Turbine							Included in Z - 3201
		Inter/After condenser							Included in Z - 3201
		Gland Condenser							Included in Z - 3201
		Steam Condenser							Included in Z - 3201
		Steam Turbine Generator							Included in Z - 3201
		Start-up Ejector							Included in Z - 3201
		Holding Ejector 1st Stage							Included in Z - 3201
		Holding Ejector 2nd Stage							Included in Z - 3201
		Condensate Pumps	Centrifugal						Included in Z - 3201 Two operating, one spare
		Start-up Ejector Silencer							Included in Z - 3201
		<b>MISCELLANEA</b>							
	1	LP Steam from ST Desuperheater							
	1	MP Steam from ST Desuperheater							





---

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**  
**Section E: Economics**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 1 of 20

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
DOCUMENT NAME : ECONOMICS

ISSUED BY : L. MANCUSO  
CHECKED BY : L. MANCUSO  
APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section E: Economics**

---

Revision no.: Final

Date: Nov. 2005

Sheet: 2 of 20

**SECTION E**

**ECONOMICS**

**INDEX**

**SECTION E ECONOMICS**

- 1.0 Introduction
  
- 2.0 Basis of Investment Cost Evaluation
  - 2.1 Basis of the Estimate
  - 2.2 Estimate Methodology and Cost Basis
  - 2.3 Estimate Accuracy
  
- 3.0 Investment Cost of the Alternatives
  - 3.1 Postcombustion CO<sub>2</sub> capture alternatives (Case 1 through 4)
  - 3.2 Precombustion CO<sub>2</sub> capture alternatives (Case 5 through 7)
  
- 4.0 Operation and Maintenance Cost of the Alternatives
  - 4.1 Variable Costs
  - 4.2 Fixed Costs
  - 4.3 Summary
  
- 5.0 Evaluation of the Electric Power cost of the alternatives
  - 5.1 Electric Power Cost

## SECTION E

### 1.0 Introduction

This section summarises the economic data evaluated for each alternative of the study, including:

- a. Investment cost;
- b. Operation & Maintenance costs;
- c. Electric power production cost.

### 2.0 Basis of Investment Cost Evaluation

#### 2.1 Basis of the Estimate

The basis of the estimate for each alternative is the technical documentation collected in Sections C and D of the report.

Depending on the alternative considered, the investment cost of the following main Units or blocks of Units is detailed:

##### Postcombustion CO<sub>2</sub> capture alternatives (Case 1 through 4):

Coal/Ash Handling & Storage  
Coal Drying  
Boiler Island with SCR and ESP  
FGD Unit (Case 1)  
Air Separation Unit (Case 2)  
Power Island  
CO<sub>2</sub> Capture Plant (MEA or MDEA solvent)  
CO<sub>2</sub> Compression and Drying  
Utilities and Offsite

##### Precombustion CO<sub>2</sub> capture alternatives (Case 5 through 7):

Coal/Ash Handling & Storage  
Coal Drying  
Gasification Section  
Air Separation Unit (Case 5 and 6) or Air Compression Unit (Case 7)  
Syngas Treatment and Conditioning Line  
Acid Gas Removal (MDEA solvent)  
CO<sub>2</sub> Compression and Drying

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 4 of 20

**Section E: Economics**


---

Power Island  
 Utilities and Offsite

Further details on the equipment included in the cost estimate of each alternative are shown in the equipment list of each alternative, included in Section D.

The overall investment cost of each Unit or block of Units is split into the following items:

- Direct Materials, including equipment and bulk materials;
- Construction, including mechanical erection, instrument and electrical installation, civil works and, where applicable, buildings and site preparation;
- Other Costs, including temporary facilities, solvents, catalysts, chemicals, training, commissioning and start-up costs, spare parts etc.;
- EPC Services including Contractor's home office services and construction supervision.

## **2.2 Estimate Methodology and Cost Basis**

### **2.2.1 Direct Materials**

The direct materials cost estimate of the main Units or Blocks of Units listed at para. 2.1 is developed according to the following general criteria:

#### **Coal/Ash Handling, Storage, Drying**

The cost of equipment delivered and erected is based on a budget quotation received from a qualified Vendor, detailing direct materials and construction costs.

The investment cost of the unit is calculated on the basis of the capacity of each alternative, as detailed in Section D.

#### **Gasification Island (Precombustion CO<sub>2</sub> capture alternatives)**

Gasification Licensors provided investment cost data of the main equipment.

These figures have been adjusted based on the actual coal flowrate resulting from finalization of the IGCC performances of alternatives 5 to 7.

After this adjustment, the investment cost of main equipment has been increased by a factor derived from in-house data, to take into account minor equipment and bulk materials.

The resulting figure is the direct materials cost.

**Boiler Island** (Postcombustion CO<sub>2</sub> capture alternatives)USC-PC and Oxy-PC Boiler (Case 1 and 2)

No Supplier provided investment cost data for this alternative; therefore figures have been calculated by using in-house and literature data. Final check of the economical data has been made with figures of the previous IEA reports, used as background.

CFB and PCFB Boiler (Case 3 and 4)

Licensors provided investment cost data of the main equipment, specifically referred to the lignite coal of this study and to the required flow rate of each alternative.

**FGD Unit** (Case 1)

Reference performance and cost data of an FGD system, designed for a coal fired power generation, are shown in Section C, paragraph 5.0. Economical data are adjusted on the basis of suitable parameters like flue gas flow rate and sulphur concentration.

**Air Separation Unit** (Case 2, 5, 6 and 7)

The investment cost is derived from competitive bids received and technically evaluated by FW in the past for similar projects.

For each alternative, the figure taken as a reference has been adjusted based on suitable parameters like feedstock flowrate and characteristics, product flowrate, purity and conditions.

**Syngas Cooling and Conditioning Line, Acid Gas Removal with MDEA solvent** (Precombustion CO<sub>2</sub> capture alternatives)

Investment cost for these units are derived from previous studies that Foster Wheeler made for the IEA, by using suitable parameters like flue gas flowrate and characteristics, product flowrate and purity conditions.

**CO<sub>2</sub> Capture Plant with MEA Solvent** (Case 1, 3)

Investment cost of this unit is derived from information contained in a previous report made for the IEA. For the two alternatives, the figure taken as a reference has been adjusted based on suitable parameters like flue gas flowrate and characteristics, product flowrate and purity conditions.



### **CO<sub>2</sub> Compression and Drying**

Direct materials cost of CO<sub>2</sub> compressors and drivers are based on a budget quotation received from qualified Vendors. Costs of other equipment are derived from in house data.

### **Power Island**

The direct materials cost is based on competitive bids received in the past for similar equipment (gas turbine, HRSG, steam turbine) and on proprietary software output for other equipment and bulk materials.

### **Utilities and Offsite**

Cost of each Unit is evaluated based on in house data for similar Units. These units also include DCS, ESD, EMS, Electrical Systems and HV substation. The overall investment cost evaluated for a reference case selected among the different alternatives is then adjusted case by case, on the basis of the actual coal flowrate.

#### **2.2.2 Construction, Other Costs and EPC Services**

Per each Unit (if necessary, for each Technology), or block of Units, the remaining costs (i.e. Construction, Other Costs and EPC Services) are calculated multiplying the cost of direct materials by factors, built up by FW from statistics based on cost estimates of similar plants.

#### **2.2.3 Contingencies**

The estimating contingency is a provisional sum that will give to an estimate equal chance of overrun or underrun within certain limits and it is meant to cover:

- Estimating errors.
- Estimating omissions.

Contingency is included in the estimate as a percentage of the estimated costs on the basis of:

- definition of the technical documentation in term of quality and completeness;
- estimate quality;
- methodology adopted to develop the estimate.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 7 of 20

**Section E: Economics**

---

Different percentages of contingency are applied to the different sections on the basis of historical data. In absence of a more detailed assessment, 10% is considered as reference contingency.

**2.2.4 Estimate Currencies**

The estimate was developed in Euro.

The following exchange Euro to US \$ rate has been used:

1 US \$ equivalent to 1 Euro.

**2.2.5 Inflation**

No escalation is applied to the estimated installed cost.

**2.2.6 Miscellanea Costs**

Land purchase, surveys and general site preparation are taken into account at a cost equal to 5% of the installed plant cost.

Additional costs for process/patent fees, fees for agents and consultants, legal and planning activities, are taken into account at a cost equal to 2% of the installed plant cost. Where the cost of license fee is more than 2% of the installed plant cost, it is separately indicated in the calculation.

The sum of the installed plant cost plus the miscellanea costs is the Total Investment Cost.

**2.3 Estimate Accuracy**

The estimate accuracy is within the range +/- 35%.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 8 of 20

**Section E: Economics**

---

**3.0 Investment Cost of the Alternatives****3.1 Postcombustion CO<sub>2</sub> capture alternatives (Case 1 through 4)**

The following Tables E.3.1/4 show the investment break down and the total figures for each alternative investigated.

Table E.3.5 summarises the results and shows the net specific investment cost for all the alternatives.



### Table E.3.2 - Case 2 - ESTIMATE SUMMARY

OXY-USC-PC Boiler with post-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : November 2005 REV. Final

FIGURE IN EURO

POS	DESCRIPTION	UNIT								REMARKS
		1000 €	1050 €	1100 €	2000 €	3000 €	4000 €	UTIL&OFF €	TOTAL €	
1	DIRECT MATERIALS	39,939,000	6,836,000	179,637,000	189,615,000	89,385,000	43,202,000	123,277,000	671,891,000	1) ESTIMATE ACCURACY +/- 35% 2) TODAY COSTS (ESCALATION NOT INCLUDED)  1000 Coal Handling, Storage, Ash and Solid Removal, 1050 Coal Drying 1100 Air Separation Unit 2000 Boiler Island Milling ESP 3000 Power Island 4000 CO <sub>2</sub> Separation Unit BOP Utilities&Offsites
2	CONSTRUCTION	18,415,000	1,401,000	69,235,000	150,354,000	45,546,000	26,084,000	67,801,000	378,836,000	
3	OTHER COSTS	2,623,000	701,000	18,712,000	7,882,000	3,128,000	4,076,000	12,328,000	49,450,000	
4	EPC SERVICES	8,048,000	1,219,000	18,712,000	37,774,000	14,992,000	8,151,000	24,656,000	113,552,000	
		—	—	—	—	—	—	—	—	
A	<b>Installed costs</b> (contingency excluded)	<b>69,025,000</b>	<b>10,157,000</b>	<b>286,296,000</b>	<b>385,625,000</b>	<b>153,051,000</b>	<b>81,513,000</b>	<b>228,062,000</b>	<b>1,213,729,000</b>	
B	Contingency	%	7	7	7	10	7	7	8.0	
		Euro	4,831,750	710,990	20,040,720	38,562,500	10,713,570	5,705,910	15,964,340	
C	Fees (2% of A)	1,380,500	203,140	5,725,920	7,712,500	3,061,020	1,630,260	4,561,240	24,274,580	
D	Land Purchases; surveys (5% of A)	3,451,250	507,850	14,314,800	19,281,250	7,652,550	4,075,650	11,403,100	60,686,450	
		—	—	—	—	—	—	—	—	
<b>TOTAL INVESTMENT COST</b>		<b>78,688,500</b>	<b>11,578,980</b>	<b>326,377,440</b>	<b>451,181,250</b>	<b>174,478,140</b>	<b>92,924,820</b>	<b>259,990,680</b>	<b>1,395,219,810</b>	

### Table E.3.3 - Case 3 - ESTIMATE SUMMARY

CFB Boiler with post-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : November 2005 REV. Final

FIGURE IN EURO

POS	DESCRIPTION	UNIT							UTIL&OFF	TOTAL	REMARKS
		1000 €	1050 €	2000 €	3000 €	4000 €	5000 €	€			
1	DIRECT MATERIALS	36,619,000	6,268,000	144,042,000	70,984,000	51,718,000	24,136,000	114,276,000	448,043,000	1) ESTIMATE ACCURACY +/- 35% 2) TODAY COSTS (ESCALATION NOT INCLUDED)  <b>1000</b> Coal Handling, Storage, Ash and Solid Removal, <b>1050</b> Coal Drying <b>2000</b> Boiler Island SCR based DeNOx ESP <b>3000</b> Power Island <b>4000</b> CO <sub>2</sub> capture plant <b>5000</b> CO <sub>2</sub> Compression & Drying BOP Utilities&Offsites	
2	CONSTRUCTION	16,884,000	1,284,000	114,216,000	36,170,000	37,592,000	9,377,000	62,851,000	278,374,000		
3	OTHER COSTS	2,405,000	643,000	5,988,000	2,484,000	2,065,000	1,369,000	11,428,000	26,382,000		
4	EPC SERVICES	7,379,000	1,118,000	28,695,000	11,906,000	9,919,000	2,625,000	22,856,000	84,498,000		
		_____	_____	_____	_____	_____	_____	_____	_____		
A	<b>Installed costs</b> (contingency excluded)	<b>63,287,000</b>	<b>9,313,000</b>	<b>292,941,000</b>	<b>121,544,000</b>	<b>101,294,000</b>	<b>37,507,000</b>	<b>211,411,000</b>	<b>837,297,000</b>		
B	Contingency	%	7	7	7	7	7	5	7		6.9
		Euro	4,430,090	651,910	20,505,870	8,508,080	7,090,580	1,875,350	14,798,770		57,860,650
C	Fees (2% of A)	1,265,740	186,260	5,858,820	2,430,880	2,025,880	750,140	4,228,220	16,745,940		
D	Land Purchases; surveys (5% of A)	3,164,350	465,650	14,647,050	6,077,200	5,064,700	1,875,350	10,570,550	41,864,850		
		_____	_____	_____	_____	_____	_____	_____	_____		
		_____	_____	_____	_____	_____	_____	_____	_____		
<b>TOTAL INVESTMENT COST</b>		<b>72,147,180</b>	<b>10,616,820</b>	<b>333,952,740</b>	<b>138,560,160</b>	<b>115,475,160</b>	<b>42,007,840</b>	<b>241,008,540</b>	<b>953,768,440</b>		



## Table E.3.5 - ESTIMATE SUMMARY

### Postcombustion CO<sub>2</sub> capture: Coal Power Plants

Refer: 1-BD-0237A

Client: IEA GREENHOUSE R & D PROJ.

Plant: CO<sub>2</sub> CAP. IN LOW RANK COAL P.P.

Location: GERMANY

Date: November 2005      REV. Final

FIGURE IN MM EURO

POS	DESCRIPTION	Case 1 USC-PC		Case 2 OXY-PC		Case 3 CFB		Case 4 PCFB	
		€	%	€	%	€	%	€	%
1	Boiler Island	463.1	37.0	451.2	32.3	334.0	35.0	345.4	28.1
2	Process Units	306.4	24.5	416.6	29.9	198.2	20.8	431.5	35.1
3	CO <sub>2</sub> Compression and Drying	47.6	3.8	92.9	6.7	42.0	4.4	47.9	3.9
4	Power Island	162.5	13.0	174.5	12.5	138.6	14.5	135.1	11.0
5	Utilities and Offsite Units	272.2	21.7	260.0	18.6	241.0	25.3	270.7	22.0
<b>TOTAL INVESTMENT COST</b>		<b>1,251.8</b>	<b>100.0</b>	<b>1,395.2</b>	<b>100.0</b>	<b>953.8</b>	<b>100.0</b>	<b>1,230.6</b>	<b>100.0</b>

<b>NET POWER OUTPUT, MWe</b>	<b>761.0</b>	<b>741.3</b>	<b>614.7</b>	<b>688.4</b>
<b>SPECIFIC INVESTMENT COST, Euro/kW</b>	<b>1645</b>	<b>1882</b>	<b>1552</b>	<b>1788</b>



### **3.2 Precombustion CO<sub>2</sub> capture alternatives (Case 5 through 7)**

The following Tables E.3.6/8 show the investment break down and the total figures for each alternative investigated.

Table E.3.9 summarises the results and shows the net specific investment cost for all the alternatives.

**Table E.3.6 - Case 5 - ESTIMATE SUMMARY**

**FUTURE ENERGY - IGCC with pre-combustion CO<sub>2</sub> capture**

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R & D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : November 2005 REV. Final

POS	DESCRIPTION	900 €	950 €	1000 €	2100 €	2200 €	2300 €	2500 €	3000 €	UTIL&OFF €	TOTAL €	REMARKS
1	DIRECT MATERIALS	50,792,000	14,530,000	61,500,000	75,693,000	20,866,000	18,874,000	23,054,000	226,311,000	105,737,342	597,357,342	1) ESTIMATE ACCURACY +/- 35%
2	CONSTRUCTION	24,414,000	2,978,000	27,675,000	22,712,000	10,074,000	11,993,000	8,956,000	56,577,000	58,155,000	223,534,000	2) TODAY COSTS (ESCALATION NOT INCLUDED)
3	OTHER COSTS	3,204,000	1,490,000	9,225,000	3,028,000	14,591,000	15,609,000	1,307,000	22,631,000	10,574,000	81,659,000	3) License fee of the proprietary technology exceeds 2% of the plant cost.
4	EPC SERVICES	10,432,000	2,591,000	21,525,000	11,371,000	6,246,000	3,592,000	2,508,000	18,105,000	21,148,000	97,518,000	
A	<b>Installed costs</b> (contingency excluded)	<b>88,842,000</b>	<b>21,589,000</b>	<b>119,925,000</b>	<b>112,804,000</b>	<b>51,777,000</b>	<b>50,068,000</b>	<b>35,825,000</b>	<b>323,624,000</b>	<b>195,614,342</b>	<b>1,000,068,342</b>	
B	Contingency											
	%	7	7	7	5	7	7	5	7	5	6.3	
	Euro	6,218,940	1,511,230	8,394,750	5,640,200	3,624,390	3,504,760	1,791,250	22,653,680	9,780,717	63,119,917	
C	Fees (2% of A)	1,776,840	431,780	(3) 4,000,000	2,256,080	1,035,540	1,001,360	716,500	6,472,480	3,912,287	21,602,867	
D	Land Purchases; surveys (5% of A)	4,442,100	1,079,450	5,996,250	5,640,200	2,588,850	2,503,400	1,791,250	16,181,200	9,780,717	50,003,417	
	<b>TOTAL INVESTMENT COST</b>	<b>101,279,880</b>	<b>24,611,460</b>	<b>138,316,000</b>	<b>126,340,480</b>	<b>59,025,780</b>	<b>57,077,520</b>	<b>40,124,000</b>	<b>368,931,360</b>	<b>219,088,063</b>	<b>1,134,794,543</b>	

900 Coal Handling, Storage, Milling  
 950 Coal Drying  
 1000 Gasification Section  
 2100 Air Separation Unit  
 2200 Syngas Treat.&Condt. Line  
 2300 Acid Gas Removal  
 2500 CO<sub>2</sub> Compression&Drying  
 3000 Power Island  
 4000+ Utilities&Offsites

**Table E.3.7 - Case 6 - ESTIMATE SUMMARY**

SHELL - IGCC with pre-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R & D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : November 2005 REV. Final

POS	DESCRIPTION	900 €	950 €	1000 €	2100 €	2200 €	2300 €	2500 €	3000 €	UTIL&OFF €	TOTAL €	REMARKS
1	DIRECT MATERIALS	49,310,000	15,839,000	117,269,000	68,275,000	17,645,000	18,677,000	22,123,000	225,173,000	102,652,000	636,963,000	1) ESTIMATE ACCURACY +/- 35%
2	CONSTRUCTION	23,702,000	3,168,000	58,635,000	20,486,000	8,519,000	11,868,000	8,595,000	56,293,000	56,458,000	247,724,000	2) TODAY COSTS (ESCALATION NOT INCLUDED)
3	OTHER COSTS	3,111,000	1,585,000	7,036,000	2,732,000	12,339,000	15,447,000	1,254,000	22,517,000	10,265,000	76,286,000	
4	EPC SERVICES	10,128,000	2,375,000	29,317,000	10,256,000	5,282,000	3,555,000	2,407,000	18,014,000	20,531,000	101,865,000	
A	Installed costs (contingency excluded)	<b>86,251,000</b>	<b>22,967,000</b>	<b>212,257,000</b>	<b>101,749,000</b>	<b>43,785,000</b>	<b>49,547,000</b>	<b>34,379,000</b>	<b>321,997,000</b>	<b>189,906,000</b>	<b>1,062,838,000</b>	
B	Contingency											
	%	7	7	7	5	7	7	5	7	5	6.4	
	Euro	6,037,570	1,607,690	14,857,990	5,087,450	3,064,950	3,468,290	1,718,950	22,539,790	9,495,300	67,877,980	
C	Fees (2% of A)	1,725,020	459,340	4,245,140	2,034,980	875,700	990,940	687,580	6,439,940	3,798,120	21,256,760	
D	Land Purchases; surveys (5% of A)	4,312,550	1,148,350	10,612,850	5,087,450	2,189,250	2,477,350	1,718,950	16,099,850	9,495,300	53,141,900	
<b>TOTAL INVESTMENT COST</b>		<b>98,326,140</b>	<b>26,182,380</b>	<b>241,972,980</b>	<b>113,958,880</b>	<b>49,914,900</b>	<b>56,483,580</b>	<b>38,504,480</b>	<b>367,076,580</b>	<b>212,694,720</b>	<b>1,205,114,640</b>	

900 Coal Handling, Storage, Milling  
 950 Coal Drying  
 1000 Gasification Section  
 2100 Air Separation Unit  
 2200 Syngas Treat.&Condt. Line  
 2300 Acid Gas Removal  
 2500 CO<sub>2</sub> Compression&Drying  
 3000 Power Island  
 4000+ Utilities & Offsites

**Table E.3.8 - Case 7 - ESTIMATE SUMMARY**

**FOSTER WHEELER - IGCC with pre-combustion CO<sub>2</sub> capture**

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R & D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : November 2005 REV. Final

POS	DESCRIPTION		900 €	950 €	1000 €	2100 €	2200 €	2300 €	2500 €	3000 €	UTIL&OFF €	TOTAL €	REMARKS
1	DIRECT MATERIALS		52,679,000	9,516,000	143,512,000	16,617,000	29,217,000	26,126,000	22,979,000	227,097,000	109,664,000	637,407,000	1) ESTIMATE ACCURACY +/- 35%
2	CONSTRUCTION		25,321,000	1,950,000	36,716,000	6,456,000	14,106,000	16,601,000	8,927,000	56,774,000	60,314,000	227,165,000	2) TODAY COSTS (ESCALATION NOT INCLUDED)
3	OTHER COSTS		3,323,000	976,000	28,179,000	942,000	20,431,000	21,607,000	1,303,000	22,710,000	10,967,000	110,438,000	
4	EPC SERVICES		10,820,000	1,697,000	40,268,000	1,808,000	8,746,000	4,973,000	2,500,000	18,168,000	21,933,000	110,913,000	
A	Installed costs (contingency excluded)		<b>92,143,000</b>	<b>14,139,000</b>	<b>248,675,000</b>	<b>25,823,000</b>	<b>72,500,000</b>	<b>69,307,000</b>	<b>35,709,000</b>	<b>324,749,000</b>	<b>202,878,000</b>	<b>1,085,923,000</b>	
B	Contingency	%	7	7	7	5	7	7	5	7	5	6.5	
		Euro	6,450,010	989,730	17,407,250	1,291,150	5,075,000	4,851,490	1,785,450	22,732,430	10,143,900		70,726,410
C	Fees (2% of A)		1,842,860	282,780	4,973,500	516,460	1,450,000	1,386,140	714,180	6,494,980	4,057,560	21,718,460	
D	Land Purchases; surveys (5% of A)		4,607,150	706,950	12,433,750	1,291,150	3,625,000	3,465,350	1,785,450	16,237,450	10,143,900	54,296,150	
<b>TOTAL INVESTMENT COST</b>			<b>105,043,020</b>	<b>16,118,460</b>	<b>283,489,500</b>	<b>28,921,760</b>	<b>82,650,000</b>	<b>79,009,980</b>	<b>39,994,080</b>	<b>370,213,860</b>	<b>227,223,360</b>	<b>1,232,664,020</b>	

900 Coal Handling, Storage, Milling  
 950 Coal Drying  
 1000 Gasification Section  
 2100 Air Compression Unit  
 2200 Syngas Treat.&Condt. Line  
 2300 Acid Gas Removal  
 2500 CO<sub>2</sub> Compression&Drying  
 3000 Power Island  
 4000+ Utilities & Offsites



### Table E.3.9 - ESTIMATE SUMMARY

#### Precombustion CO<sub>2</sub> capture: IGCC Power Plants

Refer: 1-BD-0237A

Client: IEA GREENHOUSE R & D PROJ.

Plant: CO<sub>2</sub> CAP. IN LOW RANK COAL P.P.

Location: GERMANY

Date: November 2005 REV. Final

FIGURE IN MM EURO

POS	DESCRIPTION	Case 5 FUTURE ENERGY		Case 6 SHELL		Case 7 FOSTER WHEELER	
		€	%	€	%	€	%
1	Air Separation Unit	126.3	11.1	114.0	9.5	28.9	2.3
2	Process Units	380.3	33.5	472.9	39.2	566.3	45.9
3	CO <sub>2</sub> Compression and Drying	40.1	3.5	38.5	3.2	40.0	3.2
4	Power Island	368.9	32.5	367.1	30.5	370.2	30.0
5	Utilities and Offsite Units	219.1	19.3	212.7	17.6	227.2	18.4
<b>TOTAL INVESTMENT COST</b>		<b>1,134.8</b>	<b>100.0</b>	<b>1,205.1</b>	<b>100.0</b>	<b>1,232.7</b>	<b>100.0</b>
<b>NET POWER OUTPUT, MWe</b>		<b>665.2</b>		<b>628.8</b>		<b>686.6</b>	
<b>SPECIFIC INVESTMENT COST, Euro/kW</b>		<b>1706</b>		<b>1917</b>		<b>1795</b>	

#### **4.0 Operation and Maintenance Cost of the Alternatives**

Operating and Maintenance (O&M) costs include:

- Feedstock
- Chemicals
- Catalysts
- Solvents
- Raw Water make-up
- Direct Operating labour
- Maintenance
- Overhead Charges

O&M costs are generally allocated as variable and fixed costs.

Variable operating costs are directly proportional to the amount of kilowatt-hours produced and are referred as incremental costs. They may be expressed in €/kWh.

Fixed operating costs are essentially independent of the amount of kilowatt-hours produced. They may be expressed in €/h or €/year.

However, accurately distinguishing the variable and fixed operating costs is not always simple. Certain cost items may have both, variable and fixed, components; for instance the planned maintenance and inspection of the gas turbine, that are known to occur based on number of running hours, should be allocated as variable component of maintenance cost.

#### **4.1 Variable Costs**

The variable costs of the different alternatives (Case 1 to 7) are summarized in the attached Tables E.4.1/2.

The consumption of the various items and the corresponding costs are yearly, based on the expected equivalent availability of 7446 equivalent hours of operation, in one year, based on combustion of the main fuel only.

##### **4.1.1 Postcombustion CO<sub>2</sub> capture alternatives**

The attached Table E.4.1 shows the Variable Costs for Case1, 2, 3 and 4.



**Table E.4.1 - Post-combustion CO<sub>2</sub> capture alternatives- Yearly Variable Costs**

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE R & D PROJ.  
 Date : February 2005 REV. 0

Yearly Operating hours =		7446		Case 1 - USC-PC			Case 2 - OXY-PC			Case 3 - CFB			Case 4 - PCFB		
Consumables	Unit Cost Euro/t	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)		
		Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y			
<b>Feedstock</b>															
Coal (as received)	10.50	734000	5465364.0	57,386,322	677600	5045409.6	52,976,801	592900	4414733.4	46,354,701	727000	5413242.0	56,839,041		
Limestone	20.0	5080	37825.7	756,514	0	0.0	0	27360	203722.6	4,074,451	10000	74460.0	1,489,200		
<b>Auxiliary feedstock</b>															
Make-up water	0.100	1937000	14422902.0	1,442,290	2065000	15375990.0	1,537,599	1581000	11772126.0	1,177,213	1751000	13037946.0	1,303,795		
<b>Solvents</b>															
MEA	1300	1340	9977.6	12,970,932	0	0.0	0	1466	10918.3	14,193,830	0	0.0	0		
MDEA	4500	0	0.0	0	0	0.0	0	0	0.0	0	80	595.7	2,680,560		
<b>Catalyst</b>															
DENOX Catalyst	10800	67.5	502.96	5,432,000	0.0	0.00	0	56.4	419.91	4,535,000	20	147.5	1,593,000		
<b>Chemicals</b>															
Ammonia	336	660.0	4914.4	1,651,225	0.0	0.0	0	500.0	3723.0	1,250,928	100.0	744.6	250,186		
Activated Carbon	1000	50.0	372.3	372,300	0.0	0.0	0	40.0	297.8	297,840	40.0	297.8	297,840		
Soda ash	110	110.0	819.1	90,097	0.0	0.0	0	90.0	670.1	73,715	100.0	744.6	81,906		
Coordinate phosphate	1.9	5.2	38.9	74	4.2	31.6	60	4.1	30.7	58	3.8	28.0	53		
Nalco Eliminox or equivalent	4132	3.5	25.7	106,314	2.8	20.9	86,515	2.7	20.3	84,050	2.5	18.6	76,654		
<b>TOTAL YEARLY OPERATING COSTS, Euro/year</b>				<b>80,208,067</b>	<b>54,600,975</b>			<b>72,041,785</b>			<b>64,612,234</b>				



---

**IEA GHG****CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS****Section E: Economics**

---

Revision no.: Final

Date: Nov. 2005

Sheet: 12 of 20

4.1.2 Precombustion CO<sub>2</sub> capture alternatives

The attached Table E.4.2 shows the Variable Costs for alternatives Case 5, 6, and 7.

### Table E.4.2 - IGCC alternatives - Yearly Variable Costs

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE R & D PROJ.  
 Date : February 2005 REV. 0

Yearly Operating hours =		7446			Case 5 - Future Energy			Case 6 - Shell			Case 7 - Foster Wheeler		
Consumables	Unit Cost	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)			
	Euro/t	Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y				
<b>Feedstock</b>													
Coal (as received)	10.50	653300	4864471.8	51,076,954	624200	4647793.2	48,801,829	691000	5145186.0	54,024,453			
Limestone	20.0	0	0.0	0	0	0.0	0	8.16	60.8	1,216			
<b>Auxiliary feedstock</b>													
Natural Gas	140.7	715.1	5324.6	749,176	75	558.5	78,574	75	558.5	78,574			
Make-up water	0.100	1255000	9344730.0	934,473	1748000	13015608.0	1,301,561	1289000	9597894.0	959,789			
<b>Solvents</b>													
MDEA	4500	8.60	64.0	288,000	8.85	65.9	296,523	12.96	96.5	434,277			
<b>Catalyst</b>													
Sour Shift Catalyst (3-5 years life) (1)	20000	30.349	225.98	4,519,510	20.158	150.10	3,001,912	17.186	127.97	2,559,382			
<b>Chemicals</b>													
NaOH (50%)	155.0	480.0	3574.1	553,982	661.6	4926.2	763,559	732.4	5453.4	845,273			
HCL (20%)	150.0	974.4	7255.4	1,088,313	1888.4	14061.3	2,109,202	2090.5	15566.1	2,334,922			
Coordinate phosphate	1.9	1.3	9.8	19	1.2	8.9	17	1.2	9.1	17			
Nalco Eliminox or equivalent	4132.0	0.9	6.5	26,833	0.8	5.9	24,352	0.8	6.0	24,991			
Nalco Tri-Act 1801 or equivalent	3615.0	1.3	9.7	35,206	2.5	18.9	68,231	2.8	20.9	75,532			
Filter Polyelectrolyte	2580.0	0.3	2.4	6,282	0.6	4.7	12,174	0.7	5.2	13,477			
IAF Polyelectrolyte	2580.0	0.3	2.4	6,282	0.6	4.7	12,174	0.7	5.2	13,477			
Phosphoric acid (20%)	400.0	0.3	2.4	974	0.6	4.7	1,887	0.7	5.2	2,089			
<b>TOTAL YEARLY OPERATING COSTS, Euro/year</b>				<b>59,286,002</b>	<b>56,471,994</b>			<b>61,367,471</b>					

NOTES: (1) Two catalyst beds are required. 1<sup>st</sup> bed years life: 3; 2<sup>nd</sup> bed years life: 5.

## 4.2 Fixed Costs

The fixed costs of the different Power Plants operation include the following items:

- Direct labour.
- Administrative and general overhead.
- Maintenance.

For maintenance, variable element of cost, such as gas turbine inspections (precombustion CO<sub>2</sub> capture alternatives), have been treated as part of fixed costs, on the assumption that Complex operates at the design capacity and with the expected design service factor.

### 4.2.1 Direct Labour

The yearly cost of the direct labour is calculated assuming, for each individual, an average cost equal to 50,000 Euro/year. The number of personnel engaged for the different alternatives is shown in the following.

#### *Precombustion CO<sub>2</sub> capture alternatives*

The Owner's personnel engaged in the Operation and Maintenance of the IGCC Complex (precombustion CO<sub>2</sub> alternatives) is shown in Table E.4.3.1. The Complex has been divided into 3 areas of operation: Air Separation Unit, Gasification, including syngas processing and CO<sub>2</sub> capture plant, and Power Island with common Utilities. The same division will be reflected in the design of the centralized Control Room, which will have, correspondingly, 3 main DCS control groups, each one equipped with a number of control stations, from where the operation of the plants of each of the three areas will be controlled.

The Area Responsible and his Assistant will supervise each area of operation; both are daily position.

The Shift Superintendent and the Electrical Assistant are common for the 3 areas; both are shift position. The rest of the Operation staff is structured around the standard positions: shift supervisors, control room operators and field operators.

The maintenance personnel are based on large use of external subcontractor for all medium-major type of maintenance work. Maintenance costs described at para. 4.2.3 take into account the service outsourcing. Plant Maintenance personnel like the instrument specialists perform routine maintenance and resolve emergency problems.

**IEA GHG**  
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 14 of 20

**Section E: Economics**

Personnel shown in Table E.4.3.1 are directly engaged in the Complex. Management, Administration, Technical Services and supporting clerical staff are not included since their composition and strength are very much dependent on Owner's policy.

**Table E.4.3.1 – IGCC personnel.**

OPERATION	ASU	GASIFICATIO N	CCU & UTILITIES	TOTAL	NOTES
Area Responsible	1	1	1	3	daily position
Assistant Area Responsible	1	1	1	3	daily position
Shift Superintendent		5		5	1 shift position
Electrical Assistant		5		5	1 shift position
Shift Supervisor	5	5	5	15	3 shift position
Control Room Operator	5	10	10	25	5 shift position
Field Operator	5	25	20	50	10 shift position
<b>Subtotal</b>				<b>106</b>	
<b>MAINTENANCE</b>					
Mechanical group		4		4	daily position
Instrument group		7		7	daily position
Electrical group		5		5	daily position
<b>Subtotal</b>				<b>16</b>	
<b>LABORATORY</b>					
Superintendent + Analysts		6		6	daily position
<b>TOTAL</b>				<b>128</b>	

Postcombustion CO<sub>2</sub> capture alternatives

Case 1 – USC PC

The Owner's personnel engaged in the Operation and Maintenance of this alternative is shown in Table E.4.3.2. The Complex has been divided into 2 areas of operation: Boiler Island, including flue gas processing and CO<sub>2</sub> capture plant, and Power Island with common Utilities. The same division will be reflected in the design of the centralized Control Room, which will have, correspondingly, 2 main DCS control groups, each one equipped with a number of control stations, from where the operation of the plants of each of the two areas will be controlled.

Personnel engaged as Area Responsible, Assistant, as well as the maintenance people follow the considerations made for the previous alternative.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section E: Economics**

Revision no.: Final

Date: Nov. 2005

Sheet: 15 of 20

**Table E.4.3.2 – USC-PC personnel.**

OPERATION	BOILER ISLAND	CCU & UTILITIES	TOTAL	NOTES
Area Responsible	1	1	2	daily position
Assistant Area Responsible	1	1	2	daily position
Shift Superintendent	5		5	1 shift position
Electrical Assistant	5		5	1 shift position
Shift Supervisor	5	5	10	2 shift position
Control Room Operator	10	10	20	4 shift position
Field Operator	15	25	40	8 shift position
<b>Subtotal</b>			<b>84</b>	
<b>MAINTENANCE</b>				
Mechanical group	6		6	daily position
Instrument group	6		6	daily position
Electrical group	5		5	daily position
<b>Subtotal</b>			<b>17</b>	
<b>LABORATORY</b>				
Superintendent + Analysts	4		4	daily position
<b>TOTAL</b>			<b>105</b>	

Case 2 – OXY - USC PC

The Owner's personnel engaged in the Operation and Maintenance of this alternative can be directly derived from the previous case, by simply adding the personnel required for the ASU like for the IGCC alternatives (see table E.4.3.1), i.e. 17 units overall. As a consequence, the total personnel engaged for this alternative are 122 units.

Case 3 & 4 – CFB & PCFB

The Owner's personnel engaged in the Operation and Maintenance of this alternative is shown in Table E.4.3.3. The only difference with the USC-PC case is that the need of multiple boilers results in a higher number of field operators (25 people instead of 15). As a consequence, the total personnel engaged for this alternative are 115 units.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section E: Economics**

Revision no.: Final

Date: Nov. 2005

Sheet: 16 of 20

**Table E.4.3.3 – CFB & PCFB personnel.**

OPERATION	BOILER ISLAND	CCU & UTILITIES	TOTAL	NOTES
Area Responsible	1	1	2	daily position
Assistant Area Responsible	1	1	2	daily position
Shift Superintendent	5		5	1 shift position
Electrical Assistant	5		5	1 shift position
Shift Supervisor	5	5	10	2 shift position
Control Room Operator	10	10	20	4 shift position
Field Operator	25	25	50	10 shift position
<b>Subtotal</b>			<b>94</b>	
<b>MAINTENANCE</b>				
Mechanical group	6		6	daily position
Instrument group	6		6	daily position
Electrical group	5		5	daily position
<b>Subtotal</b>			<b>17</b>	
<b>LABORATORY</b>				
Superintendent + Analysts	4		4	daily position
<b>TOTAL</b>			<b>115</b>	

**4.2.2 Administrative and General Overheads**

All other Company services not directly involved in the operation of the Complex fall in this category, such as:

- Management.
- Administration.
- Personnel services.
- Technical services.
- Clerical staff.

These services vary widely from company to company and are also dependent on the type and complexity of the operation.

Based on EPRI, Technical Assessment Guide for the Power Industry, an amount equal to 30% of the direct labour cost has been considered.

**4.2.3 Maintenance**

A precise evaluation of the cost of maintenance would require a breakdown of the costs amongst the numerous components and packages of the Complex. Since these costs are all strongly dependent on the type of equipment selected and statistical

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 17 of 20

**Section E: Economics**


---

maintenance data provided by the selected Supplier, this type of evaluation of the maintenance cost is premature at this stage of the study.

For this reason, the annual maintenance cost of the Complex has been estimated as a percentage of the installed capital cost of the facilities.

Postcombustion CO<sub>2</sub> capture alternatives

Basically, the Complex has been divided in different sections, depending on the material, solid or fluid, handled by the unit. For fluid handling units, the maintenance cost is calculated by considering 2.5% of the installed cost, whilst 4.0% is considered for the solid handling units. For common facilities (utilities and offsite units), 1.7% of the installed cost is considered.

Precombustion CO<sub>2</sub> capture alternatives

Complex has been divided in four major sections, applying to each section the following percentage of the capital cost:

- 4.0% for solid handling units;
- 2.5% for fluid handling units;
- 1.7% for utilities and offsites;
- 5.0% for the Power Island, to take into account the gas turbine maintenance cost based on the assumption of a Long Term Service Agreement (LTSA) with the gas turbine manufacturer.

The total yearly maintenance cost of the Complex is assumed subcontracted to external firms under the supervision of the maintenance staff of the Owner, included in the fixed cost as direct labour.

The overall cost of maintenance could be statistically split as follows:

- Maintenance materials: 60% of total maintenance cost;
- Maintenance labour: 40% of total maintenance cost.

Attached Tables E.4.4 and 5 summarize overall maintenance costs for both the postcombustion and precombustion CO<sub>2</sub> capture alternatives.

**Table E.4.4 - Post-combustion CO<sub>2</sub> capture alternatives - Maintenance Costs**

Refer : 1-BD-0237A  
 Client : IEA  
 Date : November 2005

Complex section	Maintenance %	Case 1		Case 2		Case 3		Case 4	
		Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year
COAL HANDLING, DRYING, MILLING, BOILER ISLAND, FGD, POW. ISL.	4.0	709011	28360	617858	24714	487085	19483	645036	25801
CO <sub>2</sub> CAPTURE PLANT, CO <sub>2</sub> COMPRESS. AND DRYING, ASU	2.5	151082	3777	367809	9195	138801	3470	186067	4652
Common facilities (BOP)	1.7	238748	4059	228062	3877	211411	3594	237438	4036
<b>TOTAL</b>		1098841	36196	1213729	37787	837297	26547	1068541	34489
		Maint. % =	3.3	Maint. % =	3.1	Maint. % =	3.2	Maint. % =	3.2



**Table E.4.5 - IGCC - Maintenance Costs**

Refer : 1-BD-0237A  
 Client : IEA  
 Date : November 2005


Complex section	Maintenance %	Case 5		Case 6		Case 7	
		Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year
<b>ASU, AGR, SRU &amp; TGT, CO<sub>2</sub> Comp.,</b> (Units: 2100,2300,2400,2500)	2.5	198697	4967	185675	4642	130839	3271
<b>Gasification, Syngas Treat.,</b> (Units: 900,1000,2200)	4.0	282133	11285	365260	14610	427457	17098
<b>Power Island</b> (Unit: 3000)	5.0 (1)	323624	16181	321997	16100	324749	16237
<b>Common facilities</b> (Utilities, Offsite, etc.)	1.7	195614	3325	189906	3228	202878	3449
<b>TOTAL</b>		1000068	35759	1062838	38581	1085923	40055
		Maint. % =	3.6	Maint. % =	3.6	Maint. % =	3.7

NOTES: (1) Including the Gas Turbine Long Term Service Agreement.


### 4.3 Summary

The following tables summarize the total Operating and Maintenance Costs on yearly basis for all the alternatives.

**Table E.4.6 – Postcombustion CO<sub>2</sub> capture alternatives – Total O&M Costs**

		Case 1 Euro/year	Case 2 Euro/year	Case 3 Euro/year	Case 4 Euro/year
<b>Fixed Costs</b>	direct labour	5,250,000	6,100,000	5,750,000	5,750,000
	adm./gen overheads	1,575,000	1,830,000	1,725,000	1,725,000
	maintenance	36,196,000	37,787,000	26,547,000	34,489,000
<b>Subtotal</b>		43,021,000	45,717,000	34,022,000	41,964,000
<b>Variable Costs</b>		80,208,000	54,601,000	72,042,000	64,612,000
<b>TOTAL O&amp;M COSTS</b>		123,229,000	100,318,000	106,064,000	106,576,000

**Table E.4.7 – Precombustion CO<sub>2</sub> capture alternatives – Total O&M Costs**

		Case 5 Euro/year	Case 6 Euro/year	Case 7 Euro/year
<b>Fixed Costs</b>	direct labour	6,400,000	6,400,000	6,400,000
	adm./gen overheads	1,920,000	1,920,000	1,920,000
	maintenance	35,759,000	38,581,000	40,055,000
<b>Subtotal</b>		44,079,000	46,901,000	48,375,000
<b>Variable Costs</b>		59,286,000	56,472,000	61,367,000
<b>TOTAL O&amp;M COSTS</b>		103,365,000	103,373,000	109,742,000

**5.0 Evaluation of the Electric Power Cost of the Alternatives****5.1 Electric Power Cost**

The following Tables summarize the economic analyses performed on each alternative in order to evaluate the electric power production cost, based on the following main assumptions:

- 7446 equivalent operating hours in normal conditions at 100% capacity;
- Total investment cost as evaluated in para.3.0 of this Section;
- O&M costs as evaluated in para 4.0;
- 10% discount rate on the investment cost over 25 operating years;
- No selling price is attributed to CO<sub>2</sub>;
- Other financial parameters as per Project Design Basis, Section B.

A sensitivity analysis with 5% discount rate is also developed.

**5.1.1 Postcombustion CO<sub>2</sub> capture alternatives**

The attached Tables E.5.1/4 show the economic analysis for Case 1, 2, 3 and 4.

The sensitivity analysis with 5% discount rate on the investment cost is shown in Tables E.5.5/8.

Table E.5.9 summarizes the electric power cost for the postcombustion CO<sub>2</sub> capture alternatives, with 10% and 5% discount rate applied on the Total Investment Cost.

**Table E.5.9 – Electric Power Cost**

ALTERNATIVE		Case 1 USC-PC	Case 2 OXY-USCPC	Case 3 CFB	Case 4 PCFB
Discount rate	%	10	10	10	10
Coal Flowrate	t/h	734.0	677.6	592.9	727.0
Net Power Output	MWe	761.0	741.3	614.7	688.4
Total Investment Cost	MM Euro	1251.8	1395.2	953.8	1230.6
<b>Specif Net Inv. Cost</b>	<b>Euro/kW</b>	<b>1645</b>	<b>1882</b>	<b>1552</b>	<b>1788</b>
Revenues/year	MM Euro/year	305.2	301.4	244.3	284.4
<b>Electricity Prod. Cost</b>	<b>cEuro/kWh</b>	<b>5.39</b>	<b>5.46</b>	<b>5.34</b>	<b>5.55</b>
ALTERNATIVE		Case 1 USC-PC	Case 2 OXY-USCPC	Case 3 CFB	Case 4 PCFB
Discount rate	%	5	5	5	5
Coal Flowrate	t/h	734.0	677.6	592.9	727.0
Net Power Output	MWe	761.0	741.3	614.7	688.4
Total Investment Cost	MM Euro	1251.8	1395.2	953.8	1230.6
<b>Specif Net Inv. Cost</b>	<b>Euro/kW</b>	<b>1645</b>	<b>1882</b>	<b>1552</b>	<b>1788</b>
Revenues/year	MM Euro/year	242.7	232.0	196.7	223.1
<b>Electricity Prod. Cost</b>	<b>cEuro/kWh</b>	<b>4.28</b>	<b>4.20</b>	<b>4.30</b>	<b>4.35</b>

### 5.1.2 Precombustion CO<sub>2</sub> capture alternatives

The attached Tables E.5.10/12 show the economic analysis for Case 5, 6 and 7.

The sensitivity analysis with 5% discount rate on the investment cost is shown in Tables E.5.13/15.

Table E.5.16 summarizes the electric power cost for the precombustion CO<sub>2</sub> capture alternatives, with 10% and 5% discount rate applied on the Total Investment Cost.

**Table E.5.16 – Electric Power Cost**

ALTERNATIVE		Case 5 IGCC-FE	Case 6 IGCC-SHELL	Case 7 IGCC-FW	Case 5 IGCC-FE	Case 6 IGCC-SHELL	Case 7 IGCC-FW
Discount rate	%	10	10	10	5	5	5
Coal Flowrate	t/h	653.3	624.2	691.0	653.3	624.2	691.0
Net Power Output	MWe	665.2	628.8	686.6	665.2	628.8	686.6
Total Investment Cost	MM Euro	1134.8	1205.1	1232.7	1134.8	1205.1	1232.7
<b>Specif Net Inv. Cost</b>	<b>Euro/kW</b>	<b>1706</b>	<b>1917</b>	<b>1795</b>	<b>1706</b>	<b>1917</b>	<b>1795</b>
Revenues/year	MM Euro/year	268.1	278.2	288.6	211.5	218.2	227.1
<b>Electricity Prod. Cost</b>	<b>cEuro/kWh</b>	<b>5.41</b>	<b>5.94</b>	<b>5.64</b>	<b>4.27</b>	<b>4.66</b>	<b>4.44</b>

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.054 Euro/kWh	
Coal Florate	734.0 t/h		Installed Costs	1098.8	<b>at 85% load factor</b>	30 days Chemical Storage	2.2	Inflation	0.00 %	
Net Power Output	761.0 MW		Land purchase; surveys	54.9	Fuel Cost	57.4	5 days Coal Storage	0.9	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	22.0	Maintenance	36.2	Total Working capital	3.1	Discount rate	10.00 %
Insurance and local taxes	2% Installed cost		Average Contingencies	76.1	Waste Disposal	0.0			Revenues / year	305.2 MM Euro/year
			Total Investment Cost	1251.8	Chemicals + Consumable	22.8				
					Insurance and local taxes	22.0				
							<b>Labour Cost</b>	<b>MM Euro/year</b>		
							# operators	111		
							Salary	0.05	NPV	0.00
							Direct Labour Cost	5.6	IRR	10.00%
							Administration 30% L.C.	1.7		
							Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				161.6	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	305.2	
<b>Operating Costs</b>																													
Fuel Cost				-30.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	
Maintenance				-24.1	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-12.1	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	
<b>Working Capital Cost</b>				-3.1																									
<b>Fixed Capital Expenditures</b>	-250.4	-563.3	-438.1																										
<b>Total Cash flow (yearly)</b>	-250.4	-563.3	-438.1	62.7	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	159.6	
<b>Total Cash flow (cumulated)</b>	-250.4	-813.7	-1251.8	-1189.2	-1029.6	-870.0	-710.4	-550.8	-391.2	-231.6	-72.1	87.5	247.1	406.7	566.3	725.9	885.5	1045.1	1204.7	1364.3	1523.8	1683.4	1843.0	2002.6	2162.2	2321.8	2481.4	2641.0	
<b>Discounted Cash Flow (Yearly)</b>	-227.6	-465.6	-329.2	42.8	99.1	90.1	81.9	74.4	67.7	61.5	55.9	50.9	46.2	42.0	38.2	34.7	31.6	28.7	26.1	23.7	21.6	19.6	17.8	16.2	14.7	13.4	12.2	11.1	
<b>Discounted Cash Flow (Cumul.)</b>	-227.6	-693.2	-1022.3	-979.6	-880.5	-790.4	-708.5	-634.0	-566.3	-504.8	-448.9	-398.0	-351.8	-309.8	-271.6	-236.8	-205.3	-176.6	-150.5	-126.8	-105.2	-85.6	-67.8	-51.6	-36.8	-23.4	-11.3	-0.2	

3.1

TABLE E.5.2 - OXY-USC-PC - Cost Evaluation - Discount Rate = 10%

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.055	Euro/kWh	
Coal Florate	677.6	t/h	Installed Costs	1213.7	<b>at 85% load factor</b>	30 days Chemical Storage	0.2	Inflation	0.00	%	
Net Power Output	741.3	MW	Land purchase; surveys	60.7	Fuel Cost	53.0	5 days Coal Storage	0.9	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	24.3	Maintenance	37.8	Total Working capital	1.0	Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	96.5	Waste Disposal	0.0			Revenues / year	301.4	MM Euro/year
			Total Investment Cost	1395.2	Chemicals + Consumable	1.6	<b>Labour Cost</b>	<b>MM Euro/year</b>			
					Insurance and local taxes	24.3	# operators	111			
							Salary	0.05			
							Direct Labour Cost	5.6	NPV	0.00	
							Administration 30% L.C.	1.7	IRR	10.00%	
							Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				159.6	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	301.4	
<b>Operating Costs</b>																													
Fuel Cost				-28.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	
Maintenance				-25.2	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-0.9	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	
<b>Working Capital Cost</b>				-1.0																									
<b>Fixed Capital Expenditures</b>	-279.0	-627.8	-488.3																										
<b>Total Cash flow (yearly)</b>	-279.0	-627.8	-488.3	73.0	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	177.5	
<b>Total Cash flow (cumulated)</b>	-279.0	-906.9	-1395.2	-1322.2	-1144.7	-967.2	-789.6	-612.1	-434.5	-257.0	-79.4	98.1	275.7	453.2	630.7	808.3	985.8	1163.4	1340.9	1518.5	1696.0	1873.6	2051.1	2228.7	2406.2	2583.7	2761.3	2938.8	
<b>Discounted Cash Flow (Yearly)</b>	-253.7	-518.9	-366.9	49.8	110.2	100.2	91.1	82.8	75.3	68.5	62.2	56.6	51.4	46.8	42.5	38.6	35.1	31.9	29.0	26.4	24.0	21.8	19.8	18.0	16.4	14.9	13.5	12.3	
<b>Discounted Cash Flow (Cumul.)</b>	-253.7	-772.6	-1139.4	-1089.6	-979.4	-879.1	-788.0	-705.2	-629.9	-561.5	-499.2	-442.7	-391.2	-344.5	-302.0	-263.3	-228.2	-196.3	-167.2	-140.9	-116.9	-95.1	-75.2	-57.2	-40.8	-25.9	-12.4	-0.1	

1.0

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.053 Euro/kWh
Coal Florate	592.9 t/h		Installed Costs	837.3	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00 %
Net Power Output	614.7 MW		Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	16.7	Maintenance	Total Working capital	3.2	Discount rate	10.00 %
Insurance and local taxes	2% Installed cost		Average Contingencies	57.9	Waste Disposal			Revenues / year	244.3 MM Euro/year
			Total Investment Cost	953.8	Chemicals + Consumable				
					Insurance and local taxes				
						<b>Labour Cost</b>	<b>MM Euro/year</b>		
						# operators	111		
						Salary	0.05	NPV	0.00
						Direct Labour Cost	5.6	IRR	10.00%
						Administration	30% L.C. 1.7		
						Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				129.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	244.3	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
Maintenance				-17.7	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-190.8	-429.2	-333.8																										
<b>Total Cash flow (yearly)</b>	-190.8	-429.2	-333.8	46.3	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	121.7	
<b>Total Cash flow (cumulated)</b>	-190.8	-619.9	-953.8	-907.5	-785.7	-664.0	-542.2	-420.5	-298.8	-177.0	-55.3	66.5	188.2	310.0	431.7	553.4	675.2	796.9	918.7	1040.4	1162.1	1283.9	1405.6	1527.4	1649.1	1770.9	1892.6	2014.3	
<b>Discounted Cash Flow (Yearly)</b>	-173.4	-354.7	-250.8	31.6	75.6	68.7	62.5	56.8	51.6	46.9	42.7	38.8	35.3	32.1	29.1	26.5	24.1	21.9	19.9	18.1	16.5	15.0	13.6	12.4	11.2	10.2	9.3	8.4	
<b>Discounted Cash Flow (Cumul.)</b>	-173.4	-528.1	-778.9	-747.3	-671.7	-603.0	-540.5	-483.7	-432.1	-385.2	-342.5	-303.7	-268.4	-236.4	-207.2	-180.7	-156.6	-134.7	-114.8	-96.7	-80.3	-65.3	-51.7	-39.4	-28.1	-17.9	-8.6	-0.2	

3.2

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.055 Euro/kWh	
Coal Florate	727.0 t/h		Installed Costs	1088.5	<b>at 85% load factor</b>	30 days Chemical Storage	0.8	Inflation	0.00 %	
Net Power Output	688.4 MW		Land purchase; surveys	53.4	Fuel Cost	56.8	5 days Coal Storage	0.9	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	21.4	Maintenance	34.5	Total Working capital	1.7	Discount rate	10.00 %
Insurance and local taxes	2% Installed cost		Average Contingencies	87.3	Waste Disposal	0.0			Revenues / year	284.4 MM Euro/year
			Total Investment Cost	1230.6	Chemicals + Consumable	7.8	<b>Labour Cost</b>	<b>MM Euro/year</b>		
					Insurance and local taxes	21.4	# operators	111		
							Salary	0.05	<b>NPV</b>	<b>0.00</b>
							Direct Labour Cost	5.6	<b>IRR</b>	<b>10.00%</b>
							Administration 30% L.C.	1.7		
							Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				150.6	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	284.4	
<b>Operating Costs</b>																													
Fuel Cost				-30.1	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	
Maintenance				-23.0	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-4.1	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	
<b>Working Capital Cost</b>				-1.7																									
<b>Fixed Capital Expenditures</b>	-246.1	-553.8	-430.7																										
<b>Total Cash flow (yearly)</b>	-246.1	-553.8	-430.7	63.1	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	156.7	
<b>Total Cash flow (cumulated)</b>	-246.1	-799.9	-1230.6	-1167.5	-1010.7	-854.0	-697.3	-540.6	-383.8	-227.1	-70.4	86.3	243.1	399.8	556.5	713.2	870.0	1026.7	1183.4	1340.1	1496.9	1653.6	1810.3	1967.1	2123.8	2280.5	2437.2	2594.0	2595.6
<b>Discounted Cash Flow (Yearly)</b>	-223.7	-457.7	-323.6	43.1	97.3	88.5	80.4	73.1	66.5	60.4	54.9	49.9	45.4	41.3	37.5	34.1	31.0	28.2	25.6	23.3	21.2	19.3	17.5	15.9	14.5	13.2	12.0	10.9	0.1
<b>Discounted Cash Flow (Cumul.)</b>	-223.7	-681.4	-1005.0	-961.9	-864.6	-776.1	-695.7	-622.6	-556.1	-495.7	-440.7	-390.8	-345.4	-304.1	-266.6	-232.5	-201.5	-173.3	-147.7	-124.4	-103.2	-84.0	-66.5	-50.5	-36.1	-22.9	-11.0	-0.1	0.0



<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.043 Euro/kWh	
Coal Florate	734.0 t/h		Installed Costs	1098.8	<b>at 85% load factor</b>	30 days Chemical Storage	2.2	Inflation	0.00 %	
Net Power Output	761.0 MW		Land purchase; surveys	54.9	Fuel Cost	57.4	5 days Coal Storage	0.9	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	22.0	Maintenance	36.2	Total Working capital	3.1	Discount rate	5.00 %
Insurance and local taxes	2% Installed cost		Average Contingencies	76.1	Waste Disposal	0.0			Revenues / year	242.7 MM Euro/year
			Total Investment Cost	1251.8	Chemicals + Consumable	22.8	<b>Labour Cost</b>	<b>MM Euro/year</b>		
					Insurance and local taxes	22.0	# operators	111		
							Salary	0.05	NPV	0.00
							Direct Labour Cost	5.6	IRR	5.00%
							Administration 30% L.C.	1.7		
							Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				128.5	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	242.7	
<b>Operating Costs</b>																													
Fuel Cost				-30.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	-57.4	
Maintenance				-24.1	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	-36.2	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-12.1	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	-22.8	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	-22.0	
<b>Working Capital Cost</b>				-3.1																									
<b>Fixed Capital Expenditures</b>	-250.4	-563.3	-438.1																										
<b>Total Cash flow (yearly)</b>	-250.4	-563.3	-438.1	29.6	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	97.1	
<b>Total Cash flow (cumulated)</b>	-250.4	-813.7	-1251.8	-1222.2	-1125.1	-1028.0	-930.8	-833.7	-736.5	-639.4	-542.2	-445.1	-348.0	-250.8	-153.7	-56.5	40.6	137.7	234.9	332.0	429.2	526.3	623.5	720.6	817.7	914.9	1012.0	1109.2	1112.3
<b>Discounted Cash Flow (Yearly)</b>	-238.4	-511.0	-378.5	24.3	76.1	72.5	69.0	65.7	62.6	59.6	56.8	54.1	51.5	49.1	46.7	44.5	42.4	40.4	38.4	36.6	34.9	33.2	31.6	30.1	28.7	27.3	26.0	24.8	0.8
<b>Discounted Cash Flow (Cumul.)</b>	-238.4	-749.4	-1127.9	-1103.5	-1027.4	-954.9	-885.9	-820.1	-757.5	-697.9	-641.1	-587.0	-535.5	-486.4	-439.7	-395.2	-352.8	-312.4	-274.0	-237.4	-202.5	-169.3	-137.7	-107.6	-78.9	-51.6	-25.5	-0.8	0.0

3.1

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.042 Euro/kWh	
Coal Florate	677.6 t/h		Installed Costs	1213.7	<b>at 85% load factor</b>	30 days Chemical Storage	0.2	Inflation	0.00 %	
Net Power Output	741.3 MW		Land purchase; surveys	60.7	Fuel Cost	53.0	5 days Coal Storage	0.9	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	24.3	Maintenance	37.8	Total Working capital	1.0	Discount rate	5.00 %
Insurance and local taxes	2%	Installed cost	Average Contingencies	96.5	Waste Disposal	0.0			Revenues / year	232.0 MM Euro/year
			Total Investment Cost	1395.2	Chemicals + Consumable	1.6	<b>Labour Cost</b>	<b>MM Euro/year</b>		
					Insurance and local taxes	24.3	# operators	111		
							Salary	0.05	NPV	0.00
							Direct Labour Cost	5.6	IRR	5.00%
							Administration 30% L.C.	1.7		
							Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				122.8	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	232.0	
<b>Operating Costs</b>																													
Fuel Cost				-28.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	-53.0	
Maintenance				-25.2	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	-37.8	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-0.9	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	-1.6	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	-24.3	
<b>Working Capital Cost</b>				-1.0																									
<b>Fixed Capital Expenditures</b>	-279.0	-627.8	-488.3																										
<b>Total Cash flow (yearly)</b>	-279.0	-627.8	-488.3	36.2	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	108.1	
<b>Total Cash flow (cumulated)</b>	-279.0	-906.9	-1395.2	-1359.0	-1250.9	-1142.8	-1034.7	-926.7	-818.6	-710.5	-602.4	-494.3	-386.2	-278.1	-170.0	-62.0	46.1	154.2	262.3	370.4	478.5	586.6	694.7	802.7	910.8	1018.9	1127.0	1235.1	
<b>Discounted Cash Flow (Yearly)</b>	-265.8	-569.5	-421.8	29.8	84.7	80.7	76.8	73.2	69.7	66.4	63.2	60.2	57.3	54.6	52.0	49.5	47.2	44.9	42.8	40.7	38.8	36.9	35.2	33.5	31.9	30.4	29.0	27.6	
<b>Discounted Cash Flow (Cumul.)</b>	-265.8	-835.2	-1257.1	-1227.3	-1142.6	-1061.9	-985.1	-912.0	-842.3	-775.9	-712.7	-652.5	-595.2	-540.6	-488.6	-439.1	-392.0	-347.1	-304.3	-263.5	-224.7	-187.8	-152.6	-119.1	-87.2	-56.8	-27.8	-0.2	

1.0

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.043	Euro/kWh
Coal Florate	592.9	t/h	Installed Costs	837.3	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	614.7	MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	16.7	Maintenance	Total Working capital	3.2	Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	57.9	Waste Disposal			Revenues / year	196.7	MM Euro/year
			Total Investment Cost	953.8	Chemicals + Consumable					
					Insurance and local taxes					
						<b>Labour Cost</b>	<b>MM Euro/year</b>			
						# operators	111			
						Salary	0.05	NPV	0.00	
						Direct Labour Cost	5.6	IRR	5.00%	
						Administration	30% L.C. 1.7			
						Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				104.1	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	196.7	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
Maintenance				-17.7	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	-26.5	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	-16.7	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-190.8	-429.2	-333.8																										
<b>Total Cash flow (yearly)</b>	-190.8	-429.2	-333.8	21.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	74.1	
<b>Total Cash flow (cumulated)</b>	-190.8	-619.9	-953.8	-932.7	-858.6	-784.5	-710.4	-636.3	-562.2	-488.1	-414.0	-339.9	-265.8	-191.7	-117.6	-43.5	30.6	104.7	178.8	252.9	327.0	401.1	475.2	549.3	623.4	697.5	771.6	845.7	
<b>Discounted Cash Flow (Yearly)</b>	-181.7	-389.3	-288.4	17.3	58.1	55.3	52.7	50.2	47.8	45.5	43.3	41.3	39.3	37.4	35.6	33.9	32.3	30.8	29.3	27.9	26.6	25.3	24.1	23.0	21.9	20.8	19.8	18.9	
<b>Discounted Cash Flow (Cumul.)</b>	-181.7	-571.0	-859.3	-842.0	-783.9	-728.6	-676.0	-625.8	-578.1	-532.6	-489.2	-448.0	-408.7	-371.2	-335.6	-301.7	-269.3	-238.5	-209.2	-181.3	-154.7	-129.4	-105.2	-82.3	-60.4	-39.5	-19.7	-0.8	

3.2

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.044	Euro/kWh
Coal Florate	727.0	t/h	Installed Costs	1088.5	<b>at 85% load factor</b>	30 days Chemical Storage	0.8	Inflation	0.00	%
Net Power Output	688.4	MW	Land purchase; surveys	53.4	Fuel Cost	5 days Coal Storage	0.9	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	21.4	Maintenance	Total Working capital	1.7	Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	87.3	Waste Disposal			Revenues / year	223.1	MM Euro/year
			Total Investment Cost	1230.6	Chemicals + Consumable					
					Insurance and local taxes					
						<b>Labour Cost</b>	<b>MM Euro/year</b>			
						# operators	111			
						Salary	0.05	NPV	0.00	
						Direct Labour Cost	5.6	IRR	5.00%	
						Administration	30% L.C. 1.7			
						Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expediture Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				118.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	223.1	
<b>Operating Costs</b>																													
Fuel Cost				-30.1	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	-56.8	
Maintenance				-23.0	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	-34.5	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-4.1	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	-7.8	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	-21.4	
<b>Working Capital Cost</b>				-1.7																									
<b>Fixed Capital Expenditures</b>	-246.1	-553.8	-430.7																										
<b>Total Cash flow (yearly)</b>	-246.1	-553.8	-430.7	30.7	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	95.4	
<b>Total Cash flow (cumulated)</b>	-246.1	-799.9	-1230.6	-1199.9	-1104.5	-1009.1	-913.7	-818.3	-722.9	-627.5	-532.1	-436.7	-341.2	-245.8	-150.4	-55.0	40.4	135.8	231.2	326.6	422.0	517.5	612.9	708.3	803.7	899.1	994.5	1089.9	
<b>Discounted Cash Flow (Yearly)</b>	-234.4	-502.3	-372.1	25.2	74.8	71.2	67.8	64.6	61.5	58.6	55.8	53.1	50.6	48.2	45.9	43.7	41.6	39.6	37.8	36.0	34.2	32.6	31.1	29.6	28.2	26.8	25.6	24.3	
<b>Discounted Cash Flow (Cumul.)</b>	-234.4	-736.7	-1108.7	-1083.5	-1008.8	-937.6	-869.8	-805.2	-743.7	-685.1	-629.3	-576.2	-525.6	-477.4	-431.5	-387.8	-346.2	-306.5	-268.8	-232.8	-198.6	-166.0	-134.9	-105.3	-77.1	-50.3	-24.7	-0.4	

1.7

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.054</b>	Euro/kWh	
Coal Florate	653.3	t/h	Installed Costs	1000.1	<b>at 85% load factor</b>	30 days Chemical Storage	0.8	Sulphur Price	103.3	Euro/t	
Net Power Output	665.2	MW	Land purchase; surveys	50.0	Fuel Cost	51.1	5 days Coal Storage	0.8	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.6	Maintenance	35.8	Total Working capital	1.6	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	63.1	Waste Disposal	0.0			Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1134.8	Chemicals + Consumable	8.2	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	268.1	MM Euro/year
					Insurance and local taxes	20.0	# operators	128			
							Salary	0.05	<b>NPV</b>	0.00	
							Direct Labour Cost	6.4	<b>IRR</b>	10.00%	
							Administration	30% L.C. 1.9			
							Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				141.9	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	268.1	
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
<b>Operating Costs</b>																													
Fuel Cost				-27.0	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	
Maintenance				-23.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	
Chemicals & Consumables				-4.3	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	
<b>Working Capital Cost</b>				-1.6																									
<b>Fixed Capital Expenditures</b>		-227.0	-510.7	-397.2																									
<b>Total Cash flow (yearly)</b>	-227.0	-510.7	-397.2	56.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	144.7	
<b>Total Cash flow (cumulated)</b>	-227.0	-737.6	-1134.8	-1078.0	-933.4	-788.7	-644.0	-499.3	-354.6	-209.9	-65.2	79.5	224.1	368.8	513.5	658.2	802.9	947.6	1092.3	1236.9	1381.6	1526.3	1671.0	1815.7	1960.4	2105.1	2249.8	2394.4	
<b>Discounted Cash Flow (Yearly)</b>	-206.3	-422.0	-298.4	38.8	89.8	81.7	74.2	67.5	61.4	55.8	50.7	46.1	41.9	38.1	34.6	31.5	28.6	26.0	23.7	21.5	19.6	17.8	16.2	14.7	13.4	12.1	11.0	10.0	
<b>Discounted Cash Flow (Cumul.)</b>	-206.3	-628.4	-926.8	-888.0	-798.2	-716.5	-642.2	-574.7	-513.4	-457.6	-406.9	-360.8	-318.9	-280.8	-246.1	-214.7	-186.0	-160.0	-136.3	-114.8	-95.3	-77.5	-61.4	-46.7	-33.3	-21.2	-10.1	-0.1	

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.059</b>	Euro/kWh
Coal Florate	624.2	t/h	Installed Costs	1062.8	<b>at 85% load factor</b>	30 days Chemical Storage	0.7	Sulphur Price	103.3	Euro/t
Net Power Output	628.8	MW	Land purchase; surveys	53.1	Fuel Cost	5 days Coal Storage	0.8	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.3	Maintenance	Total Working capital	1.5	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	67.9	Waste Disposal			Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1205.1	Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	278.2	MM Euro/year
					Insurance and local taxes	# operators	128			
						Salary	0.05	NPV	0.00	
						Direct Labour Cost	6.4	IRR	10.00%	
						Administration	30% L.C. 1.9			
						Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				147.3	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	278.2	
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
<b>Operating Costs</b>																													
Fuel Cost				-25.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	
Maintenance				-25.7	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	
Chemicals & Consumables				-4.1	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	
<b>Working Capital Cost</b>				-1.5																									
<b>Fixed Capital Expenditures</b>		-241.0	-542.3	-421.8																									
<b>Total Cash flow (yearly)</b>	-241.0	-542.3	-421.8	60.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	153.6	
<b>Total Cash flow (cumulated)</b>	-241.0	-783.3	-1205.1	-1144.5	-990.9	-837.3	-683.7	-530.1	-376.4	-222.8	-69.2	84.4	238.0	391.7	545.3	698.9	852.5	1006.1	1159.8	1313.4	1467.0	1620.6	1774.2	1927.9	2081.5	2235.1	2388.7	2542.3	2543.9
<b>Discounted Cash Flow (Yearly)</b>	-219.1	-448.2	-316.9	41.4	95.4	86.7	78.8	71.7	65.1	59.2	53.8	48.9	44.5	40.5	36.8	33.4	30.4	27.6	25.1	22.8	20.8	18.9	17.2	15.6	14.2	12.9	11.7	10.7	0.1
<b>Discounted Cash Flow (Cumul.)</b>	-219.1	-667.3	-984.2	-942.8	-847.4	-760.7	-681.9	-610.2	-545.1	-485.8	-432.0	-383.0	-338.6	-298.1	-261.3	-227.9	-197.5	-169.9	-144.8	-121.9	-101.2	-82.3	-65.1	-49.5	-35.4	-22.5	-10.7	-0.1	0.0

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.056</b>	Euro/kWh	
Coal Florate	691.0	t/h	Installed Costs	1085.9	<b>at 85% load factor</b>	30 days Chemical Storage	0.7	Sulphur Price	103.3	Euro/t	
Net Power Output	686.6	MW	Land purchase; surveys	54.3	Fuel Cost	54.0	5 days Coal Storage	0.9	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.7	Maintenance	40.1	Total Working capital	1.6	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	70.7	Waste Disposal	0.0			Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1232.7	Chemicals + Consumable	7.3	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	288.6	MM Euro/year
					Insurance and local taxes	21.7	# operators	128			
							Salary	0.05	NPV	0.00	
							Direct Labour Cost	6.4	IRR	10.00%	
							Administration	30% L.C. 1.9			
							Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				152.8	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6	288.6		
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
<b>Operating Costs</b>																														
Fuel Cost				-28.6	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0		
Maintenance				-26.7	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1		
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3		
Chemicals & Consumables				-3.9	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7		
<b>Working Capital Cost</b>				-1.6																										
<b>Fixed Capital Expenditures</b>		-246.5	-554.7	-431.4																										
<b>Total Cash flow (yearly)</b>		-246.5	-554.7	-431.4	62.0	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1	157.1		
<b>Total Cash flow (cumulated)</b>		-246.5	-801.2	-1232.7	-1170.7	-1013.6	-856.4	-699.3	-542.2	-385.0	-227.9	-70.8	86.4	243.5	400.6	557.7	714.9	872.0	1029.1	1186.3	1343.4	1500.5	1657.7	1814.8	1971.9	2129.1	2286.2	2443.3	2602.0	
<b>Discounted Cash Flow (Yearly)</b>		-224.1	-458.4	-324.1	42.3	97.6	88.7	80.6	73.3	66.6	60.6	55.1	50.1	45.5	41.4	37.6	34.2	31.1	28.3	25.7	23.4	21.2	19.3	17.5	16.0	14.5	13.2	12.0	10.9	0.1
<b>Discounted Cash Flow (Cumul.)</b>		-224.1	-682.5	-1006.7	-964.4	-866.8	-778.1	-697.5	-624.2	-557.5	-496.9	-441.9	-391.8	-346.3	-304.9	-267.3	-233.1	-202.0	-173.8	-148.1	-124.7	-103.5	-84.2	-66.6	-50.7	-36.2	-23.0	-11.0	-0.1	0.0

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.043</b>	Euro/kWh	
Coal Florate	653.3	t/h	Installed Costs	1000.1	<b>at 85% load factor</b>	30 days Chemical Storage	0.8	Sulphur Price	103.3	Euro/t	
Net Power Output	665.2	MW	Land purchase; surveys	50.0	Fuel Cost	51.1	5 days Coal Storage	0.8	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.6	Maintenance	35.8	Total Working capital	1.6	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	63.1	Waste Disposal	0.0			Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1134.8	Chemicals + Consumable	8.2	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	211.5	MM Euro/year
					Insurance and local taxes	20.0	# operators	128			
							Salary	0.05	<b>NPV</b>	0.00	
							Direct Labour Cost	6.4	<b>IRR</b>	5.00%	
							Administration	30% L.C. 1.9			
							Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				111.9	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5	211.5
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Operating Costs</b>																													
Fuel Cost				-27.0	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1	-51.1
Maintenance				-23.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8	-35.8
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3
Chemicals & Consumables				-4.3	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Insurance				-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0	-20.0
<b>Working Capital Cost</b>				-1.6																									
<b>Fixed Capital Expenditures</b>				-227.0	-510.7	-397.2																							
<b>Total Cash flow (yearly)</b>	-227.0	-510.7	-397.2	26.8	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	88.1	1.6
<b>Total Cash flow (cumulated)</b>	-227.0	-737.6	-1134.8	-1108.0	-1019.9	-931.8	-843.7	-755.7	-667.6	-579.5	-491.4	-403.3	-315.2	-227.1	-139.0	-50.9	37.1	125.2	213.3	301.4	389.5	477.6	565.7	653.8	741.9	829.9	918.0	1006.1	1007.7
<b>Discounted Cash Flow (Yearly)</b>	-216.2	-463.2	-343.1	22.0	69.0	65.7	62.6	59.6	56.8	54.1	51.5	49.1	46.7	44.5	42.4	40.4	38.4	36.6	34.9	33.2	31.6	30.1	28.7	27.3	26.0	24.8	23.6	22.5	0.4
<b>Discounted Cash Flow (Cumul.)</b>	-216.2	-679.3	-1022.4	-1000.4	-931.4	-865.6	-803.0	-743.4	-686.6	-632.6	-581.1	-532.0	-485.3	-440.8	-398.4	-358.1	-319.6	-283.0	-248.2	-215.0	-183.4	-153.2	-124.6	-97.2	-71.2	-46.5	-22.9	-0.4	0.0



<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.047</b>	Euro/kWh
Coal Florate	624.2	t/h	Installed Costs	1062.8	<b>at 85% load factor</b>	30 days Chemical Storage	0.7	Sulphur Price	103.3	Euro/t
Net Power Output	628.8	MW	Land purchase; surveys	53.1	Fuel Cost	5 days Coal Storage	0.8	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.3	Maintenance	Total Working capital	1.5	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	67.9	Waste Disposal			Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1205.1	Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	218.2	MM Euro/year
					Insurance and local taxes	# operators	128			
						Salary	0.05	NPV	0.00	
						Direct Labour Cost	6.4	IRR	5.00%	
						Administration	30% L.C. 1.9			
						Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				115.5	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2	218.2		
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
<b>Operating Costs</b>																														
Fuel Cost				-25.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8	-48.8		
Maintenance				-25.7	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6	-38.6		
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3		
Chemicals & Consumables				-4.1	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7	-7.7		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3		
<b>Working Capital Cost</b>				-1.5																										
<b>Fixed Capital Expenditures</b>		-241.0	-542.3	-421.8																										
<b>Total Cash flow (yearly)</b>		-241.0	-542.3	-421.8	28.8	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5	93.5		
<b>Total Cash flow (cumulated)</b>		-241.0	-783.3	-1205.1	-1176.3	-1082.8	-989.3	-895.8	-802.2	-708.7	-615.2	-521.6	-428.1	-334.6	-241.1	-147.5	-54.0	39.5	133.0	226.6	320.1	413.6	507.2	600.7	694.2	787.7	881.3	974.8	1068.3	1069.9
<b>Discounted Cash Flow (Yearly)</b>		-229.5	-491.9	-364.4	23.7	73.3	69.8	66.5	63.3	60.3	57.4	54.7	52.1	49.6	47.2	45.0	42.8	40.8	38.9	37.0	35.2	33.6	32.0	30.4	29.0	27.6	26.3	25.1	23.9	0.4
<b>Discounted Cash Flow (Cumul.)</b>		-229.5	-721.4	-1085.8	-1062.1	-988.8	-919.0	-852.6	-789.3	-729.0	-671.6	-616.9	-564.8	-515.2	-468.0	-423.0	-380.1	-339.3	-300.5	-263.4	-228.2	-194.6	-162.7	-132.2	-103.2	-75.6	-49.3	-24.2	-0.4	0.0

1.5

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.044</b>	Euro/kWh	
Coal Florate	691.0	t/h	Installed Costs	1085.9	<b>at 85% load factor</b>	30 days Chemical Storage	0.7	Sulphur Price	103.3	Euro/t	
Net Power Output	686.6	MW	Land purchase; surveys	54.3	Fuel Cost	54.0	5 days Coal Storage	0.9	Inflation	0.00	%
Sold Sulphur	0.00	t/h	Fees	21.7	Maintenance	40.1	Total Working capital	1.6	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Average Contingencies	70.7	Waste Disposal	0.0			Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Total Investment Cost	1232.7	Chemicals + Consumable	7.3	<b>Labour Cost</b>	<b>MM Euro/year</b>	Revenues / year	227.1	MM Euro/year
					Insurance and local taxes	21.7	# operators	128			
							Salary	0.05	<b>NPV</b>	0.00	
							Direct Labour Cost	6.4	<b>IRR</b>	5.00%	
							Administration	30% L.C. 1.9			
							Total Labour Cost	8.3			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				120.2	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	227.1	
Sulphur				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
<b>Operating Costs</b>																														
Fuel Cost				-28.6	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	-54.0	
Maintenance				-26.7	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	-40.1	
Labour				-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	-8.3	
Chemicals & Consumables				-3.9	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	-7.3	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	-21.7	
<b>Working Capital Cost</b>				-1.6																										
<b>Fixed Capital Expenditures</b>		-246.5	-554.7	-431.4																										
<b>Total Cash flow (yearly)</b>		-246.5	-554.7	-431.4	29.4	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	95.7	
<b>Total Cash flow (cumulated)</b>		-246.5	-801.2	-1232.7	-1203.2	-1107.6	-1011.9	-916.2	-820.6	-724.9	-629.2	-533.6	-437.9	-342.2	-246.6	-150.9	-55.2	40.4	136.1	231.7	327.4	423.1	518.7	614.4	710.1	805.7	901.4	997.1	1092.7	1094.3
<b>Discounted Cash Flow (Yearly)</b>		-234.8	-503.1	-372.7	24.2	75.0	71.4	68.0	64.8	61.7	58.7	55.9	53.3	50.7	48.3	46.0	43.8	41.7	39.8	37.9	36.1	34.3	32.7	31.1	29.7	28.3	26.9	25.6	24.4	0.4
<b>Discounted Cash Flow (Cumul.)</b>		-234.8	-737.9	-1110.6	-1086.4	-1011.4	-940.1	-872.1	-807.3	-745.6	-686.9	-631.0	-577.7	-527.0	-478.7	-432.6	-388.8	-347.1	-307.3	-269.5	-233.4	-199.1	-166.4	-135.2	-105.6	-77.3	-50.4	-24.8	-0.4	0.0

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 1 of 15

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : COMPARISON OF ALTERNATIVES AND SELECTION OF THE MOST  
 PROMISING TECHNOLOGY

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

Revision no.: Final  
Date: November 2005  
Sheet: 2 of 15

## **SECTION F**

# **COMPARISON OF ALTERNATIVES AND SELECTION OF THE MOST PROMISING TECHNOLOGY**

## **INDEX**

### **SECTION F**

- 1.0 Introduction
- 2.0 Post-combustion CO<sub>2</sub> capture alternatives (Case 1 through 4)
- 3.0 Pre-combustion CO<sub>2</sub> capture alternatives (Case 5 through 7)
- 4.0 Selection of the most promising technology

Appendix 1 - Summary of performance, cost and environmental data of all the alternatives.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 3 of 15

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

## **SECTION F COMPARISON OF ALTERNATIVES AND SELECTION OF THE MOST PROMISING TECHNOLOGY**

### **1.0 Introduction**

Purpose of this section F is to present the performance and cost data developed for the alternatives studied in the previous sections, in order to bring to evidence the major features and merits of each alternative.

Data used for this comparison are also summarized in Appendix 1, which collects performances, costs and environmental data of all the alternatives. From the first analysis of the table, it is evident that the alternatives have approximately a similar net electrical efficiency, despite the differences of the various technologies involved, which, on the contrary, is reflected in the wide range of both the investment and specific net investment cost. With reference to the production costs, the range of variation falls in a tight range, because the Cost of Energy is simultaneously affected by different factors like the investment cost and the operating/maintenance costs of each alternative.

The following paragraphs present a more detailed analysis of the different alternatives. Due to the number of cases analyzed, the comparison of the alternatives is initially split into two separate groups:

- Post-combustion CO<sub>2</sub> capture alternatives (Case 1 to 4).
- Pre-combustion CO<sub>2</sub> capture alternatives (Case 5 to 7).

This initial comparison allows selecting the two best alternatives, one for each group. Then, the two selected alternatives are compared in order to select the most promising technology of the project.

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section F: Comparison of alternatives and Selection  
of the most promising technology**

Revision no.: Final  
Date: November 2005  
Sheet: 4 of 15

**2.0 Post-combustion CO<sub>2</sub> capture alternatives (Case 1 through 4)**

This comparison is mainly aimed at evaluating the effect of the post combustion CO<sub>2</sub> capture on different power plant technologies, by examining plant performances, investment/production cost data and environmental impact.

Table F.2.1 summarises the most important data of the four alternatives.

**Table F.2.1 – Performance data.**

		Case 1 PC-Boiler		Case 2 PC-Oxycomb.		Case 3 CFB- FW		Case 4 PCFB-FW	
<b>ACID GAS REMOVAL TECHNOLOGY</b>		MEA Scrubbing		Gas Liquefaction		MEA Scrubbing		MDEA Scrubbing	
<b>CO<sub>2</sub> Capture Efficiency</b>	<b>%</b>	85.0		93.0		85.0		85.0	
<b>OVERALL PERFORMANCES</b>									
<b>Coal Flow Rate A.R.</b>	<b>t/h</b>	734.0		677.6		592.9		727.0	
<b>Coal LHV</b>	<b>kJ/kg</b>	10500		10500		10500		10500	
<b>Thermal Energy of Feedstock</b>	<b>MWth</b>	2140.8		1976.3		1729.2		2120.4	
<b>Gross Electric Power Output</b>	<b>MWe</b>	932.0		1039.4		763.0		816.0	
<b>Auxiliary Consumption</b>	<b>MWe</b>	168.8		295.8		146.5		125.5	
<b>Net Electric Power Output</b>	<b>MWe</b>	761.0		741.3		614.7		688.4	
<b>Gross Electrical Efficiency</b>	<b>%</b>	43.5		52.6		44.1		38.5	
<b>Net Electrical Efficiency</b>	<b>%</b>	35.5		37.5		35.5		32.5	
<b>EMISSIONS</b>		<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (6% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>g/h</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (6% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (6% O<sub>2</sub>)</b>
<b>CO<sub>2</sub></b>		166	-	71	-	168	-	181	-
<b>NO<sub>x</sub></b>		0.13	40	0	0	0.14	40	0.15	40
<b>SO<sub>x</sub></b>		0.10 <sup>(1)</sup>	29 <sup>(1)</sup>	0.0013	950	0.15 <sup>(1)</sup>	43 <sup>(1)</sup>	0.15 <sup>(1)</sup>	38 <sup>(1)</sup>
<b>CO</b>		0.50	150	0	0	0.53	150	0.58	150
<b>Particulate</b>		0.04	30	0.02	Nil	0.03	30	0.03	30
<b>NH<sub>3</sub></b> <sup>(2)</sup>		0.02	5	-	-	0.02	5	0.02	5
<b>INVESTMENT COST DATA</b>									
<b>Total Investment</b>	<b>10<sup>6</sup> €</b>	1251.8		1395.2		953.8		1230.6	
<b>Specific Net Investment Cost</b>	<b>€/kW</b>	1645		1882		1552		1788	
<b>PRODUCTION COST DATA</b>									
<b>C.O.E. (DCF=10%)</b>	<b>c€/kWh</b>	5.39		5.46		5.34		5.55	
<b>C.O.E. (DCF=5%)</b>	<b>c€/kWh</b>	4.28		4.20		4.30		4.35	

Notes: (1) SO<sub>x</sub> emissions upstream AGR unit; after solvent washing, emissions are expected close to zero.

(2) Due to ammonia slippage into the flue gas downstream the SCR/SNCR.

**Section F: Comparison of alternatives and Selection  
of the most promising technology**


---

The feature common to the four alternatives is the drying of the coal from 50.7% to 32%, before feeding the boilers (reference to Section C, paragraph 3.0).

Cases 1 and 3 (USC-PC, CFB), which are established boiler technologies for lignite coal processing, are based on a MEA scrubbing as acid gas removal technology, while the higher pressure of Case 4 (PCFB) makes more advantageous a MDEA washing in order to reduce the steam requirement of the unit.

Both MEA and MDEA washing are widely used for removal of acid gases from streams that are generally oxygen free. No application is presently in operation on large scale for CO<sub>2</sub> capture from power plants exhausts, which contain high oxygen level. However, there are smaller power plants in operation where CO<sub>2</sub> is captured from flue gas, ranging from a few tons per day to a maximum of 200 t/d from a flue gas side stream. These processes have been modified to incorporate inhibitors to limit solvent degradation and equipment corrosion, but only after commercial experience of large-scale coal power plants, a precise estimate of amine losses will be available.

Case 2 is not a well-proven technology because the combustion with pure oxygen has not been used in commercial power plants yet. However, the design of the boiler can be considered as an extrapolation of the existing air fired technology.

The main comments from Table F.2.1 are the following:

- The higher boiler pressure of Case 4 results in a lower Plant auxiliary consumption with respect to the other alternatives, because of the less AGR steam requirement of MDEA with respect to MEA. A further improvement of the AGR performances might be obtained through the selection of a physical solvent (Selexol) instead of MDEA. However, the complexity of the process scheme, specifically the need of cooling and reheating of the flue gas before and after the CO<sub>2</sub> absorption, leads to a low net electrical efficiency of the Plant, which is not expected to be offset, even if Selexol were adopted. The complexity of the process scheme also corresponds to a high investment cost and therefore to a high Cost of Electricity. As a consequence, Case 4 is the least attractive of the postcombustion CO<sub>2</sub> capture alternatives.

**Section F: Comparison of alternatives and Selection  
of the most promising technology**


---

- By comparing Case 1 (USC-PC Boiler) and Case 3 (CFB Boiler), the gross efficiency of the second alternative is higher (+0.6%). This is due to the better combustion efficiency of the fluidized bed technology, mainly related to the homogeneity of the dense phase properties and the coal particle size required by the boiler. In fact, due to the high moisture content of the coal, the conventional PC boiler requires a flue gas extraction from the furnace for final drying and milling of the coal, thus resulting in a reduction of the boiler efficiency.

With reference to the auxiliary consumption of the two alternatives, Case 3 does not require an FGD unit because the relatively low sulphur content of the coal allows to respect the SO<sub>x</sub> limit of the downstream AGR unit by adsorption on the limestone used in the fluidized bed. However, this saving of the power consumption is completely offset by the higher auxiliary consumption of the boiler island, because of the air blowers needed for the fluidization of the bed. In fact, the total auxiliary power consumption of Case 3 is higher than Case 1, if considered proportional to the coal flow rate.

The sum of the above effects leads to the same net electrical efficiency for the two alternatives (35.5%).

With reference to the investment data, the specific investment cost is lower as the FGD unit and final coal pulverization milling are not required, with a consequent lower Cost of Electricity.

- Case 2 is attractive because the flue gas at the exit of the boiler mainly consists of CO<sub>2</sub> and consequently the downstream flue gas liquefaction allows reaching a high CO<sub>2</sub> capture efficiency with respect to the other alternatives (93% vs. 85%).

The gross efficiency of the power plant is higher than the other cases because the elimination of AGR avoids its large steam consumption, with a consequent gain on the gross power production. This beneficial effect is partially reduced by the high power requirement of the ASU, which provides oxygen for the coal combustion. In any case, the net electrical efficiency is the best one amongst the four alternatives.

With reference to the investment cost data, Case 2 is strongly penalized by the cost of the Air Separation Unit that entails the highest investment and highest net specific investment cost of the four alternatives. This result is also reflected in the Cost of Energy at 10% DCF, where figures are higher than the other alternatives. On the other hand, figures at 5% DCF have an opposite trend, because of the low operating costs of this



**Section F: Comparison of alternatives and Selection  
of the most promising technology**


---

alternative (see Section E). In any case, 5 % DCF is only a sensitivity analysis of the study, being 10% DCF the design basis of the project. In fact, 5% DCF cannot be considered in line with the actual parameters of the market.

As a consequence of the above economical considerations, Case 2 is less attractive than Case 1 and 3.

- With reference to Case 3, literature data state that the CFB technology is a potential source of N<sub>2</sub>O emission, which is a powerful greenhouse gas as 1 kg of N<sub>2</sub>O is equivalent to approximately 300 kg of CO<sub>2</sub>.

N<sub>2</sub>O emission is much dependent on the combustion temperature, being the N<sub>2</sub>O emission decreasing when increasing the combustion temperature. With reference to the specific lignite of the study, the temperatures in the furnace ranges from 875°C (bed temperature) to 880°C (furnace temperature). With these temperatures, the expected N<sub>2</sub>O emission from the CFB boiler is approximately 20 mg/Nm<sup>3</sup> (as average value). Therefore, the N<sub>2</sub>O production is approximately 0.049 t/h, equivalent to 14.5 t/h of CO<sub>2</sub>. In this case, the CO<sub>2</sub> specific emission would increase from 168 to 192 g/kWh.

Based on some literature data, an additional N<sub>2</sub>O emission could also be expected from the SCR system, because of the NH<sub>3</sub> injection, but this is not generally confirmed from catalyst's Suppliers. If additional N<sub>2</sub>O emission would be considered for the SCR system, this would be higher for the PC boiler, because the injection system of the CFB is more suitable for a better distribution in the flue gas and the quantity of ammonia injected into the PC boiler is higher, due to the higher combustion temperature, which leads to a higher NO<sub>x</sub> flowrate entering the SCR system. However, it is not possible to quantify this possible N<sub>2</sub>O emission from the SCR system.

The percentage CO<sub>2</sub> capture could be increased in a CFB plant to offset the higher N<sub>2</sub>O emissions: by capturing approximately 87% of the CO<sub>2</sub> entering the AGR unit, instead of the actual 85%, the CO<sub>2</sub> specific emission would decrease from 192 g/KWh to the actual 168 g/kWh. However, the IEA GHG-Fluor study showed that the percentage capture of CO<sub>2</sub> could be increased to 95%, if necessary, without increasing the cost per tonne of CO<sub>2</sub> captured and without affecting significantly the Cost of Electricity.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 8 of 15

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

- With reference to the specific emissions of Case 2, this alternative has the lowest figures, being the pollutant emission close to zero; this is a direct consequence of the combustion with oxygen instead of air. Alternatives other than Case 2 have similar emissions (refer also to the previous point) and their pollutant concentration is in compliance with the current European Directive, as well as the design basis of the project. Therefore, the better environmental performances of Case 2 do not justify considering this alternative the most promising amongst the postcombustion CO<sub>2</sub> capture technologies.

On the basis of the considerations made in this paragraph, Case 3 (CFB) results the most promising technology among the postcombustion CO<sub>2</sub> capture alternatives of the study.

**Section F: Comparison of alternatives and Selection  
of the most promising technology**
**3.0 Pre-combustion CO<sub>2</sub> capture alternatives (Case 5 through 7)**

This comparison is mainly aimed at evaluating the effect of the pre-combustion CO<sub>2</sub> capture on different gasification technologies, by examining plant performances, investment/production cost data and environmental impact. The different gasification technologies are: Future Energy (Case 5), Shell (Case 6), FW (Case 7).

Table F.3.1 summarises the most important data of the IGCC alternatives.

**Table F.3.1 – Performance data.**

		Case 5 Future Energy Gasifier	Case 6 Shell Gasifier	Case 7 FW Gasifier			
<b>ACID GAS REMOVAL TECHNOLOGY</b>		MDEA Scrubbing	MDEA Scrubbing	MDEA Scrubbing			
CO <sub>2</sub> Capture Efficiency	%	85.8	85.2	82.9			
<b>OVERALL PERFORMANCES</b>							
Coal Flow Rate A.R.	t/h	653.3	624.2	691.0			
Coal LHV	kJ/kg	10500	10500	10500			
Thermal Energy of Feedstock	MWth	1914.4 (1)	1820.5	2015.4			
Gross Electric Power Output	MWe	900.3	868.7	900.5			
Auxiliary Consumption	MWe	233.1	238.0	211.9			
Net Electric Power Output	MWe	665.2	628.8	686.6			
Gross Electrical Efficiency	%	47.2	47.7	44.7			
Net Electrical Efficiency	%	34.7	34.5	34.1			
<b>EMISSIONS</b>		g/kWh	mg/Nm <sup>3</sup> (15% O <sub>2</sub> )	g/kWh	g/h	G/kWh	mg/Nm <sup>3</sup> (15% O <sub>2</sub> )
CO <sub>2</sub>		160	-	168	-	191	-
NO <sub>x</sub>		0.56	74	0.60	74	0.61	74
SO <sub>x</sub>		0.01	1.2	0.01	1.2	0.01	1.2
CO		0.24	31.3	0.25	31.3	0.26	31.4
Particulate		0.04	5	0.04	5	0.04	5
NH <sub>3</sub>		-	-	-	-	-	-
<b>INVESTMENT COST DATA</b>							
Total Investment	10 <sup>6</sup> €	1134.8	1205.1	1232.7			
Specific Net Investment Cost	€/kW	1706	1917	1795			
<b>PRODUCTION COST DATA</b>							
C.O.E (DCF=10%)	c€/kWh	5.41	5.94	5.64			
C.O.E (DCF=5%)	c€/kWh	4.27	4.66	4.44			

(1) Thermal Energy of Feedstock including Natural Gas to Gasifiers

The main common feature of the alternatives is a gasification pressure suitable to feed the gas turbines and the use of a MDEA scrubbing for the acid gas washing, with a combined removal of CO<sub>2</sub> and H<sub>2</sub>S.

**Section F: Comparison of alternatives and Selection  
of the most promising technology**


---

Cases 5 and 6 (Future Energy and Shell gasification technology) are based on a oxygen-blown entrained bed gasification, whilst Case 7 is based on an air blown fluidized bed gasifier, thus avoiding the presence of the Air Separation Unit.

The main comments from Table F.3.1 are the following:

- By comparing Case 5 and Case 6, the Shell gross electrical efficiency is higher than Future Energy, whilst the net electrical efficiency is lower. This is mainly due to the following reasons:
  - Gasifier efficiency of the Shell Technology is higher, thus resulting in a lower inlet coal flowrate and in a higher gross electrical efficiency of the Plant;
  - Auxiliary consumption of the Shell technology are slightly higher than those of Future Energy. In fact, the higher flowrate of Case 5 corresponds to a higher power consumption of process units (ASU, syngas treatment and conditioning line), but the higher power requirement of the Shell gasification island completely offsets the previous advantage. This leads to the higher net electrical efficiency of the Future Energy Technology.

With reference to the investment and production cost data, the Shell technology is penalized by the higher investment cost of the Gasification Island, which is explained by the use of Waste Heat Boiler vs. quench adopted by Future Energy. This leads to the highest specific net investment cost and Cost of Energy among the three IGCC alternatives.

- The main advantages of the FW technology are the possibility of avoiding the Air Separation Unit and the capability of gasifying lignite with a high moisture content (25% wt). Future Energy and Shell gasification technologies require, in fact, 10% and 5% of moisture content respectively, thus representing a real challenge of the actual drying technologies for lignite coal (reference to Section C, paragraph 3.0). This high degree of drying required by these two technologies is related to the use of pulverized coal for pneumatic transportation; the low moisture content is necessary to prevent pneumatic transportation plugging.

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 11 of 15

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

Both Shell and Future Energy technologies have commercial experience with coal. FW fluid bed gasifier does not have commercial track record, but a design particularly suited for lignite because it does not require lignite pulverisation, but most simply a size reduction and control.

The avoidance of the ASU results in the lowest plant auxiliary consumption. However, the low carbon conversion efficiency (97% vs. more than 99% of the other technologies) leads to the lowest gross efficiency among the three alternatives (44.7% vs. more than 47% of the other technologies). In addition, the low carbon conversion efficiency of the gasifier and the presence of CH<sub>4</sub> in the flue gas, because of the low gasification temperature, reduce the amount of CO that can be economically shifted to CO<sub>2</sub>, thus limiting the CO<sub>2</sub> capture efficiency to approximately 83% instead of 85% of the other alternatives.

Another disadvantage of this technology is due to the high gas flowrate of the syngas treatment and conditioning line, as well as of the AGR unit. This is because the gasification with air entails a high nitrogen content in the syngas, and a consequent low concentration of the CO<sub>2</sub> flowing to the AGR, thus increasing the steam requirement and the investment cost of the unit.

Above features of Case 7 result in a relatively high plant investment cost that, together with the low net electrical efficiency, leads to a non attractive cost of electricity.

- With reference to the environmental performances, the three alternatives have similar specific emission levels and the pollutant concentration is in compliance with the current European Directive, as well as the design basis of the project.

The considerations made in this paragraph lead to the conclusion that the Future Energy gasification is the preferred option of the pre-combustion CO<sub>2</sub> capture alternatives.

**Section F: Comparison of alternatives and Selection  
of the most promising technology**
**4.0 Selection of the most promising technology**

The considerations made in paragraph 2.0 and 3.0 allowed the selection of the two best alternatives, CFB and IGCC based on Future Energy technology, respectively for the postcombustion and precombustion CO<sub>2</sub> capture case.

Table F.4.1 summarizes the most important performances of the two alternatives.

**Table F.4.1 – Performance data.**

		Case 3 - CFB-Boiler (FW)		Case 5 - Future Energy Gasifier	
CO <sub>2</sub> capture efficiency, %		85.0		85.8	
Lignite Moisture Content After Drying %wt		32		10	
ACID GAS REMOVAL TECHNOLOGY		MEA Scrubbing		MDEA Scrubbing	
Carbon in Coal Feed	kmol/h	15466.0		17075.0	
Limestone	kmol/h	259.7		0.0	
Slag	kmol/h	50.7		42.7	
CO <sub>2</sub> to Storage	kmol/h	13324.0		14621.0	
CO <sub>2</sub> Capture Efficiency	%	85.0		85.8	
<b>OVERALL PERFORMANCES</b>					
Coal Flow Rate A.R.	t/h	592.9		653.3	
Thermal Energy of Feedstock	MWth	1729.2		1914.4 (1)	
Gross Electric Power Output	MWe	763.0		900.3	
Auxiliary Consumption	MWe	146.5		233.1	
Gross Electrical Efficiency	%	44.1		47.2	
Net Electrical Efficiency	%	35.5		34.7	
EMISSIONS		g/kWh	mg/Nm <sup>3</sup> (VD 6% O <sub>2</sub> )	g/kWh	mg/Nm <sup>3</sup> (VD 15% O <sub>2</sub> )
CO <sub>2</sub>		168	-	160	-
NO <sub>x</sub>		0.14	40	0.56	74
SO <sub>x</sub>		0.15 <sup>(2)</sup>	43 <sup>(2)</sup>	0.01	1.2
CO		0.53	150	0.24	31.3
Particulate		0.03	30	0.04	5
NH <sub>3</sub> <sup>(3)</sup>		0.02	5	-	-
<b>INVESTMENT COST DATA</b>					
Total Investment	10 <sup>6</sup> €	953.8		1134.8	
Specific Net Investment Cost	€/kW	1552		1706	
<b>PRODUCTION COST DATA</b>					
C.O.E. (DCF=10%)	c€/kWh	5.34		5.41	
C.O.E. (DCF=5%)	c€/kWh	4.31		4.27	
(1) Thermal Energy of Feedstock including Natural Gas to Gasifiers (2) SO <sub>x</sub> emissions upstream AGR unit; after solvent washing, emissions are expected close to zero. (3) Due to ammonia slippage into the flue gas downstream the SCR.					

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: November 2005

Sheet: 13 of 15

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

The IGCC alternative has a higher gross electrical efficiency (47.2% vs. 44.1%) due to the presence of the gas turbines and to the possibility of using an AGR unit based on a MDEA solvent, which allows saving a considerable quantity of thermal power for the stripper reboilers.

On the other hand, the MDEA washing unit and the need of an ASU entail a high auxiliary power requirement of the IGCC technology, which leads to a lower net electrical efficiency (34.7% vs. 35.5%).

Another advantage of the CFB technology, not negligible, is the possibility of processing a lignite coal with 32% moisture content instead of the 10% required by the Future Energy gasification technology. Current technologies have not yet proven the capability of reach such a low moisture content for a lignite coal.

With reference to the environmental performances, no significant difference is noted amongst the two alternatives.

The comparison of the investment and production cost data are also in favour of the CFB technology, due to the complexity of the IGCC plant, which requires capital intensive units like the ASU and the syngas treatment and conditioning line. On the other hand, the Cost of Energy at 5% DCF is slightly in favour of the IGCC alternative, being the operating cost of the CFB case high because of the higher consumption of the MEA solvent. In any case, as already stated in paragraph 2.0, 5% DCF cannot be considered in line with the actual parameters of the current market.

With reference to the Cost of Energy, it has to be remarked that the availability of the CFB technology should be considered higher than the IGCC Plant. The comparison made in this paragraph is based on 7446 hours of operation, after the commissioning period, for both the alternatives. If 7884 operating hours (90% load factor) for the CFB alternative were considered, the Cost of Energy would be as follows:

- 5.17 c€/kWh at 10% DCF.
- 4.18 c€/kWh at 5% DCF.

Therefore, the considerations made in this section bring to evidence that the most promising technology of the CO<sub>2</sub> capture in low rank coal power plants is the CFB alternative.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section F: Comparison of alternatives and Selection  
of the most promising technology**

---

Revision no.: Final

Date: November 2005

Sheet: 14 of 15

## **Appendix 1**

**Summary of Performance, Cost and Environmental data of all the alternatives**



**Appendix 1 – Summary of performance, cost and environmental data of all the alternatives**

<b>COMPARISON OF THE ALTERNATIVES</b>																
		<b>Post-combustion CO<sub>2</sub> Capture</b>						<b>Pre-combustion CO<sub>2</sub> Capture</b>								
		<b>Case 1 PC-Boiler</b>		<b>Case 2 PC-Oxy Combustion</b>		<b>Case 3 CFB-Boiler (FW)</b>		<b>Case 4 PCFB-Boiler (FW)</b>		<b>Case 5 Future Energy Gasifier</b>		<b>Case Shell Gasifier</b>		<b>Case 7 FW Gasifier</b>		
<b>CO<sub>2</sub> capture efficiency, %</b>		85.0		93.0		85.0		85.0		85.8		85.2		82.9		
<b>Lignite Moisture Content After Drying %wt</b>		32		32		32		32		10		5		25		
<b>ACID GAS REMOVAL TECHNOLOGY</b>		MEA Scrubbing		Gas Liquefaction		MEA Scrubbing		MDEA Scrubbing		MDEA Scrubbing		MDEA Scrubbing		MDEA Scrubbing		
<b>Carbon in Coal Feed</b>	<b>kmol/h</b>	19144.0		17674.0		15466.0		18973.0		17075.0		16283.0		18038.0		
<b>Limestone</b>	<b>kmol/h</b>	51.0		0.0		259.7		98.0		0.0		0.0		84.0		
<b>Slag</b>	<b>kmol/h</b>	118.0		426.0		50.7		190.0		42.7		99.9		661.0		
<b>CO<sub>2</sub> to Storage</b>	<b>kmol/h</b>	16215.0		16044.0		13324.0		16050.0		14621.0		13785.0		14474.5		
<b>CO<sub>2</sub> Capture Efficiency</b>	<b>%</b>	85.0		93.0		85.0		85.0		85.8		85.2		82.9		
<b>OVERALL PERFORMANCES</b>																
<b>Coal Flow Rate A.R:</b>	<b>t/h</b>	734.0		677.6		592.9		727.0		653.3		624.2		691.0		
<b>Coal LHV</b>	<b>kJ/kg</b>	10500		10500		10500		10500		10500		10500		10500		
<b>Thermal Energy of Feedstock</b>	<b>MWth</b>	2140.8		1976.3		1729.2		2120.4		1914.4 (1)		1820.5		2015.4		
<b>Gross Electric Power Output</b>	<b>MWe</b>	932.0		1039.4		763.0		816.0		900.3		868.7		900.5		
<b>Auxiliary Consumption</b>	<b>MWe</b>	168.8		295.8		146.5		125.5		233.1		238.0		211.9		
<b>Gross Electrical Efficiency</b>	<b>%</b>	43.5		52.6		44.1		38.5		47.2		47.7		44.7		
<b>Net Electrical Efficiency</b>	<b>%</b>	35.5		37.5		35.5		32.5		34.7		34.5		34.1		
<b>EMISSIONS</b>		<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 6% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>g/h</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 6% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 6% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 15% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 15% O<sub>2</sub>)</b>	<b>g/kWh</b>	<b>mg/Nm<sup>3</sup> (VD 15% O<sub>2</sub>)</b>	
<b>CO<sub>2</sub></b>		166	-	71	-	168	-	181	-	160	-	168	-	191	-	
<b>NO<sub>x</sub></b>		0.13	40	0	0	0.14	40	0.15	40	0.56	74	0.60	74	0.61	74	
<b>SO<sub>x</sub></b>		0.10 <sup>(2)</sup>	29 <sup>(2)</sup>	0.0013	950	0.15 <sup>(2)</sup>	43 <sup>(2)</sup>	0.08 <sup>(2)</sup>	38 <sup>(2)</sup>	0.01	1.2	0.01	1.2	0.01	1.2	
<b>CO</b>		0.50	150	0	0	0.53	150	0.58	150	0.24	31.3	0.25	31.3	0.26	31.4	
<b>Particulate</b>		0.04	30	0.02	Nil	0.03	30	0.03	30	0.04	5	0.04	5	0.04	5	
<b>NH<sub>3</sub><sup>(3)</sup></b>		0.02	5	-	-	0.02	5	0.02	5	-	-	-	-	-	-	
<b>INVESTMENT COST DATA</b>																
<b>Total Investment</b>	<b>10<sup>6</sup> €</b>	1251.8		1395.2		953.8		1230.6		1134.8		1205.1		1232.7		
<b>Specific Net Investment Cost</b>	<b>€/kW</b>	1645		1882		1552		1788		1706		1917		1795		
<b>PRODUCTION COST DATA</b>																
<b>C.O.E. (DCF=10%)</b>	<b>c€/kWh</b>	5.39		5.46		5.34		5.55		5.41		5.94		5.64		
<b>C.O.E. (DCF=5%)</b>	<b>c€/kWh</b>	4.28		4.20		4.30		4.35		4.27		4.66		4.44		
NOTES: (1) Thermal Energy of Feedstock including Natural Gas to Gasifiers. (2) SO <sub>x</sub> emissions upstream AGR unit; after solvent washing, emissions are expected close to zero. (3) Due to ammonia slippage into the flue gas downstream the SCR/SNCR.																

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 1 of 47

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : DETAILED INFORMATION FOR THE SELECTED TECHNOLOGY

ISSUED BY : S. RIPANI  
 CHECKED BY : L. MANCUSO  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

Revision no.: Final  
Date: Nov. 2005  
Sheet: 2 of 47

## **SECTION G**

### **DETAILED INFORMATION FOR THE SELECTED TECHNOLOGY**

#### **I N D E X**

#### **SECTION G DETAILED INFORMATION FOR THE SELECTED TECHNOLOGY**

##### **G.1 CFB boiler without CO<sub>2</sub> Capture**

- 1.0 Summary
- 1.1 Process Description
- 1.2 Process Flow Diagrams
- 1.3 Heat and Material Balances
- 1.4 Utility Consumption
- 1.5 CFB Overall Performance
- 1.6 Environmental Impact
- 1.7 Equipment List

##### **G.2 CFB boiler with CO<sub>2</sub> Capture**

- 2.0 Summary
- 2.1 Process Description
- 2.2 Process Flow Diagrams
- 2.3 Heat and Material Balances
- 2.4 Utility Consumption
- 2.5 CFB Overall Performance
- 2.6 Environmental Impact
- 2.7 Equipment List

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 3 of 47

**G.3 Economics**

- 3.0 Introduction
- 3.1 Basis of investment cost evaluation
- 3.2 Investment cost of the two alternatives
- 3.3 Operation and maintenance costs
- 3.4 Evaluation of the Electric Power cost and CO<sub>2</sub> removal cost

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 4 of 47

**Section G: Detailed Information for the Selected Technology**

---

## **SECTION G DETAILED INFORMATION FOR THE SELECTED TECHNOLOGY**

Purpose of this Section G is to present a detailed assessment of performances and costs of the most attractive technology, the CFB boiler based on the Foster Wheeler's technology, which was selected on the basis of the technical/economical analysis made in section D, E and F of this study.

Section G provides technical and economical information both for the alternative with and without the CO<sub>2</sub> capture, in order to evaluate the penalties on performances and investment cost, due to the CO<sub>2</sub> sequestration.

Section G.1 presents a complete technical report for the CFB technology without the CO<sub>2</sub> capture, providing a detailed process description, heat and material balances, process flow diagrams, sized equipment list, utility consumption and performances.

The same information are also provided for the CFB alternative with the CO<sub>2</sub> capture, in section G.2, with a higher level of detail with respect to same case already developed in section D.3.

In this phase, further investigation was made with Siemens on the steam turbine, leading to some marginal modifications on both the design and the performances with respect to the assumption made in section D.3. As a consequence, the plant performances developed in section G.2 are slightly different from those already shown in section D.3 for the same case, but the analysis made for the comparison of the different alternatives (section F) is not affected. Further details of these modifications are given in section G.2.

Following the technical information of these two cases, a detailed economical analysis is developed in section G.3, evaluating the investment cost, with an accuracy of +/-30%, and the cost of energy for both the alternatives. From the comparison of the two cases, the cost of CO<sub>2</sub> avoidance is also determined.

## **SECTION G.1 CFB boiler without CO<sub>2</sub> Capture**

### **1.0 Summary**

The power plant is based on two SuperCritical CFB boilers, based on the Foster Wheeler's technology. Main features of the plant are summarized herebelow:

- The size of the plant considered for this configuration is based on the actual commercial size of CFB boilers, with the same capacity of Case 3, studied in section D.
- A pre-drying of the coal from a moisture level of 50.7% in as-received coal to about 32% is considered, before feeding the boiler plant. Drying of the coal allows to increase the overall performances of the plant.
- The limits of NO<sub>x</sub> emissions, established by regulations, can be achieved with a firing system integrated with a SNCR package.
- Flue gas desulphurization, downstream the boiler, is not required to meet SO<sub>x</sub> emission limits. SO<sub>x</sub> are captured by a limestone injection in the combustion chamber. The limestone reacts with the sulphur released from the fuel.
- Partial heat recovery from the flue gas from boiler, to preheat water for drying of the coal, is made to improve the plant electrical efficiency.


### **1.1 Process Description**

The configuration of the CFB complex is based on two supercritical once through steam generators, with superheating and steam reheating.

Reference is made to the attached Overall Block Flow Diagram of the CFB power plant.

The arrangement of the process units is the following:

# CFB Overall Block Flow Diagram



**Unit**

1000	Storage and Handling of solid materials, including Coal handling and storage Limestone handling and storage
2000	Boiler Island with SNCR based De NO <sub>x</sub> , Limestone injection and Electro Static Precipitators (ESP) Ash and solid removal
3000	Power Island, consisting of one Steam Turbine and Preheating Line
4100-4500	Utility and Offsite Units

*Note:* ‘Coal’ referred to in the following section means ‘low rank coal’ as defined in the BEDD document.

**1.1.1 Unit 1000: Storage and Handling of solid materials**
**Coal Handling and Storage**

The process flow diagram of the coal handling unit is attached to paragraph 1.2 of this section (PFD: 1000-1-50-1001).

According to the study basis, the plant is assumed close to the lignite mine, so the delivery of the coal is made by a railway that discharges the coal in dedicated coal conveyors (CR-1001 A/B) below the railway track. The coal conveyors move the coal to the coal elevators (CR-1002 A/B) and then to the coal storage dome (X-1002) by means of dedicated coal conveyors (CR-1009 A/B).

The dome provides a minimum of 5 days storage, equivalent to approximately 72,000 tons of coal. A series of coal conveyors (CR-1010 A/B, CR-1011, CR-1012) and one coal bucket elevator (CR-1013) take the coal from the dome and transport this to the screen grinder (SCR-1001 A/B) for milling down to a maximum size of 2 cm.

The crushed coal is transported to the drying unit by a series of coal conveyors (from CR-1003 A/B to CR-1007 A/B) before feeding the CFB boilers of the power island.



The whole system is designed to avoid fine powder dispersion to the ambient. Exhaust air blowers are equipped with dedicated coal dust filters for the collection of powder, before discharge of the air to the atmosphere.

*Limestone Handling and Storage:*

The process flow diagram of the limestone handling unit is attached to paragraph 1.2 of this section (PFD: 1000-1-50-1002).

Limestone is transported to the plant in big lumps, by using the railway. It is transferred to the limestone storage building (X-1004) by using a system similar to that used for the coal, basically made of a series of limestone conveyors and elevators. The storage building is by the coal storage area, with an autonomy of approximately 30 days of operation, corresponding to about 40,000 m<sup>3</sup> of limestone.

The limestone feeding system, from the storage building, is the same of that employed for coal, with conveyors that bring the limestone to the crusher for its pulverization. The pulverization is useful to increase the surface area and consequently the sulphur removal efficiency of the boiler. After milling, limestone is transported by conveyors to the silos next to the boilers. All the conveyors are placed inside a metallic tunnel in order to avoid dispersion of fines. Conveyors are preferred to the pneumatic system to avoid possible problems of plugging, because of the capacity of limestone to absorb humidity.

*Coal Pre-Drying:*

The process flow diagram of the drying unit is attached to paragraph 2.2 (PFD: 1000-1-50-1003).

This unit is mainly composed of two parallel trains, each sized for 50% of rated capacity.

Pre-drying of the coal is used to improve the plant performances, making use of some low energy temperature heat and taking advantage from the increase of the boiler efficiency due to a lower inlet water content of the coal.

The coal from the coal handling unit is conveyed to the lignite drying system and fed to the fluidized bubbling bed. The air necessary to fluidize the bed and drying the lignite is blown by a dedicated air fan (B-1001 A/B). Air is first pre-heated in the air preheater (E-2001) and then fed to the bubbling bed (FB-1001).

Air is preheated against hot water that circulates in closed loop through the different units of the plant, recovering heat from the following sources.

- Part of the flue gases leaving the CFB boiler after the SNCR system (E-2005) (26 MWth);
- Condensate from the pre-heating line of the power island, before entering the deaerator (98 MWth).

Part of the hot water in closed loop is also sent to the water coils submerged in the fluidized bed. The heat contained in the hot water completes the lignite drying and allows to maintain the bed at constant temperature.

The air that crosses the fluid beds partially removes the moisture content of the coal and is then directed to a dust filter, which reduces the entrained amount of ash, before discharging to the atmosphere. The coal ash collected in the filter is finally sent to the fly ash handling and storage system.

The dry coal at 32% wt of moisture content is discharged in the hopper (X-1001) and sent to the CFB boiler island, by using dedicated coal conveyors (CR-1001 A/B).

### **1.1.2 Unit 2000: Boiler Island**

The boiler island consists of two parallel CFB boilers, for the generation of superheated and reheated steam.

The following description makes reference to the process flow diagram of the boiler island, attached to paragraph 1.2 of this section (PFD: 2000-1-50-2001).

#### *Supercritical Tower Type Boiler:*

Each boiler is a tower-type super critical boiler. The boiler is once through type, without steam generator. The steam generation is fixed by the coal feeding system to the boiler, whilst the steam temperature is as consequence of the thermal power of the combustion process.

Coal from the storage and handling system (Unit 1000) is discharged into the coal silos and then fed to the boilers by dedicated pressurized coal feeders. This system is pressurized to avoid possible back flows of gas from the combustion chamber of the boiler. Coal is then mixed with the combustion air in a high turbulence zone to increase the process combustion efficiency.

Limestone is added into the boilers through the dedicated limestone silos, close to the boiler. The presence of the limestone makes the desulphurization of the exhaust gas and allows to have a uniform temperature of the bed.

Part of the fine particles of the bed are entrained by the flue gas into the convective section of the boiler island. The convective section of the boiler recovers heat from the exhaust gas to preheat boiler feedwater, generate superheated HP steam and reheat the cold steam flow rate coming from the steam turbine. Part of the exhaust energy of the exhaust gas is also used to preheat the combustion air in the regenerative air preheater (E-2001). The remaining part of the flue gas is used to partially heat the water necessary for the lignite drying (E-2005), thus increasing the overall efficiency of the plant.

The flue gas from the air preheater and the LP economizer are mixed together, with a resulting temperature of approximately 130°C. The flue gas then flows to the electrostatic precipitator (ESP-2001), for the removal of the fly ash carried out from the CFB boiler. Downstream the ESP, a flue gas induced draught fan (B-2003 A/B) blows the flue gas to the gas cooler (E-2004), where part of the low energy heat is used to preheat water, which is further sent to air preheaters of the CFB Boilers (E-2002 A/B).

Flue gases are finally discharged to the atmosphere at a temperature of approximately 85°C. The buoyancy for dispersion of the flue gas out from the stack could be improved by using a natural draft cooling tower instead of a dedicated stack. This alternative has been already implemented in some German brown coal power station and would not significantly affect the investment cost of the plant.

The heat recovery made on the low energy exhaust gas leads to an improvement of the plant electrical efficiency.

The main components of the circulating fluidized bed steam generator are described in the following paragraphs.

#### Combustion chamber

The main components of the combustion chamber are:

- Distribution grate;
- Water tubes combustion chamber.

The primary air comes to the distribution grate through the inner tube. The grate is made up by water tubes with several air nozzles, suitably oriented to fluidize the bed material, to prevent back flows and to move the spent bed material

towards the drain. These operations are made by an airflow rate above the minimum fluidization velocity of the bed. At partial load of the boiler, the primary airflow cannot be reduced under this minimum value, to make a proper fluidization of the solids bed.

The combustion chamber works at a relative low temperature (850-880 °C), which corresponds to the optimum condition to remove the sulphur and control the NO<sub>x</sub> emissions. For a further reduction of NO<sub>x</sub> emissions, ammonia is injected into the bed by means of dedicated nozzles, located above the combustion chamber.

The bottom of the bed, close to the distribution grate, is a high density and a high turbulence zone, where most of the combustion process occurs. The bed material is mainly made of support material like sand and limestone (approximately 95%), the remaining part being the burning coal. The main function of the bed material is to act as a thermal stabilizer, to allow the uniformity of the distribution temperature in the boiler.

Part of the combustion air is also sent above the grate. This is the secondary air, used to complete the staged combustion process and further reduce the NO<sub>x</sub> formation.

Water tubes cover the walls of the combustion chamber, in order to improve the heat transfer from flue gas and bed material to the water, generating steam at supercritical conditions.

#### Separators

The flue gas leaves the top of the combustion chamber and enters the solid separators cyclones located on both sides of the furnace, made of steam cooled refractory panels. The flue gas enters the cyclones with a whirling flow and the solid particles are separated by a centrifugal force. The particles of bigger size flow down along the walls toward the discharge section. A seal system allows the recirculation of these particles to the furnace or, alternatively, to the convective section. The ashes are fluidized by high-pressure air coming from the high-pressure blowers.

#### Convective heat recovery

Downstream solid separators, flue gas enters the convective heat recovery section, passing through the superheater, the reheater, the economizer and the combustion air preheater.

The superheater consists of different sections, suitable spaced, to avoid fouling problems and to allow a good ash discharge into the downstream hoppers. Spray

water desuperheaters control the steam temperature, using boiler feed water as moderator. After the superheating section, flue gas passes through the counter current reheaters, which increase the temperature of the steam from the HP section of the steam turbine. After the reheating section, flue gas flows to the economizer section and finally to the air preheater, which preheats both the primary and secondary air for the combustion process. This flue gas heat is recovered in a rotating tube bundles and transferred counter currently to the combustion air. The density of the heating surfaces is made to minimize pressure drop and avoid fouling.

#### Combustion air system

The primary air is taken from the atmosphere by means of two centrifugal fans (design capacity of each fan is 60% of the maximum load) and is blown to the distribution grate in order to fluidize the bed and to provide the required amount of combustion air. The control of the airflow rate is made by a Venturi tube and a control valve. A minimum airflow rate is necessary to allow a continuous fluidization of the bed, also at partial load.

The secondary air is blown by two dedicated blowers (design of each fan is 60% of the maximum load) above the distribution grate, in order to complete the combustion process and maintain a low NO<sub>x</sub> emission level. The secondary air is also partially used to pressurize the coal feeders and allow the inlet of the coal in the furnace.

For a proper combustion process, the oxygen content in the flue gas is maintained at 3% vol., dry basis.

High-pressure air is used to fluidize the solid material coming from the solid separation system, allowing the recirculation of the solids in the combustion chamber.

#### Auxiliary burners

Natural gas auxiliary burners are used during the start-up of the boiler. Burning natural gas, the bed material is preheated up to the ignition temperature. From this temperature on, the coal can be continuously fed to the combustion chamber and the auxiliary burners can be turned off. The start-up burners are placed in the combustion chamber walls, close to the fluid bed.

#### Soot Blowers

The soot blowers are used in the boilers to allow the cleaning of the heat exchange surfaces. Soot blowers are located in the convective section of the

boiler and can be either fixed or retractable. The soot blowers are motors driven. The ash removed is drag in the flue gas and falls in the hoppers, or is separated by the ESP.

The flue gas exits the furnace and crosses the convective heat recovery by the suction action of the two induced draft fans. At the top of the furnace, the pressure is maintained at 0.5 mbar below the ambient pressure.

A flue gas analysis is performed in order to control the composition (O<sub>2</sub>, CO, NO<sub>x</sub>, SO<sub>x</sub>) and check possible combustion inefficiencies.

#### De-NO<sub>x</sub> System

The SNCR system is provided to reduce the NO<sub>x</sub> produced during the combustion process to a level that does not exceed the limits of regulations. The possibility to use a water-ammonia solution at 25% weight allows to reduce the NO<sub>x</sub> emissions to a low level, without the use of a catalyst. The ammonia solution atomized by air is directly injected at the top of the furnace and in the solid separators via dedicated nozzles. This technical solution is simple and cheap. The ammonia solution is not dangerous and can be transported and handled in the plant.

#### Ash Handling:

The ash handling system takes care of conveying the ash generated in the boiler plant, e.g. the furnace bottom and fly ash from different hoppers.

The bottom ash are mainly made of calcium sulphate, unreacted calcium oxide, coal ash and unburned carbon coming from the bottom of the boilers. Bottom ash is humidified and transported by dedicated conveyors to the storage building, before final destination for disposal to the outside plant battery limits. Ashes are humidified to avoid dispersion in the ambient.

The fly ash are mainly made of unburned carbon, unreacted calcium oxide and coal ash. The Electro Static Precipitators (ESP) separates fly ash from exhaust flue gas. Fly ash is collected in hoppers and then pneumatically transported to the storage silos. Fly ash is fluidized by high-pressure air coming from the pressurization system. All the fly ash handling units are equipped with a filtration system in order to be insulated from ambient, thus avoiding dispersion to the atmosphere.

---

**IEA GHG**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 13 of 47

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

**1.1.3 Unit 3000: Steam Turbine and Preheating Line**

The following description makes reference to the process flow diagram of the power island attached to paragraph 1.2 of this section (PFD: 3000-1-50-3001).

The power island is a single train, mainly composed of one supercritical steam turbine and one preheating line. Supercritical steam from the two boilers is sent to the steam turbine (ST-3001), which consists of a HP, IP and LP section, all connected to the generator (SG-3001) on a single shaft. The steam turbine is a condensing type, with multiple extractions for the preheating of the condensate and boiler feedwater.

Main steam from the boiler passes through the stop valves and control valves and enters the turbine at 283 bar, 584°C. Steam from the exhaust of the HP turbine, except the flow extracted for the heating of the boiler feed water, is returned to the boiler gas path for reheating, and then throttled into the double flow IP turbine at 48 bar, 602°C.

Different extractions from the IP section at different conditions of steam pressure/temperature allow the preheating of the boiler feed water, while the low-pressure extraction is used to provide the steam necessary for the degassing of the condensate. Steam condensate recovered into the boiler feed water heaters (from E-3006 to E-3009) is recovered back to the deaerator (D-3001).

Part of the exhaust steam from the IP ST section, together with three extractions from the LP steam turbine, provide heat to the four condensate heaters downstream the condensate pumps (P-3001 A/B), before entering the deaerator.

Hot condensate from E-3004 is used to pre-heat the water in closed loop, which makes the pre-drying of the coal. Steam condensate from the first two preheaters (E-3002/3) is recovered back to the condenser. Condensate from the gland steam condenser (E-3001), upstream the condensate preheaters, is also recovered back to the condenser.

All the steam that is not used for preheating of the boiler feedwater/condensate flows to the LP steam turbine section and then downward into the water-cooled condenser (E-3010), at 0.032 bar (25°C).

Boiler feedwater exiting the deaerator is pumped to the economizers of the boilers by means of the boiler feedwater pumps (P-3003 A/B/C, two in operation and one common spare). The two pumps in normal operation are steam turbine driven, while the remaining one is motor driven.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 14 of 47

Chemical injection for control of the water quality is made by dedicated packages (Z-3001/Z-3002) on the suction of the boiler feedwater pumps and at the inlet of the boilers.

#### **1.1.4 Unit 4100 to 4500: Auxiliary units**

The process description of the auxiliary units is made in section C, paragraph 10.

The process flow diagram of the main auxiliary units is attached to paragraph 1.2 of this section (PFD 4100-1-50-4101).



---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 15 of 47


**Section G: Detailed Information for the Selected Technology**

---

**1.2 Process Flow Diagrams**


The Process Flow Diagrams of the following process units are attached to this paragraph:

- UNIT 1000: Coal handling and storage (PFD: 1000-1-50-1001)  
Limestone handling and storage (PFD: 1000-1-50-1002)
  
- UNIT 2000: Boiler Island with SNCR  
Electro Static Precipitators  
Limestone Injection (PFD: 2000-1-50-2001)
  
- UNIT 3000: Power Island consisting of  
Steam Turbine and Preheating Line (PFD: 3000-1-50-3001)
  
- UNIT 4100-4500: Utility and Offsite Units (PFD: 4100-1-50-4001)




COAL HANDLING

REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION	DWG. REV.	DATE
A		FIRST ISSUE	SF		
REVISIONS					
CFB BOILER WITHOUT CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			APPROVED FOR CONSTRUCTION		
			DWG. REV. DATE		
			SIGNATURE		
PROCESS FLOW DIAGRAM COAL HANDLING UNIT 1000			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		
			SCALE		
FOSTER WHEELER			SHEET OF		
THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH- OUT COMPENSATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT, OR OTHERWISE OR DIRECTLY OR INDIRECTLY FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.			FWI DWG N°		
			1000-1-50-1001		
			SHEET OF		
			REV. A		
CAD FILE NAME					




LIMESTONE HANDLING

REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION
A		FIRST ISSUE	SF
REVISIONS			
CFB-BOILER WITHOUT CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			DWG. REV. DATE
PROCESS FLOW DIAGRAM LIMESTONE HANDLING UNIT 1000			DATE
FOSTER WHEELER			SCALE
SHEET OF			REV.
1000-1-50-1002			A
SHEET OF			




LIGNITE DRYING

REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION
A		FIRST ISSUE	SF
REVISIONS CFB BOILER WITHOUT CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			APPROVED FOR CONSTRUCTION DWG. REV. DATE SIGNATURE
PROCESS FLOW DIAGRAM LIGNITE DRYING SYSTEM UNIT 1000			ORDER N° SUPPLIER CONTRACT N° FRAME N°
FOSTER WHEELER			CLIENT DWG N° SCALE
<small>THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH            OUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL            NOT BE REPRODUCED, COPIED, LENT, OR DISCLOSED OR DIRECTLY OR INDIRECTLY            FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY            FURNISHED. THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.</small>			SHEET OF DWG N° 1000-1-50-1003 SHEET OF
CAD FILE NAME			REV. A



REV.	DATE	DESCRIPTION	REVISED	BY	CHKD	APP.
A		FIRST ISSUE	SF			
REVISIONS						
CFB BOILER WITHOUT CO <sub>2</sub> CAPTURE						
IEA GHG R&D PROGRAMME						
PROCESS FLOW DIAGRAM						
BOILER ISLAND						
CFB-BOILER						
UNIT 1-2000						
APPROVED FOR CONSTRUCTION						
						DATE
						SIGNATURE
						DWG. REV.
						ORDER N°
						SUPPLIER
						CONTRACT N°
						FRAME N°
						CLIENT DWG N°
						SCALE
						SHEET
						OF
						REV.
						2000-1-50-2001
						A
FOSTER WHEELER						
THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH OUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, LOANED, OR OTHERWISE DISSEMINATED WITHOUT THE WRITTEN PERMISSION OF FOSTER WHEELER (ITALY). FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.						
CAD FILE NAME						


EL-2002





REV.	DATE	DESCRIPTION	REVISED	BY	CHKD	APP.
A		FIRST ISSUE	SF			
REVISIONS						
CFB BOILER WITHOUT CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME						
PROCESS FLOW DIAGRAM POWER ISLAND UNIT 3000						
APPROVED FOR CONSTRUCTION						DATE
SIGNATURE						
DRAWN BY						
SUPERVISOR						
CONTRACT N°						
FRAME N°						
CLIENT DWG N°						SCALE
SHEET						OF
FWJ DWG N°						REV.
3000-1-50-3001						A
SHEET						OF
CAD FILE NAME						

RAW-SERVICE-POTABLE WATER SYSTEMS  
(UNIT 4500)

DEMI WATER SYSTEM  
(UNIT 4200)



COOLING WATER AND MACHINERY COOLING WATER SYSTEMS  
(UNIT 4100)



REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION
A		FIRST ISSUE	SF
REVISIONS			
CFB BOILER WITHOUT CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			DWG. REV. DATE
PROCESS FLOW DIAGRAM AUXILIARY EQUIPMENT UNIT 4100			SUPPLIER
			CONTRACT N°
			FRAME N°
			CLIENT DWG N°
			SCALE
FOSTER WHEELER			SHEET OF
THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH OUT COOPERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT, OR OTHERWISE OR DIRECTLY OR INDIRECTLY FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED. THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.			REV. 4100-1-50-4001 A
CAD FILE NAME			SHEET OF

---

**IEA GHG**

Revision no.: Final

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

Date: Nov. 2005

Sheet: 16 of 47

**Section G: Detailed Information for the Selected Technology**

---


**1.3 Heat and Material Balances**

The Heat & Material Balances of the following process units are attached to this section:

- UNIT 1000: Storage and Handling of solid materials
- UNIT 2000: Boiler Island with SNCR based De-NO<sub>x</sub>  
Electro Static Precipitators (ESP)  
Limestone Injection
- UNIT 3000: Power Island, consisting of  
Steam Turbine and Preheating Line

Stream numbers are as shown on the process flow diagrams attached to paragraph 1.2 of this section.




 <b>FOSTER WHEELER</b>	CFB HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CFB without CO<sub>2</sub> Capture</b>						APPROVED	LM		
	<b>UNIT : 1000 Solid materials storage and handling</b>						DATE	Nov-05		
STREAM	1	2	3	4	5	6	7	8	9	10
	Wet Coal to Lignite Drying System (1)	Dry Coal to Boiler Island UNIT 2000 (1)	Air intake from atmosphere for Lignite Drying (1)	Cold Water in Close Loop (1)	Hot Water in Close Loop (1)	Wet Air to Atmosphere				
Temperature (°C)	AMB	AMB	6	65	85	65				
Pressure (bar)	ATM	ATM	AMB	3	3	ATM				
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	592883	429840	908820	5290600	5290600	1071865				
Molar flow (kgmole/h)			31458	293759	293759	40513				
	Moisture 50.70%	Moisture 32%								
Composition wt% with moisture										
Carbon	31.33%	43.20%								
Hydrogen	2.29%	3.16%								
Oxygen	11.56%	15.94%								
Sulfur	0.22%	0.31%								
Nitrogen	0.37%	0.51%								
Chlorine	0.03%	0.05%								
Moisture	50.70%	32.00%								
Ash	3.50%	4.83%								

Note (1): All the enclosed data are for two CFB boilers in parallel

FOSTER WHEELER	CFB HEAT AND MATERIAL BALANCE											REVISION	0	1	
	CLIENT : IEA GREEN HOUSE R & D PROGRAMME											PREP.	SR		
	CASE : CFB without CO <sub>2</sub> Capture											APPROVED	LM		
	UNIT : 2000 Boiler Island											DATE	Nov-05		
STREAM	1-4	5	6	7	8	9	10	11	12	13-14	15	16	Sheet 1 of 2		
	Coal from UNIT 1000 (2)	Primary Air (2)	Secondary Air (2)	High pressure Air (2)	Flue Gas From Boiler to Stack (2)	HP Boiler Feed Water from Preheating line UNIT 3000 (2)	HP Steam to Steam Turbine (2)	IP Steam from Preheating Line UNIT 3000 (2)	IP Reheated Steam to Steam Turbine (2)	Limestone injection (1)-(2)	Cold Water from Lignite Drying UNIT 1000 (2)	Hot Water to Lignite Drying UNIT 1000 (2)			
Temperature (°C)	AMB	15	15	15	85	272	584	319	602	AMB	80	85			
Pressure (bar)	ATM	1.23	1.13	1.61	1.03	313	283	51	48	ATM	3	3			
<b>TOTAL FLOW</b>															
Mass flow (kg/h)	592883	1867900	925400	119750	3361176	2182000	2182000	2016000	2016000	22690	5290600	5290600			
Molar flow (kgmole/h)		64656	32032	4145	116023	121155	121155	111938	111938		293759	293759			
<b>LIQUID PHASE</b>															
Mass flow (kg/h)	0	0	0	0	0	2182000					5290600	5290600			
<b>GASEOUS PHASE</b>															
Mass flow (kg/h)		1867900	925400	119750	3361176	0	2182000	2016000	2016000		0	0			
Molar flow (kgmole/h)		64656	32032	4145	116023	0	121155	111938	111938		0	0			
Molecular Weight		28.89	28.89	28.89	28.97	18.01	18.01	18.01	18.01		18.01	18.01			
Composition (vol %)	See UNIT 1000														
N <sub>2</sub>		77.57%	77.57%	77.57%	68.14%	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
CO <sub>2</sub>		0.00%	0.00%	0.00%	13.51%	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
H <sub>2</sub> O		0.68%	0.68%	0.68%	13.70%	100%	100%	100%	100%		100%	100%			
O <sub>2</sub>		20.86%	20.86%	20.86%	3.88%	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
Ar		0.89%	0.89%	0.89%	0.77%	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
NO <sub>x</sub>		0.00%	0.00%	0.00%	98 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
SO <sub>x</sub>		0.00%	0.00%	0.00%	70 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			
CO		0.00%	0.00%	0.00%	120 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%		0.00%	0.00%			

Note (1): Limestone Analysis (wt%) CaCO<sub>3</sub> = 95% - MgCO<sub>3</sub> = 3.4% - Inert = 1.6%  
Note (2): All the enclosed data are for two CFB boilers in parallel

 <b>FOSTER WHEELER</b>	CFB HEAT AND MATERIAL BALANCE						REVISION	0	1	
	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CFB without CO<sub>2</sub> Capture</b>						APPROVED	LM		
	<b>UNIT : 2000 Boiler Island</b>						DATE	Nov-05		
<b>STREAM</b>	17	18	19	20	21	22	23	24	25	26
	Cooling Water Inlet (2)	Cooling Water outlet (2)	Bottom Ash to UNIT 1000 (2)	Fly Ash to UNIT 1000 (2)						
<b>Temperature (°C)</b>	11	21	6	6						
<b>Pressure (bar)</b>	3	3	AMB	AMB						
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	104000	104000	12240	28800						
Molar flow (kgmole/h)	5775	5775								
<b>LIQUID PHASE</b>										
Mass flow (kg/h)	104000	104000								
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)	0	0								
Molar flow (kgmole/h)	0	0								
Molecular Weight	18.01	18.01								
Composition (vol %)										
N <sub>2</sub>	0.00%	0.00%								
CO <sub>2</sub>	0.00%	0.00%								
H <sub>2</sub> O	100%	100%								
O <sub>2</sub>	0.00%	0.00%								
Ar	0.00%	0.00%								
NO <sub>x</sub>	0.00%	0.00%								
SO <sub>x</sub>	0.00%	0.00%								
CO	0.00%	0.00%								

Note (2): All the enclosed data are for two CFB boilers in parallel

**CFB HEAT AND MATERIAL BALANCE**

CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME

CASE : CFB without CO<sub>2</sub> Capture

UNIT : 3000 Steam Turbine &amp; Preheating Line

Sheet 1 of 1

Stream	Description	Flowrate t/h	Temperature °C	Pressure bar a	Entalphy kJ/kg
1	HP Water to Boiler Island	2182	272	313	1191
2	HP Steam from Boiler	2182	584	283	3413
3	IP Steam to Boiler	2016	319	51	2978
4	IP hot reheated steam to Steam Turbine	2016	602	48	3673
5	IP Steam Turbine exhaust	1620	287	5.5	3037
6	LP Steam to Steam Turbine	1414	287	5.5	3037
7	Steam to Condenser	1286	25	0.032	2288
8	Condensate	1423	25	0.032	106
9	LP Preheated Condensate	1748	156	13	658
10	Condensate to HP FWH (Deaer. Outlet)	2182	175	9	742
11	BFW Pump Delivery	2182	181	315	783
12	1st HP Extraction to E-3008	78	338	59	3011
13	2nd HP Extraction to E-3007	88	318	51	2978
14	1st MP Extraction to E-3009 and E-3006	194	535	32	3535
15	2nd MP Extraction to Deaer. And ST BFW Pump	201	356	9	3172
16	3rd MP Extraction to E-3005	206	287	5.5	3037
17	1st LP Extraction to E-3004	89	220	2.8	2907
18	2nd LP Extraction to E-3003	80	114	0.9	2706
19	3rd LP Extraction to E-3002	86	67	0.3	2533
20	Hot Condensate to Lignite Drying UNIT 1000	1748	130	15	548
21	Cold Condensate from Lignite Drying UNIT 1000	1748	84	13	353
22	Cooling water Inlet	67122	11	3	47
23	Cooling water Outlet	67122	21	2	88

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 17 of 47

#### **1.4 Utility Consumption**

The utility consumption of the process/utility and offsite units are shown in the attached tables.



CLIENT: IEA GHG  
 PROJECT: GASIFICATION POWER GENERATION STUDY  
 LOCATION: Germany  
 FWI N°: 1BD0237A

Rev 0  
 Nov-05  
 ISSUED BY: SR.  
 CHECKED BY: LM  
 APPR. BY: RD

**ELECTRICAL CONSUMPTION SUMMARY - CFB without CO<sub>2</sub> Capture**

UNIT	DESCRIPTION UNIT	Absorbed Electric Power [kW]
<b>PROCESS UNITS</b>		
1000	Solid Materials Storage and Handling	
	Coal Conveyors and Feeders	630
	Coal Milling and Powder control System	280
	Lignite Drying System	565
	Limestone Conveyors	50
	Limestone Milling and Powder control System	100
	<b>PARTIAL TOTAL</b>	<b>1625</b>
2000	Boiler Island	
	Primary Air Fans	13200
	Secondary Air Fans	3170
	Induced Draught Fans	8950
	High Pressure Blowers	2050
	Bottom Ash Handling	105
	Fly Ash Handling and Storage	140
	Miscellanea	730
	<b>PARTIAL TOTAL</b>	<b>28345</b>
<b>POWER ISLANDS UNITS</b>		
3000	Steam Turbine and Preheating line	
	Steam Turbine	1000
	Condensate Extraction Pumps	600
	Condensate Pump	30
	<b>PARTIAL TOTAL</b>	<b>1630</b>
<b>UTILITY and OFFSITE UNITS</b>		
4100	Cooling Water and Machinery Cooling Water System	
	Cooling Towers - Condenser - Process Units - Utilities	12870
	Cooling Towers - Machinery Cooling Water	160
	Cooling Towers - Make-Up	145
4200	Demi Water System	10
4300	Natural Gas Start-Up System	0
4400	Plant and Instrument Air System	1200
4500	Raw / Service / Potable Water System	255
	Miscellanea	1400
	<b>PARTIAL TOTAL</b>	<b>16040</b>
	<b>GRAN TOTAL</b>	<b>47640</b>







**1.5 CFB Overall Performances**

The following table shows the overall performance of the CFB complex.

<b>CFB without CO<sub>2</sub> Capture</b>		
<b>OVERALL PERFORMANCES OF THE CFB COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	592.9
Coal LHV (A.R.)	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>1729.3</b>
Steam turbine power output (@gen. Terminals)	MWe	841.9
<b>GROSS ELECTRIC POWER OUTPUT OF CFB COMPLEX (D)</b>	<b>MWe</b>	<b>841.9</b>
Coal Storage / Handling	MWe	1.6
Boiler Island	MWe	28.3
Power Island	MWe	1.6
Utilities	MWe	16.0
<b>ELECTRIC POWER CONSUMPTION OF CFB COMPLEX</b>	<b>MWe</b>	<b>47.6</b>
<b>NET ELECTRIC POWER OUTPUT OF CFB (C)</b>		
Step-Up Transformer Efficiency (0.997)	MWe	791.8
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>48.7%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>45.8%</b>

## 1.6 Environmental Impact

The CFB complex is designed to process coal and produce electric power. The advanced technology allows to reach a high efficiency and to minimise the environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the CFB complex are summarised in this section.

### 1.6.1 Gaseous Emissions

#### Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases leaving the stack.

Table 1.6.1 summarises expected flow rate and concentration of the combustion flue gas.

**Table 1.6.1** – Expected gaseous emissions from the CFB plant.

	Normal Operation
Wet gas flow rate, kg/s	934
Flow, Nm <sup>3</sup> /h	2600540
Temperature, °C	85
Composition	(%vol)
N <sub>2</sub>	68.91
O <sub>2</sub>	3.88
CO <sub>2</sub>	13.51
H <sub>2</sub> O	13.70
Emissions	mg/Nm <sup>3</sup> <sup>(1)</sup>
NO <sub>x</sub>	200
SO <sub>x</sub>	200
CO	150
Particulate	30

(1) Dry gas, O<sub>2</sub> content 6% vol

In normal operation at full load, the following emission to the atmosphere is foreseen from the coal drying process:

Flow rate : 1072 t/h  
 Particulate : 21 kg/h

### Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by routing all vents to a bag filter.

### **1.6.2 Liquid Effluent**

The plant would be designed for zero contaminated liquid effluents. All the liquid effluents are treated in the wastewater treatment system in order to be discharged in accordance with the current regulations.

The liquid effluents generated in the power plant are mainly the following:

- Rain water contaminated by powder;
- Wash water contaminated by oil and powder;
- Cooling towers blowdown;
- Eluates from demineralizing water system;
- Sanitary water.

As the handling and storage systems of the solid materials are insulated from the ambient, to limit the powder dispersion, the meteoric water treatment could be avoided. In any case, it is preferable to collect the rainwater from the buildings and storage areas to the chemical/physical water treatment.

The wash water from the equipment washing is also collected and routed to the water treatment as it can be contaminated by oil and powder.

The cooling towers blowdown and the eluates from the demi water system are not contaminated by any pollutant and therefore can be directly discharged to the receiving basin, without any treatment.

The sanitary water from sanitary fittings, containing biodegradable pollutants, is routed to a collection basin and then to the biological water treatment, for the oxidizing process.

The water treatment includes the physical pre-treatment with settling, deoiling and filtration systems, the biological oxidation and the chemical treatment of clariflocculation. In the settling and deoiling phases the solids (particulate, tar, carbon residues) heavier than water, are collected on the bottom of the collection basin, while oils, lighter than water, are separated on the surface and routed to the oil drain well. The water is then filtered in coke filters and routed,

through pumps, to the biological treatment for the biological oxidation. The oxidation process is accelerated by the addition of activated carbons. The water is finally routed to the clariflocculation system for the final purification and then to the plant battery limits.

### **1.6.3 Solid Effluent**

The power plant is expected to produce the following solid by-products:

#### Fly Ash

Flow rate : 28.8 t/h

#### Bottom Ash

Flow rate : 12.2 t/h

Fly and bottom ash are used as bed filling and returned back to the mine or dispatched to cement industries, if available in the neighbours.

The Calcium Sulphate is not a pure product and cannot be sold as pure gypsum.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 22 of 47

### **1.7 Equipment List**

The list of the main equipment and process packages are included in this section.



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COAL SYSTEM</b>									
		The coal handling and storage system includes: - Stacker reclaimers - Coal conveyors - Coal mills - Filters - Fans		Capacity: 635 t/h					
<b>BOTTOM ASH SYSTEM</b>									
		The bottom ash handling and storage system includes - Ash storage silos - Ash conveyors - Clinker crusher - Filters - Fans		Capacity: 18 t/h					
<b>FLY ASH SYSTEM</b>									
		The fly ash handling and storage system includes - Ash storage silos - Pneumatic conveying system - Compressors - Filters - Fans		Capacity: 26 t/h					
<b>LIMESTONE SYSTEM</b>									
		The limestone handling and storage system includes - Limestone reclaimers area - Limestone conveyors - Limestone mills - Filters - Fans		Capacity: 25 t/h					



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>CONVEYORS</b>									
		<b>Coal Handling</b>							
1	CR-1001 A/B	Coal Conveyor							
1	CR-1002 A/B	Coal Elevator							
1	CR-1003 A/B	Coal Conveyor							
1	CR-1004 A/B	Coal Conveyor							
1	CR-1005 A/B	Coal Conveyor							
1	CR-1006 A/B	Coal Conveyor							
1	CR-1007 A/B	Coal Conveyor							
1	CR-1008 A/B	Coal Conveyor							
1	CR-1009 A/B	Coal Conveyor							
1	CR-1010 A/B	Coal Conveyor							
1	CR-1011	Coal Conveyor							
1	CR-1012	Coal Conveyor							
1	CR-1013	Coal Bucket Elevator							
		<b>Bottom Ash Handling</b>							
1/2		Bottom Ash Conveyor							
1/2		Bottom Ash Elevator							
2/2		Bottom Ash Conveyor							
2/2		Bottom Ash Elevator							
		<b>Fly Ash Handling</b>							
1/2		Fly Ash Conveyor							
1/2		Fly Ash Roller Transfer to Recirculation Silc							
1/2		Fly Ash Roller Transfer to Storage							
2/2		Fly Ash Conveyor							
2/2		Fly Ash Roller Transfer to Recirculation Silc							
2/2		Fly Ash Roller Transfer to Storage							
		<b>Limestone Handling</b>							
1	CR-1014	Limestone Conveyor							
1	CR-1015	Limestone Elevator							
1	CR-1016	Limestone Conveyor							
1	CR-1017	Limestone Conveyor							
1	CR-1018	Limestone Conveyor							
1	CR-1019	Limestone Conveyor							
1	CR-1020	Limestone Elevator							
1	CR-1021	Limestone Conveyor							
1	CR-1022	Limestone Conveyor							
1	CR-1023	Limestone Conveyor							
1	CR-1024	Limestone Conveyor							
1	CR-1025	Limestone Conveyor							
1	CR-1026	Limestone Conveyor							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>MILLING</b>									
1	SCR-1001 A/B	<b>Coal Milling</b> Coal Screen Grinder							
1/2		<b>Bottom Ash Crushing</b> Bottom Ash Screen Grinder							
2/2		Bottom Ash Screen Grinder							
1	SCR-1002 A/B	<b>Limestone Milling</b> Limestone Screen Grinder							
<b>STORAGE</b>									
1	X-1001	<b>Coal Storage</b> Coal Discharging Hopper							
1	X-1002	Coal Storage							
1/2		<b>Bottom Ash Storage</b> Bottom Ash Silo							
1/2		Bed Filling Material Silo							
1/2		Plenum tanks							
2/2		Bottom Ash Silo							
2/2		Bed Filling Material Silo							
2/2		Plenum tanks							
1/2		<b>Fly Ash Storage</b> Fly Ash Storage							
1/2		Fly Ash Recirculation Silo							
2/2		Fly Ash Storage							
2/2		Fly Ash Recirculation Silo							
1	X-1003	<b>Limestone Storage</b> Limestone Discharging Hopper							
1	X-1004	Limestone Storage							
<b>FILTERS</b>									
1	F-1001	Coal Dust Filter							
1	F-1002	Coal Dust Filter							
1/2	1-F-1001 A/B	Bottom Ash Dust Filter							
2/2		Bottom Ash Dust Filter							
1/2		Fly Ash Exhaust Filter							
2/2		Fly Ash Exhaust Filter							
1	F-1003	Limestone Dust Filter							
1	F-1004	Limestone Dust Filter							





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>FANS</b>									
1	B-1001	Coal Exhaust Fan							
1	B-1002	Coal Exhaust Fan							
1/2		Bottom Ash Exhaust Fan							
2/2		Bottom Ash Exhaust Fan							
1/2		Fly Ash Exhaust Fan							
2/2		Fly Ash Exhaust Fan							
1	B-1003	Limestone Exhaust Fan							
1	B-1004	Limestone Exhaust Fan							
<b>COMPRESSORS</b>									
1/2		Compressor for Fly Ash pneumatic Handling to Storage							
1/2		Compressor for Fly Ash pneumatic Handling to Recirc. Silo							
2/2		Compressor for Fly Ash pneumatic Handling to Storage							
2/2		Compressor for Fly Ash pneumatic Handling to Recirc. Silo							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanic  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N:

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 2000 - Boiler Island - CFB without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>BOILERS</b>									
1/2	1-C-2001	Supercritical CFB Boiler		MCR: SH: 1090 t/h RH: 1010 t/h		MCR: 285 bar 51 bar	Feed Water 275°C 585 °C 600 °C		Boiler Package including: - Coal Silos - Limestone Silos - Coal Screw Feeders - Coal Burners (1-BR-2001 A-N) - Regenerative Air Preheater - Hot Water Air Preheater - Bottom Ash Coolers - High Pressure Blowers - Air Fans - Flue Gas Induced Draught Fans - Desuperheaters - Start-Up System - Electrostatic Precipitators ESP - Continuous Emission monitoring System - Ammonia Storage and Injection Package - Stack
2/2	2-C-2001	Supercritical CFB Boiler		MCR: SH: 1090 t/h RH: 1010 t/h		MCR: 285 bar 51 bar	Feed Water 275°C 585 °C 600 °C		Boiler Package including: - Coal Silos - Limestone Silos - Coal Screw Feeders - Coal Burners (2-BR-2001 A-N) - Regenerative Air Preheater - Hot Water Air Preheater - Bottom Ash Coolers - High Pressure Blowers - Air Fans - Flue Gas Induced Draught Fans - Desuperheaters - Start-Up System - Electrostatic Precipitators ESP - Continuous Emission monitoring System - Ammonia Storage and Injection Package - Stack



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 2000 - Boiler Island - CFB without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>FANS</b>									
1/2	1-B-2001 A/B	Primary Air Fans		m=165 kg/s; H=22000 Pa	4000 kW				Included in 1-C-2001
1/2	1-B-2002 A/B	Secondary Air Fans		m=84 kg/s; H=12000 Pa	1100 kW				Included in 1-C-2001
1/2	1-B-2003 A/B	Flue Gas Induced Draught Fans		m=285 kg/s; H=8100 Pa	3700 kW				Included in 1-C-2001
1/2	1-B-2004 A/B/C/D	High Pressure Blowers		m=9 kg/s; H=60000 Pa	580 kW				Included in 1-C-2001
2/2	2-B-2001 A/B	Primary Air Fans		m=165 kg/s; H=22000 Pa	4000 kW				Included in 2-C-2001
2/2	2-B-2002 A/B	Secondary Air Fans		m=84 kg/s; H=12000 Pa	1100 kW				Included in 2-C-2001
2/2	2-B-2003 A/B	Flue Gas Induced Draught Fans		m=285 kg/s; H=8100 Pa	3700 kW				Included in 2-C-2001
2/2	2-B-2004 A/B/C/D	High Pressure Blowers		m=9 kg/s; H=60000 Pa	580 kW				Included in 2-C-2001
<b>HEAT EXCHANGERS</b>									
1/2	1-E-2001	Regenerative Air Preheater							Included in 1-C-2001
1/2	1-E-2002 A/B	Hot Water Air Preheater							Included in 1-C-2001
1/2	1-E-2003 A/B...I/L	Bottom Ash Coolers							Included in 1-C-2001
1/2	1-E-2004	Flue Gas Cooler							
1/2	1-E-2005	LP-Economizer							
2/2	2-E-2001	Regenerative Air Preheater							Included in 2-C-2001
2/2	2-E-2002 A/B	Hot Water Air Preheater							Included in 2-C-2001
2/2	2-E-2003 A/B...I/L	Bottom Ash Coolers							Included in 2-C-2001
2/2	2-E-2004	Flue Gas Cooler							
2/2	2-E-2005	LP-Economizer							
<b>SILOS</b>									
1/2	1-D-2005	Coal Silo							Included in 1-C-2001
1/2	1-D-2006	Coal Silo							Included in 1-C-2001
1/2	1-D-2007	Coal Silo							Included in 1-C-2001
1/2	1-D-2008	Coal Silo							Included in 1-C-2001
1/2	1-D-2009	Limestone Silo							Included in 1-C-2001
1/2	1-D-2010	Limestone Silo							Included in 1-C-2001
2/2	2-D-2005	Coal Silo							Included in 2-C-2001
2/2	2-D-2006	Coal Silo							Included in 2-C-2001
2/2	2-D-2007	Coal Silo							Included in 2-C-2001
2/2	2-D-2008	Coal Silo							Included in 2-C-2001
2/2	2-D-2006	Limestone Silo							Included in 2-C-2001
2/2	2-D-2007	Limestone Silo							Included in 2-C-2001



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanic  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 2000 - Boiler Island - CFB without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>START-UP SYSTEM</b>									
1/2		Water-Steam Separators							Included in 1-C-2001
1/2		Start-up Tank							Included in 1-C-2001
1/2		Flash Tank							Included in 1-C-2001
1/2		Blow-Down Tank							Included in 1-C-2001
1/2		Drainage Tank							Included in 1-C-2001
1/2		Recirculation Pump							Included in 1-C-2001
1/2		Drainage Transfer Pump							Included in 1-C-2001
2/2		Water-Steam Separators							Included in 2-C-2001
2/2		Start-up Tank							Included in 2-C-2001
2/2		Flash Tank							Included in 2-C-2001
2/2		Blow-Down Tank							Included in 2-C-2001
2/2		Drainage Tank							Included in 2-C-2001
2/2		Recirculation Pump							Included in 2-C-2001
2/2		Drainage Transfer Pump							Included in 2-C-2001
<b>DESUPERHEATERS</b>									
1/2		HP Steam Desuperheater							Included in 1-C-2001
1/2		By-Pass Desuperheater							Included in 1-C-2001
1/2		Reheated Steam Desuperheater							Included in 1-C-2001
2/2		HP Steam Desuperheater							Included in 2-C-2001
2/2		By-Pass Desuperheater							Included in 2-C-2001
2/2		Reheated Steam Desuperheater							Included in 2-C-2001
<b>FEEDERS</b>									
1/2	1-FD-2001 A/B...E/F	Coal Screw Feeders							Included in 1-C-2001
1/2	1-FD-2002 A/B...E/F	Coal Screw Feeders							Included in 1-C-2001
2/2	2-FD-2001 A/B...E/F	Coal Screw Feeders							Included in 2-C-2001
2/2	2-FD-2002 A/B...E/F	Coal Screw Feeders							Included in 2-C-2001



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev 0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 3000 - Power Island - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>STEAM TURBINE</b>									
1	ST-3001	Steam Turbine		886 MWe SH: 285 bar; 585 °C RH: 48 bar; 600°C Cond: 0.032 bar					Steam Turbine Package Including: - Master Controller - By-pass System - By-pass Logic Controller - Ejectors - Silencer
<b>GENERATOR</b>									
1	SG-3001	Generator		886 MWe					Generator Package Including: - Cooling System with Hydrogen - Start-up System - Vibration Control System
<b>HEAT EXCHANGERS</b>									
				<b>Duty</b>					
1	E-3001	Gland Steam Condenser		600 kW					
1	E-3002	LP Feedwater Heater 1		47090 kW					
1	E-3003	LP Feedwater Heater 2		44440 kW					
1	E-3004	LP Feedwater Heater 3		58590 kW					
1	E-3005	LP Feedwater Heater 4		60990 kW					
1	E-3006	HP Feedwater Heater 1		63000 kW					
1	E-3007	HP Feedwater Heater 2		64450 kW					
1	E-3008	HP Feedwater Heater 3		50900 kW					
1	E-3009	HP Feedwater Heater 4		82200 kW					
1	E-3010	Steam Condenser		857560 kW					Delta T Cooling Water = 10 °C
<b>PUMPS</b>									
1	P-3001 A/B	Condensate Extraction Pump		Q=750 m <sup>3</sup> /h; H=130 m	355 kW				
1	P-3002 A/B	Condensate Pump		Q=80 m <sup>3</sup> /h; H=100 m	30 kW				
1	P-3003 A	Steam Turbine Driven BFW Pump		Q=2180 m <sup>3</sup> /h; H=3700 m					In operation - Steam Turbine Driven
1	P-3003 B	Motor Driven BFW Pump		Q=2180 m <sup>3</sup> /h; H=3700 m	28000 kW				Spare - Electric Motor Driven
1	P-3004	Drain Pump		Q=25 m <sup>3</sup> /h; H=10 m	7.5 kW				
1	P-3005 A/B	Vacuum Pumps							Included in Steam Turbine Auxiliaries
<b>TANKS</b>									
1	D-3001	Deaerator							
1	D-3002	ST Drain Drum							
<b>CHEMICAL INJECTION PACKAGE</b>									
1	Z-3001	Chemical Injection Package							
1	Z-3002	Chemical Additives							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 4000 - Cooling Water and Machinery Cooling Water System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COOLING TOWERS</b>									
1/2	1-TR-4001	Cooling Towers	Natural Draught						Package Including: - Distribution System - Heat Exchangers - Water Conditioning
2/2	2-TR-4001	Cooling Towers	Natural Draught						Package Including: - Distribution System - Heat Exchangers - Water Conditioning
<b>PACKAGES</b>									
1/2	1-PK-4001	Water Conditioning Package							Package Including: - Chemical Additives Storage Tanks - Chemical Additives Dosing Pumps
2/2	2-PK-4001	Water Conditioning Package							Package Including: - Chemical Additives Storage Tanks - Chemical Additives Dosing Pumps
<b>PUMPS</b>									
1	P-4001 A/B/C/D	Cooling Water Pump		m <sup>3</sup> /h x m	3300 kW				All Operating - Electric Motor Driven One operating and one spare- Electric Motor Driven
1	P-4002 A/B	Machinery Cooling Water Pump		19400x55 900x40	80 kW				
<b>BASINS</b>									
1/2	1-BA-4001	Cooling Water Basin							
2/2	2-BA-4001	Cooling Water Basin							
<b>FILTERS</b>									
1/2	1-F-4001	Filter							
2/2	2-F-4001	Filter							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 4100 - Demi Water System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4101	Demi Water Production System		2 lines 30 m <sup>3</sup> /h each					Package Including: - Neutralized Effluents Discharge Pump - Cationic Column - Decarbonation Tower - Decarbonation Tower Pump - Decarbonation Tower Fan - HCl System - NaOH System - Anionic Column - Neutralization Tank
<b>PUMPS</b>									
				<b>m<sup>3</sup>/h x m</b>					
1	P-4101 A/B	Demi Water Distribution Pump		30x60	12				
1	P-4102	Filling Pump		125x25	15				During Star-Up
<b>DRUMS</b>									
				<b>D(m)xH(m)</b>					
1	D-4101	Demi Water Storage Collection Basin		12x18					Volume = 2000 m <sup>3</sup>



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 4200 - Raw-Service-Potable Water System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4201	Clariflocculation System							Package Including: - Clariflocculator - Sludge Pump - Membrane Press - Recirculation Water System - Filtered Water System
1	PK-4202	Water Conditioning System							
1	PK-4203	Additives Package							
<b>PUMPS</b>									
				<b>m<sup>3</sup>/h x m</b>					
1	P-4201 A/B/C	Raw Water Pump		645x36	75 kW				Two operating - one spare
1	P-4202 A/B	Service Water Pump		50x40	5.5 kW				
1	P-4203 A/B	Cooling Towers Make-Up Pump		620x36	72.5 kW				
1	P-4204 A/B	Service Water Booster Pump		50x40	5.5 kW				
<b>DRUMS</b>									
				<b>D(m)xH(m)</b>					
1	BA-4201	Raw Water Pumping Basin							Volume = 600 m <sup>3</sup>
1	D-4201	Service Water Collection Basin		8x12					
<b>FILTERS</b>									
1	F-4201 A/B	Sand Filter							
1	F-4202 A/B...I/L	Sand Filter							





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 4300 - Plant Instrument Air System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COMPRESSORS</b>									
1	K-4301 A/B	Air Compressor		52500 Nm <sup>3</sup> /h	660 kW				Two operating and one spare - Electrical Motors Included
<b>DRUMS</b>									
1	D-4301	Compressed Air Drum							
<b>DRYER</b>									
1	DR-4301	Instrument Air Dryer							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 4400 - Natural Gas Start-Up System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4401	Natural Gas Reduction and Metering Station							Package Including: - Filter - Preheating System - Flow Indicator - Reduction Valves



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germanie  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N.

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 4500 - Fire Fighting System - CFB Boiler without CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4501	Fire Water Distribution System							Package Including: - Pressurization Pump - Fire Fighting Water Pump Electrical Motor Driven Q=610 m <sup>3</sup> /h - Fire Fighting Water Pump Diesel Motor Driven Q=610 m <sup>3</sup> /h
1	PK-4502	Relieving and Extinguishing System							Package Including: - Deluge System - Outdoor Hydrants - Portable Equipment - Fire Detector - Smoke Detector - No Toxic Gas Flooding System

**SECTION G.2 CFB boiler with CO<sub>2</sub> Capture****2.0 Summary**

Purpose of this section G.2 is to provide a more detailed set of technical information for the CFB alternative, based on the Foster Wheeler's technology, with the CO<sub>2</sub> capture, which was already investigated in section D.3.

In this case, the performances of the plant are slightly different from those already shown in section D.3, due to the investigation made with one steam turbine supplier, which suggested the following main modifications on the design of the steam turbine:

- Marginal decrease of the efficiency of the LP steam turbine section;
- Reduction of the number of steam extractions from the IP section, so to use a steam turbine design that is similar to that of a conventional power plant.

With reference to the latter point, to reduce the number of steam extractions, part of the heat required for the heating of the boiler feed water is now directly taken from the cold reheat of the HP section, instead of using a dedicated steam extraction from the IP section. This allows to simplify the design of the steam turbine, but results in a loss of power production and a marginal decrease of the plant net electrical efficiency.

The same considerations were also applied to the alternative of the CFB boiler without the CO<sub>2</sub> capture, developed in section G.1.

It has to be noted that, applying these modifications to the USC-PC alternative developed in section D.1, the reduction of the net electrical efficiency of the plant would approximately be 0.6%, as per this case. Therefore, the analysis performed in section F is not affected by the modifications made on the steam turbine design, remaining the CFB alternative the most promising technology for the CO<sub>2</sub> capture in a lignite coal power plant.

## 2.1 Process Description

The configuration of the CFB complex is based on two supercritical once through steam generators, with amine wash for CO<sub>2</sub> absorption and CO<sub>2</sub> compression unit.

Reference is made to the attached Overall Block Flow Diagram of the CFB power plant.


The arrangement of the process units is the following:

### Unit

1000	Storage and handling of solid materials, including Coal handling and storage Coal pre-drying system Limestone handling and storage
2000	Boiler island with SCR based DeNO <sub>x</sub> , Limestone injection and Electro Static Precipitators (ESP) Ash and solid removal
3000	Power island, consisting of Steam Turbine and Preheating Line
4000	CO <sub>2</sub> capture plant
5000	CO <sub>2</sub> compression and drying
4100-4500	Utility and Offsite Units

Note: 'Coal' referred to in all the following sections means 'low rank coal' as defined in the BEDD document.

# CFB with CO<sub>2</sub> Capture Overall Block Flow Diagram



**2.1.1 Unit 1000: Solid Materials Storage – Handling and Lignite Drying**
Coal handling and storage

The process flow diagram of the coal handling unit is attached to paragraph 2.2 of this section (PFD: 1000-1-50-1001).

The process description of this unit does not differ from that made for the alternative without CO<sub>2</sub> capture (section G.1, paragraph 1.1.1).

Coal pre-drying:

The process flow diagram of the drying unit is attached to paragraph 2.2 of this section (PFD: 1000-1-50-1003).

This unit is mainly composed of two parallel trains, each sized for 50% of the rated capacity.

Pre-drying of the coal is made to improve the plant performances, exploiting the large amount of low temperature heat that is available from the downstream CO<sub>2</sub> capture and compression units, also avoiding the use of large cooling water flow rates.

Coal from the coal-handling unit is conveyed to the lignite drying system and fed to the fluidized bubbling bed. The air necessary to fluidize the bed and dry the lignite is blown by a dedicated air fan (B-1001 A/B). Air is first pre-heated in the air preheater (E-2001) and then fed to the bubbling bed (FB-1001). Air is preheated against hot water that circulates in closed loop through the different units of the plant, recovering heat from various sources.

In particular, the exploited low temperature heat sources are:

- Part of the flue gases leaving the CFB boiler after the SCR system (26 MWth);
- Overhead stripper condenser of the CO<sub>2</sub> capture plant; (72 MWth)
- Intercooling system of the CO<sub>2</sub> compression unit (26 MWth).

A more detailed scheme of the heat integration is also shown in the process flow diagram of the CO<sub>2</sub> compression unit, attached to paragraph 2.2 of this section (PFD: 5000-1-50-5001).

Part of the hot water in closed loop is also sent to the water coils submerged in the fluidized bed. The heat contained in the hot water completes the lignite drying and allows to maintain the bed at constant temperature.

The air crossing the fluid beds partially removes the moisture content of the coal and is then diverted to a dust filter, which reduces the entrained amount of ash, before discharge to the atmosphere. The coal ash collected in the filter is finally sent to the fly ash handling and storage system.

The dry coal at 32% wt of moisture content is discharged in the hopper (X-1001) and sent to the CFB boiler island, by using dedicated coal conveyors (CR-1001 A/B).

*Limestone handling and storage:*

The process flow diagram of the limestone-handling unit is attached to paragraph 2.2 of this section (PFD: 1000-1-50-1002).

The process description of this unit does not differ from that made for the alternative without the CO<sub>2</sub> capture (Section G.1, para. 1.1.1).

The main difference between the two alternatives is the limestone flowrate, because of the more stringent limit on SO<sub>x</sub> emission, as a requirement of the downstream CO<sub>2</sub> capture unit, which lead to a higher limestone requirement.

**2.1.2 Unit 2000: Boiler Island**

The boiler island consists of two parallel CFB boilers, for the generation of superheated and reheated steam, with the same size of the alternative without the CO<sub>2</sub> sequestration.

The process flow diagram of the boiler island is attached to paragraph 2.2 of this section (PFD: 2000-1-50-2001).

The main difference with respect to the description made in section G.1, para 1.1.2, is the use of a SCR system, instead of a SNCR, due to the more stringent NO<sub>x</sub> emission level for the downstream CO<sub>2</sub> capture unit.

In a traditional plant, the SNCR system is sufficient to respect the NO<sub>x</sub> emission levels of 200 mg/Nm<sup>3</sup> @ 6% O<sub>2</sub>, volume dry. For the alternative with CO<sub>2</sub> capture, a SCR system is used to reduce the NO<sub>x</sub> produced by the combustion process to a level that does not exceed the inlet requirement of the carbon dioxide capture plant, e.g. less than 20 ppmv of NO<sub>2</sub>.



The catalytic DeNO<sub>x</sub> reactor is situated in the gas stream between the boiler outlet and the air heaters (PK-2001). This location offers the adequate temperature window, necessary for the good functioning of the SCR system, limiting the formation of ammonium sulphates. Gaseous ammonia is injected into the flue gas and, in presence of the catalyst, reacts with nitrogen oxides to produce nitrogen.

Further details of the SCR DeNO<sub>x</sub> system are given in section C, para. 4.0.

### **2.1.3 Unit 3000: Steam Turbine and Preheating Line**

The following description makes reference to the process flow diagram of the power island, attached to paragraph 2.2 of this section (PFD: 3000-1-50-3001).

The power island is a single train, mainly composed of one (1) supercritical steam turbine and preheating line, as per the alternative without the CO<sub>2</sub> capture. The main differences between the two alternatives are the following:

- Large LP steam export from the steam turbine to the AGR unit, for the solvent regeneration of the CO<sub>2</sub> capture plant;
- Preheating of the condensate, which is made by using low sensible heat available from the CO<sub>2</sub> sequestration and compression units (Unit 4000-5000).

The LP steam export to the AGR unit is made by extracting the steam from the crossover between the IP and LP sections of the steam turbine. In order to optimize the plant efficiency, the IP expansion is increased with respect to the case without the CO<sub>2</sub> capture, thus making the design of this turbine different from that of a conventional power plant.

The condensate extracted from the condenser is pumped to the carbon dioxide capture plant for preheating in the amine stripper overhead condenser and then in the carbon dioxide compressor intercoolers.

This optimisation of the integration between the power plant and the CO<sub>2</sub> capture units allows to maximize the efficiency of the process, avoiding the necessity of LP steam extractions to preheat the condensate in the LP preheating line.

As already explained in the summary of this section (para. 2.0), following the investigation made with one steam turbine supplier, the pre-heating of the boiler feed water is made by using part of the cold reheat, flowing to the boiler, and

two extractions from the IP steam turbine. This solution partially decreases the performances of the plant, but significantly simplifies the design of the steam turbine.

#### **2.1.4 Unit 4000: CO<sub>2</sub> capture plant**

The following description makes reference to the process flow diagram of the CO<sub>2</sub> capture plant, attached to paragraph 2.2 of this section (PFD: 4000-1-50-4001).

This unit is mainly composed of two parallel trains made of one direct contact cooler and one absorption column, followed by a common regeneration stripper.

The flue gas from the boiler island is at approximately 85°C and shall be cooled to about 30-35°C in a dedicated flue gas cooler (DCC-4001), as an operational requirement for the downstream CO<sub>2</sub> absorption. The direct contact cooler makes an adiabatic quench of the flue gas, with the advantage of reducing the particulate concentration to very low level, before entering the absorption column. At the bottom of the quench column, part of the condensed water is recovered and recycled back to the top of the DCC, after cooling with cooling water. The remaining water is sent to the wastewater treatment of the plant.

Downstream the direct contact cooler, the flue gas is fed to the absorption tower (ABS-4001) by a flue gas blower (B-4001A/B). The gas entering the absorption column is contacted firstly with a semi lean MEA stream, secondly with a counter current flow of lean MEA, to allow the 85% CO<sub>2</sub> capture with respect to stream entering the unit.

Some of the heat reaction of MEA with CO<sub>2</sub> is removed by pump around coolers (E-4001, E-4002), located at two different sections of the column. Before leaving the column, the sweet gas is scrubbed with make up water to remove the entrained MEA and to avoid any dispersion of solvent.

The flue gas is then discharged to the atmosphere at the top of the absorption columns at approximately 50°C.

From the bottom of the columns, the rich MEA is splitted into two streams: one is heated in a regenerative cross exchanger (E-4002) against the hot stripper bottom and sent to the regeneration column; the other one is heated in two regenerative exchangers (E-4003, E-4004), before flashing in the flash drum (F-4002). The flash allows to separate steam and CO<sub>2</sub> from the rich MEA stream, generating a stream of semi lean MEA from the bottom of the flash. The flashed

vapour flows to the regeneration column, allowing to reduce the amount of steam required for the regeneration of the solvent in the reboiler (E-4008). The separated semi lean MEA stream is pumped back to the first bed of the absorption columns.

The rich solvent is regenerated in the stripping column, which is mainly composed of a stripping and a rectification section. Steam necessary for solvent regeneration comes from the power island, while saturated condensate is recovered back to the deaerator.

The vapour at the top of the column passes through the overhead stripper condenser, where it is cooled first with condensate recycled from the power island and then with water from the lignite drying (E-4006, E-4007). At the overhead stripper condenser outlet the double phase flow is separated in a K.O. drum (D-4001), generating the rich CO<sub>2</sub> stream, which flows to the CO<sub>2</sub> compression (Unit 5000), while condensed water is partially returned to the column as reflux.

The lean MEA at the bottom of the stripping column is pumped back to the absorption, after final cooling against cooling water (E-4005).

A partial flow of the circulating lean amine is periodically sent to the amine reclaimer area to remove the heat stable salts, formed from the reaction of the MEA with gas impurities like SO<sub>2</sub> and NO<sub>2</sub>.

### **2.1.5 Unit 5000: CO<sub>2</sub> Compression and Drying**

The following description makes reference to the process flow diagram of the CO<sub>2</sub> compression and drying unit, attached to paragraph 2.2 of this section (PFD: 5000-1-50-5001/2).

This unit is basically made of two parallel trains, each sized for 50% of the total capacity.

The CO<sub>2</sub> rich stream flows from the outlet of the regeneration column (Unit 4000) to the CO<sub>2</sub> compression unit, which is mainly composed of four different stages, with intercooling between them. The intercooling of the compressed CO<sub>2</sub> stream allows to recover heat both for the preheating of the condensate and for the lignite drying system. Cooling water makes final cooling of the CO<sub>2</sub> rich flow gas, between each compression stage.

The condensed water in the intercooling system is separated in the KO drums (D-5001/2). Between the second and the third stage of the compression, the

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 30 of 47

drying system (PK-5001) reduces the water content of the gas to very low levels (less than 1 ppm), by means of a molecular sieve.

The dried gas flows to the last two stages of compression and intercooling, where CO<sub>2</sub> is compressed up to a pressure of 74 bar. Beyond the CO<sub>2</sub> critical conditions (73.8 bar, 31°C) a booster pump (P-5001) is used to deliver a dense phase carbon dioxide to the plant battery limits at 110 bar.

### **2.1.6 Unit 4100 to 4500: Auxiliary Units**

The process description of the auxiliary units is made in section C, paragraph 10.

The process flow diagram of the main auxiliary units is attached to paragraph 2.2 of this section (PFD 4100-1-50-4101).

---

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section G: Detailed Information for the Selected Technology**



---

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 31 of 47

**2.2 Process Flow Diagrams**


The process flow diagrams of the following process units are attached to this paragraph:

- UNIT 1000: Coal handling and storage (PFD: 1000-1-50-1001)  
 Limestone handling and storage (PFD: 1000-1-50-1002)  
 Coal pre-drying system (PFD: 1000-1-50-1003)
- UNIT 2000: Boiler island with SCR  
 Electro Static Precipitators (ESP)  
 Limestone injection (PFD: 2000-1-50-2001)
- UNIT 3000: Power island consisting of  
 Steam Turbine and Preheating Line (PFD: 3000-1-50-3001)
- UNIT 4000: CO<sub>2</sub> capture plant (PFD: 4000-1-50-4001)
- UNIT 5000: CO<sub>2</sub> compression and drying (PFD: 5000-1-50-5001)
- UNIT 4100-4500: Utility and Offsite units (PFD: 4100-1-50-4101)



COAL HANDLING


REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION	DWG. REV.	DATE
A		FIRST ISSUE	SF		
REVISIONS					
CFB BOILER WITH CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			APPROVED FOR CONSTRUCTION		
			SIGNATURE		
PROCESS FLOW DIAGRAM COAL HANDLING UNIT 1000			DATE		
			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		
			SCALE		
			SHEET OF		
<small>THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH OUT COMPENSATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT, OR OTHERWISE OR DIRECTLY OR INDIRECTLY FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED. THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.</small>			FWI DWG N°		
			1000-1-50-1001		
			REV. A		
			SHEET OF		
			CAD FILE NAME		



LIMESTONE HANDLING

CA No. 153.00200F


REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION
A		FIRST ISSUE	SF
REVISIONS			
CFB BOILER WITH CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			DWG. REV. DATE
PROCESS FLOW DIAGRAM LIMESTONE HANDLING UNIT 1000			SIGNATURE
FOSTER WHEELER			ORDER N°
SHEET OF			SUPPLIER
SHEET OF			CONTRACT N°
SHEET OF			FRAME N°
SHEET OF			CLIENT DWG N°
SHEET OF			SCALE
SHEET OF			REV.
SHEET OF			1000-1-50-1002
SHEET OF			A
CAD FILE NAME			



LIGNITE DRYING


REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION	DWG. REV.	DATE
A		FIRST ISSUE	SF		
REVISIONS					
CFB BOILER WITH CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME			APPROVED FOR CONSTRUCTION		
			DWG. REV. SIGNATURE		
PROCESS FLOW DIAGRAM LIGNITE DRYING SYSTEM UNIT 1000			DATE		
			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG. N°		
			SCALE		
FOSTER WHEELER			SHEET OF		
THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH OUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, EITHER WHOLLY OR IN PART, OR IN ANY MANNER, FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.			FWI DWG. N°		
			1000-1-50-1003		
			SHEET OF		
			REV. A		
CAD FILE NAME					





REV.	DATE	DESCRIPTION	REVISED BY	DATE	APP.
A		FIRST ISSUE	SF		
REVISIONS					
CFB BOILER WITH CO <sub>2</sub> CAPTURE			APPROVED FOR CONSTRUCTION		
IEA GHG R&D PROGRAMME			DWG. REV. DATE		
PROCESS FLOW DIAGRAM			SIGNATURE		
BOILER ISLAND			ORDER N°		
CFB-BOILER			SUPPLIER		
UNIT 1-2000			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		
			SCALE		
			SHEET OF		
			FWI DWG N°		
			2000-1-50-2001		
			SHEET OF		
			REV. A		
CAD FILE NAME					


64 No. 153-02028F



CO2 CAPTURE PLANT



REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION	DWG. REV.	DATE
A		FIRST ISSUE	SF		
REVISIONS					
			APPROVED FOR CONSTRUCTION		
			DWG. REV.	DATE	
			SIGNATURE		
			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		
			SCALE		
			SHEET	OF	REV.
			FWJ DWG N°	4000-150-4001	A
			SHEET	OF	
CAD FILE NAME					

EA No. 153-0202P




REV.	DATE	DESCRIPTION	REV.	DATE	DESCRIPTION
A		FIRST ISSUE	SF		
REVISIONS					
			APPROVED FOR CONSTRUCTION		
			DWG. REV.	DATE	
			SIGNATURE		
			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		SCALE
<small>THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH-          OUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL          NOT BE REPRODUCED, COPIED, LENT, OR DISPOSED OF DIRECTLY OR INDIRECTLY,          FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY          FURNISHED. THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.</small>					
SHEET	OF	REV.			
3000-1-50-3001		A			
SHEET	OF	REV.			
CAD FILE NAME					

CAD FILE NAME



CO2 COMPRESSION & DRYING (HEAT INTEGRATION)

REV.	DATE	DESCRIPTION	DRAW	BY	CHK	APP.
A		FIRST ISSUE	SF			
REVISIONS						
CFB BOILER WITH CO <sub>2</sub> CAPTURE IEA GHG R&D PROGRAMME PROCESS FLOW DIAGRAM CO <sub>2</sub> COMPRESSION & DRYING (HEAT INTEGRATION) UNIT 5000						APPROVED FOR CONSTRUCTION DWG. REV. _____ DATE _____ SIGNATURE _____ ORDER N° _____ SUPPLIER _____ CONTRACT N° _____ FRAME N° _____ CLIENT DWG. N° _____
FOSTER WHEELER						SCALE _____ SHEET _____ OF _____ DWG N° _____ 5000-1-50-5001 SHEET _____ OF _____
<small>THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER (ITALY) AND IS LENT WITH            OUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL            NOT BE REPRODUCED, COPIED, LENT, OR DISPOSED OF DIRECTLY OR INDIRECTLY,            FOR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY            FURNISHED THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.</small>						REV. _____ A
<small>CAD FILE NAME</small>						



CO2 COMPRESSION AND DRYING PLANT

REV.	DATE	DESCRIPTION	APPROVED FOR CONSTRUCTION	DWG. REV.	DATE
A		FIRST ISSUE	SF		
REVISIONS			APPROVED FOR CONSTRUCTION		
CFB BOILER WITH CO2 CAPTURE IEA GHG R&D PROGRAMME			DWG. REV.	DATE	
PROCESS FLOW DIAGRAM CO2 COMPRESSION & DRYING UNIT 5000			SIGNATURE		
			ORDER N°		
			SUPPLIER		
			CONTRACT N°		
			FRAME N°		
			CLIENT DWG N°		
			SCALE		
			SHEET	OF	REV.
			FWI DWG N°		
			5000-1-50-5002		A
			SHEET	OF	
			EAD FILE NAME		

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---


Revision no.: Final  
Date: Nov. 2005  
Sheet: 32 of 47

### **2.3 Heat and Material Balances**


The Heat & Material Balances of the following process units are attached to this section:

- UNIT 1000: Solid materials storage – handling and lignite drying
- UNIT 2000: Boiler island
- UNIT 3000: Steam turbine and preheating line
- UNIT 4000: CO<sub>2</sub> capture plant
- UNIT 5000: CO<sub>2</sub> compression and drying

Stream numbers are as shown on the process flow diagrams attached to paragraph 2.2 of this section.

CFB HEAT AND MATERIAL BALANCE							REVISION	0	1	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						Sheet 1 of 1	PREP.	SR	
	<b>CASE : CFB with CO<sub>2</sub> Capture</b>							APPROVED	LM	
	<b>UNIT : 1000 Solid Materials Handling-Storage and Lignite Drying</b>							DATE	Nov-05	
STREAM	1	2	3	4	5	6	7	8	9	
	Wet Coal to Lignite Drying System (1)	Dry Coal to Boiler Island UNIT 2000 (1)	Air intake from atmosphere for Lignite Drying (1)	Hot Water from UNITS 2000 - 4000 - 5000 (1)	Cold Water to UNITS 2000 - 4000 - 5000 (1)	Wet Air to Atmosphere (1)				
Temperature (°C)	AMB	AMB	6	85	65	65				
Pressure (bar)	ATM	ATM	ATM	3	3	ATM				
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	592883	429840	908820	5290600	5290600	1071865				
Molar flow (kgmole/h)			31458	293759	293759	40513				
	Moisture 50.70%	Moisture 32%								
Composition wt% with moisture										
Carbon	31.33%	43.20%								
Hydrogen	2.29%	3.16%								
Oxygen	11.56%	15.94%								
Sulfur	0.22%	0.31%								
Nytrogen	0.37%	0.51%								
Chlorine	0.03%	0.05%								
Moisture	50.70%	32.00%								
Ash	3.50%	4.83%								


Note (1): All the enclosed data are for two CFB boilers in parallel

CFB HEAT AND MATERIAL BALANCE							REVISION	0	1	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>						PREP.	SR		
	<b>CASE : CFB with CO<sub>2</sub> Capture</b>						APPROVED	LM		
	<b>UNIT : 2000 Boiler Island</b>						DATE	Nov-05		
	Sheet 1 of 2									
STREAM	1-4	5	6	7	8	9	10	11	12	13-14
	Coal from Coal Drying System (2)	Primary Air intake from Atmosphere (2)	Secondary Air Intake from Atmosphere (2)	High Pressure Air Intake from Atmosphere (2)	Flue Gas From Boiler to CO <sub>2</sub> Capture Plant UNIT 4000 (2)	Feed Water from Preheating line UNIT 3000 (2)	HP SH Steam to Steam Turbine (2)	IP Steam from Preheating Line UNIT 3000 (2)	IP Reheated Steam to Steam Turbine (2)	Limestone Injection (1) - (2)
Temperature (°C)	AMB	15	15	15	85	272	584	319	602	AMB
Pressure (bar)	AMB	1.23	1.13	1.61	1.03	313	283	51	48	ATM
<b>TOTAL FLOW</b>										
Mass flow (kg/h)	429840	1867900	925400	119750	3361176	2182000	2182000	2016000	2016000	27360
Molar flow (kgmole/h)		64656	32032	4145	116023	121155	121155	111938	111938	
<b>LIQUID PHASE</b>										
Mass flow (kg/h)		0	0	0	0	2182000				
<b>GASEOUS PHASE</b>										
Mass flow (kg/h)		1867900	925400	119750	3361176	0	2182000	2016000	2016000	
Molar flow (kgmole/h)		64656	32032	4145	116023	0	121155	111938	111938	
Molecular Weight		28.89	28.89	28.89	28.97	18.01	18.01	18.01	18.01	
Composition (vol %)	See UNIT 1000									
N <sub>2</sub>		77.57%	77.57%	77.57%	68.14%	0.00%	0.00%	0.00%	0.00%	
CO <sub>2</sub>		0.00%	0.00%	0.00%	13.51%	0.00%	0.00%	0.00%	0.00%	
H <sub>2</sub> O		0.68%	0.68%	0.68%	13.70%	100%	100%	100%	100%	
O <sub>2</sub>		20.86%	20.86%	20.86%	3.88%	0.00%	0.00%	0.00%	0.00%	
Ar		0.89%	0.89%	0.89%	0.77%	0.00%	0.00%	0.00%	0.00%	
NO <sub>x</sub>		0.00%	0.00%	0.00%	20 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%	
SO <sub>x</sub>		0.00%	0.00%	0.00%	15 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%	
CO		0.00%	0.00%	0.00%	120 ppm VD 6% O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%	

Note (1): Limestone Analysis (wt %) CaCO<sub>3</sub> = 95% - MgCO<sub>3</sub> = 3.4% - Inert = 1.6%

Note (2): All the enclosed data are for two CFB boilers in parallel



CFB HEAT AND MATERIAL BALANCE					REVISION	0	1	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b>				PREP.	SR		
	<b>CASE : CFB with CO<sub>2</sub> Capture</b>				APPROVED	LM		
	<b>UNIT : 2000 Boiler Island</b>				DATE	Nov-05		
	Sheet 2 of 2							
STREAM	15	16	17	18	19	20	21	22
	Cold Water from Lignite Drying UNIT 1000 (2)	Hot Water to Lignite Drying UNIT 1000 (2)	Cooling Water Inlet (2)	Cooling Water Outlet (2)	Bottom Ash to UNIT 1000 (2)	Fly Ash to UNIT 1000 (2)		
Temperature (°C)	65	85	11	21	AMB	AMB		
Pressure (bar)	3	3	3	3	ATM	ATM		
<b>TOTAL FLOW</b>								
Mass flow (kg/h)	1108000	1108000	104000	104000	12240	28800		
Molar flow (kgmole/h)	61521	61521	5775	5775				
<b>LIQUID PHASE</b>								
Mass flow (kg/h)	1108000	1108000	104000	104000				
<b>GASEOUS PHASE</b>								
Mass flow (kg/h)								
Molar flow (kgmole/h)								
Molecular Weight	18.01	18.01	18.01	18.01				
Composition (vol %)								
N <sub>2</sub>	0.00%	0.00%	0.00%	0.00%				
CO <sub>2</sub>	0.00%	0.00%	0.00%	0.00%				
H <sub>2</sub> O	100%	100%	100%	100%				
O <sub>2</sub>	0.00%	0.00%	0.00%	0.00%				
Ar	0.00%	0.00%	0.00%	0.00%				
NO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%				
SO <sub>x</sub>	0.00%	0.00%	0.00%	0.00%				
CO	0.00%	0.00%	0.00%	0.00%				

Note (1): Limestone Analysis (wt %) CaCO<sub>3</sub> = 95% - MgCO<sub>3</sub> = 3.4% - Inert = 1.6%

Note (2): All the enclosed data are for two CFB boilers in parallel

# CFB HEAT AND MATERIAL BALANCE




CLIENT : IEA GREEN HOUSE R & D PROGRAMME

CASE : CFB with CO<sub>2</sub> Capture

UNIT : 3000 Steam Turbine & Preheating Line

Sheet 1 of 1

Stream	Description	Flowrate t/h	Temperature °C	Pressure bar a	Entalphy kJ/kg
1	HP Water to Boiler Island	2182	272	313	1191
2	HP Steam from Boiler	2182	584	283	3413
3	IP Steam to Boiler	2016	319	51	2978
4	IP hot reheated steam to Steam Turbine	2016	602	48	3673
5	IP Steam Turbine exhaust	1572	239	3.6	2943
6	LP Steam to Reboiler	873	146	3.6	2747
7	Hot Condensate returned from Reboiler	873	135	3	566
8	LP Steam to Steam Turbine	770	239	3.6	2943
9	Condensate to UNIT 4000 - 5000	889	25	0.032	105
10	LP Preheated Condensate from UNIT 4000 - 5000	889	124	9	522
11	Condensate to HP FWH (Deaer. Outlet)	2182	175	9	742
12	BFW Pump Delivery	2182	181	315	783
13	1st HP Extraction to E-3004	78	338	59	3011
14	2nd HP Extraction to E-3003	88	318	51	2978
15	1st MP Extraction to E-3005 and 3002	194	535	32	3535
16	2nd MP Extraction to Deaer. And ST BFW Pump	250	356	9	3172
17	Cooling water Inlet	46332	11	3	47
18	Cooling Water Outlet	46332	21	2	88

CFB HEAT AND MATERIAL BALANCE										REVISION	0	1	
 <b>FOSTER WHEELER</b>	<b>CLIENT : IEA GREEN HOUSE R &amp; D PROGRAMME</b> <b>CASE : CFB with CO<sub>2</sub> Capture</b> <b>UNIT : 4000 CO<sub>2</sub> Capture Plant</b>									PREP.	SR		
										APPROVED	LM		
										DATE	Nov-05		
	1	2	3	4	5	6	7	8	9	10	11	12	13
<b>STREAM</b>	Flue Gas from Boiler Island UNIT 2000 (1)	Sweet Gas to Atmosphere	CO <sub>2</sub> Rich Flow to Compression UNIT 5000	LP Steam From Turbine Extraction to Reboiler	Condensate from Reboiler to Power Island	Cold Condensate from UNIT 3000	Hot Condensate to UNIT 5000	Lignite Drying Water from UNIT 1000	Lignite Drying water to UNIT 1000	Cooling Water inlet from UNIT 4100	Cooling water outlet to UNIT 4100	Water Make-Up	MEA Make-Up
Temperature (°C)	85	46	38	146	135	26	75	65	85	11	21	30	
Pressure (bar)	1.03	1.01	1.6	3.6	3	14	12	3	3	3	3	2	
<b>TOTAL FLOW</b>													
Mass flow (kg/h)	3361176	2667505	596737	873000	873000	889000	889000	3074200	3074200	42704000	42704000	148725	
Molar flow (kgmole/h)	116023	96789	13897	48473	48473	49361	49361	170694	170694	2371127	2371127	8258	
<b>LIQUID PHASE</b>													
Mass flow (kg/h)	0	0	0	0	873000	889000	889000	3074200	3074200	42704000	42704000	148725	
<b>GASEOUS PHASE</b>													
Mass flow (kg/h)	3361176	2667505	596737	873000	0	0	0	0	0	0	0	0	
Molar flow (kgmole/h)	116023	96789	13897	48473	0	0	0	0	0	0	0	0	
Molecular Weight	28.97	27.56	42.94	18.01	18.01	18.01	18.01	18.01	18.01	18.01	18.01	18.01	
Composition (vol %)													
N <sub>2</sub>	68.14%	81.68%	0.01%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
CO <sub>2</sub>	13.51%	2.43%	95.88%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
H <sub>2</sub> O	13.70%	10.31%	4.11%	100%	100%	100%	100%	100%	100%	100%	100%	100.00%	
O <sub>2</sub>	3.88%	4.65%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Ar	0.77%	0.93%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
NOx	20 ppm VD 6% O2	<20 ppm VD 6% O2	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
SOx	15 ppm VD 6% O2	<15 ppm VD 6% O2	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
CO	120 ppm VD 6% O2	<120 ppm VD 6% O2	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	

Note (1): All the enclosed data are for two CFB boilers in parallel



---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 33 of 47

## **2.4 Utility Consumption**

The utility consumption of the process/utility and offsite units are shown in the attached tables.



CLIENT: IEA GHG  
 PROJECT: GASIFICATION POWER GENERATION STUDY  
 LOCATION: Germany  
 FWI N°: 1BD0237A

Rev 0  
 Nov-05  
 ISSUED BY: SR.  
 CHECKED BY: LM  
 APPR. BY: RD

**ELECTRICAL CONSUMPTION SUMMARY - CFB with CO<sub>2</sub> Capture**

UNIT	DESCRIPTION UNIT	Absorbed Electric Power [kW]
<b>PROCESS UNITS</b>		
1000	Solid Materials Storage - Handling and Lignite Drying	
	Coal Conveyors and Feeders	630
	Coal Milling and Powder control System	280
	Lignite Drying System	565
	Limestone Conveyors	70
	Limestone Milling and Powder control System	130
	<b>PARTIAL TOTAL</b>	<b>1675</b>
2000	Boiler Island	
	Primary Air Fans	13200
	Secondary Air Fans	3170
	Induced Draught Fans	8950
	High Pressure Blowers	2050
	Bottom Ash Handling	105
	Fly Ash Handling and Storage	140
	Miscellanea	730
	<b>PARTIAL TOTAL</b>	<b>28345</b>
4000	CO <sub>2</sub> Capture Plant	25400
5000	CO <sub>2</sub> Compression and Drying	64600
<b>POWER ISLANDS UNITS</b>		
3000	Steam Turbine and Preheating line	
	Steam Turbine	760
	Condensate Extraction Pump	380
	<b>PARTIAL TOTAL</b>	<b>1140</b>
<b>UTILITY and OFFSITE UNITS</b>		
4100	Cooling Water and Machinery Cooling Water System	
	Cooling Towers - Condenser - Boiler Island - Utilities	8880
	Cooling Towers - CO <sub>2</sub> Capture and Compression	9390
	Cooling Towers - Make-Up	190
	Cooling Towers - Machinery Cooling Water	280
4200	Demi Water System	60
4300	Natural Gas Start-Up System	0
4400	Plant and Instrument Air System	1500
4500	Raw / Service / Potable Water System	370
	Miscellanea	4800
	<b>PARTIAL TOTAL</b>	<b>25470</b>
	<b>GRAN TOTAL</b>	<b>146630</b>







**2.5 CFB overall performances**

The following table shows the overall performance of the CFB complex.

<b>CFB</b>		
<b>CFB with CO<sub>2</sub> Capture</b>		
<b>OVERALL PERFORMANCES OF THE CFB COMPLEX</b>		
Coal Flowrate (A.R.)	t/h	592.9
Coal LHV (A.R.)	kJ/kg	10500
<b>THERMAL ENERGY OF FEEDSTOCK (based on coal LHV) (A)</b>	<b>MWt</b>	<b>1729.3</b>
Steam turbine power output (@gen. Terminals)	MWe	758.2
<b>GROSS ELECTRIC POWER OUTPUT OF PC - USC COMPLEX (D )</b>	<b>MWe</b>	<b>758.2</b>
Coal Storage / Handling / Drying	MWe	1.7
Boiler Island	MWe	28.3
CO <sub>2</sub> Plant incl. Blowers	MWe	25.4
CO <sub>2</sub> Compression	MWe	64.6
Power Island	MWe	1.1
Utilities	MWe	25.5
<b>ELECTRIC POWER CONSUMPTION OF CFB COMPLEX</b>	<b>MWe</b>	<b>146.6</b>
<b>NET ELECTRIC POWER OUTPUT OF CFB (C )</b> Step-Up Transformer Efficiency (0.997)	<b>MWe</b>	<b>609.7</b>
<b>Gross electrical efficiency (D/A *100) (based on coal LHV)</b>	<b>%</b>	<b>43.8%</b>
<b>Net electrical efficiency (C/A*100) (based on coal LHV)</b>	<b>%</b>	<b>35.3%</b>

As already explained in the summary of this section (para 2.0), the plant performances of this alternative are slightly less than those previously developed in section D.3 for the same case. This is for the investigation made with one steam turbine supplier, which led to some modifications on the design of this machine (see para 2.0).

**IEA GHG**
**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**
**Section G: Detailed Information for the Selected Technology**

Revision no.: Final  
 Date: Nov. 2005  
 Sheet: 35 of 47

The following table shows the overall CO<sub>2</sub> removal efficiency of the CFB complex:

	<b>Equivalent flow of CO<sub>2</sub> kmol/h</b>
Coal (Carbon = 43.21%wt)	15466
Limestone	259.7
Slag	50.7
<b>Net Carbon flowing to Process Units (A)</b>	<b>15675</b>
Liquid Storage	
CO	0.0
CO <sub>2</sub>	<u>13324</u>
<b>Total to storage (B)</b>	<b>13324</b>
Emission	
CO	0.0
CO <sub>2</sub>	<u>2351</u>
<b>Total Emission</b>	<b>2351</b>
<b>Overall CO<sub>2</sub> removal efficiency, % (B/A)</b>	<b>85.0</b>

## 2.6 Environmental Impact

The CFB complex is designed to process coal and produce electric power. The advanced technology allows to reach a high efficiency and to minimise the environmental impact.

The gaseous emissions, liquid effluents and solid wastes from the CFB complex are summarised in this section.

### 2.6.1 Gaseous Emissions

#### Main Emissions

In normal operation at full load, the main continuous emissions are the combustion flue gases leaving the absorber unit of the CO<sub>2</sub> capture plant.

Table 2.6.1 summarises expected flow rate and concentration of the combustion flue gas after CO<sub>2</sub> capture treatment.

**Table 2.6.1** – Expected gaseous emissions from CFB plant integrated with CO<sub>2</sub> capture.

	Normal Operation
Wet gas flow rate, kg/s	741
Flow, Nm <sup>3</sup> /h	2169430
Temperature, °C	46
Composition	(%vol)
N <sub>2</sub>	82.60
O <sub>2</sub>	4.65
CO <sub>2</sub>	2.43
H <sub>2</sub> O	10.31
Emissions	mg/Nm <sup>3</sup> ( <sup>1</sup> )
NO <sub>x</sub>	40
SO <sub>x</sub>	43 ( <sup>2</sup> )
CO	Less than 150
Particulate	Less than 30
NH <sub>3</sub>	5 ( <sup>3</sup> )

(1) Dry gas, O<sub>2</sub> Content 6% vol

(2) SO<sub>x</sub> Emissions upstream AGR unit; after solvent washing, emissions are expected close to zero

(3) Due to ammonia slippage into the flue gas downstream the SCR

In normal operation at full load, the following emission to the atmosphere is foreseen from the coal drying process:

Flow rate : 1072 t/h  
 Particulate : 21 kg/h

#### Minor Emissions

Fugitive emissions are those emissions caused by storage and handling of materials (solids transfer, leakage, etc.). They are prevented by routing all vents to a bag filter.

### **2.6.2 Liquid Effluent**

The plant would be designed for zero contaminated liquid effluents. All the liquid effluents are treated in the wastewater treatment system in order to be discharged in accordance with the current regulations.

For the description of the wastewater treatment refer to section G.1, para. 1.6.2.

### **2.6.3 Solid Effluent**

The power plant is expected to produce the following solid by-products:

#### Fly Ash

Flow rate : 28.8 t/h

#### Bottom Ash

Flow rate : 12.2 t/h

Fly and bottom ash are used as bed filling and returned back to the mine or dispatched to cement industries, if available in the neighbours.

The calcium Sulphate is not a pure product and cannot be sold as pure gypsum.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 38 of 47

## **2.7 Equipment List**

The list of the main equipment and process packages are included in this section.



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COAL SYSTEM</b>									
		The coal handling storage and drying system includes: - Stacker reclaimers - Coal conveyors - Coal mills - Filters - Fans		Capacity: 600 t/h					
<b>LIGNITE DRYING SYSTEM</b>									
		- Fluidized Bubbling Bed Dryer - Air Fan - Hot water based air heater - Filters for exhaust air		Capacity: 600 t/h					
<b>LIMESTONE SYSTEM</b>									
		The limestone handling and storage system includes: - Limestone reclaimers area - Limestone conveyors - Limestone mills - Filters - Fans		Capacity: 30 t/h					



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>CONVEYORS</b>									
<b>Coal Handling</b>									
1	CR-1001 A/B	Wet Coal Conveyor							
1	CR-1002 A/B	Wet Coal Elevator							
1	CR-1003 A/B	Wet Coal Conveyor							
1	CR-1004 A/B	Wet Coal Conveyor							
1	CR-1005 A/B	Wet Coal Conveyor							
1	CR-1006 A/B	Wet Coal Conveyor							
1	CR-1007 A/B	Wet Coal Conveyor							
1	CR-1008 A/B	Wet Coal Conveyor							
1	CR-1009 A/B	Wet Coal Conveyor							
1	CR-1010 A/B	Wet Coal Conveyor							
1	CR-1011	Wet Coal Conveyor							
1	CR-1012	Wet Coal Conveyor							
1	CR-1013	Wet Coal Bucket Elevator							
1/2	1-CR-1001 A/B	Dry Coal Conveyor							
2/2	2-CR-1001 A/B	Dry Coal Conveyor							
<b>Limestone Handling</b>									
1	CR-1014	Limestone Conveyor							
1	CR-1015	Limestone Elevator							
1	CR-1016	Limestone Conveyor							
1	CR-1017	Limestone Conveyor							
1	CR-1018	Limestone Conveyor							
1	CR-1019	Limestone Conveyor							
1	CR-1020	Limestone Elevator							
1	CR-1021	Limestone Conveyor							
1	CR-1022	Limestone Conveyor							
1	CR-1023	Limestone Conveyor							
1	CR-1024	Limestone Conveyor							
1	CR-1025	Limestone Conveyor							
1	CR-1026	Limestone Conveyor							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 1000 - Solid Materials Storage and Handling - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>MILLING</b>									
1	SCR-1001 A/B	<b>Coal Milling</b> Coal Screen Grinder							
1	SCR-1002 A/B	<b>Limestone Milling</b> Limestone Screen Grinder							
<b>STORAGE</b>									
1	X-1001	<b>Coal Storage</b> Wet Coal Discharging Hopper							
1	X-1002	Wet Coal Storage							
1	X-1003	<b>Limestone Storage</b> Limestone Discharging Hopper							
1	X-1004	Limestone Storage							
<b>FILTERS</b>									
1	F-1001	Wet Coal Dust Filter							
1	F-1002	Wet Coal Dust Filter							
1/2	1-F-1001	Dry Coal Dust Filter							
2/2	2-F-1001	Dry Coal Dust Filter							
1	F-1003	Limestone Dust Filter							
1	F-1004	Limestone Dust Filter							
<b>FLUIDIZED BUBBLING BED PACKAGE</b>									
				<b>Capacity</b>					
1/2	1-FB-1001	Fluidized Bubbling Bed Lignite Dryer		300 t/h					
1/2	1-WC-1001	Hot water submerged coils		55 MWth					
1/2	1-E-1001	Hot water air heater		7.5 MWth					
1/2	1-X-1001	Dry Coal discharging hopper							
2/2	2-FB-1001	Fluidized Bubbling Bed Lignite Dryer		300 t/h					
2/2	2-WC-1001	Hot water submerged coils		55 MWth					
2/2	2-E-1001	Hot water air heater		7.5 MWth					
2/2	2-X-1001	Dry Coal discharging hopper							
<b>FANS</b>									
1	B-1001	Wet Coal Exhaust Fan							
1	B-1002	Wet Coal Exhaust Fan							
1/2	1-B-1001 A/B	Air Fan		m=65 kg/s; H=2000 Pa	160 kW				All operating; single design capacity = 60% of the maximum load
2/2	2-B-1001 A/B	Air Fan		m=65 kg/s; H=2000 Pa	160 kW				
1	B-1003	Limestone Exhaust Fan							
1	B-1004	Limestone Exhaust Fan							





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 2000 - Boiler Island - CFB with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>BOILERS</b>									
1/2	1-C-2001	Supercritical CFB Boiler		MCR: SH: 1095 t/h RH: 1010 t/h		MCR: 285 bar 51 bar	Feed Water 275°C 585 °C 600 °C		Boiler Package including: - Coal Silos - Limestone Silos - Coal Screw Feeders - Coal Burners (1-BR-2001 A-N) - Regenerative Air Preheater - Hot Water Air Preheater - Bottom Ash Coolers - High Pressure Blowers - Air Fans - Flue Gas Induced Draught Fans - Desuperheaters - Start-Up System - Electrostatic Precipitators ESP - Continuous Emission monitoring System - Selective Catalytic Reduction SCR - Ammonia Storage and Injection Package
2/2	2-C-2001	Supercritical CFB Boiler		MCR: SH: 1095 t/h RH: 1010 t/h		MCR: 285 bar 51 bar	Feed Water 275°C 585 °C 600 °C		Boiler Package including: - Coal Silos - Limestone Silos - Coal Screw Feeders - Coal Burners (2-BR-2001 A-N) - Regenerative Air Preheater - Hot Water Air Preheater - Bottom Ash Coolers - High Pressure Blowers - Air Fans - Flue Gas Induced Draught Fans - Desuperheaters - Start-Up System - Electrostatic Precipitators ESP - Continuous Emission monitoring System - Selective Catalytic Reduction SCR - Ammonia Storage and Injection Package



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 2000 - Boiler Island - CFB with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>FANS</b>									
1/2	1-B-2001 A/B	Primary Air Fans		m=165 kg/s; H=22000 Pa	4000 kW				Included in 1-C-2001
1/2	1-B-2002 A/B	Secondary Air Fans		m=84 kg/s; H=12000 Pa	1100 kW				Included in 1-C-2001
1/2	1-B-2003 A/B	Flue Gas Induced Draught Fans		m=285 kg/s; H=8100 Pa	3700 kW				Included in 1-C-2001
1/2	1-B-2004 A/B/C/D	High Pressure Blowers		m=9 kg/s; H=60000 Pa	580 kW				Included in 1-C-2001
2/2	2-B-2001 A/B	Primary Air Fans		m=165 kg/s; H=22000 Pa	4000 kW				Included in 2-C-2001
2/2	2-B-2002 A/B	Secondary Air Fans		m=84 kg/s; H=12000 Pa	1100 kW				Included in 2-C-2001
2/2	2-B-2003 A/B	Flue Gas Induced Draught Fans		m=285 kg/s; H=8100 Pa	3700 kW				Included in 2-C-2001
2/2	2-B-2004 A/B/C/D	High Pressure Blowers		m=9 kg/s; H=60000 Pa	580 kW				Included in 2-C-2001
<b>HEAT EXCHANGERS</b>									
1/2	1-E-2001	Regenerative Air Preheater							Included in 1-C-2001
1/2	1-E-2002 A/B	Hot Water Air Preheater							Included in 1-C-2001
1/2	1-E-2003 A/B...I/L	Bottom Ash Coolers							Included in 1-C-2001
1/2	1-E-2004	Flue Gas Cooler							
1/2	1-E-2005	Lignite Drying Exchanger							
2/2	2-E-2001	Regenerative Air Preheater							Included in 2-C-2001
2/2	2-E-2002 A/B	Hot Water Air Preheater							Included in 2-C-2001
2/2	2-E-2003 A/B...I/L	Bottom Ash Coolers							Included in 2-C-2001
2/2	2-E-2004	Flue Gas Cooler							
2/2	2-E-2005	Lignite Drying Exchanger							
<b>SILOS</b>									
1/2	1-D-2005	Coal Silo							Included in 1-C-2001
1/2	1-D-2006	Coal Silo							Included in 1-C-2001
1/2	1-D-2007	Coal Silo							Included in 1-C-2001
1/2	1-D-2008	Coal Silo							Included in 1-C-2001
1/2	1-D-2009	Limestone Silo							Included in 1-C-2001
1/2	1-D-2010	Limestone Silo							Included in 1-C-2001
2/2	2-D-2005	Coal Silo							Included in 2-C-2001
2/2	2-D-2006	Coal Silo							Included in 2-C-2001
2/2	2-D-2007	Coal Silo							Included in 2-C-2001
2/2	2-D-2008	Coal Silo							Included in 2-C-2001
2/2	2-D-2006	Limestone Silo							Included in 2-C-2001
2/2	2-D-2007	Limestone Silo							Included in 2-C-2001
<b>CATALYST</b>									
1/2	1-PK-2001	SCR- Selective Catalytic Reduction							
2/2	2-PK-2001	SCR- Selective Catalytic Reduction							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 2000 - Boiler Island - CFB with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>DESUPERHEATERS</b>									
1/2		HP Steam Desuperheater							Included in 1-C-2001
1/2		By-Pass Desuperheater							Included in 1-C-2001
1/2		Reheated Steam Desuperheater							Included in 1-C-2001
2/2		HP Steam Desuperheater							Included in 2-C-2001
2/2		By-Pass Desuperheater							Included in 2-C-2001
2/2		Reheated Steam Desuperheater							Included in 2-C-2001
<b>FEEDERS</b>									
1/2	1-FD-2001 A/B...E/F	Coal Screw Feeders							Included in 1-C-2001
1/2	1-FD-2002 A/B...E/F	Coal Screw Feeders							Included in 1-C-2001
2/2	2-FD-2001 A/B...E/F	Coal Screw Feeders							Included in 2-C-2001
2/2	2-FD-2002 A/B...E/F	Coal Screw Feeders							Included in 2-C-2001
<b>BOTTOM ASH SYSTEM</b>									
		The bottom ash handling and storage system includes: - Ash storage silos - Ash conveyors - Clinker crusher - Filters - Fans		Capacity: 15 t/h					
<b>FLY ASH SYSTEM</b>									
		The fly ash handling and storage system includes: - Ash storage silos - Pneumatic conveying system - Compressors - Filters - Fans		Capacity: 30 t/h					
<b>FILTERS</b>									
1/2	1-ESP-2001	Electrostatic Precipitator ESP							
2/2	2-ESP-2001	Electrostatic Precipitator ESP							
<b>PACKAGES</b>									
1/2	1-X-2001	Control Emission Monitoring System							
2/2	2-X-2001	Control Emission Monitoring System							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 3000 - Power Island - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks	
<b>STEAM TURBINE</b>										
1	ST-3001	Steam Turbine		760 MWe SH: 285 bar; 585 °C RH: 48 bar; 600°C Cond: 0.032 bar					Steam Turbine Package Including: - Master Controller - By-pass System - By-pass Logic Controller - Ejectors - Silencer	
<b>GENERATOR</b>										
1	SG-3001	Generator		760 MWe					Generator Package Including - Cooling System with Hydrogen - Start-up System - Vibration Control System	
<b>HEAT EXCHANGERS</b>										
				<b>Duty</b>						
1	E-3001	Gland Steam Condenser		600 kW						
1	E-3002	HP Feedwater Heater 1		142400 kW						
1	E-3003	HP Feedwater Heater 2		48700 kW						
1	E-3004	HP Feedwater Heater 3		40300 kW						
1	E-3005	HP Feedwater Heater 4		15500 kW						
1	E-3006	Steam Condenser		539000 kW						
1	DS-3001	LP-Steam Desuperheater								
<b>PUMPS</b>										
1	P-3001 A/B	Condensate Extraction Pump		Q=445 m <sup>3</sup> /h; H=130 m	210 kW					
1	P-3002 A/B	Steam Turbine Driven BFW Pump		Q=1090 m <sup>3</sup> /h; H=3700 m					In operation - Steam Turbine Driven	
1	P-3002 C	Motor Driven BFW Pump		Q=2180 m <sup>3</sup> /h; H=3700 m	28000 kW				Spare - Electric Motor Driven	
1	P-3003	Drain Pump		Q=25 m <sup>3</sup> /h; H=10 m	7.5 kW					
1	P-3004 A/B	Vacuum Pumps							Included in Steam Turbine Auxiliaries	
<b>TANKS</b>										
1	D-3001	Deaerator								
1	D-3002	ST Drain Drum								
<b>CHEMICAL INJECTION PACKAGE</b>										
1	Z-3001	Chemical Injection Package								
1	Z-3002	Chemical Additives								

				CLIENT: IEA GREENHOUSE R&D PROGRAMME LOCATION: Germany PROJ. NAME: CO <sub>2</sub> Capture in Low-rank coal Power Plants CONTRACT N. 1BD0237A			REVISION	Rev.0	Rev.1	
							DATE	July - 05	Nov - 05	
							ISSUED BY	S.R.	S.R.	
							CHECKED BY	L.M.	L.M.	
							APPROVED BY	R.D.	R.D.	
<b>EQUIPMENT LIST</b>										
<b>Unit 4000 - CO<sub>2</sub> Capture Plant - CFB Boiler with CO<sub>2</sub> Capture</b>										
TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks	
<b>TOWERS</b>				<b>D(m) x H(m)</b>						
1/2	1-ABS-4001	Acid Gas Absorber	Packing Column	15.3 x 33.0		3.5	80		Random packing (PP)	
2/2	2-ABS-4001	Acid Gas Absorber	Packing Column	15.3 x 33.0		3.5	80		Random packing (PP)	
1/1	STR-4001	MEA Regenerator	Packing Column	12.5 x 25.0		3.5	150		Structured packing (304LSS)	
<b>HEAT EXCHANGERS</b>				<b>Surface Area (m<sup>2</sup>)</b>		<b>Shell / Tube</b>				
1/1	1-E-4001	DCC Cooling Water Cooler	Shell & Tube	3500		4/4	80/50			
2/2	2-E-4001	DCC Cooling Water Cooler	Shell & Tube	3500		4/4	80/50			
1/1	E-4002	Lean/Rich Exchanger	Plate	10700		5/8	140/130			
1/1	E-4003	Semi Lean MEA cooler	Plate	10600		5/8	90/70			
1/1	E-4004	Flash Preheater	Plate	3500		5/8	150/140			
1/1	E-4005	Lean Solvent Cooler	Shell & Tube	4000		4/8	90/50			
1/1	E-4006	Overhead Stripper Condenser	Shell & Tube	2700		3/5	150/120			
1/1	E-4007	Overhead Stripper Condenser	Shell & Tube	7900		3/5	110/90			
1/1	E-4008	Stripper Reboiler	Thermosiphon	25700		4/5	130/170			
1/1	1-E-4001	Pump around Cooling Water Cooler top	Shell & Tube	4400		3/5	70/50			
2/2	2-E-4001	Pump around Cooling Water Cooler top	Shell & Tube	4400		3/5	70/50			
1/1	1-E-4002	Pump around Cooling Water Cooler bottom	Shell & Tube	3600		3/5	70/50			
2/2	2-E-4002	Pump around Cooling Water Cooler bottom	Shell & Tube	3600		3/5	70/50			
<b>PUMPS</b>				<b>Q (m<sup>3</sup>/h) x H (m)</b>		<b>kW</b>				
1/2	1-P-4001 A/B	Rich MEA Circulation Pump	centrifugal	9600 x 55	2000				One operating and one spare	
2/2	2-P-4001 A/B	Rich MEA Circulation Pump	centrifugal	9600 x 55	2000				One operating and one spare	
1/2	P-4001 A/B	Lean MEA Circulation Pump	centrifugal	10200 x 25	950				One operating and one spare	
1/2	P-4002 A/B	Semi Lean MEA Circulation Pump	centrifugal	8200 x 25	760				One operating and one spare	
1/1	P-4003	Overhead Stripper Condenser Reflux Pump	centrifugal	260 x 15	15					
1/2	1-P-4001 A/B	Direct Contact Cooler Recirculation Pump	centrifugal	3000 x 25	280				One operating and one spare	
2/2	2-P-4001 A/B	Direct Contact Cooler Recirculation Pump	centrifugal	3000 x 25	280				One operating and one spare	
1/2	1-P-4002	Pump around Recirculation Pump top	centrifugal	1200 x 10	40					
2/2	2-P-4002	Pump around Recirculation Pump top	centrifugal	1200 x 10	40					
1/2	1-P-4003	Pump around Recirculation Pump bottom	centrifugal	1050 x 10	35					
2/2	2-P-4003	Pump around Recirculation Pump bottom	centrifugal	1050 x 10	35					
<b>BLOWERS</b>				<b>Q (Nm<sup>3</sup>/h) x H (mmH<sub>2</sub>O)</b>						
1/2	1-B-4001 A/B/C	Flue Gas Blower	axial	1315000 x 1450	9300				Two blowers operating for each train and one common blower spare	
2/2	2-B-4001 A/B	Flue Gas Blower	axial	1315000 x 1450	9300					
<b>DRUMS</b>				<b>D (m) x H (m)</b>						
1/2	1-DCC-4001	Direct Contact Cooler Drum	vertical							
2/2	2-DCC-4001	Direct Contact Cooler Drum	vertical							
1/1	D-4001	Phase Separator Drum	vertical							
1/1	F-4002	Flash Drum	vertical	5 x 12						
<b>PACKAGES</b>										
1/1	PK-4001	Amine Reclaimer Area Soda Ash Dosing Amine Filter Package							Included in PK-4001	
1/1	MU-4001	Solvent Storage Tank							Included in PK-4001	

	CLIENT: IEA GREENHOUSE R&D PROGRAMME LOCATION: Germany PROJ. NAME: CO <sub>2</sub> Capture in Low-rank coal Power Plants CONTRACT N. 1BD0237A	REVISION	Rev.0		
		DATE	Nov-05		
		ISSUED BY	S.R.		
		CHECKED BY	L.M.		
		APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 5000 - CO<sub>2</sub> Compression and Drying - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COMPRESSOR</b>									
	1-K-5001	First Stage	Centrifugal	330000 Nm <sup>3</sup> /h					
	1-K-5002	Second Stage	Centrifugal	320000 Nm <sup>3</sup> /h					
	1-K-5003	Third Stage	Centrifugal	315000 Nm <sup>3</sup> /h					
	1-K-5004	Fourth Stage	Centrifugal	315000 Nm <sup>3</sup> /h					
<b>EXCHANGERS</b>									
				<b>Duty</b>		<b>Shell/Tube</b>	<b>Shell /Tube</b>		
	1-E-5001	Condensate Preheater	Shell & Tube	11000 kWth		6/14	190/150		
	1-E-5002	Lignite Drying Water Heater	Shell & Tube	7000 kWth		6/5	145/120		
	1-E-5003	Cooling Water Exchanger	Shell & Tube	12000 kWth		6/5	110/50		
	1-E-5004	Condensate Preheater	Shell & Tube	11000 kWth		14/14	195/150		
	1-E-5005	Lignite Drying Water Heater	Shell & Tube	7000 kWth		14/5	145/120		
	1-E-5006	Cooling Water Exchanger	Shell & Tube	9000 kWth		14/5	110/50		
	1-E-5007	Condensate Preheater	Shell & Tube	12000 kWth		32/14	200/150		
	1-E-5008	Lignite Drying Water Heater	Shell & Tube	7500 kWth		32/5	145/120		
	1-E-5009	Cooling Water Exchanger	Shell & Tube	10500 kWth		32/5	110/50		
	1-E-5010	Condensate Preheater	Shell & Tube	10000 kWth		76/14	190/150		
	1-E-5011	Lignite Drying Water Heater	Shell & Tube	8500 kWth		76/5	145/120		
	1-E-5012	Cooling Water Exchanger	Shell & Tube	38000 kWth		76/5	110/50		
<b>DRUMS</b>									
	1-D-5001	K.O. Drum							
	1-D5002	K.O. Drum							
<b>PUMPS</b>									
				<b>Q(m<sup>3</sup>/h) / H(m)</b>					
	1-P-5001	CO <sub>2</sub> Pump	Horizontal	750/540	1200 kW				
<b>DRYING PACKAGE</b>									
		Drying Package							Package including: - Two Drying beds (1 operating - 1 Regenerating) - Cooling Water Exchanger - Electric Heater - K.O. Drum



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. IBD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 4100 - Cooling Water and Machinery Cooling Water System - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COOLING TOWERS</b>									
				<b>Duty</b>					
1/2	1-TR-4101	Cooling Towers	Natural Draught	600 MWth					Package Including: - Distribution System - Heat Exchangers - Water Conditioning
2/2	2-TR-4101	Cooling Towers	Natural Draught	600 MWth					Package Including: - Distribution System - Heat Exchangers - Water Conditioning
<b>PACKAGES</b>									
1/2	1-PK-4101	Water Conditioning Package							Package Including: - Chemical Additives Storage Tanks - Chemical Additives Dosing Pumps
2/2	2-PK-4101	Water Conditioning Package							Package Including: - Chemical Additives Storage Tanks - Chemical Additives Dosing Pumps
<b>PUMPS</b>									
				<b>m<sup>3</sup>/h x m</b>					
1	P-4101 A/B/C/D/E	Cooling Water Pump		19400x55	3700 kW				All Operating - Electric Motor Driven One operating and one spare- Electric Motor Driven
1	P-4102 A/B	Machinery Cooling Water Pump		900x40	80 kW				
<b>BASINS</b>									
1/2	1-BA-4101	Cooling Water Basin							
2/2	2-BA-4101	Cooling Water Basin							
<b>FILTERS</b>									
1/2	1-F-4101	Filter							
2/2	2-F-4101	Filter							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**  
**Unit 4200 - Demi Water System - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4201	Demi Water Production System		2 lines 100 m <sup>3</sup> /h each					Package Including: - Neutralized Effluents Discharge Pump - Cationic Column - Decarbonation Tower - Decarbonation Tower Pump - Decarbonation Tower Fan - HCl System - NaOH System - Anionic Column - Neutralization Tank
<b>PUMPS</b>									
				<b>m<sup>3</sup>/h x m</b>					
1	P-4201 A/B	Demi Water Distribution Pump		100x60	40 kW				
1	P-4202	Filling Pump		375x25	45 kW				During Star-Up
<b>DRUMS</b>									
				<b>D(m)xH(m)</b>					
1	D-4201	Demi Water Storage Collection Basin A/B/C		12x18					Volume = 6000 m <sup>3</sup>





CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**

**Unit 4300 - Natural Gas Start-Up System - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4301	Natural Gas Reduction and Metering Station							Package Including: - Filter - Preheating System - Flow Indicator - Reduction Valves



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. 1BD0237A

REVISION	Rev.0		
DATE	Nov-05		
ISSUED BY	S.R.		
CHECKED BY	L.M.		
APPROVED BY	R.D.		

**EQUIPMENT LIST**  
**Unit 4400 - Plant Instrument Air System - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>COMPRESSORS</b>									
1	K-4401 A/B	Air Compressor		65500 Nm <sup>3</sup> /h	750 kW				Two operating and one spare - Electrical Motors Included
<b>DRUMS</b>									
1	D-4401	Compressed Air Drum							
<b>DRYER</b>									
1	DR-4401	Instrument Air Dryer							



CLIENT: IEA GREENHOUSE R&D PROGRAMME  
 LOCATION: Germany  
 PROJ. NAME: CO<sub>2</sub> Capture in Low-rank coal Power Plants  
 CONTRACT N. IBD0237A

REVISION	Rev.0
DATE	Nov-05
ISSUED BY	S.R.
CHECKED BY	L.M.
APPROVED BY	R.D.

**EQUIPMENT LIST**

**Unit 4500 - Raw-Service-Potable Water System - CFB Boiler with CO<sub>2</sub> Capture**

TRAIN	ITEM	DESCRIPTION	TYPE	SIZE	motor rating [kW]	P design [barg]	T design [°C]	Materials	Remarks
<b>PACKAGES</b>									
1	PK-4501	Clariflocculation System							Package Including: - Clariflocculator - Sludge Pump - Membrane Press - Recirculation Water System - Filtered Water System
1	PK-4502	Water Conditioning System							
1	PK-4503	Additives Package							
<b>PUMPS</b>									
				<b>m<sup>3</sup>/h x m</b>					
1	P-4501 A/B/C	Raw Water Pump		800x36	95 kW				Two operating - one spare
1	P-4502 A/B	Service Water Pump		75x40	10 kW				
1	P-4503 A/B	Cooling Towers Make-Up Pump		720x36	86 kW				
1	P-4504 A/B	Service Water Booster Pump		75x40	10 kW				
<b>DRUMS</b>									
				<b>D(m)xH(m)</b>					
1	BA-4501	Raw Water Pumping Basin							Volume = 880 m <sup>3</sup>
1	D-4501	Service Water Collection Basin		10x14					
<b>FILTERS</b>									
1	F-4501 A/B	Sand Filter							
1	F-4502 A/B...I/L	Sand Filter							

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 39 of 47

## **SECTION G.3**

## **ECONOMICS**

### **3.0 Introduction**

Purpose of this section is to summarize the results of the economic analysis made for the CFB technology, with and without the CO<sub>2</sub> sequestration (sections G.1 and G.2).

For the two alternatives, the economic analysis includes:

- Investment cost;
- Operation & Maintenance costs;
- Electric power production costs (C.O.E.);
- Sensitivity analysis:
  - C.O.E. vs. Discount rate (D.R.);
  - C.O.E. vs. Carbon Tax (C.T.).

### **3.1 Basis of Investment Cost evaluations**

The bases of the estimate for the two alternatives are the technical information provided in section G.1 and G.2.

With respect to the analysis already developed in section E, the main features of this investment cost evaluation are the following:

- Direct materials cost estimate of the CO<sub>2</sub> capture plant are based on a detailed design of the equipment and a budget quotation of the columns, as received from qualified Vendors.
- Power Island cost estimate is based on a steam turbine budgetary quotation, as received from Siemens.
- Utilities and Offsite unit costs are based on the design made for the main equipment of the different units.
- Estimate accuracy is within the range +/- 30%.

For all the other bases of investment cost evaluations, refer to section E, para 2.0.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section G: Detailed Information for the Selected Technology**

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 41 of 47

### **3.2 Investment cost of the two alternatives**

The following Tables G.3.1/2 show the investment break down and the total figures respectively for the CFB alternative without and with the CO<sub>2</sub> capture.

Tables G.3.3/4 show the break down of the Utilities and Offsite units for the two alternatives.

Table G.3.5 summarises the results of the estimate and shows the net specific investment cost for the two alternatives.



## Table G.3.1 - Case G.1 - ESTIMATE SUMMARY

**CFB Boiler without post-combustion CO<sub>2</sub> capture**

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : July 2005 REV. 0

FIGURE IN EURO

POS	DESCRIPTION	UNIT						REMARKS
		1000 €	1050 €	2000 €	3000 €	UTIL&OFF €	TOTAL €	
1	DIRECT MATERIALS	33,644,000	6,268,000	145,977,000	85,673,000	97,425,000	368,987,000	1) ESTIMATE ACCURACY +/- 30%  2) TODAY COSTS (ESCALATION NOT INCLUDED)  <b>1000</b> Storage and Handling of solid materials: Coal handling and storage Limestone handling and storage <b>1050</b> Coal Drying <b>2000</b> Boiler Island SNCR based DeNOx ESP Ash and Solid Removal <b>3000</b> Power Island <b>BOP</b> Utilities&Offsites
2	CONSTRUCTION	15,623,000	1,284,000	115,752,000	43,654,000	57,091,000	233,404,000	
3	OTHER COSTS	2,191,000	643,000	6,068,000	2,999,000	8,545,000	20,446,000	
4	EPC SERVICES	6,789,000	1,118,000	29,081,000	14,370,000	24,357,000	75,715,000	
		_____	_____	_____	_____	_____	_____	
A	<b>Installed costs</b> (contingency excluded)	<b>58,247,000</b>	<b>9,313,000</b>	<b>296,878,000</b>	<b>146,696,000</b>	<b>187,418,000</b>	<b>698,552,000</b>	
B	Contingency	%	7	7	7	7	7.0	
		Euro	4,077,290	651,910	20,781,460	10,268,720	13,119,260	
C	Fees (2% of A)	1,164,940	186,260	5,937,560	2,933,920	3,748,360	13,971,040	
D	Land Purchases; surveys (5% of A)	2,912,350	465,650	14,843,900	7,334,800	9,370,900	34,927,600	
		_____	_____	_____	_____	_____	_____	
<b>TOTAL INVESTMENT COST</b>		<b>66,401,580</b>	<b>10,616,820</b>	<b>338,440,920</b>	<b>167,233,440</b>	<b>213,656,520</b>	<b>796,349,280</b>	

### Table G.3.2 - Case G.2 - ESTIMATE SUMMARY

CFB Boiler with post-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : Novemeber 2005 REV. Final

FIGURE IN EURO

POS	DESCRIPTION	UNIT							UTIL&OFF	TOTAL	REMARKS
		1000 €	1050 €	2000 €	3000 €	4000 €	5000 €	€			
1	DIRECT MATERIALS	33,644,000	6,268,000	146,518,000	70,694,000	58,996,000	24,136,000	105,957,500	446,213,500	1) ESTIMATE ACCURACY +/- 30% 2) TODAY COSTS (ESCALATION NOT INCLUDED)  <b>1000</b> Storage and Handling of solid materials: Coal handling and storage Limestone handling and storage <b>1050</b> Coal Drying <b>2000</b> Boiler Island SCR based DeNOx ESP Ash and Solid Removal <b>3000</b> Power Island <b>4000</b> CO <sub>2</sub> capture plant <b>5000</b> CO <sub>2</sub> Compression & Drying <b>BOP</b> Utilities&Offsites	
2	CONSTRUCTION	15,623,000	1,284,000	116,180,000	36,022,000	34,572,000	9,377,000	62,090,000	275,148,000		
3	OTHER COSTS	2,191,000	643,000	6,091,000	2,474,000	5,174,000	1,369,000	9,291,000	27,233,000		
4	EPC SERVICES	6,789,000	1,118,000	29,189,000	11,857,000	11,799,000	2,625,000	26,490,000	89,867,000		
		_____	_____	_____	_____	_____	_____	_____	_____		
A	<b>Installed costs</b> (contingency excluded)	<b>58,247,000</b>	<b>9,313,000</b>	<b>297,978,000</b>	<b>121,047,000</b>	<b>110,541,000</b>	<b>37,507,000</b>	<b>203,828,500</b>	<b>838,461,500</b>		
B	Contingency										
	%	7	7	7	7	7	5	7	6.9		
	Euro	4,077,290	651,910	20,858,460	8,473,290	7,737,870	1,875,350	14,267,995	57,942,165		
C	Fees (2% of A)	1,164,940	186,260	5,959,560	2,420,940	2,210,820	750,140	4,076,570	16,769,230		
D	Land Purchases; surveys (5% of A)	2,912,350	465,650	14,898,900	6,052,350	5,527,050	1,875,350	10,191,425	41,923,075		
		_____	_____	_____	_____	_____	_____	_____	_____		
<b>TOTAL INVESTMENT COST</b>		<b>66,401,580</b>	<b>10,616,820</b>	<b>339,694,920</b>	<b>137,993,580</b>	<b>126,016,740</b>	<b>42,007,840</b>	<b>232,364,490</b>	<b>955,095,970</b>		



### Table G.3.3 - Case G.1 - BOP ESTIMATE SUMMARY

CFB Boiler without post-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : July 2005 REV. 0

FIGURE IN EURO

POS	DESCRIPTION	UNIT						TOTAL	REMARKS
		4100 €	4200 €	4400 €	4500 €	4300/4600/ 4700/4800 €	5000 €		
1	DIRECT MATERIALS	28,714,000	1,158,000	3,852,000	2,700,000	12,812,000	48,189,000	97,425,000	1) ESTIMATE ACCURACY +/- 30% 2) TODAY COSTS (ESCALATION NOT INCLUDED)
2	CONSTRUCTION	16,826,000	679,000	2,257,000	1,582,000	7,508,000	28,239,000	57,091,000	
3	OTHER COSTS	2,518,000	102,000	338,000	237,000	1,124,000	4,226,000	8,545,000	
4	EPC SERVICES	7,179,000	290,000	963,000	675,000	3,203,000	12,047,000	24,357,000	
A	<b>Installed costs</b> (contingency excluded)	<b>55,237,000</b>	<b>2,229,000</b>	<b>7,410,000</b>	<b>5,194,000</b>	<b>24,647,000</b>	<b>92,701,000</b>	<b>187,418,000</b>	<b>4100 Cooling Water system</b> <b>4200 Demineralized water system</b> <b>4300 Natural Gas System</b> <b>4400 Plant &amp; Instrument Air System</b> <b>4500 Raw-Service-Potable water system</b> <b>4600 Water Treatment</b> <b>4700 Fire Fighting system</b> <b>4800 Chemicals</b> <b>5000 Interconnecting (DCS, piping, HV substation etc.)</b>
B	Contingency	%	7	7	7	7	7	7.0	
		Euro	3,866,590	156,030	518,700	363,580	1,725,290	6,489,070	
C	Fees (2% of A)	1,104,740	44,580	148,200	103,880	492,940	1,854,020	3,748,360	
D	Land Purchases; surveys (5% of A)	2,761,850	111,450	370,500	259,700	1,232,350	4,635,050	9,370,900	
<b>TOTAL INVESTMENT COST</b>		<b>62,970,180</b>	<b>2,541,060</b>	<b>8,447,400</b>	<b>5,921,160</b>	<b>28,097,580</b>	<b>105,679,140</b>	<b>213,656,520</b>	

### Table G.3.4 - Case G.2 - BOP ESTIMATE SUMMARY

CFB Boiler with post-combustion CO<sub>2</sub> capture

Refer : 1-BD-0237A  
 Client : IEA GREENHOUSE GAS R&D PROGRAMME  
 Plant : CO<sub>2</sub> capture in low rank coals  
 Location : GERMANY (Inland)  
 Date : July 2005 REV. 0

FIGURE IN EURO

POS	DESCRIPTION	UNIT						TOTAL	REMARKS
		4100 €	4200 €	4400 €	4500 €	4300/4600/ 4700/4800 €	5000 €		
1	DIRECT MATERIALS	34,245,000	2,115,000	4,350,000	3,007,500	14,540,000	47,700,000	105,957,500	1) ESTIMATE ACCURACY +/- 30% 2) TODAY COSTS (ESCALATION NOT INCLUDED)
2	CONSTRUCTION	20,068,000	1,239,000	2,549,000	1,762,000	8,520,000	27,952,000	62,090,000	
3	OTHER COSTS	3,003,000	185,000	381,000	264,000	1,275,000	4,183,000	9,291,000	
4	EPC SERVICES	8,561,000	529,000	1,088,000	752,000	3,635,000	11,925,000	26,490,000	
A	<b>Installed costs</b> (contingency excluded)	<b>65,877,000</b>	<b>4,068,000</b>	<b>8,368,000</b>	<b>5,785,500</b>	<b>27,970,000</b>	<b>91,760,000</b>	<b>203,828,500</b>	<b>4100 Cooling Water system</b> <b>4200 Demineralized water system</b> <b>4300 Natural Gas System</b> <b>4400 Plant &amp; Instrument Air System</b> <b>4500 Raw-Service-Potable water system</b> <b>4600 Water Treatment</b> <b>4700 Fire Fighting system</b> <b>4800 Chemicals</b> <b>5000 Interconnecting (DCS, piping, HV substation etc.)</b>
B	Contingency	%	7	7	7	7	7	7.0	
		Euro	4,611,390	284,760	585,760	404,985	1,957,900	6,423,200	
C	Fees (2% of A)	1,317,540	81,360	167,360	115,710	559,400	1,835,200	4,076,570	
D	Land Purchases; surveys (5% of A)	3,293,850	203,400	418,400	289,275	1,398,500	4,588,000	10,191,425	
<b>TOTAL INVESTMENT COST</b>		<b>75,099,780</b>	<b>4,637,520</b>	<b>9,539,520</b>	<b>6,595,470</b>	<b>31,885,800</b>	<b>104,606,400</b>	<b>232,364,490</b>	

**Table G.3.5 - ESTIMATE SUMMARY**

POS	DESCRIPTION	Case G.1		Case G.2	
		CFB without CO <sub>2</sub> capture		CFB with CO <sub>2</sub> capture	
		€	%	€	%
1	Boiler Island	338.4	42.5	339.7	35.6
2	Process Units	77.0	9.7	203.0	21.3
3	CO <sub>2</sub> Compression and Drying	0	0.0	42.0	4.4
4	Power Island	167.2	21.0	138.0	14.4
5	Utilities and Offsite Units	213.7	26.8	232.4	24.3
<b>TOTAL INVESTMENT COST</b>		<b>796.3</b>	<b>100.0</b>	<b>955.1</b>	<b>100.0</b>
<b>NET POWER OUTPUT, MWe</b>		<b>791.8</b>		<b>609.7</b>	
<b>SPECIFIC INVESTMENT COST, Euro/kW</b>		<b>1006</b>		<b>1567</b>	

**3.3 Operation and maintenance costs**


Refer to section E, para 4.0, for general considerations on the operation and maintenance costs.

The variable costs of the two alternatives are summarized in the attached Table G.3.6.

The attached Table G.3.7 summarizes the maintenance costs of the two alternatives.

Below Table G.3.8 summarizes the total operating and maintenance costs of the two alternatives. Direct labor of the CFB alternative with the CO<sub>2</sub> capture is based on 115 total engaged personnel, as shown in section E, para. 4.2, table E.4.3.3. For the alternative without the CO<sub>2</sub> capture and compression units, the number of field operators can be reduced to 15 people (instead of 25), thus leading to a total personnel engaged for this alternative equal to 105.

**Table G.3.8 - CFB detailed information - Total O&M Costs**

		<b>Case G.1</b> Euro/year	<b>Case G.2</b> Euro/year
<b>Fixed Costs</b>	direct labour	5,250,000	5,750,000
	adm./gen overheads	1,575,000	1,725,000
	maintenance	23,631,000	26,630,000
<b>Subtotal</b>		30,456,000	34,105,000
<b>Variable Costs</b>		57,372,000	72,043,000
<b>TOTAL O&amp;M COSTS</b>		87,828,000	106,148,000



**Table G.3.6 - CFB detailed information  
Yearly Variable Costs**

Refer : 1-BD-0237A  
Client : IEA GREENHOUSE R & D PROJ.  
Date : July 2005 REV. 0

Yearly Operating hours =		7446			Case G.1 - CFB without CO <sub>2</sub> capture			Case G.2 - CFB with CO <sub>2</sub> capture		
Consumables	Unit Cost	Consumption		Oper. Costs (yearly basis)	Consumption		Oper. Costs (yearly basis)			
	Euro/t	Hourly kg/h	Yearly t/y		Hourly kg/h	Yearly t/y				
<b>Feedstock</b>										
Coal (as received)	10.50	592900	4414733.4	46,354,701	592900	4414733.4	46,354,701			
Limestone	20.0	23000	171258.0	3,425,160	27360	203722.6	4,074,451			
<b>Auxiliary feedstock</b>										
Make-up water	0.100	1108000	8250168.0	825,017	1582000	11779572.0	1,177,957			
<b>Solvents</b>										
MEA	1300	0	0.0	0	1466	10918.3	14,193,830			
<b>Catalyst</b>										
DENox Catalyst	10800	67.5	502.96	5,432,000	56.4	419.91	4,535,000			
<b>Chemicals</b>										
Ammonia	336	500.0	3723.0	1,250,928	500.0	3723.0	1,250,928			
Activated Carbon	1000	0.0	0.0	0	40.0	297.8	297,840			
Soda ash	110	0.0	0.0	0	90.0	670.1	73,715			
Coordinate phosphate	1.9	4.1	30.7	58	4.1	30.7	58			
Nalco Eliminox or equivalent	4132	2.7	20.3	84,050	2.7	20.3	84,050			
<b>TOTAL YEARLY OPERATING COSTS, Euro/year</b>				<b>57,371,913</b>	<b>72,042,530</b>					



**Table G.3.7 - CFB Detailed information  
Maintenance Costs**

Refer : 1-BD-0237A  
Client : IEA  
Date : Novemeber 2005

Complex section	Maintenance %	Case G.1		Case G.2	
		Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year	Capital Cost Euro x 10 <sup>3</sup> (1)	Maintenance 10 <sup>3</sup> Euro/Year
<b>COAL HANDLING, DRYING, MILLING, BOILER ISLAND, POW. ISL.</b>	4.0	511134	20445	486585	19463
<b>CO<sub>2</sub> CAPUTRE PLANT, CO<sub>2</sub> COMPRESS. AND DRYING</b>	2.5	0	0	148048	3701
<b>Common facilities (BOP)</b>	1.7	187418	3186	203829	3465
<b>TOTAL</b>		698552	23631	838462	26630
		Maint. % =	3.4	Maint. % =	3.2

**3.4 Evaluation of the Electric Power cost and CO<sub>2</sub> removal cost**

**3.4.1 Electric Power cost**

Refer to section E, para 5.0, for general considerations on the operation and maintenance costs.

Tables A.G.1/2, attached to the end of this section, show the economic analysis of the two alternatives.

The sensitivity analysis with 5% discount rate on the investment cost is shown in the attached Tables A.G.3/4.

Below Table G.3.9 summarizes the electric power cost for the two alternatives, with 10% and 5% discount rate applied on the Total Investment Cost.

**Table G.3.9 - Electric power cost.**

ALTERNATIVE		Case G.1 no capture	Case G.1 no capture	Case G.2 capture	Case G.2 capture
Discount rate	%	10	5	10	5
Coal Flowrate	t/h	592.9	592.9	592.9	592.9
Net Power Output	MWe	791.8	791.8	609.7	609.7
Total Investment Cost	MM Euro	796.3	796.3	955.1	955.1
<b>Specif Net Inv. Cost</b>	<b>Euro/kW</b>	<b>1006</b>	<b>1006</b>	<b>1567</b>	<b>1567</b>
Revenues/year	MM Euro/year	203.8	164.1	244.6	196.9
<b>Electricity Prod. Cost</b>	<b>cEuro/kWh</b>	<b>3.46</b>	<b>2.78</b>	<b>5.39</b>	<b>4.34</b>

**3.4.2 CO<sub>2</sub> removal cost**

The CO<sub>2</sub> removal cost can be expressed as follows:

$$\frac{\Delta \text{ Electric Power Cost}}{\Delta \text{ Specific CO}_2 \text{ emission}} [=] \frac{\text{Euro}}{\text{t of CO}_2 \text{ captured}}$$

where:

- $\Delta$  Electric Power Cost = Electric Power Cost of the alternative with CO<sub>2</sub> capture – Electric Power Cost of alternative w/o CO<sub>2</sub> capture. The Unit of measurement is Euro/kWh.
- $\Delta$  Specific CO<sub>2</sub> emission = Ratio of (CO<sub>2</sub> emission/Power production) of alternative with CO<sub>2</sub> capture – ratio of (CO<sub>2</sub> emission/Power production) of the alternative with CO<sub>2</sub> capture. The unit of measurement is ton CO<sub>2</sub>/kWh.

The following Table G.3.10 summarizes the CO<sub>2</sub> removal cost with 10% and 5% discount rate applied on the Total Investment Cost.

**Table G.3.10 - CO<sub>2</sub> removal cost.**

ALTERNATIVE		Case G.1 no capture	Case G.2 capture	Case G.1 no capture	Case G.2 capture
Discount rate	%	<b>10</b>	<b>10</b>	<b>5</b>	<b>5</b>
Coal Flowrate	t/h	592.9	592.9	592.9	592.9
Net Power Output	MWe	791.8	609.7	791.8	609.7
Total Investment Cost	MM Euro	796.3	955.1	796.3	955.1
Specif Net Inv. Cost	Euro/kW	<b>1006</b>	<b>1566.5</b>	<b>1006</b>	<b>1566.5</b>
Revenues/year	MM Euro/year	203.8	244.6	164.1	196.9
Electricity Prod. Cost	cEuro/kWh	<b>3.46</b>	<b>5.39</b>	<b>2.78</b>	<b>4.34</b>
CO <sub>2</sub> emissions	t/h	689.7	103.5	689.7	103.5
CO <sub>2</sub> specific emiss.	10 <sup>-3</sup> kg/kWh	871.1	169.8	871.1	169.8
<b>CO<sub>2</sub> removal cost</b>	Euro/t	-	<b>27.5</b>	-	<b>22.2</b>



### 3.4.3 Electric Power cost in presence of carbon tax

The following Tables summarize the economic analyses performed in order to evaluate the electric power production cost in presence of a carbon tax, expressed as Euro/t of CO<sub>2</sub> emitted.

The economic analysis is performed respectively at 25 and 50 Euro/t of CO<sub>2</sub> emitted.

The Tables A.G.5/8, attached to the end of this section, show the economic analysis of the two alternatives at the above carbon tax values and 10% discount rate.

The sensitivity analysis with 5% discount rate on the investment cost is shown in the attached Tables A.G.9/12.

Tables G.3.11 and 12 summarize the electric power cost for the two alternatives, with 10% and 5% discount rate applied on the Total Investment Cost at different carbon tax value.

Fig. G.3.1 also reports the results of the economic analysis shown in the previous tables. This figure shows that the taxation level necessary to make the two alternatives economically equivalent are approximately 27 and 22 Euro/t of CO<sub>2</sub> emitted, respectively for a discount rate of 10% and 5%.

**Table G.3.11** - Electric power cost at different carbon tax value (DCF=10%).

ALTERNATIVE		Case G.1 no capture	Case G.2 capture	Case G.1 no capture	Case G.2 capture	Case G.1 no capture	Case G.2 capture
Discount rate	%	10	10	10	10	10	10
Carbon tax	Euro/t	0	0	25	25	50	50
Coal Flowrate	t/h	592.9	592.9	592.9	592.9	592.9	592.9
Net Power Output	MWe	791.8	609.7	791.8	609.7	791.8	609.7
CO <sub>2</sub> emissions	t/h	689.7	103.5	689.7	103.5	689.7	103.5
Total Investment Cost	MM Euro	796.3	955.1	796.3	955.1	796.3	955.1
Specif Net Inv. Cost	Euro/kW	<b>1006</b>	<b>1566.5</b>	<b>1006</b>	<b>1566.5</b>	<b>1006</b>	<b>1566.5</b>
Revenues/year	MM Euro/year	203.8	244.6	203.8	244.6	203.8	244.6
Electricity Prod. Cost	cEuro/kWh	<b>3.46</b>	<b>5.39</b>	<b>5.63</b>	<b>5.81</b>	<b>7.81</b>	<b>6.24</b>

**Table G.3.12** - Electric power cost at different carbon tax value (DCF=5%).

ALTERNATIVE		Case G.1 no capture	Case G.2 capture	Case G.1 no capture	Case G.2 capture	Case G.1 no capture	Case G.2 capture
Discount rate	%	5	5	5	5	5	5
Carbon tax	Euro/t	0	0	25	25	50	50
Coal Flowrate	t/h	592.9	592.9	592.9	592.9	592.9	592.9
Net Power Output	MWe	791.8	609.7	791.8	609.7	791.8	609.7
CO <sub>2</sub> emissions	t/h	689.7	103.5	689.7	103.5	689.7	103.5
Total Investment Cost	MM Euro	796.3	955.1	796.3	955.1	796.3	955.1
Specif Net Inv. Cost	Euro/kW	<b>1006</b>	<b>1566.5</b>	<b>1006</b>	<b>1566.5</b>	<b>1006</b>	<b>1566.5</b>
Revenues/year	MM Euro/year	164.1	196.9	203.8	244.6	203.8	244.6
Electricity Prod. Cost	cEuro/kWh	<b>2.78</b>	<b>4.34</b>	<b>4.96</b>	<b>4.76</b>	<b>7.14</b>	<b>5.19</b>




TABLE A.G.1 - CFB without CO<sub>2</sub> capture- Cost Evaluation - Discount Rate = 10%

Rev. : 0  
Date : July 2005  
Page : 1 of 1

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0346	Euro/kWh	
Coal Florate	592.9	t/h	Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00	%	
Net Power Output	791.8	MW	Land purchase; surveys	34.9	Fuel Cost	46.4	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	14.0	Maintenance	23.6	Total Working capital	1.8	Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	48.9	Waste Disposal	0.0			Revenues / year	203.8	MM Euro/year
			Total Investment Cost	796.3	Chemicals + Consumable	11.0	<b>Labour Cost</b>	<b>MM Euro/year</b>			
					Insurance and local taxes	14.0	# operators	111			
							Salary	0.05			
							Direct Labour Cost	5.6	NPV	0.00	
							Administration	30% L.C. 1.7	IRR	10.00%	
							Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
Load Factor				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
Equivalent yearly hours				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
Expenditure Factor		20%	45%	35%																										
Revenues																														
Electric Energy				107.9	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8	203.8		
Operating Costs																														
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4		
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6		
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2		
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0		
Working Capital Cost				-1.8																										
Fixed Capital Expenditures		-159.3	-358.4	-278.7																										
Total Cash flow (yearly)		-159.3	-358.4	-278.7	38.8	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	1.8	
Total Cash flow (cumulated)		-159.3	-517.6	-796.3	-757.6	-655.9	-554.3	-452.6	-351.0	-249.3	-147.7	-46.1	55.6	157.2	258.9	360.5	462.2	563.8	665.4	767.1	868.7	970.4	1072.0	1173.7	1275.3	1377.0	1478.6	1580.2	1681.9	1683.7
Discounted Cash Flow (Yearly)		-144.8	-296.2	-209.4	26.5	63.1	57.4	52.2	47.4	43.1	39.2	35.6	32.4	29.4	26.8	24.3	22.1	20.1	18.3	16.6	15.1	13.7	12.5	11.4	10.3	9.4	8.5	7.8	7.0	0.1
Discounted Cash Flow (Cumul.)		-144.8	-441.0	-650.4	-623.9	-560.8	-503.4	-451.2	-403.8	-360.7	-321.5	-285.9	-253.5	-224.1	-197.3	-173.0	-150.8	-130.7	-112.4	-95.8	-80.7	-67.0	-54.5	-43.1	-32.8	-23.4	-14.9	-7.2	-0.1	0.0

1.8

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0539	Euro/kWh	
Coal Florate	592.9	t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%	
Net Power Output	609.7	MW	Land purchase; surveys	41.9	Fuel Cost	46.4	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	16.8	Maintenance	26.6	Total Working capital	3.2	Discount rate	10.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	57.9	Waste Disposal	0.0			Revenues / year	244.6	MM Euro/year
			Total Investment Cost	955.1	Chemicals + Consumable	25.7	<b>Labour Cost</b>	<b>MM Euro/year</b>			
					Insurance and local taxes	16.8	# operators	111			
							Salary	0.05			
							Direct Labour Cost	5.6	<b>NPV</b>	0.00	
							Administration	30% L.C. 1.7	<b>IRR</b>	10.00%	
							Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				129.5	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	244.6	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-191.0	-429.8	-334.3																										
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	46.4	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-908.7	-786.8	-664.9	-543.0	-421.1	-299.2	-177.3	-55.3	66.6	188.5	310.4	432.3	554.2	676.1	798.0	919.9	1041.9	1163.8	1285.7	1407.6	1529.5	1651.4	1773.3	1895.2	2017.1	2020.4
<b>Discounted Cash Flow (Yearly)</b>	-173.7	-355.2	-251.2	31.7	75.7	68.8	62.6	56.9	51.7	47.0	42.7	38.8	35.3	32.1	29.2	26.5	24.1	21.9	19.9	18.1	16.5	15.0	13.6	12.4	11.3	10.2	9.3	8.5	0.2
<b>Discounted Cash Flow (Cumul.)</b>	-173.7	-528.9	-780.0	-748.3	-672.6	-603.8	-541.3	-484.4	-432.7	-385.7	-343.0	-304.1	-268.8	-236.7	-207.5	-181.0	-156.9	-134.9	-115.0	-96.9	-80.4	-65.4	-51.8	-39.4	-28.2	-18.0	-8.7	-0.2	0.0

3.2

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0278 Euro/kWh
Coal Florate	592.9 t/h		Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00 %
Net Power Output	791.8 MW		Land purchase; surveys	34.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00 %
Fuel Price	10.50 Euro/t (*)		Fees	14.0	Maintenance	Total Working capital	1.8	Discount rate	5.00 %
Insurance and local taxes	2% Installed cost		Average Contingencies	48.9	Waste Disposal			Revenues / year	164.1 MM Euro/year
			Total Investment Cost	796.3	Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>		
					Insurance and local taxes	# operators	111		
						Salary	0.05	<b>NPV</b>	<b>0.00</b>
						Direct Labour Cost	5.6	<b>IRR</b>	<b>5.00%</b>
						Administration 30% L.C.	1.7		
						Total Labour Cost	7.2		

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expediture Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				86.9	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	164.1	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	
<b>Working Capital Cost</b>				-1.8																									
<b>Fixed Capital Expenditures</b>	-159.3	-358.4	-278.7																										
<b>Total Cash flow (yearly)</b>	-159.3	-358.4	-278.7	17.7	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	
<b>Total Cash flow (cumulated)</b>	-159.3	-517.6	-796.3	-778.6	-716.7	-654.9	-593.0	-531.1	-469.2	-407.3	-345.5	-283.6	-221.7	-159.8	-97.9	-36.1	25.8	87.7	149.6	211.5	273.3	335.2	397.1	459.0	520.9	582.7	644.6	706.5	
<b>Discounted Cash Flow (Yearly)</b>	-151.7	-325.0	-240.8	14.6	48.5	46.2	44.0	41.9	39.9	38.0	36.2	34.5	32.8	31.3	29.8	28.3	27.0	25.7	24.5	23.3	22.2	21.2	20.1	19.2	18.3	17.4	16.6	15.8	
<b>Discounted Cash Flow (Cumul.)</b>	-151.7	-476.7	-717.5	-702.9	-654.4	-608.2	-564.3	-522.4	-482.5	-444.5	-408.3	-373.9	-341.1	-309.8	-280.0	-251.7	-224.7	-199.0	-174.5	-151.2	-129.0	-107.8	-87.7	-68.5	-50.2	-32.8	-16.2	-0.4	

1.8

 0.4  
 0.0

<b>Production</b>			<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.0434</b>	Euro/kWh
Coal Florate	592.9	t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	609.7	MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50	Euro/t (*)	Fees	16.8	Maintenance	Total Working capital	3.2	Discount rate	5.00	%
Insurance and local taxes	2%	Installed cost	Average Contingencies	57.9	Waste Disposal			Revenues / year	196.9	MM Euro/year
			Total Investment Cost	955.1	Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>			
					Insurance and local taxes	# operators	111			
						Salary	0.05	<b>NPV</b>	<b>0.00</b>	
						Direct Labour Cost	5.6	<b>IRR</b>	<b>5.00%</b>	
						Administration	30% L.C. 1.7			
						Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				104.2	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	196.9	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-191.0	-429.8	-334.3																										
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	21.1	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-934.0	-859.8	-785.6	-711.4	-637.2	-563.0	-488.8	-414.6	-340.4	-266.2	-191.9	-117.7	-43.5	30.7	104.9	179.1	253.3	327.5	401.7	475.9	550.1	624.3	698.5	772.7	846.9	
<b>Discounted Cash Flow (Yearly)</b>	-181.9	-389.8	-288.8	17.4	58.1	55.4	52.7	50.2	47.8	45.6	43.4	41.3	39.4	37.5	35.7	34.0	32.4	30.8	29.4	28.0	26.6	25.4	24.2	23.0	21.9	20.9	19.9	18.9	
<b>Discounted Cash Flow (Cumul.)</b>	-181.9	-571.8	-860.5	-843.2	-785.0	-729.6	-676.9	-626.7	-578.9	-533.3	-489.9	-448.6	-409.2	-371.8	-336.1	-302.1	-269.7	-238.9	-209.5	-181.5	-154.9	-129.5	-105.4	-82.4	-60.5	-39.6	-19.7	-0.8	

3.2

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0563	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00	%
Net Power Output	791.8 MW	Land purchase; surveys	34.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	14.0	CO <sub>2</sub> cost	Total Working capital	1.8	Discount rate	10.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	48.9	Maintenance			Revenues / year	332.2	MM Euro/year
CO2 emissions	689.7 t/h	Total Investment Cost	796.3	Waste Disposal			Carbon tax =	25	Euro/t
				Chemicals + Consumable					
				Insurance and local taxes					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111			
					Salary	0.05			
					Direct Labour Cost	5.6	NPV	0.00	
					Administration	30% L.C. 1.7	IRR	10.00%	
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				175.9	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2	332.2		
<b>Operating Costs</b>																														
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4		
CO <sub>2</sub>				-68.0	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4		
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6		
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2		
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0		
<b>Working Capital Cost</b>				-1.8																										
<b>Fixed Capital Expenditures</b>		-159.3	-358.4	-278.7																										
<b>Total Cash flow (yearly)</b>		-159.3	-358.4	-278.7	38.8	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6		
<b>Total Cash flow (cumulated)</b>		-159.3	-517.6	-796.3	-757.6	-655.9	-554.3	-452.6	-351.0	-249.3	-147.7	-46.1	55.6	157.2	258.9	360.5	462.2	563.8	665.4	767.1	868.7	970.4	1072.0	1173.7	1275.3	1377.0	1478.6	1580.2	1681.9	1683.7
<b>Discounted Cash Flow (Yearly)</b>		-144.8	-296.2	-209.4	26.5	63.1	57.4	52.2	47.4	43.1	39.2	35.6	32.4	29.4	26.8	24.3	22.1	20.1	18.3	16.6	15.1	13.7	12.5	11.4	10.3	9.4	8.5	7.8	7.0	0.1
<b>Discounted Cash Flow (Cumul.)</b>		-144.8	-441.0	-650.4	-623.9	-560.8	-503.4	-451.2	-403.8	-360.7	-321.5	-285.9	-253.5	-224.1	-197.3	-173.0	-150.8	-130.7	-112.4	-95.8	-80.7	-67.0	-54.5	-43.1	-32.8	-23.4	-14.9	-7.2	-0.1	0.0



<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0781	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00	%
Net Power Output	791.8 MW	Land purchase; surveys	34.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	14.0	CO <sub>2</sub> cost	Total Working capital	1.8	Discount rate	10.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	48.9	Maintenance			Revenues / year	460.6	MM Euro/year
CO2 emissions	689.7 t/h	Total Investment Cost	796.3	Waste Disposal			Carbon tax =	50	Euro/t
				Chemicals + Consumable					
				Insurance and local taxes					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)									
					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111	NPV	0.00	
					Salary	0.05	IRR	10.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				243.9	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6	460.6		
<b>Operating Costs</b>																														
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4		
CO <sub>2</sub>				-135.9	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8		
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6		
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2		
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0		
<b>Working Capital Cost</b>				-1.8																										
<b>Fixed Capital Expenditures</b>		-159.3	-358.4	-278.7																										
<b>Total Cash flow (yearly)</b>		-159.3	-358.4	-278.7	38.8	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6		
<b>Total Cash flow (cumulated)</b>		-159.3	-517.6	-796.3	-757.6	-655.9	-554.3	-452.6	-351.0	-249.3	-147.7	-46.1	55.6	157.2	258.9	360.5	462.2	563.8	665.4	767.1	868.7	970.4	1072.0	1173.7	1275.3	1377.0	1478.6	1580.2	1681.9	1683.7
<b>Discounted Cash Flow (Yearly)</b>		-144.8	-296.2	-209.4	26.5	63.1	57.4	52.2	47.4	43.1	39.2	35.6	32.4	29.4	26.8	24.3	22.1	20.1	18.3	16.6	15.1	13.7	12.5	11.4	10.3	9.4	8.5	7.8	7.0	0.1
<b>Discounted Cash Flow (Cumul.)</b>		-144.8	-441.0	-650.4	-623.9	-560.8	-503.4	-451.2	-403.8	-360.7	-321.5	-285.9	-253.5	-224.1	-197.3	-173.0	-150.8	-130.7	-112.4	-95.8	-80.7	-67.0	-54.5	-43.1	-32.8	-23.4	-14.9	-7.2	-0.1	0.0

TABLE A.G.7 - CFB with CO<sub>2</sub> capture- Cost Evaluation - Discount Rate = 10%

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0581	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	609.7 MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	16.8	CO <sub>2</sub> cost	Total Working capital	3.2	Discount rate	10.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	57.9	Maintenance			Revenues / year	263.8	MM Euro/year
CO <sub>2</sub> emissions	103.5 t/h	Total Investment Cost	955.1	Waste Disposal			Carbon tax =	25	Euro/t
				Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>			
				Insurance and local taxes	# operators	111	NPV	0.00	
					Salary	0.05	IRR	10.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				139.7	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	263.8	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
CO <sub>2</sub>				-10.2	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-191.0	-429.8	-334.3																										
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	46.4	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-908.7	-786.8	-664.9	-543.0	-421.1	-299.2	-177.3	-55.3	66.6	188.5	310.4	432.3	554.2	676.1	798.0	919.9	1041.9	1163.8	1285.7	1407.6	1529.5	1651.4	1773.3	1895.2	2017.1	2020.4
<b>Discounted Cash Flow (Yearly)</b>	-173.7	-355.2	-251.2	31.7	75.7	68.8	62.6	56.9	51.7	47.0	42.7	38.8	35.3	32.1	29.2	26.5	24.1	21.9	19.9	18.1	16.5	15.0	13.6	12.4	11.3	10.2	9.3	8.5	0.2
<b>Discounted Cash Flow (Cumul.)</b>	-173.7	-528.9	-780.0	-748.3	-672.6	-603.8	-541.3	-484.4	-432.7	-385.7	-343.0	-304.1	-268.8	-236.7	-207.5	-181.0	-156.9	-134.9	-115.0	-96.9	-80.4	-65.4	-51.8	-39.4	-28.2	-18.0	-8.7	-0.2	0.0

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0624	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	609.7 MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	16.8	CO <sub>2</sub> cost	Total Working capital	3.2	Discount rate	10.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	57.9	Maintenance			Revenues / year	283.1	MM Euro/year
CO2 emissions	103.5 t/h	Total Investment Cost	955.1	Waste Disposal			Carbon tax =	50	Euro/t
				Chemicals + Consumable					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)				Insurance and local taxes					
					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111			
					Salary	0.05	NPV	0.00	
					Direct Labour Cost	5.6	IRR	10.00%	
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				149.9	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	283.1	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
CO <sub>2</sub>				-20.4	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-191.0	-429.8	-334.3																										
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	46.4	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	121.9	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-908.7	-786.8	-664.9	-543.0	-421.1	-299.2	-177.3	-55.3	66.6	188.5	310.4	432.3	554.2	676.1	798.0	919.9	1041.9	1163.8	1285.7	1407.6	1529.5	1651.4	1773.3	1895.2	2017.1	2020.4
<b>Discounted Cash Flow (Yearly)</b>	-173.7	-355.2	-251.2	31.7	75.7	68.8	62.6	56.9	51.7	47.0	42.7	38.8	35.3	32.1	29.2	26.5	24.1	21.9	19.9	18.1	16.5	15.0	13.6	12.4	11.3	10.2	9.3	8.5	0.2
<b>Discounted Cash Flow (Cumul.)</b>	-173.7	-528.9	-780.0	-748.3	-672.6	-603.8	-541.3	-484.4	-432.7	-385.7	-343.0	-304.1	-268.8	-236.7	-207.5	-181.0	-156.9	-134.9	-115.0	-96.9	-80.4	-65.4	-51.8	-39.4	-28.2	-18.0	-8.7	-0.2	0.0

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0496	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00	%
Net Power Output	791.8 MW	Land purchase; surveys	34.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	14.0	CO <sub>2</sub> cost	Total Working capital	1.8	Discount rate	5.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	48.9	Maintenance			Revenues / year	292.5	MM Euro/year
CO <sub>2</sub> emissions	689.7 t/h	Total Investment Cost	796.3	Waste Disposal			Carbon tax =	25	Euro/t
				Chemicals + Consumable					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)				Insurance and local taxes					
					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111	<b>NPV</b>	0.00	
					Salary	0.05	<b>IRR</b>	5.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446		
<b>Expenditure Factor</b>		20%	45%	35%																										
<b>Revenues</b>																														
Electric Energy				154.8	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5		
<b>Operating Costs</b>																														
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4		
CO <sub>2</sub>				-68.0	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4	-128.4		
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6		
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2		
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0		
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0		
<b>Working Capital Cost</b>				-1.8																										
<b>Fixed Capital Expenditures</b>		-159.3	-358.4	-278.7																										
<b>Total Cash flow (yearly)</b>		-159.3	-358.4	-278.7	17.7	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9		
<b>Total Cash flow (cumulated)</b>		-159.3	-517.6	-796.3	-778.6	-716.7	-654.9	-593.0	-531.1	-469.2	-407.3	-345.5	-283.6	-221.7	-159.8	-97.9	-36.1	25.8	87.7	149.6	211.5	273.3	335.2	397.1	459.0	520.9	582.7	644.6	706.5	768.3
<b>Discounted Cash Flow (Yearly)</b>		-151.7	-325.0	-240.8	14.6	48.5	46.2	44.0	41.9	39.9	38.0	36.2	34.5	32.8	31.3	29.8	28.3	27.0	25.7	24.5	23.3	22.2	21.2	20.1	19.2	18.3	17.4	16.6	15.8	15.0
<b>Discounted Cash Flow (Cumul.)</b>		-151.7	-476.7	-717.5	-702.9	-654.4	-608.2	-564.3	-522.4	-482.5	-444.5	-408.3	-373.9	-341.1	-309.8	-280.0	-251.7	-224.7	-199.0	-174.5	-151.2	-129.0	-107.8	-87.7	-68.5	-50.2	-32.8	-16.2	-0.4	0.0

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0714	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	698.6	<b>at 85% load factor</b>	30 days Chemical Storage	1.1	Inflation	0.00	%
Net Power Output	791.8 MW	Land purchase; surveys	34.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	14.0	CO <sub>2</sub> cost	Total Working capital	1.8	Discount rate	5.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	48.9	Maintenance			Revenues / year	420.8	MM Euro/year
CO2 emissions	689.7 t/h	Total Investment Cost	796.3	Waste Disposal			Carbon tax =	50	Euro/t
				Chemicals + Consumable					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)				Insurance and local taxes					
					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111	NPV	0.00	
					Salary	0.05	IRR	5.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				222.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	420.8	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
CO <sub>2</sub>				-135.9	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	-256.8	
Maintenance				-15.8	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	-23.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-5.8	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	-11.0	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	-14.0	
<b>Working Capital Cost</b>				-1.8																									
<b>Fixed Capital Expenditures</b>		-159.3	-358.4	-278.7																									
<b>Total Cash flow (yearly)</b>	-159.3	-358.4	-278.7	17.7	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	61.9	
<b>Total Cash flow (cumulated)</b>	-159.3	-517.6	-796.3	-778.6	-716.7	-654.9	-593.0	-531.1	-469.2	-407.3	-345.5	-283.6	-221.7	-159.8	-97.9	-36.1	25.8	87.7	149.6	211.5	273.3	335.2	397.1	459.0	520.9	582.7	644.6	706.5	768.3
<b>Discounted Cash Flow (Yearly)</b>	-151.7	-325.0	-240.8	14.6	48.5	46.2	44.0	41.9	39.9	38.0	36.2	34.5	32.8	31.3	29.8	28.3	27.0	25.7	24.5	23.3	22.2	21.2	20.1	19.2	18.3	17.4	16.6	15.8	15.0
<b>Discounted Cash Flow (Cumul.)</b>	-151.7	-476.7	-717.5	-702.9	-654.4	-608.2	-564.3	-522.4	-482.5	-444.5	-408.3	-373.9	-341.1	-309.8	-280.0	-251.7	-224.7	-199.0	-174.5	-151.2	-129.0	-107.8	-87.7	-68.5	-50.2	-32.8	-16.2	-0.4	0.0

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	<b>0.0476</b>	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	609.7 MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	16.8	CO <sub>2</sub> cost	Total Working capital	3.2	Discount rate	5.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	57.9	Maintenance			Revenues / year	216.1	MM Euro/year
CO2 emissions	103.5 t/h	Total Investment Cost	955.1	Waste Disposal			Carbon tax =	25	Euro/t
				Chemicals + Consumable	<b>Labour Cost</b>	<b>MM Euro/year</b>			
				Insurance and local taxes	# operators	111	NPV	0.00	
					Salary	0.05	IRR	5.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

(\*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				114.4	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	216.1	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
CO <sub>2</sub>				-10.2	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	-19.3	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>		-191.0	-429.8	-334.3																									
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	21.1	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-934.0	-859.8	-785.6	-711.4	-637.2	-563.0	-488.8	-414.6	-340.4	-266.2	-191.9	-117.7	-43.5	30.7	104.9	179.1	253.3	327.5	401.7	475.9	550.1	624.3	698.5	772.7	846.9	850.1
<b>Discounted Cash Flow (Yearly)</b>	-181.9	-389.8	-288.8	17.4	58.1	55.4	52.7	50.2	47.8	45.6	43.4	41.3	39.4	37.5	35.7	34.0	32.4	30.8	29.4	28.0	26.6	25.4	24.2	23.0	21.9	20.9	19.9	18.9	0.8
<b>Discounted Cash Flow (Cumul.)</b>	-181.9	-571.8	-860.5	-843.2	-785.0	-729.6	-676.9	-626.7	-578.9	-533.3	-489.9	-448.6	-409.2	-371.8	-336.1	-302.1	-269.7	-238.9	-209.5	-181.5	-154.9	-129.5	-105.4	-82.4	-60.5	-39.6	-19.7	-0.8	0.0

TABLE A.G.12 - CFB with CO<sub>2</sub> capture- Cost Evaluation - Discount Rate = 10%

<b>Production</b>		<b>Capital Expenditures</b>	<b>MM Euro</b>	<b>Operating Costs [MM Euro/year]</b>	<b>Working Capital</b>	<b>MM Euro</b>	Electricity Production Cost	0.0519	Euro/kWh
Coal Fiorate	592.9 t/h	Installed Costs	838.5	<b>at 85% load factor</b>	30 days Chemical Storage	2.5	Inflation	0.00	%
Net Power Output	609.7 MW	Land purchase; surveys	41.9	Fuel Cost	5 days Coal Storage	0.7	Taxes	0.00	%
Fuel Price	10.50 Euro/t (*)	Fees	16.8	CO <sub>2</sub> cost	Total Working capital	3.2	Discount rate	5.00	%
Insurance and local taxes	2% Installed cost	Average Contingencies	57.9	Maintenance			Revenues / year	235.4	MM Euro/year
CO2 emissions	103.5 t/h	Total Investment Cost	955.1	Waste Disposal			Carbon tax =	50	Euro/t
				Chemicals + Consumable					
				Insurance and local taxes					
(*) 10.5 Euro/t = 1 \$/GJ (1 Euro= 1 \$)									
					<b>Labour Cost</b>	<b>MM Euro/year</b>			
					# operators	111	NPV	0.00	
					Salary	0.05	IRR	5.00%	
					Direct Labour Cost	5.6			
					Administration	30% L.C. 1.7			
					Total Labour Cost	7.2			

CASH FLOW ANALYSIS Millions Euro	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
	000	00	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
<b>Load Factor</b>				45%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	
<b>Equivalent yearly hours</b>				3942	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	7446	
<b>Expenditure Factor</b>		20%	45%	35%																									
<b>Revenues</b>																													
Electric Energy				124.6	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	235.4	
<b>Operating Costs</b>																													
Fuel Cost				-24.5	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	-46.4	
CO <sub>2</sub>				-20.4	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	-38.5	
Maintenance				-17.8	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	-26.6	
Labour				-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
Chemicals & Consumables				-13.6	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	-25.7	
Waste Disposal				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance				-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	-16.8	
<b>Working Capital Cost</b>				-3.2																									
<b>Fixed Capital Expenditures</b>	-191.0	-429.8	-334.3																										
<b>Total Cash flow (yearly)</b>	-191.0	-429.8	-334.3	21.1	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	74.2	
<b>Total Cash flow (cumulated)</b>	-191.0	-620.8	-955.1	-934.0	-859.8	-785.6	-711.4	-637.2	-563.0	-488.8	-414.6	-340.4	-266.2	-191.9	-117.7	-43.5	30.7	104.9	179.1	253.3	327.5	401.7	475.9	550.1	624.3	698.5	772.7	846.9	850.1
<b>Discounted Cash Flow (Yearly)</b>	-181.9	-389.8	-288.8	17.4	58.1	55.4	52.7	50.2	47.8	45.6	43.4	41.3	39.4	37.5	35.7	34.0	32.4	30.8	29.4	28.0	26.6	25.4	24.2	23.0	21.9	20.9	19.9	18.9	0.8
<b>Discounted Cash Flow (Cumul.)</b>	-181.9	-571.8	-860.5	-843.2	-785.0	-729.6	-676.9	-626.7	-578.9	-533.3	-489.9	-448.6	-409.2	-371.8	-336.1	-302.1	-269.7	-238.9	-209.5	-181.5	-154.9	-129.5	-105.4	-82.4	-60.5	-39.6	-19.7	-0.8	0.0

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section H: Year 2020 Improvements**

Revision no.: Final  
 Date: November 2005  
 Sheet: 1 of 18

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
 PROJECT NAME : CO<sub>2</sub> Capture in Low-rank Coal Power Plants  
 DOCUMENT NAME : YEAR 2020 IMPROVEMENTS

ISSUED BY : G.L. FARINA  
 CHECKED BY : G.L. FARINA  
 APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by



---

IEA GHG

CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS

Section H: Year 2020 Improvements

---

Revision no.: Final

Date: November 2005

Sheet: 2 of 18

## SECTION H

### YEAR 2020 IMPROVEMENTS

#### I N D E X

#### SECTION H

- 1.0 General Background
- 2.0 Pulverized Coal Combustion
- 3.0 Oxyfuel
- 4.0 Circulating Fluid Bed
- 5.0 Pressurized Fluid Bed
- 6.0 Integrated Gasification Combined Cycle
- 7.0 Environmental protection Technologies

---

## SECTION H YEAR 2020 IMPROVEMENTS

### 1.0 General Background

The coal firing technology greatly improved in the past years. At the beginning of the 20<sup>th</sup> century 1 kWh required for 4 to 6 kg of coal, depending on coal quality. Today the most modern power plants can produce 1 kWh with 300 g of coal, corresponding to a net efficiency of about 45%.

An increase of efficiency is generally coupled with an increase of investment, but the saving in fuel cost more than compensate the additional capital. So the efficiency increase has been a constant trend in the past years to increase the competitiveness of the technology. But an even more important advantage of the efficiency increase is the proportional reduction of the emissions and consequent increase of the level of acceptance.

However the increase of efficiency, albeit important, is not sufficient to reduce the emissions to the level imposed by the regulations and desired by the population. Consequently clean-up technologies have been developed to reduce emissions.

A today state of the art coal fired power plant operates with efficiency greater than 45% and can incorporate the following clean-up facilities:

- catalytic removal of NO<sub>x</sub>;
- Electrostatic precipitation or bag filtration for the separation of particulates;
- Capture of SO<sub>x</sub> with wet or dry scrubbing;
- Mercury and heavy metals removal.

The reduction of CO<sub>2</sub> emission is also under examination. Technologies are available to reduce CO<sub>2</sub> by 90%-95%.

All these options make coal the first positive answer to the great demand of power of the future years.

In the following paragraphs the coal firing technology improvements, expected in the next 15 years, are examined and evaluated.

Obviously these improvements are goals reflecting an educated guess of what may be the rate of success of the ongoing research and development programmes.

**2.0 Pulverized Coal Combustion**

This technology has been the main route for production of power from coal. Today the state of the art of this technology employs the following steam cycle ultrasupercritical conditions:

HP steam pressure	300 bar
Superheating temperature	600°C
Reheating temperature (1 or 2 stages)	620°C

At these conditions the net efficiency, based on coal LHV, is 45-47%, mainly dependent on the temperature level of the cooling water.

Operating examples of this state of the art technology are the following power plants:

- Aalborg (Denmark) : 285 bar/580°C/580°C  
net efficiency: 47%
- Avedøre (Denmark) : 285 bar/580°C/600°C  
net efficiency: 46%
- Matsuura (Japan) : 241 bar/593°C/593°C  
net efficiency: 45%

This level of performance is achieved with bituminous/subbituminous coals. With lignite the efficiency drops by about 2% points, due to the water content of lignite, but a similar efficiency can be achieved if the water content of lignite is reduced below 20%.

Using low rank coals, the largest single module offered today is 1000 MW. An example is the Niederaußem plant, owned by RWE, with the following steam conditions:

- Pressure: 290 bar
- Temperature: 580/600 °C

The reduction of moisture of the lignite is a great area of interest in Europe and USA, because a lignite is expected to play a growing role in power production. As described in Section C, paragraph 2.0, research activities are going on to develop and demonstrate different process routes to effectively reduce lignite moisture. These efforts are expected to make available in the coming years drying technologies making competitive the use of lignite in the power industry.

Major research and developments are directed to test and commercialize new special alloys for the boiler components, steam turbines, connecting piping and valves, in order to operate the steam cycle at more severe supercritical conditions and thus achieving higher efficiency.

R&D programs are ongoing in Europe USA and Japan, sponsored respectively by the European Community (Thermie), the Department of Energy (DOE) and Japanese public

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section H: Year 2020 Improvements**

---

Revision no.: Final  
Date: November 2005  
Sheet: 5 of 18

authorities. Various metallurgical options are under evaluation aiming to achieve in 2010-2015 steam cycle conditions equal to 350 bar/700°C/720°C and a corresponding net efficiency equal to 50%.

The most aggressive program is the one in USA, which has set a goal for the steam temperature equal to 750°C, with a net efficiency close to 52%.

### 3.0 Oxyfuel

This technology, although not yet used in commercial units, is attracting the attention of power producers in USA and Europe, in view of a future need to produce power from coal with close to zero emissions of greenhouse gases, including CO<sub>2</sub>.

The technology is based on the use of a mixture of oxygen and recycled flue gas as oxidant, in lieu of air. The non recycled portion of the flue gas, mainly constituted of CO<sub>2</sub> and H<sub>2</sub>O is treated cryogenically to separate CO<sub>2</sub> while the non condensables, N<sub>2</sub>, O<sub>2</sub> and some CO<sub>2</sub>, are purged to the atmosphere.

This technology is theoretically applicable to different power cycles: natural gas combined cycle, PC combustion, gasification (IGCC) and hybrid cycle (2<sup>nd</sup> generation PCFB).

The oxyfuel process permits to avoid the CO<sub>2</sub> enriching and separation processes, pre or postcombustion, and allows direct collection of CO<sub>2</sub> at the exit of the power cycle, resulting in a simpler power production process with sequestration of CO<sub>2</sub>. The major penalty of the process is the cost of production of oxygen in quantity sufficient to fully oxidize the fuel feed.

So far the technology has been studied at the level of design to discover how much the existing technologies have to be stretched to operate in the oxyfuel mode.

Oxyfuel operation of natural gas combined cycles is a great technology challenge because this would require a complete redesign of the gas turbine, compressor and expander. In fact the working fluid characteristics are drastically different from those used in normal operation, with air combustion. The main component of the working fluid is CO<sub>2</sub> instead of N<sub>2</sub> and with CO<sub>2</sub> the temperature change, with a given pressure ratio across the turbine, is much lower. In order to maintain a high efficiency and therefore a high turbine inlet temperature (TIT) and, at the same time, a low turbine exhaust temperature (540°C or lower) it would be necessary to increase dramatically the turbine inlet pressure, which means to develop a completely new family of gas turbines. Further a combined cycle, based on natural gas and without CO<sub>2</sub> capture, achieves a CO<sub>2</sub> emission rate equal to approximately 370 g of CO<sub>2</sub> per kWh, much lower than the typical emission of CO<sub>2</sub> of a PC boiler, based on coal and without CO<sub>2</sub> capture, which is approximately 750-800 g of CO<sub>2</sub> per kWh. So the incentive to reduce CO<sub>2</sub> emissions in a combined cycle are definitely lower.

The same problem of gas turbine availability for oxyfuel operation makes the oxyfuel application to IGCC or hybrid cycles difficult for the next 15 years, although in these two last cases the incentive to capture CO<sub>2</sub> is much greater than for the combined cycles, because the fuel used is coal.

Oxyfuel, on the contrary, is expected to have a realistic chance of success with the more traditional combustion processes, PC or CFB. In these cases, in fact, the currently used technologies can be easily adopted to oxyfuel operation. By year 2020 some commercial applications of oxyfuel for coal combustion are a distinct possibility in geographical areas, commanding a drastic drop of CO<sub>2</sub> emissions.

---

However the oxyfuel technology must be improved to increase its current degree of competitiveness (see Section F).

The main areas for Technological improvements are:

a. O<sub>2</sub> concentration in the furnace and related furnace peak temperature

So far the study efforts, developed for oxyfuel, have attempted to keep these parameters as close as possible to the values currently use in air fired boiler. However there is a great room for design improvements, because the average wall heat flux can be greatly increased compared to air fired boilers due to the higher CO<sub>2</sub> concentration (75% versus 14%) and higher flame temperature (2200° vs. 1850°C). This could easily achieve a reduction of the surface and, thus, size of the furnace possibly equal to 50% of what used in air fired boilers.

The impact of these changes on metallurgy, emissions and other aspect of the technology must however be evaluated.

b. Burner design

The design of the burners must be optimized to operate satisfactorily in the oxyfuel conditions.

c. Furnace design

The design of the furnace must reduce to a minimum the leakage of air into the furnace operating under slight vacuum. Air leaks, together with the N<sub>2</sub> present in the oxygen, must be purged from the recycle loop, does causing an increase of the loss of CO<sub>2</sub> to the atmosphere.

d. Air Separation Unit (ASU)

ASU is an important capital and operating item of cost in oxyfuel. New technologies for O<sub>2</sub> separation, able to reduce the cost of oxygen, such as membrane or pressure swing, will greatly improve the competitiveness of oxyfuel.

e. CO<sub>2</sub> separation from purge gas

The currently proposed technique is cryogenic, i.e., the purged flue gas is cooled to < 60°C to separate liquid CO<sub>2</sub>. This requires capital (large heat exchangers) and energy. Improvements in this area would also be greatly beneficial.

#### 4.0 Circulating Fluid Bed

The circulating fluid bed technology is expected to play, in the future years, an increasing role in the power industry and become the most serious competitor of the traditional PC combustion technology.

The most positive aspects of CFB are:

- Flexibility to process different fuels and in particular, difficult to burn, low cost, coals and lignite with high moisture content;
- coal need not to be pulverized but only reduced in size (5-8 mm), making the feed preparation and transportation less costly than what needed for PC combustion;
- in situ desulphurization using limestone/dolomite as bed material;
- possibility to use ultrasupercritical steam conditions similar to PC boilers;
- low NO<sub>x</sub> emissions due to the lower combustion temperature (850-900°).

The main advantage, compared to PC boilers, is the flexibility to process different fuels like bituminous or brown coals. The main disadvantage is still the scale economy. Largest single module capacity in operation is 350 MW (260 MW using lignite), but it is likely that this limitation will be removed in the future years and CFB boilers of capacity similar to PC boilers, 800 MW or more, will become available. Actually, Foster Wheeler awarded a contract to build the world's first CFB boiler operating at supercritical steam conditions. This unit will be a 460 MW plant at the Lagisza station (Poland), operating at supercritical pressure (275 bar), with superheat and reheat steam temperatures of 560°C and 580°C.

**5.0 Pressurized Fluid Bed**

The pressurized fluid bed technology became a technology of interest in the early nineties. ABB offered two modules, P200 and P800, where 200 and 800 are the thermal MW liberated in the boiler. Units using the P200 module were constructed and operated in US (Tidd-Ohio), Spain (Escatron) and Sweden (Vartan). Other PFB plants have been installed in Germany (Cottbus) and other countries. In Japan a P800 modules was installed at Karita Power Station.

The operation of these PFB plants did not prove to be suitable on the whole. Investment and insufficient availability were the weak points of this technology. The gas turbine used in the process was a special equipment available only from one vendor (ABB) and its efficiency was penalized by the low turbine inlet temperature (TIT), about 850°C.

Alstom (formerly ABB), the world’s leading developer, discounted few years later the marketing of the technology.

Case 4 of Section D of this study has evaluated PFB because of the potential advantages of CO<sub>2</sub> postcombustion capture from flue gas at 15 bar pressure. Nevertheless the results of this evaluation have confirmed the lack of competitiveness of this technology. The future of PFB technology is however kept alive by a modification/improvement called 2<sup>nd</sup> Generation PFB or Hybrid Cycle. This is a drastic change of the PFB process formally proposed by ABB.

The process is described by the attached block flow diagram (Fig. 1).




Figure 1 - Second Generation PFB Plant



Coal is processed in an air blown, pressurized (20 bar), fluid bed gasifier, called Carbonizer, which produces a low BTU syngas (1250 kcal/Nm<sup>3</sup>) and a solid residue, char. The syngas pass through cyclones and ceramic filter for the removal of entrained particulates. Alkali vapours, detrimental for the gas turbine blades, are removed by injecting in the syngas pulverized emathelite. The hot (850-900°C) syngas is burnt in a specially designed gas turbine combustor, called topping combustor.

The char from the Carbonizer is fed to a PFB Combustor, which burns completely the char residue and generate HP steam.

Air compressed by the gas turbine compressor is fed to the Carbonizer and to the PFB Combustor. The O<sub>2</sub> rich flue gas from the PFB Combustor, flows to the Topping Combustor to burn the syngas and then drives the gas turbine. The exhaust flue gas from the gas turbine flows to a heat recovery steam generator (HRSG) and then to the stack.

Electric energy is generated by the gas turbine and by the steam turbine, driven by HP steam produced by the PFB Combustor and by the turbine HRSG.

Limestone or dolomite is the bed material of the Carbonizer and PFB Combustor. Sulphur is captured as calcium sulphide in the Carbonizer and later converted to sulphate in the oxidizing atmosphere of the PFB Combustor.

The 2<sup>nd</sup> Generation PFB is somewhat more complicated and costly but the great efficiency limit of the 1<sup>st</sup> Generation, i.e., the low turbine inlet temperature does not longer exists, thanks to the topping combustor. Net cycle efficiencies greater than 48% can be achieved.

The 2<sup>nd</sup> Generation PFB has been demonstrated at the level of large pilot plant scale by a group of companies: Foster Wheeler, Siemens-Westinghouse and Parsons. DOE provided financial support for these tests.

Carbonizer (10 inch diameter) and PFB Combustor (8 inch diameter) have been successfully tested, isolated and connected together.

An 18 inch diameter model of the Topping Combustor was also tested with simulated syngas.

The 2<sup>nd</sup> Generation PFB Technology has thus achieved a high level of development and is ready to enter commercial operation, based on Siemens-Westinghouse W501F gas turbine.

This technology is a serious candidate for the implementation of clean coal projects in USA in the next 10-15 years.

## 6.0 Integrated Gasification Combined Cycle

IGCC is the technology with the greatest potential of improvements. All the key components of the technology, are derived from previously demonstrated industrial applications and can be improved by optimizing their design for the specific IGCC type of operation.

### a. Gas Turbine

Gas Turbines are continuously growing in capacity and performance. Several developments, tailored for IGCC, are being studied:

- air compressor power demand reduced by staging and intercooling;
- compressor and expander capacities better balanced to allow easier integration with ASU;
- fuel firing in two or more stages;
- TIT increase to allow, with the same pressure ratio across the turbine, the use of a supercritical or ultrasupercritical steam cycle.

### b. Steam Cycle

To follow the current trend of increase of cycle efficiency the HRSGs of future IGCC are expected to operate in once-through and supercritical conditions. This development is, however, strictly related to the turbine exhaust temperature so the design of the two components, turbine and HRSG, must be jointly optimized having as target the maximum energy efficiency of the IGCC.

### c. Gasifier

The priority for the design improvements of the gasifier are the reduction of the capital cost and the improvement of the reliability. A second priority is an increase of the cold gas efficiency.

Areas of improvements in gasification are:

- feed injector
- refractory
- quench design
- coal feeding system: pneumatic or slurry but avoiding the efficiency penalty associated with the use of water slurry
- slag and ash removal
- capability to handle low rank coals.

---

GE recently announced (at the Gasification Technologies 2005 Conference held in S. Francisco on October 9<sup>th</sup> –12<sup>th</sup>, 2005) a technology development program which includes modifications/ improvements to the following items:

- Feed system to enable low rank coal processing (presently GE gasifier is not suitable for the lignite composition selected for this study), increase gasifier efficiency and reduce oxygen consumption;
- Feed injection aimed at optimizing the gasifier flow distribution thus increasing availability and efficiency;
- Refractory aimed at increasing its life thus improving the availability and decreasing the maintenance costs.
- Synthesis Gas Cooler aimed at decreasing the size, increasing heat recovery and eliminating the deposition, with the benefits to increase availability and efficiency and decrease the investment cost.

At the same conference Shell declared to be implementing in the next and far future features and improvements aimed at reducing the investment cost (i.e. reactor/syngas cooler, steam system simplified), increasing the reactor syngas train capacity up to 5000 t/d, and increasing the plant availability (< 4% unplanned outages).

New gasification technologies are under development and will become available before year 2020. To mention two of them: Eagle gasifier in Japan and KBR Transport Gasifier in USA.

The KBR Transport Reactor is an advanced fluidized bed reactor which can operate as a pressurized boiler or as a gasifier, in two versions: air blown and oxygen blown. A pilot plant has been operated, with the support of DOE, at the PSDF testing facility in Wilsonville, Alabama. It was operated for three years as a pressurized combustor until coal gasification testing began in September 1999. Through September 2005, the Transport Gasifier has achieved over 7,700 hours of coal gasification including 750 hours with North Dakota lignite.

The gasifier is a refractory lined vessel with 2 feed injections in the bottom section and one in the upper section; so it is classified as a two stage gasification (theoretically better cold gas efficiency). The coal feed is slurry type, while heat recovery is by WHB.

It seems to be particularly suitable for low-rank, high moisture/high ash coals due to the low temperature operation, and high circulating solid rates. The high reactivity of lignite results in a high carbon conversion with respect to the bituminous coals. However the test campaign shows a maximum value equal to 97% for low sodium ash seam (1.7% Na<sub>2</sub>O) and 96% for high sodium one (5.5% Na<sub>2</sub>O).

In KBR's opinion the air blown made would be the adopted for power generation and oxygen made for chemical production.

The Transport Gasifier has been selected for an advanced 285 to 300 MW<sub>e</sub> coal gasification demonstration project to be located in Orlando (Florida) partially funded by the DOE under the Clean Coal Power Initiative (CCPI).

There are other technologies that may be suitable for low rank coals, but have not been investigated in this study. Two of these are the HTW and HRL gasification technologies.

The High Temperature Winkler (HTW) gasifier is a development of the old Winkler atmospheric pressure gasifier used in the 1920s.

The high temperature feature of the HTW is accomplished by injecting a portion of the oxidant above the fluidized bed to obtain a much higher temperature over the original Winkler with the following advantages:

- increased carbon conversion (less char)
- reduced methane and heavier hydrocarbons formation.

Rheinbraun, a major producer of lignites, developed the HTW gasifier for lignite gasification.

A first demonstration unit was built in 1985 at Berrenrath (Germany) to gasify 700 t/d brown coal, at 10 bar pressure, with minimum content of methane to meet the requirements of a downstream methanol synthesis.

In 1989 a second demonstration unit, optimized for IGCC power generation, was started in Wesseling. This unit, having a capacity of 170 t/d coal, operates at 25 bar, and can be operated either as a bubbling or circulating bed, using either air or O<sub>2</sub>. This unit was the demonstration step for a 350 MW IGCC project, called KoBRA, which was dropped later, for economical reasons. The KoBRA plant was expected to gasify 3600 t/d coal in an air blown gasifier.

Fuel is pressurized in a coal hopper and fed to the gasifier by a screw conveyor.

The gasifier vessel is refractory lined; the bottom is occupied by the fluid bed, fluidized by steam, O<sub>2</sub> or air. Generated gas is further heated in the upper zone by injection of oxidant. Entrained solids at the outlet of the gasifier are separated in a cyclone and recycled to the gasifier for further char conversion. The gasifier bottom temperature is kept at about 800-900°C to avoid ash melting, while the freeboard temperature can be 150-200°C higher.

Ash and residual char are removed from the base of the gasifier. Depending on the char content, the ash may be sent to an external fluid bed boiler for full combustion of char. When high rank, low reactive, coals are gasified additional combustion is necessary; whereas this may not be required with highly reactive lignites.

---

HRL is an Australian owned energy, technology and project development company. Its gasification technology was originally developed for low-rank coals, but is also applicable to high-reactivity bituminous coals.

HRL has worked with the air-blown pressurised fluidised bed gasification process since the late 1980s. The relatively moderate temperature of the process is suitable for high-reactivity coal and avoids the problems of handling molten ash associated with oxygen-blown entrained flow gasification systems.

HRL gasification technology for power generation IS called Integrated Drying Gasification Combined Cycle or "IDGCC".

This technology generates electricity at a higher efficiency and as a consequence, produces significantly less CO<sub>2</sub> when compared to current brown coal thermal technology.

The IDGCC technology has been developed over the last decade at an investment of over \$120M. It is currently at the stage of commercialisation, having been proven at the 10 MW scale with electricity generated into the Grid.

HRL Developments has been granted an Exploration Licence in the Driffield coalfield in the Latrobe Valley for the development of a new commercial power station utilising IDGCC technology.

d. Syngas cooler

Design improvements of the syngas cooler are expected to achieve a reduction of the capital cost of this expensive equipment.

e. Acid Gas Removal

This technology has been studied and developed for the Chemical Industry for decades. So the technology is mature and important break-through are not expected in the next 15 years.

f. Air Separation Unit

This IGCC component, based on cryogenic technology, is also a mature process so major improvements are not expected.

New concepts are proposed for the separation of O<sub>2</sub> from N<sub>2</sub>, based on use of selective membrane or pressure swing. Whether these technologies will become available before 2020 is still not known but, if successful, they could improve IGCC competitiveness substantially, since, even the most efficient cryogenic separation, absorbs 15% of the power produced by the IGCC.

---

**IEA GHG**

**CO<sub>2</sub> CAPTURE IN LOW RANK COAL POWER PLANTS**

**Section H: Year 2020 Improvements**

---

Revision no.: Final  
Date: November 2005  
Sheet: 15 of 18

If all these improvements will become available it is reasonable to expect that the IGCC in 2020 may achieve a net efficiency from coal to electric energy equal or superior to 50%, without CO<sub>2</sub> capture.

## 7.0 Environment Protection Technologies

All the power generation processes, examined in the previous paragraphs, have a common requirement to become acceptable to the population: a drastic reduction of the rate of emissions.

Great improvements have already been achieved in the abatement of the contaminants, as summarized herebelow.

### a. Flue Gas Denitrification

The reduction of NO<sub>x</sub>, a mixture of NO and NO<sub>2</sub>, can be undertaken in the combustion stage, with the use of special burners or use of fuel re-burn, or after the combustion stage with alternative processes, SNCR, SCR, Low Tox as better described in Section C, paragraph 4.0.

NO<sub>x</sub> reduction in the combustion stage is the first step undertaken because is the most economical way to achieve a NO<sub>x</sub> reduction. However, if a high NO<sub>x</sub> reduction is desired the answer can come only from processes located after the combustion stages.

SCR is the dominant technology that can achieve final NO<sub>x</sub> concentrations down to 100 and even 40 mg/Nm<sup>3</sup> (6%O<sub>2</sub>-dry).

When the combustion takes place at low temperatures, for instance CFB boilers, the production of NO<sub>x</sub> is reduced but when the temperature comes close to 800°C there is risk of formation of N<sub>2</sub>O. N<sub>2</sub>O and CH<sub>4</sub> are the two greenhouse gases of greater concern for global warming. N<sub>2</sub>O is 296 times more effective than CO<sub>2</sub> and CH<sub>4</sub> 23 times.

The formation of N<sub>2</sub>O can be contrasted by an increase of temperature (after burning in the cyclone). Limestone used as bed material has also demonstrated to reduce N<sub>2</sub>O formation.

In conclusion the technology for reduction of NO<sub>x</sub> is mature, well developed and suitable to match present and future legislation standards, so no great break-through are expected for year 2020.

### b. Flue Gas Desulphurization

The capture of S contained in the fuel is made with several different processes:

- capture of SO<sub>2</sub> with limestone in fluid bed combustion processes;
- capture of SO<sub>2</sub> in the flue gas with wet or dry FGD scrubbing processes, as described in Section C, paragraph 5;
- capture of H<sub>2</sub>S in syngas generated during gasification, with the use of regenerative chemical or physical solvents.

All these processes can achieve a high rate of sulphur capture. Limestone and wet/dry FGD can reach sulphur removal efficiency equal or greater than 96-97%.

Chemical and physical solvents can easily achieve an efficiency of sulphur removal from syngas greater than 99%. This removal efficiency is generally sufficient to meet present and future environmental standards.

Also the S capture available technologies are mature and well developed so no major break-through is expected for year 2020.

c. Mercury and Heavy Metals removal

As explained in Section C, paragraph 6.0, the removal of Hg and heavy metals from the flue gas is a relatively recent requirement with a limited industrial experience so far accumulated. The technology available today, active carbon injection followed by a fabric filter, seems to work all right at reasonable costs. Improvements of the technology are possible but their impact on power production cost will be negligible.

d. CO<sub>2</sub> capture

CO<sub>2</sub> produced in the combustion of coal can be captured in different ways:

- Postcombustion: this process is generally applicable to all combustion processes: PC, CFB, PFB.  
The process proposed today is based on the use of a formulated amine regenerative solvent. A detailed description of this process is given Section C, paragraph 7.0.
- Precombustion: this process is applicable only to gasification processes and is based on the use of selective chemical and physical solvents, operating in a regenerative mode.  
A detailed description of these processes is given in Section C, paragraph 8.

Postcombustion processes are not proved on a large scale as required by the power industry. Several question marks still exist on the rate of solvent deterioration and plant corrosion. Capital and energy demands are very high. Consequently improvements of the technology are highly desirable and are expected to be implemented if the pressure for CO<sub>2</sub> removal will become greater. How much the technology can be improved and when these improvements will become available is not known. The only foreseeable step-forwards of the post-combustion processes, achievable in the coming years, will come from the operating experience of the first large plant(s), which hopefully will provide adequate solutions to the question marks indicated before.

Precombustion processes are better proved and do not present question marks as postcombustion processes. Their utilization in the power industry is only a problem of scale-up to the large capacities involved. However the available processes still require high capital and large consumption of energy, therefore



improvements are desired but it is difficult to predict when these improvements will be available and the level of benefits involved. Considering of maturity achieved by these processes through the wide spread use in the chemical industry over the past 50-60 years, the probability of important new break troughs cannot ranked very high.

A third and interesting route to achieve the capture of CO<sub>2</sub> is the use of oxyfuel technology. As explained in paragraph 3 of this Section H, oxyfuel can be reasonably applied only to combustion processes, as PC or CFB. The level of development of oxyfuel is today in the very first stages. A number of improvements are possible, as described in paragraph 3 and it is not unrealistic to predict for the year 2020 a successful development of oxyfuel as a competitive technology in areas requiring a drastic reduction of CO<sub>2</sub> emissions.

---

IEA GHG  
CO<sub>2</sub> capture in Low-Rank Coal Power Plants  
Attachment I.1 - Analyses of low rank coals

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 1 of 27

CLIENT : IEA GREENHOUSE GAS R&D PROGRAMME  
PROJECT NAME : CO<sub>2</sub> CAPTURE IN LOW-RANK COAL POWER PLANTS  
DOCUMENT NAME : ANALYSES OF LOW-RANK COALS

ISSUED BY : P. COTONE  
CHECKED BY : L. MANCUSO  
APPROVED BY : R. DOMENICHINI

Date	Revised Pages	Issued by	Checked by	Approved by

## **ANALYSES OF LOW-RANK COALS**

### **I N D E X**

- 1.0 INTRODUCTION
- 2.0 CLASSIFICATION OF COAL BY RANK
- 3.0 WORLD WIDE DISTRIBUTION OF COAL DEPOSITS
- 4.0 PROPERTIES OF LOW-RANK COAL DEPOSITS
- 5.0 SELECTION OF THE REFERENCE COAL FOR THE STUDY

### **REFERENCES**

### **APPENDIX**

- A-1:** Summary of world estimate recoverable coal (high-rank and low-rank coals)
- A-2:** Summary of world estimate recoverable coal (Sub bit. and lignite coals, 1999)
- A-3:** Summary of world estimate coal production (Sub bit. and lignite coals, 1999)

## 1.0 INTRODUCTION

Coal is one of the most important resources of fossil fuel in the world.

Today, coal is mined in 50 countries and current reserve/production ratios confirm over 200 years of resource availability. Actually, 38% of global electricity is generated from coal: Australia, Poland, South Africa and China all rely on coal to produce three quarters on their electricity, India over 60%, USA and Germany more than half.

Global hard (black) coal production has grown by almost 50% in the last 25 years to 3,639 millions of tons. Top five major producers include China (1171 million of tons), USA (899 millions of tons), India (310 million of tons), Australia (259 millions of tons) and South Africa (225 millions of tons.) Brown coal/lignite production totaled 895 millions of tons in 2000 with Germany, Greece and North Korea among the leading producers and consumers.

Purpose of this report is to summarize the distribution of coal deposits, both high and low-rank coal type, performing the analyses of low rank coals from the major producing regions worldwide.

## 2.0 CLASSIFICATION OF COAL BY RANK

The rank of coal is a measure of its degree of metamorphism, or progressive alteration, in the natural series from lignite to anthracite.

The ASTM classification is shown in table 2.1 (D388, “Standard Specification for Classification of Coals by Rank”, 1976 Annual Book of ASTM Standards, Part 26). Depending on the coal type, the following parameters are used for the classification:

- High-rank coals: dry, mineral-matter-free fixed carbon (or its complement, the volatile matter).
- Low-rank coals: gross calorific value on the basis of mineral-matter – free coal containing bed moisture, i.e., moisture just sufficient to fill the pores of the coal in its natural state in the ground.

Agglomerating character, as determined on the volatile-matter residue, is used as an additional criterion in two instances: agglomerating coal within the semi-

---

IEA GHG

CO<sub>2</sub> capture in Low-Rank Coal Power Plants

Attachment I.1 - Analyses of low rank coals

---

Revision no.: Final

Date: Nov. 2005

Sheet: 4 of 27

anthracite fixed-carbon range is classified as low-volatile bituminous, whilst coal in the 10,500 to 11,500 Btu/lb range (moist, mineral-matter-free) is classified high-volatile C bituminous if agglomerating, or sub-bituminous A if non-agglomerating.

**Table 2.1 – ASTM Classification of coal by rank.**

Class	Group	Fixed Carbon Limits, %		Volatiles, %		Calorific Value Limits, Btu/lb		Agglomerating Character
		Greater Than	Less Than	Greater Than	Less Than	Greater Than	Less Than	
I. Anthracitic	1. Meta-anthracite	98	—	—	2	—	—	Nonagglomerating
	2. Anthracite	92	98	2	8	—	—	
	3. Semianthracite <sup>c</sup>	86	92	8	14	—	—	
II. Bituminous	1. Low volatile bituminous coal	78	86	14	22	—	—	Commonly agglomerating <sup>e</sup>
	2. Medium volatile bituminous coal	69	78	22	31	—	—	
	3. High volatile A bituminous coal	—	69	31	—	14,000 <sup>d</sup>	—	
	4. High volatile B bituminous coal	—	—	—	—	13,000 <sup>d</sup>	14,000	
	5. High volatile C bituminous coal	—	—	—	—	11,500	13,000	
III. Subbituminous	1. Subbituminous A coal	—	—	—	—	10,500	11,500	Nonagglomerating
	2. Subbituminous B coal	—	—	—	—	9,500	10,500	
	3. Subbituminous C coal	—	—	—	—	8,300	9,500	
IV. Lignite	1. Lignite A	—	—	—	—	6,300	8,300	Agglomerating
	2. Lignite B	—	—	—	—	—	6,300	

<sup>a</sup>This classification does not include a few coals, principally nonbanded varieties, which have unusual physical and chemical properties and which come within the limits of fixed carbon or calorific value of the high volatile bituminous and subbituminous ranks. All of these coals either contain less than 48% dry, mineral-matter-free Btu/lb.

<sup>b</sup>Moist refers to coal containing its natural inherent moisture but not including visible water on the surface of the coal.

<sup>c</sup>If agglomerating, classify in low volatile group of the bituminous class.

<sup>d</sup>Coals having 69% or more fixed carbon on the dry, mineral-matter-free basis shall be classified according to fixed carbon, regardless of calorific value.

<sup>e</sup>It is recognized that there may be nonagglomerating varieties in these groups of the bituminous class, and there are notable exceptions in high volatile C bituminous group.

### 3.0 WORLD WIDE DISTRIBUTION OF COAL DEPOSITS

Many data are available in literature or in the web sites on the distribution of coal reserves, but the most important and reliable sources can be considered the following:

- ◆ **EIA:** Energy Information Administration, mainly operating in the United States.
- ◆ **WEC:** World Energy Council, with Member Committees in over 90 countries in the world.

The coal resource/reserve classification systems include several terms and criteria that have been jointly agreed upon by several authorities. The systems employ a concept by which coal beds are classified in terms of their degree of geologic identification (assurance of existence) and economic and technologic feasibility of recovery.

Following paragraph represents a summary of the most common terminology used in the coal classification systems.

#### 3.1 Main terminology of coal classification systems

<b>Resources:</b>	Concentrations of coal in such forms that economic extraction is currently or may become feasible.
<b>Identified Resources:</b>	Specific bodies of coal whose location, rank, quality and quantity are known from geologic evidence supported by engineering measurements.
<b>Undiscovered Resources:</b>	Unspecified bodies of coal surmised to exist on the basis of broad geologic knowledge and theory.
<b>Demonstrated Reserve Base (DRB) or Reserve Base:</b>	The portion of identified coal resources from which reserves are calculated. These resources meet specified minimum physical and chemical criteria related to current mining and production practices.

<b>Reserve:</b>	That portion of the Identified Coal Resource that can be economically mined at the time of determination. Reserves include only recoverable coal.
<b>Recoverable:</b>	Coal that is, or can be, extracted from a coal-bed during mining.
<b>Measured resources:</b>	Refers to coal for which estimates of the rank and quantity have been computed to a high degree of geologic assurance, from sample analyses and measurements from closely spaced and geologically well known sample sites.
<b>Indicated resources:</b>	Refers to coal for which estimates of the rank, quality and quantity have been computed to a moderate degree of geologic assurance, partly from sample analyses and measurements from closely spaced and partly from reasonable geologic projections.
<b>Proved Recoverable resources</b> (World Energy Council):	Tonnage within the proved amount in place that can be recovered (extracted from the earth in raw form) under present and expected local economic conditions with existing available technology.

### **3.2 World Estimate Recoverable Coal**

Data presented in this paragraph come from the Energy Information Administration (2004) and include both estimates from EIA for the United States and from the World Energy Council for all other countries.

Data from the World Energy Council represent the “Proved Recoverable Resources” (see paragraph 3.1), whilst data for the United States represent both the measured and indicated tonnage. However, the two terminologies can be considered equivalent.

Figures are dependent on the judgment of each reporting country to interpret local economic conditions and mineral assessment criteria. Consequently, the data may not all meet the same standards of reliability.



Further, data in this paragraph are referred to different base years: figures for the U.S. represent recoverable coal estimates as of December 31, 2002, and data for other countries are as of December 31, 1999.

Detailed data among each world country are presented in the Appendix A-1. Table 3.1 summarizes the total results of data shown in Appendix A-1 for the main world regions.

**Table 3.1 – World Estimate Recoverable Sources (million short tons)**


<b>Region</b>	<b>Anthracite and Bituminous</b>	<b>Lignite and Sub-bituminous</b>	<b>Total Recoverable Coal</b>
<b>North America</b>	130,629	149,836	280,465
<b>Central &amp; South America</b>	8,530	15,448	23,978
<b>Western Europe</b>	27,650	73,693	101,343
<b>Eastern Europe &amp; Former U.S.S.R</b>	132,046	158,138	290,184
<b>Middle East</b>	1,885	0	1,885
<b>Africa</b>	60,816	216	61,032
<b>Asia &amp; Oceania</b>	208,719	113,675	322,394
<b>WORLD TOTAL</b>	570,274	511,006	1,081,280

Table 3.1 demonstrates the abundance of worldwide low-rank coal deposits: 47% of recoverable deposits is mainly composed of lignite and sub-bituminous coal (low-rank coals), the remaining 53% being of high-rank type.

The world concentration of low-rank coal deposits is mainly in the North America, Eastern Europe/Former U.S.S.R and Asia/Oceania (reference to be made to Appendix A-1 for further details on each country). Figure 3.1 summarizes the world distribution of the low-rank coals.

Similar data are available in the WEC web site and reported in the table of Appendix A-2. These data are dated 1999 also for the American countries (previous data for U.S. were date 2002), but allow knowing the recoverable reserves of both the sub bituminous and lignite coal in the world. Table 3.2 summarizes the total results for the main world regions.

**Figure 3.1 – World distribution of low-rank coal deposits.**



**Table 3.2 – World Estimate Recoverable Sources of sub bituminous and lignite (million short tons)**

Region	Sub bituminous	Lignite	Total Low-Rank Coal
Central & North America	112,849	38,987	151,836
South America	15,311	137	15,448
Total Europe	131,295	89,266	220,561
Middle East	-	-	-
Africa	213	3	216
Asia	42,646	38,118	80,764
Oceania	2,255	41,924	44,179
<b>WORLD TOTAL</b>	<b>304,569</b>	<b>208,435</b>	<b>513,004</b>

Table 3.2 shows that 59.4% of worldwide low-rank coal deposits is composed of sub-bituminous coal, being the remaining 40.6 % of lignite type.

Finally, figures 3.2 and 3.3 illustrate the distribution respectively of sub-bituminous and lignite in the world.

Figure 3.2 – World distribution of sub-bituminous coal deposits.





Figure 3.3 – World distribution of lignite coal deposits.



Figures 3.2 and 3.3 clearly demonstrate the importance of Europe & Former U.S.S.R. as recoverable reserve of low-rank coals, both for the sub-bituminous and lignite type. In particular, data shown in Appendix A-2, as well as papers listed in the references, demonstrate that Germany is the world's largest brown coal (lignite) producer and reserve, representing the 20% of global production in 2001.

#### **4.0 PROPERTIES OF LOW-RANK COAL DEPOSITS**

Investors and policymakers around the world require accurate information on coal properties and characteristics to make rational and informed decision on the investments.

Unfortunately, this comprehensive information is not yet available and an integrated source of reliable worldwide coal-quality does not exist. However, the U.S. Geological Survey (USGS), in conjunction with other partners, is developing an electronic database with geographic information system (GIS) coverage. The database is called the World Coal Quality Inventory (WoCQI) and will be available on the web (<http://geode.usgs.gov>). Actually, many data are available for the localization of the fossil fuels of several countries, but unfortunately at the moment only a few information are included on the coal-quality parameters.

Different data have been collected from several sources: literature, web sites, etc (see references). Many data for the U.S. deposits are available in the literature, from the Coal Research Station of Pennsylvania State University or from the U.S. CHEM computer file of the U.S. Geological Survey. Only figures relevant to the most important deposits of low-rank coal are reported.

All data collected from different sources are shown in table 4.1/2/3. Table 4.1 summarizes the main world regions production of low-rank coal, including also the typical production (reference to be made to Appendix A-3 for further details on each country). More detailed data relevant to the main U.S. low-rank coal deposits are reported in table 4.2, whilst table 4.3 summarizes detailed characteristics available for the other countries.

**Table 4.1** – Production and characteristics of the world’s lignites and brown coals (WEC, 2001; Couch, 1988) (1)

	<b>Production, Mt/y (1999)</b>	<b>Typical Characteristics</b>
USA	77	H <sub>2</sub> O 16-36% Ash 5-24% LHV 21-30 MJ/kg
Germany	161	H <sub>2</sub> O 30-60% Ash 7-25% LHV 7-16 MJ/kg
Turkey	65	H <sub>2</sub> O 46% Ash 22% LHV 5 MJ/kg
Australia	66	H <sub>2</sub> O 50-65% Ash 1-3% LHV 8-12 MJ/kg
Bulgaria	26	H <sub>2</sub> O 40-50% Ash 20-30% LHV 5-8 MJ/kg
China	45	H <sub>2</sub> O 35-50% Ash 15-40% LHV 9-12 MJ/kg
Czech Republic	45 (*)	H <sub>2</sub> O 35-40% Ash 17-25% LHV 9-13 MJ/kg
Greece	62	H <sub>2</sub> O 50-65% Ash 5-20% LHV 5-11 MJ/kg

Poland	61	H <sub>2</sub> O	50-55%
		Ash	5-10%
		LHV	5-10 MJ/kg
Russia	83	H <sub>2</sub> O	35-40%
		Ash	7-15%
		LHV	6-15 MJ/kg
Thailand	18	H <sub>2</sub> O	20-35%
		Ash	10-35%
		LHV	5-10 MJ/kg

**Notes** (1): Source: The potential for coal use in Pakistan (IEA Clean Coal Centre).  
 (\*) mainly classified as subbituminous in the WEC listing

**Table 4.2** – Properties and composition of U.S. low-rank coal deposits (2).

Country	Colorado	Illinois	Montana	Montana	North Dakota	Texas	Utah	Wyoming	West Virginia
<b>Rank (1)</b>	Sub	Sub	Lig	Sub	Lig	Sub	Sub	Sub	Sub
<b>Proximate, wt %:</b>									
Moisture	19.69	17.69	35.92	19.84	31.70	24.52	16.66	24.12	18.21
Volatile matter, dry	38.04	38.46	54.95	39.02	41.60	42.28	40.56	52.57	39.12
Fixed Carbon, dry	56.56	51.39	35.58	51.82	46.91	47.44	51.31	23.39	38.39
Ash, dry	5.40	10.14	9.47	9.16	11.49	10.28	8.14	24.04	22.48
<b>Ultimate, wt %:</b>									
Carbon	72.00	70.78	64.78	68.39	63.63	66.68	70.25	53.07	56.27
Hydrogen	4.76	5.22	4.42	4.64	4.29	4.45	4.90	4.09	4.49
Nitrogen	1.63	1.39	0.75	0.99	0.72	0.33	0.07	0.55	1.09
Chlorine	0.02	0.00	0.00	0.02	0.00	0.03	0.00	0.00	0.02
Sulfur	0.39	2.59	0.45	0.79	1.22	0.68	1.32	0.72	1.01
Ash	5.40	10.14	9.47	9.16	11.49	10.28	8.14	24.04	22.48
Oxygen	15.80	9.87	20.13	16.01	18.65	17.55	15.32	17.53	14.62
<b>Heating Value:</b>									
Gross Dry, kJ/kg	28,863	29,481	25,146	27,177	25,149	26,672	28,307	21,671	23,148

**Notes:** (1) lig = lignite; sub = sub-bituminous. (2) Source: Coal Research Station of Pennsylvania State University.



**Table 4.3** – Properties and composition of low-rank coal deposits for countries other than U.S.A..

Country	Canada (2)	Canada (2)	Germany (5)	Germany (5)	Turkey (6)	India (8)	India (8)	Pakistan (9)
<b>Location</b>	Alberta	Saskatchewan	Garantie	Mittel-punkt	TKI	Nevyeli	Kutch	Sindh
<b>Rank (1)</b>	Sub	Lig	Lig	Lig	Lig	Lig	Lig	Lig/Sub
<b>Proximate, wt %:</b>								
Moisture	20.00	33.54	50.70	55.50	46.56	47.00	36.00	9.7-38.1
Volatile matter, dry	NA	NA	54.00	54.00	1.84	NA	NA	18.3-38.6
Fixed Carbon, dry	NA	NA	38.90	29.15	36.54	NA	NA	9.8-38.2
Ash, dry	13.93	13.46	7.10	16.85	21.71	13.09	23.65	4.3-49
<b>Ultimate, wt %:</b>								
Carbon	73.93(4)	74.67(4)	63.54	56.54	52.99	48.78	44.66	NA
Hydrogen	4.26(4)	4.85(4)	4.65	4.16	4.02	4.36	4.78	NA
Nitrogen	0.91(4)	1.26(4)	0.74	0.67	19.89 (7)	0.45	1.39	NA
Sulfur	0.39(4)	0.92(4)	0.45	1.24	1.38	2.80	3.55	NA
Ash	NA	NA	7.10	16.85	21.72	13.09	23.65	NA
Oxygen	20.51(4)	18.30(4)	23.44	20.47	(7)	30.52	21.97	NA
Chlorine	NA	NA	0.05	0.06	NA	NA	NA	NA
Fluorite	NA	NA	0.03	0.01	NA	NA	NA	NA
<b>Heating Value:</b>								
LHV, kJ/kg	17,810(3)	13,560(3)	10,500	8,100	5,024	9,330	9,330	12,800-21,300

**Notes:** (1) lig = lignite; sub = sub-bituminous. (2) Source: Canadian Clean Power Coalition Studies on CO<sub>2</sub> capture and storage (March 2004). (3) Calculated from the HHV using a conversion factor indicated in the 7<sup>th</sup> edition of “Technical Data on Fuel”. (4) As received. (5) BoA 2 Projekt. (6) Mining Analysis and Tech. Department. (7) O<sub>2</sub> + N<sub>2</sub>. (8) Ohio Super Computer Center (OSC) web site. (9) Geological Survey of Pakistan web site.

**Table 4.3** – Properties and composition of Australian low-rank coal deposits.

Country	Australia	Australia	Australia	Australia	Australia	Australia	Australia	Australia
Location	Gippsland, Yallorun	Gippsland, Morwell	Gippsland, Latrobe	Lochiel	Kingston	Leigh Ck.	Esperance	Victoria, Morwell
Rank (1)	Lig	Lig	Lig	Lig	Lig	Lig	Lig	Lig
<b>Proximate, wt %:</b>								
Moisture	65.50	60.10	51.70	62.00	57.00	31.00	66.00	60.00
Volatile matter, dry	51.10	48.20	48.80	58.70	54.17	34.86	54.40	49.14
Fixed Carbon, dry	47.20	48.60	46.80	39.13	43.43	58.86	41.55	50.34
Ash, dry	1.70	3.20	4.40	2.17	2.40	6.28	4.05	0.52
<b>Ultimate, wt %:</b>								
Carbon	66.70	67.80	66.70	67.99	65.97	66.64	55.36	69.04
Hydrogen	4.70	4.80	4.70	5.48	4.98	3.84	5.09	4.87
Nitrogen	NA	NA	NA	0.68	0.59	1.69	30.22	0.60
Sulfur	0.30	0.40	0.50	3.13	3.22	0.84	5.28	0.30
Ash	NA	NA	NA	2.17	2.40	6.28	4.05	0.52
Oxygen	NA	NA	NA	23.48	22.84	20.71	NA	24.67
Chlorine	NA	NA	NA	NA	NA	NA	NA	NA
Fluorite	NA	NA	NA	NA	NA	NA	NA	NA
<b>Heating Value:</b>								
Gross Dry, kJ/kg	25,900	26,500	26,200	9,000 (3)	10,100 (3)	15,200 (3)	7,600 (3)	10,600 (3)

**Notes:** (1) lig = lignite; sub = sub-bituminous. (2) Calculated from the HHV using a conversion factor indicated in the 7<sup>th</sup> edition of “Technical Data on Fuel”. (3) As-received basis.

#### **4.1 Composition of Ash**

Table 4.4 summarizes ash characteristics mainly for the U.S. low-rank-coal deposits. Only data from countries that have large coal deposits are shown. Main source for these data is U.S. Bureau of Mines; U.S. data were included in the Coal Conversion Systems Technical Data Book (Prepared for U.S. Department of Energy, March 1984).

**Table 4.4** – Ash composition of low-rank coal deposits.

Country	Arizona	Colorado	Montana	Montana	New Mexico	North Dakota	Texas	Wyoming
<b>Rank (1)</b>	Sub	Sub	Lig	Sub	Sub	Lig	Lig	Sub
<b>Source</b>	(2)	(2)	(2)	(2)	(2)	(2)	(2)	(2)
<b>Ash Analysis, wt %:</b>								
SiO <sub>2</sub>	54.1	18.8	30.7	35.7	58.2	4.9	32.5	41.0
Al <sub>2</sub> O <sub>3</sub>	35.4	12.1	19.6	20.3	27.7	4.8	19.3	15.0
Fe <sub>2</sub> O <sub>3</sub>	5.4	10.6	18.9	5.3	4.2	14.0	5.3	2.5
TiO <sub>2</sub>	-	0.5	1.1	0.6	-	-	1.6	-
P <sub>2</sub> O <sub>5</sub>	-	-	-	0.6	-	0.10	0.08	0.6
CaO	2.2	23.4	11.3	16.4	4.2	26.0	22.2	15.0
MgO	0.5	6.6	3.7	7.0	0.4	8.40	3.2	3.80
Na <sub>2</sub> O	-	-	1.9	0.4	-	2.65	-	0.71
K <sub>2</sub> O	-	-	0.5	0.9	-	<0.10	-	1.1
SO <sub>3</sub>	1.6	26.5	12.2	12.8	3.9	39.0	14.3	10.0
Initial Deformation	N.A.	1221	1121	N.A.	N.A.	N.A.	N.A.	N.A.
Softening	N.A.	1243	1149	1227	N.A.	N.A.	N.A.	N.A.
Fluid	N.A.	1271	1178	N.A.	N.A.	N.A.	N.A.	N.A.

**Notes:** (1) lig = lignite; sub = sub-bituminous. (2) Coal Conversion Systems Technical Data Book.

**Table 4.4** – Ash composition of low-rank coal deposits.

Country	Germany Garantie	Germany Mittelp.	Australia Gippsland, Yallorun	Australia Gippsland, Morwell	Australia Gippsland, Latrobe			
<b>Rank (1)</b>	Lig	Lig	Lig	Lig	Lig			
<b>Source</b>	(2)	(2)						
<b>Ash Analysis, wt %:</b>								
SiO <sub>2</sub>	4.0/54.0	7.0/70.0	26.9	16.4	8.6			
Al <sub>2</sub> O <sub>3</sub>	1.7/22.0	1.0/22.0	8.6	3.4	5.0			
Fe <sub>2</sub> O <sub>3</sub>	5.0/26.0	4.0/30.0	20.0	9.3	19.8			
TiO <sub>2</sub>	0.2/2.5	0.1/2.5	0.5	0.3	0.6			
P <sub>2</sub> O <sub>5</sub>	-	-	-	-	-			
CaO	7.0/34.0	7.0/45.0	6.0	24.7	25.1			
MgO	3.0/17.0	1.8/17.0	14.3	14.2	8.6			
Na <sub>2</sub> O	1.0/9.4	0.1/9.4	6.5	4.9	3.5			
K <sub>2</sub> O	0.4/1.5	0.1/1.5	0.3	0.3	0.2			
SO <sub>3</sub>	11.0/24.0	10/75	17.1	26.6	28.6			
Initial Deformation	N.A.	N.A.	N.A.	N.A.	N.A.			
Softening	N.A.	N.A.	N.A.	N.A.	N.A.			
Fluid	N.A.	N.A.	N.A.	N.A.	N.A.			

**Notes:** (1) lig = lignite; sub = sub-bituminous. (2) BoA 2 Projekt.

#### 4.2 Heavy metals in low-rank coals

Heavy metals can be present as trace elements in coals and their quantification can be very difficult. Generally these elements have relatively large ranges in concentrations and can be found in distinct phases in the coals.

Table 4.5 summarizes the typical range of elements determined for a large quantity of USA coals. These elements have been selected on the basis of the priority as potential pollutant of the EPA. Minimum and maximum values cannot be defined as absolute figures, but shall be considered as “minimum and maximum medium” data for the most common coals.

**Table 4.5** – Trace elements in coal.

<b>Trace elements</b>	<b>Min Value</b> µg/g (1)	<b>Max Value</b> µg/g (1)
Antimony	0.2	5
Arsenic	1	30
Beryllium	0.2	4
Cadmium	0.05	30
Chromium	0.5	30
Lead	2	20
Manganese	4	500
Mercury	0.01	0.8
Nickel	1.3	60
Selenium	0.1	8

**Notes:** (1) Whole coal basis.

## 5.0 SELECTION OF THE REFERENCE COAL FOR THE STUDY

Considerations made in the previous paragraphs lead the following main conclusions:

- Low-rank coal deposits are abundant all over the world, being 47% of the quantity recoverable deposits in the world mainly composed of lignite and sub-bituminous coal.
- The higher concentration of low-rank coal deposits is in the North America, Eastern Europe/Former U.S.S.R and Asia.
- 59.4 % of worldwide low-rank coal deposits is composed of sub-bituminous coal, the remaining 40.6 % being of lignite type.
- Germany is the world's largest brown coal producer/reserve, representing 20% of global production in 2001.
- Depending on the country, a wide range of coal-quality parameters is expected for the low-rank coals, both for the ultimate and proximate analyses.

Based on the above conclusions, the analysis of the different coal power plants alternatives will be made by assuming as a reference the "Garantie" German brown coal with the following variation ranges:

Moisture:	30% to	60%
Ash (dry basis):	7% to	25%
LHV:	7000 to	16000 kJ/kg

With reference to the ash composition, the "Garantie" German lignite shows a very wide variation of alkali (Na<sub>2</sub>O, K<sub>2</sub>O), SO<sub>3</sub> and Fe<sub>2</sub>O<sub>3</sub> (reference to Table 4.4, paragraph 4.1).

Several literature studies demonstrated that:

- Fouling potential of ash is related to the alkali percentage;
- Slagging potential of ash is connected to the iron concentration;
- Fireside corrosion is related to the concentration in the ash of alkali iron and sulphur (corrosion results from the presence of molten sodium-potassium-iron sulfates).

The ash composition corresponding to the maximum percentage of the above components can represent a very severe operating condition for any coal power plant technology.

Metal temperature is an important corrosion-rate variable; this means that for the different boiler technologies is necessary to pay specific attention to this aspect, together with the material capability to operate under high stresses at ever increasing temperature. Corrosion problems are more and more important when increasing the firing temperature of the boiler, leading to possible severe constraints on both the material selection (high chromium content) and the equipment life.

Purpose of the study is to compare performances and costs of different Power Plant technologies that use low rank coal as primary fuel. The wide range of the ash composition, shown in Table 4.4 for the selected coal, leads to possible constraints in the design of some specific power plant technology.

Therefore, in order to develop a study on coal power plants which process low rank fuel with characteristics that are common to the majority of the coals, the range of the most critical components is reduced as follows:

- Fe<sub>2</sub>O<sub>3</sub>: 5.0/16.0 %
- Na<sub>2</sub>O: 1.0/4.0 %
- SO<sub>3</sub>: 11.0/15.0 %

In any case, it has to be taken into account that a power plant burning lignite coal with a wide variation of the characteristics requires a frequent monitoring of the composition. If the coal composition becomes severe, with respect to design parameter, the power plant will be generally capable to process the different coal by adjusting the combustion temperature of the boilers, thus affecting the performances of the plant.



## REFERENCES

- Energy Information Administration web site (<http://www.eia.doe.gov>).
- World Energy Council web site (<http://www.worldenergy.org/wec-geis/>).
- Coal Conversion Systems Technical Data Book (Prepared for U.S. Department of Energy, March 1984)
- U.S. Geological Survey (USGS) web site (<http://www.usgs.gov/>) and U.S. Geological Survey National Center.
- World Coal Quality Inventory web site (<http://geode.usgs.gov/>).
- U.S. Department of Energy web site (<http://www.doe.gov/engine/content.do>).
- Coal Market Data and Statistics (<http://power.about.com/od/coalindustry/>).
- Canadian Clean Power Coalition Studies on CO<sub>2</sub> capture and storage (March, 2004).
- Ohio Super Computer Centre (OSC) web site: (<http://www.osc.edu/research/pcrm/emissions/coal.shtml>).
- Geological Survey of Pakistan (<http://www.gsp.gov.pk/>).
- World Coal Institute (WCI) web site ([http://www.wci-coal.com/web/bl\\_content.php?menu\\_id=0.0](http://www.wci-coal.com/web/bl_content.php?menu_id=0.0)).
- IEA Clean Coal Center: “The potential for coal use in Pakistan” (Gordon Couch, April 2004).

---

IEA GHG  
CO<sub>2</sub> capture in Low-Rank Coal Power Plants  
Attachment I.1 - Analyses of low rank coals

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 25 of 27

## **APPENDIX A-1**

### **Summary of world estimate recoverable coal (High rank and low rank coals)**

Table A-1 World Estimated Recoverable Coal  
(Million Short Tons)

Energy Information Administration			
<i>International Energy Annual 2002</i>			
Table Posted: May 21, 2004			
Next Update: March 2005			
<b>A-1 World Estimated Recoverable Coal</b>			
(Million Short Tons)			
	<b>Recoverable Anthracite and Bituminous</b>	<b>Recoverable Lignite and Subbituminous</b>	<b>Total Recoverable Coal</b>
<b>Region/Country</b>			
Bermuda			
Canada	3,826	3,425	7,251
Greenland	0	202	202
Mexico	948	387	1,335
Saint Pierre and Miquelon			
United States	125,855	145,822	271,677
<b>North America</b>	<b>130,629</b>	<b>149,836</b>	<b>280,464</b>
Antarctica			
Antigua and Barbuda			
Argentina	0	474	474
Aruba			
Bahamas, The			
Barbados			
Belize			
Bolivia	1	0	1
Brazil	0	13,149	13,149
Cayman Islands			
Chile	34	1,268	1,302
Colombia	6,908	420	7,328
Costa Rica			
Cuba			
Dominica			
Dominican Republic			
Ecuador	0	26	26
El Salvador			
Falkland Islands			
French Guiana			
Grenada			
Guadeloupe			
Guatemala			
Guyana			
Haiti			
Honduras			
Jamaica			
Martinique			
Montserrat			
Netherlands Antilles			
Nicaragua			
Panama			
Paraguay			

Table A-1 World Estimated Recoverable Coal  
(Million Short Tons)

Region/Country	Recoverable Anthracite and Bituminous	Recoverable Lignite and Subbituminous	Total Recoverable Coal
Peru	1,058	110	1,168
Puerto Rico			
Saint Kitts and Nevis			
Saint Lucia			
Saint Vincent/Grenadines			
Suriname			
Trinidad and Tobago			
Turks and Caicos Islands			
Uruguay			
Venezuela	528	0	528
Virgin Islands, U.S.			
Virgin Islands, British			
<b>Central &amp; South America</b>	<b>8,530</b>	<b>15,448</b>	<b>23,977</b>
Austria	0	28	28
Belgium			
Bosnia and Herzegovina			
Croatia	7	36	43
Denmark			
Faroe Islands			
Finland			
Former Yugoslavia			
France	24	15	40
Germany	25,353	47,399	72,753
Germany, East			
Germany, West			
Gibraltar			
Greece	0	3,168	3,168
Iceland			
Ireland	15	0	15
Italy	0	37	37
Luxembourg			
Macedonia, TFYR			
Malta			
Netherlands	548	0	548
Norway	0	1	1
Portugal	3	36	40
Slovenia	0	303	303
Spain	220	507	728
Sweden	0	1	1
Switzerland			
Turkey	306	3,760	4,066
United Kingdom	1,102	551	1,653
Yugoslavia	71	17,849	17,919
<b>Western Europe</b>	<b>27,650</b>	<b>73,693</b>	<b>101,343</b>
Albania			
Armenia			
Azerbaijan			
Belarus			

Table A-1 World Estimated Recoverable Coal  
(Million Short Tons)

Region/Country	Recoverable Anthracite and Bituminous	Recoverable Lignite and Subbituminous	Total Recoverable Coal
Bulgaria	14	2,974	2,988
Czech Republic	2,330	3,929	6,259
Estonia			
Former Czechoslovakia			
Former U.S.S.R.			
Georgia			
Hungary	0	1,209	1,209
Kazakhstan	34,172	3,307	37,479
Kyrgyzstan	0	895	895
Latvia			
Lithuania			
Moldova			
Poland	22,377	2,050	24,427
Romania	1	1,605	1,606
Russia	54,110	118,964	173,074
Slovakia	0	190	190
Tajikistan			
Turkmenistan			
Ukraine	17,939	19,708	37,647
Uzbekistan	1,102	3,307	4,409
<b>Eastern Europe &amp; Former U.S.S.R.</b>	<b>132,046</b>	<b>158,138</b>	<b>290,183</b>
Bahrain			
Cyprus			
Iran	1,885	0	1,885
Iraq			
Israel			
Jordan			
Kuwait			
Lebanon			
Oman			
Qatar			
Saudi Arabia			
Syria			
United Arab Emirates			
Yemen			
<b>Middle East</b>	<b>1,885</b>	<b>0</b>	<b>1,885</b>
Algeria	44	0	44
Angola			
Benin			
Botswana	4,740	0	4,740
Burkina Faso			
Burundi			
Cameroon			
Cape Verde			
Central African Republic	0	3	3
Chad			
Comoros			
Congo (Brazzaville)			

Table A-1 World Estimated Recoverable Coal  
(Million Short Tons)

Region/Country	Recoverable Anthracite and Bituminous	Recoverable Lignite and Subbituminous	Total Recoverable Coal
Congo (Kinshasa)	97	0	97
Cote d'Ivoire (Ivory Coast)			
Djibouti			
Egypt	0	24	24
Equatorial Guinea			
Eritrea			
Ethiopia			
Gabon			
Gambia, The			
Ghana			
Guinea			
Guinea-Bissau			
Kenya			
Lesotho			
Liberia			
Libya			
Madagascar			
Malawi	0	2	2
Mali			
Mauritania			
Mauritius			
Morocco			
Mozambique	234	0	234
Namibia			
Niger	77	0	77
Nigeria	23	186	209
Reunion			
Rwanda			
Saint Helena			
Sao Tome and Principe			
Senegal			
Seychelles			
Sierra Leone			
Somalia			
South Africa	54,586	0	54,586
Sudan			
Swaziland	229	0	229
Tanzania	220	0	220
Togo			
Tunisia			
Uganda			
Western Sahara			
Zambia	11	0	11
Zimbabwe	553	0	553
<b>Africa</b>	<b>60,816</b>	<b>216</b>	<b>61,032</b>
Afghanistan	73	0	73
American Samoa			
Australia	46,903	43,585	90,489
Bangladesh			

Table A-1 World Estimated Recoverable Coal  
(Million Short Tons)

Region/Country	Recoverable Anthracite and Bituminous	Recoverable Lignite and Subbituminous	Total Recoverable Coal
Bhutan			
Brunei			
Burma	2	0	2
Cambodia			
China	68,564	57,651	126,215
Cook Islands			
Fiji			
French Polynesia			
Guam			
Hawaiian Trade Zone			
Hong Kong			
India	90,826	2,205	93,031
Indonesia	871	5,049	5,919
Japan	852	0	852
Kiribati			
Korea, North	331	331	661
Korea, South	86	0	86
Laos			
Macau			
Malaysia	4	0	4
Maldives			
Mongolia			
Nauru			
Nepal	2	0	2
New Caledonia	2	0	2
New Zealand	36	594	631
Niue			
Pakistan	0	2,497	2,497
Papua New Guinea			
Philippines	0	366	366
Samoa			
Singapore			
Solomon Islands			
Sri Lanka			
Taiwan	1	0	1
Thailand	0	1,398	1,398
Tonga			
U.S. Pacific Islands			
Vanuatu			
Vietnam	165	0	165
Wake Island			
<b>Asia &amp; Oceania</b>	<b>208,719</b>	<b>113,675</b>	<b>322,394</b>
<b>World Total</b>	<b>570,275</b>	<b>511,005</b>	<b>1,081,279</b>

---

IEA GHG  
CO<sub>2</sub> capture in Low-Rank Coal Power Plants  
Attachment I.1 - Analyses of low rank coals

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 26 of 27

## **APPENDIX A-2**

**Summary of world estimate recoverable coal  
(Sub bituminous and lignite coals, 1999)**



<b>Table A.2 Coal: proved recoverable reserves at end-1999</b>				
	million tonnes			
	Bituminous including anthracite	Sub-bituminous	Lignite	TOTAL
Algeria	40			40
Botswana	4 300			4 300
Central African Republic			3	3
Congo (Democratic Rep.)	88			88
Egypt (Arab Rep.)		22		22
Malawi		2		2
Morocco	N			N
Mozambique	212			212
Niger	70			70
Nigeria	21	169		190
South Africa	49 520			49 520
Swaziland	208			208
Tanzania	200			200
Zambia	10			10
Zimbabwe	502			502
<b>Total Africa</b>	<b>55 171</b>	<b>193</b>	<b>3</b>	<b>55 367</b>
Canada	3 471	871	2 236	6 578
Greenland		183		183
Mexico	860	300	51	1 211
United States of America	115 891	101 021	33 082	249 994
<b>Total North America</b>	<b>120 222</b>	<b>102 375</b>	<b>35 369</b>	<b>257 966</b>
Argentina		430		430
Bolivia	1			1
Brazil		11 929		11 929
Chile	31	1 150		1 181
Colombia	6 267	381		6 648
Ecuador			24	24
Peru	960		100	1 060
Venezuela	479			479
<b>Total South America</b>	<b>7 738</b>	<b>13 890</b>	<b>124</b>	<b>21 752</b>
Afghanistan	66			66
China	62 200	33 700	18 600	114 500
India	82 396		2 000	84 396
Indonesia	790	1 430	3 150	5 370
Japan	773			773
Kazakhstan	31 000		3 000	34 000
Korea (Democratic People's Rep.)	300	300		600
Korea (Republic)	78			78
Kyrgyzstan			812	812
Malaysia	4			4
Mongolia				
Myanmar (Burma)	2			2
Nepal	2			2
Pakistan		2 265		2 265
Philippines		232	100	332
Taiwan, China	1			1
Thailand			1 268	1 268
Turkey	278	761	2 650	3 689
Uzbekistan	1 000		3 000	4 000
Vietnam	150			150
<b>Total Asia</b>	<b>179 040</b>	<b>38 688</b>	<b>34 580</b>	<b>252 308</b>

<b>Table A.2 Coal: proved recoverable reserves at end-1999</b>				
	million tonnes			
	Bituminous including anthracite	Sub-bituminous	Lignite	TOTAL
Albania				
Austria			25	25
Bulgaria	13	233	2 465	2 711
Croatia	6		33	39
Czech Republic	2 114	3 414	150	5 678
France	22		14	36
Germany	23 000		43 000	66 000
Greece			2 874	2 874
Hungary		80	1 017	1 097
Ireland	14			14
Italy		27	7	34
Netherlands	497			497
Norway		1		1
Poland	20 300		1 860	22 160
Portugal	3		33	36
Romania	1	35	1 421	1 457
Russian Federation	49 088	97 472	10 450	157 010
Serbia, Montenegro	64	1 460	14 732	16 256
Slovakia			172	172
Slovenia		40	235	275
Spain	200	400	60	660
Sweden		1		1
Ukraine	16 274	15 946	1 933	34 153
United Kingdom	1 000		500	1 500
<b>Total Europe</b>	<b>112 596</b>	<b>119 109</b>	<b>80 981</b>	<b>312 686</b>
Iran (Islamic Rep.)	1 710			1 710
<b>Total Middle East</b>	<b>1 710</b>			<b>1 710</b>
Australia	42 550	1 840	37 700	82 090
New Caledonia	2			2
New Zealand	33	206	333	572
<b>Total Oceania</b>	<b>42 585</b>	<b>2 046</b>	<b>38 033</b>	<b>82 664</b>
<b>TOTAL WORLD</b>	<b>519 062</b>	<b>276 301</b>	<b>189 090</b>	<b>984 453</b>

**Notes:**

1. A quantification of proved recoverable reserves for Mongolia and Albania is not available
2. The data shown against Serbia, Montenegro include reserves in Bosnia-Herzegovina and the Former Yugoslav Republic of Macedonia
3. Sources: WEC Member Committees, 2000/2001; data reported for previous WEC Surveys of Energy Resources; national and international published sources

---

IEA GHG  
CO<sub>2</sub> capture in Low-Rank Coal Power Plants  
Attachment I.1 - Analyses of low rank coals

---

Revision no.: Final  
Date: Nov. 2005  
Sheet: 27 of 27

## **APPENDIX A-3**

**Summary of world estimate coal production  
(Sub bituminous and lignite coals, 1999)**

<b>Table 1.3 Coal: 1999 production</b>				
	thousand tonnes			
	Bituminous	Sub-bituminous	Lignite	Total
Algeria	25			25
Botswana	945			945
Congo (Democratic Rep.)	50			50
Egypt	200			200
Malawi		44		44
Morocco	129			129
Mozambique	18			18
Niger	168			168
Nigeria		20		20
South Africa	223 510			223 510
Swaziland	426			426
Tanzania	5			5
Zambia	128			128
Zimbabwe	4 977			4 977
<b>Total Africa</b>	<b>230 581</b>	<b>64</b>		<b>230 645</b>
Canada	36 538	24 300	11 659	72 497
Mexico	2 366	7 678		10 044
United States of America	568 260	352 260	76 570	997 090
<b>Total North America</b>	<b>607 164</b>	<b>384 238</b>	<b>88 229</b>	<b>1 079 631</b>
Argentina	337			337
Brazil	5 602			5 602
Chile	170	470		640
Colombia	32 754			32 754
Peru	20			20
Venezuela	6 500			6 500
<b>Total South America</b>	<b>45 383</b>	<b>470</b>		<b>45 853</b>
Afghanistan	2			2
Bhutan	50			50
China	985 000		45 000	1 030 000
Georgia	12			12
India	292 203		22 212	314 415
Indonesia	70 703			70 703
Japan	3 906			3 906
Kazakhstan	56 436		1 763	58 199
Korea (Democratic People's Rep.)	60 000	21 500		81 500
Korea (Republic)		4 197		4 197
Kyrgyzstan	135		280	415
Laos	202			202
Malaysia		309		309
Mongolia	1 423		3 529	4 952
Myanmar (Burma)	13		27	40
Nepal			9	9
Pakistan		3 307		3 307
Philippines		1 028		1 028
Taiwan, China	90			90
Tajikistan		19		19
Thailand			18 270	18 270
Turkey	1 990		65 050	67 040
Uzbekistan	89		2 864	2 953
Vietnam	8 830			8 830
<b>Total Asia</b>	<b>1 481 084</b>	<b>30 360</b>	<b>159 004</b>	<b>1 670 448</b>
Albania			33	33
Austria			1 137	1 137
Bosnia-Herzegovina			1 850	1 850
Bulgaria	90		25 940	26 030
Croatia	15			15
Czech Republic	14 419	44 278	512	59 209
FYR Macedonia			8 400	8 400
France	4 533		558	5 091
Germany	40 500		161 282	201 782

<b>Table 1.3 Coal: 1999 production</b>				
	<b>thousand tonnes</b>			
	<b>Bituminous</b>	<b>Sub-bituminous</b>	<b>Lignite</b>	<b>Total</b>
Greece			61 900	61 900
Hungary	700	6 500	7 700	14 900
Italy			19	19
Norway		400		400
Poland	110 200		60 800	171 000
Romania	N	2 751	20 131	22 882
Russian Federation	166 000		83 400	249 400
Serbia, Montenegro	49		30 451	30 500
Slovakia			3 748	3 748
Slovenia		758	3 804	4 562
Spain	13 200	3 700	8 500	25 400
Ukraine	34 871	46 176	1 182	82 229
United Kingdom	37 077			37 077
<b>Total Europe</b>	<b>421 654</b>	<b>104 563</b>	<b>481 347</b>	<b>1 007 564</b>
Iran (Islamic Rep.)	1 500			1 500
<b>Total Middle East</b>	<b>1 500</b>			<b>1 500</b>
Australia	222 000	16 200	65 800	304 000
New Zealand	1 630	1 670	210	3 510
<b>Total Oceania</b>	<b>223 630</b>	<b>17 870</b>	<b>66 010</b>	<b>307 510</b>
<b>TOTAL WORLD</b>	<b>3 010 996</b>	<b>537 565</b>	<b>794 590</b>	<b>4 343 151</b>

**Notes:**

1. Sources: WEC Member Committees, 2000/2001; BP Statistical Review of World Energy 2001; Energy - Monthly Statistics, Eurostat; World Mineral Statistics 1995-1999, British Geological Survey; national sources; estimates by the editors