



ieaghg

4TH CCS COST NETWORK, 2016 WORKSHOP

Report: 2016/09

August 2016

INTERNATIONAL ENERGY AGENCY

The International Energy Agency (IEA) was established in 1974 within the framework of the Organisation for Economic Co-operation and Development (OECD) to implement an international energy programme. The IEA fosters co-operation amongst its 28 member countries and the European Commission, and with the other countries, in order to increase energy security by improved efficiency of energy use, development of alternative energy sources and research, development and demonstration on matters of energy supply and use. This is achieved through a series of collaborative activities, organised under more than 40 Implementing Agreements. These agreements cover more than 200 individual items of research, development and demonstration. IEAGHG is one of these Implementing Agreements.

DISCLAIMER

This report was prepared as an account of the work sponsored by IEAGHG. The views and opinions of the authors expressed herein do not necessarily reflect those of the IEAGHG, its members, the International Energy Agency, the organisations listed below, nor any employee or persons acting on behalf of any of them. In addition, none of these make any warranty, express or implied, assumes any liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product of process disclosed or represents that its use would not infringe privately owned rights, including any parties intellectual property rights. Reference herein to any commercial product, process, service or trade name, trade mark or manufacturer does not necessarily constitute or imply any endorsement, recommendation or any favouring of such products.

COPYRIGHT

Copyright © IEA Environmental Projects Ltd. (IEAGHG) 2016.

All rights reserved.

ACKNOWLEDGEMENTS AND CITATIONS

The steering committee for this meeting were:

- George Booras, EPRI
- Lynn Brickett., USDOE/NETL
- John Chamberlain, GASNATURAL FENOSA
- John Davison, IEAGHG
- Howard J. Herzog, MIT
- Wilfried Maas, SHELL GLOBAL
- Sean T. McCoy, LLNL
- Richard Rhudy, EPRI
- Edward S. Rubin, CMU

The report should be cited in literature as follows:

‘IEAGHG, “CCS Cost Network, 2016 Workshop”, 2016/09, August, 2016.’

Further information or copies of the report can be obtained by contacting IEAGHG at:

IEAGHG, Pure Offices, Cheltenham Office Park

Hatherley Lane, Cheltenham,

GLOS., GL51 6SH, UK

Tel: +44 (0)1242 802911

E-mail: mail@ieaghg.org

Internet: www.ieaghg.org

CCS COST NETWORK

2016 WORKSHOP

23–24 MARCH 2016

CAMBRIDGE, MASSACHUSETTS, USA

ORGANISED UNDER THE AEGIS OF THE:

**CCS COST NETWORK
INTERNATIONAL ENERGY AGENCY GREENHOUSE GAS PROGRAMME
CHELTENHAM, UK**

BY STEERING COMMITTEE MEMBERS:

GEORGE BOORAS, EPRI
LYNN BRICKETT, USDOE/NETL
JOHN CHAMBERLAIN, GASNATURAL FENOSA
JOHN.DAVISON, IEAGHG
HOWARD J. HERZOG, MIT
WILFRIED MAAS, SHELL GLOBAL
SEAN T. MCCOY, LLNL
RICHARD RHUDY, EPRI
EDWARD S. RUBIN, CMU

PUBLISHED: MAY 2016



TABLE OF CONTENTS

AGENDA	1
PARTICIPANTS	2
INTRODUCTION	3
PRESENTATION SUMMARIES	4
Session 1: Framing the Issue	4
Session 2: Project Costs – Industrial Applications	4
Session 3: Project Costs – Power Applications	5
Session 4: CCS in the Context of Changing Electricity Markets	7
BREAK-OUT SESSION SUMMARIES	8
Session A. Reconciling Real and Estimated CCS Plant Costs	8
Session B. Challenges of CCS Cost Estimation and Financing	9
Session C. Making CCS More Competitive	10
PRESENTATIONS	13

AGENDA

Tuesday, March 22, 2016

8:00 Registration and Coffee:

Massachusetts of Institute Technology (MIT),
Silverman Skyline Room, Building E14, Room 648

8:30 Introduction

9:00 Session 1: Framing the Issue (Chair: Howard Herzog, MIT)

- The Cost of CCS: A Review of Recent Studies (Ed Rubin, CMU)
- Methodology of a Detailed CCS Cost Study (Jeff Hoffmann, NETL)

10:30 Break

11:00 Session 2: Project Costs – Industrial Applications (Chair: John Davison, IEAGHG)

- Quest (Wilfried Maas, Shell)
- Illinois Basin/Decatur (Sallie Greenberg, Univ. of Illinois; Ray McKaskle, Trimeric)

12:30 Lunch

1:30 Session 3: Project Costs – Power Applications (Chair: George Booras, EPRI)

- Boundary Dam (Max Ball and Peter Versteeg, SaskPower, via teleconference)
- FutureGen 2.0 (Ken Humphreys, FutureGen 2.0)
- White Rose (Leigh Hackett, GE Power)

3:45 Break

4:15 Session 4: CCS in the context of changing electricity markets (Chair: Sean McCoy, LLNL)

- The value of flexible, firm capacity on a decarbonized grid (Andy Boston, Energy Research Partnership)
- Initial Respondents: Neil Kern (Duke Energy), Geoffrey Bongers (Gamma Energy Technology)

5:30 Adjourn

7:00 Dinner (sponsored by Shell),
EVOO, 350 Third St, Cambridge, MA

Wednesday, March 23, 2016

8:30 Coffee

9:00 Three parallel breakout sessions:

- A. Can we reconcile real project and N^{th} plant costs?
How should we present this information to policy makers?
(Co-chairs: Ed Rubin, CMU; George Booras, EPRI)
- B. What are the main challenges of industrial and power CCS cost estimation and financing?
(Co-chairs: Jeff Hoffmann, NETL; Howard Herzog, MIT)
- C. What can be done to make CCS more competitive?
What are realistic expectations for CCS cost reductions over next 10-20 years? By 2050?
(Co-chairs: Wilfried Maas, Shell; Sean McCoy, LLNL)

12:00 Lunch

1:00 Breakout Session Reports

2:00 General Discussion

- What have we learned?
- Where should we be going?

2:45 Next meeting – Topics, Location, Timing

3:00 Adjourn

PARTICIPANTS

NAME	ORGANIZATION	NAME	ORGANIZATION
Ståle Aakenes	Gassnova	Paul Johnson	Corning
Makoto Akai	AIST	Neil Kern	Duke Energy
Brian Anderson	West Virginia University	Jordan Kearns	MIT
Tim Barckholtz	Exxon Mobil	Haroon Khashgi	ExxonMobil
Geoffery Bongers	Gamma Energy Technology	Amishi Kumar	USEA
George Booras	EPRI	John Litvynski	DOE
Andy Boston	Energy Research Partnership	Monica Lupion	MIT
Henry Chen	MIT	Wilfried Maas	Shell
Ganesh Dasari	Exxon Mobil	Niall Mac Dowell	Imperial College
John Davison	IEAGHG	Sean McCoy	LLNL
James Duffy	Clean Air Task Force	Mike McGroddy	8 Rivers Capital
Paul Fennell	Imperial College	Ray McKaskle	Trimeric
Brock Forrest	8 Rivers Capital	Jen Morris	MIT
Mike Fowler	MHIA	Masaki Nemoto	GCCSI
Kristin Gerdes	NETL	Mark Northam	University of Wyoming
Jon Gibbins	UK CCS Research Centre	Sergey Paltsev	MIT
Sallie Greenberg	University of Illinois	Bruce Phillips	NorthBridge Group
Leigh Hackett	GE Power	Massimiliano Pieri	ENI
Howard Herzog	MIT	Ed Rubin	Carnegie Mellon University
Jeff Hoffmann	NETL	Hans Thomann	Exxon Mobil
Ken Humphreys	FutureGen 2.0	John Thompson	Clean Air Task Force
Lawrence Irlam	GCCSI	Via Teleconference:	
Nigel Jenvey	BP	Max Ball	SaskPower
		Peter Versteeg	SaskPower



INTRODUCTION

The fourth meeting of the CCS Cost Workshop (also known as the Expert Group on CCS Costs) was held on March 23-24, 2016 at the Massachusetts Institute of Technology (MIT) in Cambridge, Massachusetts. This function is now designated as the CCS Cost Network under the auspices of the International Energy Agency Greenhouse Gas Programme.

The meeting was organized by a Steering Committee including representatives from: Carnegie Mellon University (Ed Rubin), Electric Power Research Institute (George Booras and Richard Rhudy), IEA Greenhouse Gas Programme (John Davison), Lawrence Livermore National Laboratory (Sean McCoy), Massachusetts Institute of Technology (Howard Herzog), National Energy Technology Laboratory (Lynn Brickett), NaturalGas Fenosa (John Chamberlain) and Shell Global (Wilfried Maas).

The purpose of the workshop is to share and discuss the most currently available information on the cost

of carbon capture and storage (CCS) in electric utility and other industrial applications, as well as the current outlook for future CCS costs and deployment. The workshop also seeks to identify key issues or topics related to CCS costs that merit further discussion and study.

As shown on the previous pages, the first day of the workshop was a plenary session addressing four general topics, each addressed by invited presentations, followed by a discussion among workshop participants. The second day pursued three topics in more detail via parallel breakout sessions, followed by a plenary session with group reports and discussion.

This document presents brief summaries of each of the four sessions from Day 1 and the three breakout sessions from Day 2, together with the full set of presentations by invited speakers on Day 1. The proceedings of previous workshops are available at: <https://www.globalccsinstitute.com/publications/ccs%20cost%20workshop>



PRESENTATION SUMMARIES

Session 1: Framing the Issue

The purpose of this session was to frame the issue of CCS cost estimates by providing background on the current status of these estimates. The first talk presented the results of a review of recent cost studies found in the open literature. The second presented the methodology that goes into a detailed CCS cost estimate. A brief description of each talk follows.

The Cost of CCS: A Review of Recent Studies

Presented by Edward S. Rubin, Carnegie Mellon University

This presentation was based on a paper written for a special edition of the *International Journal of Greenhouse Gas Control*¹ that celebrated the tenth anniversary of the 2005 IPCC Special Report on Carbon Dioxide Capture and Storage (SRCCS).² The paper included costs of four capture technologies: Supercritical Pulverized Coal (SCPC) with post-combustion capture, SCPC with oxy-combustion capture, Integrated Coal Gasification Combined Cycle with pre-combustion capture, and Natural Gas Combined Cycle with post-combustion capture. Costs for CO₂ transport and storage were also included. The current reported range of costs were presented and compared to the costs found in the SRCCS after adjusting all costs to a common 2013 cost basis. While current capital costs were generally higher than adjusted SRCCS costs, the cost of electricity comparison showed little change primarily because of lower fuel prices and higher assumed capacity factors in recent studies. The ranges of CO₂ avoidance costs also were similar to adjusted SRCCS values after accounting for some changes in CO₂ transport and storage costs. The talk concluded with a discussion of the outlook for future cost reductions.

¹ Rubin, E.S., J.E. Davison, and H.J. Herzog, "The Cost of CO₂ Capture and Storage," *International Journal of Greenhouse Gas Control*, **40**, pp 378-400, September (2015).

² IPCC, 2005: IPCC Special Report on Carbon Dioxide Capture and Storage. Prepared by Working Group III of the Intergovernmental Panel on Climate Change [Metz, B., O. Davidson, H. C. de Coninck, M. Loos, and L. A. Meyer (eds.)]. Cambridge University Press, Cambridge, United Kingdom and New York, NY, USA, 442 pp.

Methodology of a Detailed CCS Cost Study

Presented by Jeff Hoffmann, National Energy Technology Laboratory (NETL)

NETL has produced a series of baseline studies on the cost and performance of various state-of-the-art CCS power plants.³ These studies are very detailed and provide a valuable reference for the CCS community. This presentation reviewed the methodology that goes into generating a baseline technology cost estimate for the "next commercial offering." The seven key steps are:

1. Develop a technology analysis plan and solicit feedback from stakeholders.
2. Create a performance model of each power plant based on NETL process models.
3. Integrate carbon capture technology models based on literature and developer input.
4. Adjust balance of plant as needed per the new technology demands.
5. Estimate the capital, operating and maintenance cost of all plant components using the method described in NETL's QGESS documents and elaborated in the Baseline studies.
6. Apply plant financing and utilization assumptions to develop a cost of electricity.
7. Perform sensitivity analyses and provide R&D guidance.

After describing each step in detail, a case study was presented based on a SCPC plant with an amine-based post-combustion CO₂ capture system.

Session 2: Project Costs – Industrial Applications

John Davison introduced the session on industrial capture project costs. He highlighted that there is increasing interest in industrial CCS but cost estimation can be complex, for example due to integration with existing sites and in some cases multiple CO₂ sources. Also, many industrial plants are located in developing countries, where cost data are not easily available. There are examples however some successful industrial CCS projects and

³ <http://www.netl.doe.gov/research/energy-analysis/baseline-studies>

presentations were made on two of them: the Quest and Illinois Basin/Decatur projects.

Wilfried Maas of Shell made a presentation about the Quest CCS project and its costs. The Quest project involves capture of CO₂ at a hydrogen plant at the Scotford upgrader near Edmonton, Canada, which processes hydrocarbons from oil sands fields. The capture plant uses Shell's ADIP-X amine process. The captured CO₂ is compressed in a multistage centrifugal compressor and is transported 65km to a saline reservoir storage site. Modular construction involving 69 modules was used for the capture and compression plant, which minimises site construction.

The plant has operated continuously for 6 months during which time 0.5Mt of CO₂ has been injected, exceeding the target rate. The FOAK facilities cost forecast is CAN\$812M, equivalent to 752 \$/tpa captured. A substantial part of the costs (CAN\$137M) is venture costs which could be reduced substantially in NOAK plants. There is an extensive knowledge sharing part of the programme, as described in the presentation slides. Some key messages were:

- It was emphasised that adequate support is needed to demonstrate CCS and reduce costs from FOAK to NOAK to deliver a competitive and viable technology in a decarbonised world.
- For FOAK plants, capital grants (to support build) and OPEX support (to ensure the plant operates) are required, plus other temporary measure (e.g. CCS certificates) if the uptake rate continues to be disappointing.
- Non-financial measures (enabling regulations, liability agreements etc) are also important.
- The main requirement for NOAK plants is expected to be a robust CO₂ price.

Sallie Greenberg of the University of Illinois and Ray McKaskle of Timeric Corporation presented insights into costs of CCS gained from the Illinois Basin – Decatur Project. This project involves compression, dehydration, transmission and storage of high purity CO₂ from a bio-ethanol plant at a rate of 1,000t/d. The pipeline is relatively short (1.9km) but it had to be above ground and insulated. The Illinois project uses reciprocating compressors. An important issue in the selection of reciprocating compressors, rather than the multi-stage centrifugal compressor used at Quest, was greater familiarity and proximity to a local supplier for support and spares. The project costs were presented in detail, showing a cost for compression, dehydration and transmission of

\$31/t. The capital cost was amortised over the 3 year injection period, costs for a commercial project would be amortised over much longer period, resulting in lower costs. The capital costs were higher than the initial estimate but operating costs were lower. Some significant conclusions are:

- CCS is a major undertaking involving many types of industry, government and financial professional, as well as many industry trades.
- First mover projects can provide useful benchmarks and lessons learned that will benefit future projects.
- Incorporating CCS into existing operational plants comes with additional case-specific challenges and costs.
- Permitting timelines and general economic conditions may impact costs of future projects in ways that are difficult to predict.

Session 3: Project Costs – Power Applications

This session focused on cost estimates for CCS applications in electric power generation applications. The overall session objectives were to learn about the cost of actual CCS projects, including a summary of lessons learned and opportunities for future cost reductions. The projects included one operating post-combustion capture project, and two large-scale oxy-combustion projects that were in the advanced stages of development at the time the projects were cancelled.

Boundary Dam Carbon Capture Project

The first speakers were Max Ball and Peter Versteeg who joined the workshop via teleconference from SaskPower's office in Regina, Saskatchewan. Peter started with a summary operating statistics for the first-of-a-kind Boundary Dam Carbon Capture Project. In 2015 the net power output averaged 107 MW, with the plant being down for maintenance during the month of September. The daily average amount of CO₂ captured was 1,739 tonnes in 2015, however that increased to 2,726 tonnes in February of 2016.

The major factors impacting the capital cost of the project included site-specific, first-of-a-kind (FOAK), and market factors, as well as specific plant design features. The small size of the plant resulted in dis-economies of scale relative to the larger plant sizes assumed in most conceptual

studies. Firing lignite also imposed a cost and performance penalty relative to higher rank coals. At the time the plant was constructed, an abundance of other heavy industrial activity in the Province resulted in higher hourly labor costs and reduced productivity. A heavy emphasis was placed on maximizing power output, as opposed to minimizing capital cost.

FOAK issues included schedule extensions due to conducting three parallel CO₂ capture plant FEED studies, additional regulatory requirements to be met, development of operating and environmental health & safety standards for a power plant integrated with a CO₂ capture system. Contingency provisions and design margins were impacted by an “it must work” philosophy. And finally, some components did not perform to their design expectations. A chart showing the wide fluctuations in the price of steel illustrated one example of how market factors adversely impacted the cost during the time period when Boundary Dam plant was constructed.

Based on the learnings from construction, start-up, and initial operation of the Boundary Dam capture plant, SaskPower expects the cost of the next capture plant to be substantially less. Max also noted that their next plant would be designed to reduce CO₂ emissions to essentially natural gas equivalence to meet the Canadian Federal requirements, as opposed to the nominal 90% CO₂ capture capability at Boundary Dam.

FutureGen 2.0

Ken Humphreys, CEO of the FutureGen Alliance gave an overview of the project and the many milestones that were achieved prior to the project being terminated. Unit 4 of the Meredosia Energy Center in Illinois was to be repowered with oxy-combustion and CCS technology. The net plant output was expected to be 167 MW, while capturing 90+% of the CO₂ (or about 1.1 MMT/yr). A 28 mile pipeline would transport the CO₂ to a deep geologic storage site. Some of the many milestones achieved by the project team included:

- Power purchase agreement signed
- Final permits were issued for air, water, pipeline and CO₂ storage
- Subsurface rights were acquired and CO₂ liability management was addressed
- Mega-FEED was completed (70-90% of final design, at a cost of \$90 million)
- Project labor agreements were signed.

Unfortunately the federal co-funding expired and the project had to be terminated. The EPC costs were well known due to the fact they had fixed price contracts. The total as-spent capital cost of the power plant was estimated to be \$1,256 million, which excludes the over-the-fence ASU and the \$423 million cost for the CO₂ pipeline and storage facilities. Ken presented detailed breakdowns for the Owner, Financing and Start-Up costs. Plant operating costs were estimated to be \$128/MWh on a 20-year levelized basis. The major operating cost drivers included oxygen, fuel, purchased power, ash disposal & consumables, and CO₂ transportation & storage. The total 20-year levelized LCOE including capital recovery was estimated to be \$179/MWh. However, after the MISO energy/capacity sales credit the net cost to the ratepayers would have only been \$138/MWh, representing less than a 2% average rate increase.

Lessons learned during the project included how to deal with a very large number of landowners for the CO₂ pipeline right-of-way, and the CO₂ storage subsurface rights. They also found that the EPC negotiations took much longer, and the balance of plant (BOP) was more complicated than originally planned. Future oxy-combustion plants will have reduced capital costs and improved efficiency due to retrofitting newer, larger USC plants that will benefit from economies of scale. CO₂ transportation and storage costs will also benefit from economies of scale.

White Rose CCS Project

The final speaker in this session was Dr. Leigh Hackett from GE Power, who talked about the White Rose CCS Project. The White Rose project is a new ultra-supercritical oxy-combustion plant with a gross output of 448 MW. The plant was designed to capture 90% of the CO₂, or about 2 million tonnes CO₂ per year. The plant would have been the “anchor” project for National Grid’s regional CO₂ transport & offshore storage network, where the infrastructure was sized for 17 million tonnes CO₂ per year to enable future projects. The captured CO₂ was to be stored in a deep saline formation offshore, beneath the North Sea.

The UK Department of Energy & Climate Change (DECC) will publish 41 White Rose project key-knowledge reports later in 2016, including the full-chain FEED summary report, FEED lessons learned, FEED risk report, and full-chain project cost estimate report. The term “full-chain”

refers to the oxy power plant, the onshore & offshore pipeline networks, and the CO₂ injection & storage systems. The full-chain project cost estimate was classified as an AACE Level 2 estimate for the majority of items, with 90% of the costs based on vendor quotes.

For the DECC reports, the actual White Rose project cost estimates were adjusted and normalized to take out project specific data and allow comparison to other published data. For example, the site was adjusted to US Gulf Coast basis and site preparation costs were removed. The normalized project cost estimate was broken down into externally supplied utilities, the oxy boiler/ASU/gas processing unit, power generation equipment & BOP, onshore pipeline, offshore pipeline, and storage facilities. Dr. Hackett then showed a chart illustrating the savings achievable for follow-on projects where they can take advantage of the existing CO₂ transportation and storage network.

The White Rose Project resulted in lessons learned in the following four key areas:

- Full-chain commercial structuring and management of cross-chain risks
- Non-EOR CO₂ storage business model
- Oversizing and sharing CO₂ transportation & storage infrastructure
- Potential insurance gaps

Key take-aways from the White Rose project were that no significant technical barriers remain to project implementation, full-chain aspects were adequately defined and developed, and the next step is a large-scale commercial project. Dr. Hackett concluded by saying that the UK Government's decision to cancel the UK CCS Competition has stalled commercialization in the UK and Europe and "dented" confidence in CCS.

Session 4: CCS in the Context of Changing Electricity Markets

In the fourth session of the workshop, speakers took a step back from the topic of CCS cost estimation to look at the context for CCS in future electrical systems, what this implies about the value of CCS-equipped generation, and some alternative metrics that might better convey its value to decision makers. The session began with a presentation from Andy Boston (Energy Research Partnership), which was followed by responses from Neil Kern (Duke

Energy) and Geoffrey Bongers (Gamma Energy Technology), and then general discussion.

The presentation from Andy Boston captured the lessons from an ERP analysis of future United Kingdom electricity systems, and highlighted three key messages:

- A zero- or very low-carbon electricity system with variable renewables (e.g., solar, wind) needs dispatchable, low-carbon technologies to provide firm capacity
- Policy makers and system operators need to value services that ensure grid stability to establish a market for new providers
- A holistic approach that accounts for the cost of balancing the system would better recognize the importance of firm low carbon technologies than conventional measures of individual technology cost

To illustrate the final point, Andy presented results from his analysis showing that, even though gas-fired generation equipped with CCS had a relatively high LCOE, addition of capacity could result in a net reduction in system cost. His results also clearly showed, however, that the value of a technology is dependent on the existing generation mix and the grid services it provides, which makes these results difficult to generalize. His provocative conclusion was that this value cannot be captured by LCOE.

In the first invited response to the initial presentation, Neil Kern highlighted that Duke Energy sees a paradigm shift in the way traditional utility planning takes place as a result of the growing trend towards distributed generation. The result is that Duke is placing an increased emphasis on flexibility of centralized generation, and seeking to identify non-traditional markets for central stations. In the second invited response, Geoffrey Bongers highlighted the multi-attribute comparisons of generating technology in the recently published Australian Power Generation Technology Study. In that study, technologies were evaluated not only on their LCOE, but also on their capital cost, water requirements, CO₂ emissions, waste products, availability and flexibility.

In the ensuing discussion, participants debated whether LCOE is an inadequate metric or is simply being used inappropriately, such as by comparing baseload plants with intermittent renewable that do not provide comparable services (ignoring the additional integration and backup system costs that would be required).

Others felt the true value of dispatchable generation, like fossil-fuels equipped with CCS, can best be measured by the reductions in system-level cost that results as such capacity is added. Others noted that many decision makers want simpler metrics like LCOE. While most participants agreed on the need for ways to make better technology comparisons, and to more clearly quantify the value of CCS, there was no consensus on how this should be done.



BREAK-OUT SESSION SUMMARIES

Session A. Reconciling Real and Estimated CCS Plant Costs

Questions: *Can we reconcile real project and N^{th} plant costs? How should we present this information to policy makers?*

Co-chairs: Ed Rubin, CMU; George Booras, EPRI; assisted by Kristen Gerdes, NETL

This session focused on identifying the factors that typically contribute to higher costs of initial full-scale installations of CCS and other newly-commercial technologies (often referred to as FOAK, or “first-of-a-kind”) relative to the longer-term (NOAK, or “ N^{th} -of-a-kind”) costs commonly reported for mature technologies. Additional thoughts on how this information

should be presented to policy makers follow the presentation of the factors identified.

Reconciling Actual vs. N^{th} Plant Costs

In general, the cost of a specific project is affected by several classes of factors, including:

- Site Specific Factors
- Market Factors
- Design Basis Factors
- Project Execution Factors
- Financing/Contracting/Owner’s Costs
- FOAK Factors (Planned & Unplanned)

Each of these categories can be further expanded to identify more specific factors that influence actual costs. Given the focus of this workshop on CCS costs, the factors whose cost is exacerbated by FOAK installations are highlighted with an asterisk (*).

- Site-Specific Factors
 - Labor Costs, Productivity, Availability/Skill Requirements*
 - Materials cost
 - Seismic activity
 - Ambient conditions (temperature, etc.)
 - Water availability & quality
 - Fuel availability & quality
 - Proximity to CO₂ storage
- Design Basis Factors
 - Scope and battery limits: base plant, capture, transport, storage
 - Fuel type
 - Plant size
 - Pipeline capacity
 - Storage capacity
 - Cooling system design
 - Ambient conditions
 - CO₂ capture rate
 - CO₂ purity requirements
 - Emission standards
 - Brownfield vs. greenfield vs. retrofit
 - Flexibility of operations *
 - Load following*
 - Start-up/shutdown*
 - Flexible capture*
- Market Factors
 - Commodity prices
 - Labor costs
 - Engineering costs
 - Competition and availability
 - Currency exchange rates
 - Construction equipment and services availability
 - CO₂ value
 - Offtake agreements*

- Regulations and policies
- Private sector incentives?
- Public sector tolerance for R&D
- Project Execution Factors
 - Scheduling*
 - Re-design in mid-construction*
 - Modular vs. stick build (shop vs. field fabrication)
- Financing and Other Factors
 - Financing (risk premiums)*
 - Permitting-related costs and delays*
 - Regulatory and legal issues
 - Plant availability, capacity factor, and dispatch expected (when assessing financial viability)*
 - Owner's costs*
 - Contracting strategy (where is the risk?)*
- FOAK Factors (Planned)
 - Schedule length
 - Contingency/over-design
 - Development of training, simulators, maintenance protocols
 - Extended ramp-up
 - Chemical plant operation in a power plant culture
 - Performance guarantee limitations
- FOAK Factors (Unplanned)
 - Performance shortfalls

Presenting to Policy and Decision Makers

Rather than showing how various factors *add* to FOAK plant costs, our approach should be to show how *removing* various cost escalation factors that are unique to, or exacerbated by, FOAK projects will *reduce* the cost of subsequent projects. This could be illustrated, for example, with a set of bar graphs like those presented by SaskPower, but in the reverse order, starting with the high cost of an FOAK installation, with costs then coming down as various cost adders are removed with increasing experience and know-how.

Session B. Challenges of CCS Cost Estimation and Financing

Question: *What are the main challenges of industrial and power CCS cost estimation and financing?*

(Co-chairs: Jeff Hoffmann, NETL; Howard Herzog, MIT)

The breakout started by asking each participant to respond to the question for this breakout

session. The responses and additional questions generated follow:

- How do you capture the global market competitiveness for internationally traded industrial products made with processes including CCS?
- For projects with government support, how do you capture government subsidy (and risk) as it relates to financing?
- How do you capture costs of real world projects?
- How do you effectively estimate project contingencies?
- How can we best assure cost estimates are used in an appropriate manner?
- Since industrial processes are more heterogeneous than fossil-fueled power generation, how to develop a novel plant for policy modeling and market deployment studies that is widely representative?
- The cycle times for industrial processes are long. The developed world is not building new plants and the typical business model is to replace rather than refurbish and retrofit.
- It is difficult to estimate costs in non-OECD countries.
- Policymakers view CCS and renewables as interchangeable. Cost estimating using LCOE support interchangeability.
- Time factor (permitting, etc.) can drive costs higher.
- Credibility of publically available cost estimates is difficult to assess because of frequent lack of transparency in assumptions. The lack of transparency makes it very difficult to calibrate, compare and validate individual published studies.
- Even studies that seem to be reasonably transparent are complicated, and a primer to methodology and intended purpose would be helpful in addressing how to use the studies.
- Studies are made in the context of “something” (i.e., specific policy scenario, fuel price scenario, anticipated future capacity needs), but the “something” is often changing.

After some discussion in trying to get a handle on these many disparate issues, the group focused on two areas to gain some insights.

Cost vs. economic analysis

A major issue for cost estimation is how to develop costs to compare CCS to other technologies. Right now there is an over-

reliance on the levelized cost of electricity (LCOE), which is not always a very good metric for comparison. Therefore, there is a need to go beyond the LCOE.

Cost estimates can generate what we term “hard” numbers, as well as context specific numbers. Examples of hard numbers include capital costs and heat rates. While capital costs can vary over time (e.g., inflation) and geography, these variations can generally be captured through sets of cost indices. Other hard number metrics can include process inputs (e.g., water), process effluents, and availability for dispatch.

Doing an economic analysis, such as one that produces an LCOE, requires context. The plant’s capacity factor depends on dispatch, which can only be known in the context of the utility system in which the plant operates. There are many project specific factors that depend on the plant’s location, permitting requirements of that location, labor environment, access to utilities, etc. The monetizing of risk and the valuation of ancillary services (e.g., capacity) will also vary widely depending on the context.

For comparing CCS to other technologies, developing methods based on the relatively hard numbers involved in a cost estimate (both cost and performance metrics) are preferred. Much more care must be taken when comparing technologies using context dependent numbers like LCOE.

Industrial processes

A big challenge in trying to determine the costs of Industrial CCS (ICCS) is the significant amount of process heterogeneity, both between industrial sectors and within industrial sectors. The appropriate technological approaches for CO₂ capture may vary greatly across industries. While at first blush it may seem that post-combustion capture with amines will always be an option, this may not be so. Impurities associated with exhaust streams may pose a significant challenge to amines. An example is the exhaust stream from the catalytic cracker at the Mongstad refinery, where the SO₃ in the exhaust gas caused the amine process to fail.

A potential major issue with ICCS is maintaining the integrity of the product. While this may not be an issue for post-combustion capture, other pathways that integrate CCS with the process must make sure that they maintain product integrity. As a result, there is a need for more detailed engineering assessments for capture

options for the various industrial sectors and a need for more engagement with the industries.

An additional potential barrier to deployment of CCS technologies in the industrial sector is the approach that many industrial business take regarding existing and new assets. Several of the breakout participants suggested that it is more common for industrial sector businesses to run existing capacity to the end of its useful life “as built” or replace with new state-of-the-art infrastructure rather than modify (i.e., retrofit) existing (and potentially outdated) capacity with new add-on processes. Therefore, it is likely that any back-end CCS technologies would compete against 1) alternative lower carbon intensive industrial processes and 2) location for replacement industrial facilities (either regionally or globally). Ultimately, the selection will be for the scenario that leads to the least-cost production of the industrial product and CCS is expected to play a role only if a low-carbon “benefit” can be monetized.

Session C. Making CCS More Competitive

Questions: *What can be done to make CCS more competitive? What are realistic expectations for CCS cost reductions over next 10-20 years? By 2050?*

(Co-chairs: Wilfried Maas, Shell; Sean McCoy, LLNL)

Round-table comments

- We know how much stuff costs; getting it financed and built is the hard part.
- Real questions about accuracy of public literature costs for capture (e.g., the US government can’t even agree on a number) and we’re not sure how to add-up the costs. But, from a practical industry standpoint, this isn’t a big deal because they’re in the right ballpark.
- Variability of costs is, however, a surprise; also, surprised at the cost of compression and injection.
- Worried about risks associated with storage. Looking at risk separately is convenient, but the whole chain matters; what about injection and monitoring costs? What are the costs when we have surprises (e.g., OK seismicity from w/w re-injection, BC seismicity from fracking)?
- The big issue facing CCS is getting the whole thing together; system costs are important.

- Commercial structures are key in getting CCS built but...
- ...the commercial case for CCS isn't there, at least in global aggregate near-term; creates an issue of timing, since we need to work technology development today.
- In a really tough place on the technology development curve: need to de-risk technologies and get policy support. Need some data points.
- Current technologies not socially acceptable, and learning-by-doing won't cut it
- Nonetheless, there is a strong societal case for CCS; but massive market failure means there is no business case for individual developers. Need policy to address the failures.
- Perhaps early projects were too ambitious: they tried to solve both capture and storage simultaneously.
- What is the right scale for CCS: little with high unit cost (and lower risk) or high with low unit cost (and higher risk). Does this argue for small-scale?
- Busy talking about cost, rather than revenue maximization. How can CCS have value to those who are doing it?
- Need to move towards system costs and away from LCOE; however, as bad as LCOE might be, but we don't have a good alternative.
- Don't be too negative on recent progress: much in the technology space has improved over the last decade.
- fundamental difference between CCS and other technologies in power generation.
- Much of the past CCS focus was based on the presumption that there was going to be a rush to building coal that was going to happen in US and Europe.
- So, what is the state support package for development of a CCS industry? One answer is regulatory frameworks to push deployment: accelerate learning-by-doing and technology innovation. Create a market pull.
- Opposite commercial logic between US and Europe: US wants cheap CO₂ and low-cost sources fill the need; Europe want emissions reductions from expensive sources, who are begging oil and gas to play. For example, in the US physical CO₂ has value, but in Europe it is paper contracts that have the (uncertain) value.
- In the absence of EOR/CCUS, Europe has no revenue in the transport and storage chain.
- US thinking is that the storage side is well understood (from a technology perspective) based on R&D and current operations. Agreement that this is a trans-Atlantic difference, where Europe is more concerned with the transport and storage risk.
- With LCFS, issue is that there are cheaper ways to meet the requirements today via biofuels. Need to hit blend wall before CCS comes into play. However, LCFS in one jurisdiction that can drive CCS somewhere else – opposite to discussion with economic leakage.
- What about carbon takeback obligations? Thinking about this in Europe.
- Energy systems analysis (e.g. IPCC) says CCS is critical and lowest-cost. But analysis is complicated, and question is how to sell it to the public and to policy makers.
- China and SE Asia are wild cards acknowledged by all – huge potential, but capability gaps.
- Another wild card is advanced nuclear technologies; technology and resource availability enables targets to be set (e.g., REGGI, CPP).
- Other drivers (e.g., reductions in water use) may put us in a position to deliver cheaper capture as a co-benefit – like molten carbonate fuel cells.

What do we do?

- Marginal value of additional paper cost studies is very low.
- UK CCS cost reduction taskforce found that 25% reduction from technology improvement, 50% economies of scale in T&S, 25% from reduction in finance costs; all that is needed are a handful of plants in the UK to reach their cost reduction targets...
- Comments suggest main issue in risk is not capture related: it's the transport and storage that is the problem and where focus needs to be. History is filled with programs focused on capture/plant side justified by technology development, few (noteworthy) successes; has this been the wrong focus?
- Need government action to handle T&S problem or no real way to manage risk –

Question to the group: Will CCS be at 100 USD/MWh and commercially available by 2030?

- 5 No – timing of needs and business case, scale-up cannot be rapid enough; supply chain collapsed and will need to be rebuilt; competition from other technologies; government not willing to acknowledge that prices need to go up (or justify increased prices) to make this all work
- 12 Yes – prices will rise, and CCS will be marginal technology; Asia will do it, initial regulations will spur a discussion of what happens next that will lead to CCS; potential for breakthrough technology; CCS with gas will be where cost happens; cost might be there, but not widely demonstrated; new way of pricing energy in future enables CCS; costs for capture on gas are already there.
- 1 Abstention – don't know enough

Report to Plenary Session:

1. We asked the question: will CCS be commercially available for power generation in 2030 at a cost of \$100-120/MWh? 12 responded “yes”; 5 said “no”; and 1 abstention. Disagreement on whether it will actually be deployed, though.
2. Difference between EU and US perspectives on where cost reductions are going to come from: capture technology, versus T&S infrastructure (particularly in regards to risk).
3. Cost reduction requires learning-by-doing which implies markets; need markets!
4. Market for CCS was going to be new coal, but now, not much new coal—at least in developed countries—so now there is a gap before we get to gas.
5. Tension between small-scale with high unit cost but low project cost, hence, lower risk; or large-scale with low unit cost but high project cost, hence higher risk.
6. Marginal benefit of additional cost studies is low.
7. Need to come up with effective means (messaging) to convey importance of CCS in a system context.
8. In the meanwhile, industrial CCS—oil and gas sector—will continue be a big driver. Wild card: what China decides to do is a huge deal.

PRESENTATIONS

Introduction

CCS Cost Network Workshop Overview
Howard J. Herzog

Session 1: Framing the Issue

The Cost of CCS: A Review of Recent Studies
Edward S. Rubin

Methodology of a Detailed CCS Cost Study
Jeff Hoffman

Session 2: Project Costs – Industrial Applications

Quest Project and Its Costs
Wilfried Maas

Insights into Cost of CCS Gained from the Illinois Basin-Decatur Project
Sallie E. Greenberg, Ray McKaskle

Session 3: Project Costs – Power Applications

Project Costs Power Applications
George Booras

Factors Impacting Capital Costs at SaskPower's Boundary Dam Integrated CCS Project
Max Ball and Peter Versteeg

FutureGen 2.0
Ken Humphries

White Rose—Oxy-fuel CCS Project
Leigh A. Hackett

Session 4: CCS in the Context of Changing Electricity Markets

The Value of Flexible, Firm Capacity on a Decarbonised Grid
Andy Boston

Duke Energy
Neil Kern

CCS Cost Network Workshop Overview

Howard Herzog
MIT
March 22-23, 2016

Howard Herzog / MIT Energy Initiative

Steering Committee

- Howard Herzog (MIT)
- Ed Rubin (Carnegie Mellon)
- Richard Rhudy/George Booras (EPRI)
- Sean McCoy (LLNL, formerly IEA)
- John Davison (IEAGHG)
- John Chamberlain (Gas Natural Fenosa)
- Wilfried Maas (Shell)
- Lynn Brickett/ Jeff Hoffmann (USDOE/NETL)

Howard Herzog / MIT Energy Initiative

Acknowledgements

- IEAGHG – Umbrella for the Cost Network
- MIT Energy Initiative – Meeting Planning
- Sponsors
 - MIT Carbon Sequestration Initiative – Meeting Space, Lunches, and Breaks
 - » API, Chevron, Duke Energy, Entergy, EPRI, ExxonMobil, Shell, Southern Company, Suncor
 - Shell – Workshop Dinner
- Thanks to all the presenters

Howard Herzog / MIT Energy Initiative

History

- Initial Discussions
 - GHGT-10, Amsterdam, September 2010
- Workshops
 - IEA Paris, 22 – 23 March 22-23, 2011
 - EPRI, Palo Alto, CA, April 25-26, 2012
 - IEA , Paris, November 6-7, 2013
- Now sanctioned as a Network under the IEAGHG

Howard Herzog / MIT Energy Initiative

Agenda

- Framing the Issue
 - The Cost of CCS: A Review of Recent Studies (Ed Rubin, CMU)
 - Methodology of a Detailed CCS Cost Study (Jeff Hoffmann, NETL)
- Project Costs
 - Quest (Wilfried Maas, Shell)
 - Illinois Basin Decatur (Sallie Greenberg, University of Illinois; Ray McKaskle, Trimeric)
 - Boundary Dam (Max Ball and Peter Versteeg, SaskPower via teleconference)
 - FutureGen 2.0 (Ken Humphreys, FutureGen 2.0)
 - White Rose (Leigh Hackett, GE Power)
- CCS in the context of changing electricity markets
 - The value of flexible, firm capacity on a decarbonized grid (Andy Boston, Energy Research Partnership)
 - Initial Respondents: Neil Kern (Duke Energy), Geoffrey Bongers (Gamma Energy Technology)

Howard Herzog / MIT Energy Initiative

Breakouts

- A. Can we reconcile real project and n^{th} plant costs? How should we present this information to policy makers? (9)
 - Ed Rubin, CMU; George Booras, EPRI
- B. What are the main challenges of industrial and power CCS cost estimation and financing? (11.5)
 - Jeff Hoffmann, NETL; Howard Herzog, MIT
- C. What can be done to make CCS more competitive? What are realistic expectations for CCS cost reductions over next 10-20 years? By 2050? (18.5)
 - Wilfried Maas, Shell; Sean McCoy, LLNL

Howard Herzog / MIT Energy Initiative

Other items

- Internet – MIT GUEST (No password)
- General discussion on Wednesday afternoon on future activities of the Costing Network
- A proceedings of the meeting will be produced as a public document
- Dinner tonight
 - Reception starts at 7 pm
 - Sit down for dinner at 7:30
 - Wine and beer included

Howard Herzog - MIT Energy Initiative

Contact Information

Howard Herzog
Massachusetts Institute of Technology (MIT)
Energy Initiative
Room E19-370L
Cambridge, MA 02139
Phone: 617-253-0688
E-mail: hjherzog@mit.edu
Web Site: sequestration.mit.edu

Howard Herzog - MIT Energy Initiative

The Cost of CCS: A Review of Recent Studies

The Cost of CCS: A Review of Recent Studies

Edward S. Rubin

Department of Engineering and Public Policy
Department of Mechanical Engineering
Carnegie Mellon University
Pittsburgh, Pennsylvania

Presentation to the
CCS Cost Network Workshop
Cambridge, Massachusetts


March 22, 2016

Special Issue of *IJGGC*: 10 Years After the SRCCS



The IPCC Special Report on CCS

- Commissioned by IPCC in 2003; completed in December 2005
- First comprehensive look at CCS as a climate change mitigation option (9 chapters; ~100 authors)
- Included a detailed review of cost estimates for CO₂ capture, transport and storage options



SRCCS Costs for CO₂ Capture

(excludes transport and storage; all costs in constant 2002 US\$)

Performance and Cost Measures	New NGCC Plant			New SCPC Plant		New IGCC Plant	
	Range	Rep. Value		Range	Rep. Value	Range	Rep. Value
Emission rate w/o capture (kg CO ₂ /MWh)	344 - 379	367		736 - 811	762	682 - 846	773
Emission rate with capture (kg CO ₂ /MWh)	40 - 66	52		92 - 145	112	65 - 152	108
Percent CO ₂ reduction per kWh (%)	83 - 88	86		81 - 88	85	81 - 91	86
Plant efficiency w/ capture, LHV basis (%)	47 - 50	48		30 - 35	33	31 - 40	35
Capture energy reqm't. (% more input/MWh)	11 - 22	16		24 - 40	31	14 - 25	19
Total capital reqm't. w/o capture (US\$/kW)	515 - 724	568	1161 - 1486	1286	1169 - 1565	1326	
Total capital reqm't. w/ capture (US\$/kW)	909 - 1261	998	1894 - 2578	2096	1414 - 2270	1825	
Percent increase in capital cost w/ capture	64 - 100	76	44 - 74	63	19 - 66	37	
COE w/o capture (US\$/MWh)	31 - 50	37	43 - 52	46	41 - 61	47	
COE w/ capture only (US\$/MWh)	43 - 72	54	62 - 86	73	54 - 79	62	
Increase in COE w/ capture (US\$/MWh)	12 - 24	17	18 - 34	27	9 - 22	16	
Percent increase in COE w/ capture (%)	37 - 69	46	42 - 66	57	20 - 55	33	
Cost of CO ₂ captured (US\$/t CO ₂)	33 - 57	44	23 - 35	29	11 - 32	20	
Cost of CO ₂ avoided (US\$/t CO ₂)	37 - 74	53	29 - 51	41	13 - 37	23	

SRCCS Costs for New Power Plants Using Current Technology

Power Plant System	Natural Gas Combined Cycle Plant	Supercritical Pulverized Coal Plant	Integrated Gasification Combined Cycle Plant
Levelized Cost of Electricity (constant 2002 US\$/kWh)			
<i>Reference Plant Cost (without capture)</i>	0.03–0.05	0.04–0.05	0.04–0.06
Added cost of CCS with geological storage	0.01–0.03	0.02–0.05	0.01–0.03
Added cost of CCS with EOR storage	0.01–0.02	0.01–0.03	0.00–0.01
Cost of CO₂ Avoided (constant 2002 US\$/tonne)			
Same plant with CCS (geological storage)	40–90	30–70	15–55
Same plant with CCS (EOR storage)	20–70	10–45	(-5)–30

Source: IPCC (2005), p. 1000

EPA Region 5 Regional Office

2015 Cost Update

(Hulón, Davison and Herzog, *ETC*)

- Compiled data from recent CCS cost studies in the U.S. and Europe for new power plants with:
 - Post-combustion CO₂ capture (SCPC and NGCC)
 - Pre-combustion CO₂ capture (IGCC)
 - Oxy-combustion CO₂ capture (SCPC)
- Adjusted all costs to constant 2013 US dollars
- Adjusted SRCCS costs from 2002 to 2013 USD using:
 - Capital /O&M cost escalation factors +
 - Fuel cost escalation factors (for COE)
- Compared recent cost estimates to SRCCS values

EPA Region 5 Regional Office

Recent Cost Studies Reviewed

- IEAGHG, 2014
- NETL, 2014
- EPRI, 2013
- NETL, 2013a, b
- ES&T, 2012
- IEAGHG, 2012
- Léandri et al., 2011
- GCCSI, 2011
- NETL, 2011a, b, c
- ZEP, 2011a, b, c
- NETL, 2010

16 studies, each with multiple cases


U.S. Energy Information Administration

Differences in Key Assumptions

- Basic power plant design parameters such as net plant efficiency, CO₂ emission rates, and CO₂ capture rates have not changed appreciably since the SRCCS
- Some assumptions affecting CCS costs have changed:
 - Average power plant sizes without CCS are about 10% to 25% larger than in SRCCS studies
 - Assumed capacity factors are higher (by 10 %-pts for PC, plants, 2 %-pts for IGCC plants, and 8 %-pts for NGCC)
 - Fixed charge factor are lower (by about 10% for NGCC, 20% for IGCC and 30% for SCPC)
 - Parameter values often differ for plants with and w/o CCS
 - Increased focus on potential for utilization via CO₂-EOR

U.S. Energy Information Administration


Capital Cost Trends



CPI= U.S. Consumer Price Index (BLS, 2014)
 CEPCI= Chemical Engineering Plant Cost Index (CE, 2014)
 PCCI= Power Capital Costs Index (excluding nuclear) (EPRI-CEBA, 2014)

EPRI-CEBA, 2014

Fuel Cost Trends for U.S. Power Plants



EPRI-CEBA, 2014


EPRI-CEBA, 2014

Capture System Costs Then and Now: New SCPC Plants w/ Post-Combustion Capture


Bituminous coals, 90% capture, all costs in constant 2013 \$ (million)

Performance and Cost Measures for New SCPC Plants w/ Bituminous Coal	Current Values			Adjusted SRCCS Values			Change in Rep. Value (Current - Adjusted SRCCS)	
	Range		Rep. Value	Range		Rep. Value	Δ Value	Δ%
	Low	High		Low	High			
Plant Performance Measures								
SCPC reference plant net power output (MW)	550	1030	742	462	758	587	155	26
Emission rate w/o capture (kg CO ₂ /MWh)	0.746	0.840	0.788	0.736	0.811	0.762	0.03	3
Emission rate with capture (kg CO ₂ /MWh)	0.092	0.120	0.104	0.092	0.145	0.112	-0.01	-7
Percent CO ₂ reduction per MWh (%)	86	88	87	81	88	85	2	
Total CO ₂ captured or stored (Mt/yr)	3.8	5.6	4.6	1.8	4.2	2.9	1.7	57
Plant efficiency w/o capture, HHV basis (%)	39.0	44.4	41.4	39.3	43.0	41.6	-0.2	-1
Plant efficiency w/ capture, HHV basis (%)	27.2	36.5	31.6	28.9	34.0	31.8	-0.2	-1
Capture energy reqm't. (% more input/MWh)	21	44	32	24	40	31	1.1	3
Plant Cost Measures								
Total capital reqm't. w/o capture (USD/kW)	2313	2990	2618	1862	2441	2040	578	28
Total capital reqm't. with capture (USD/kW)	4091	5252	4580	2788	4236	3333	1247	37
Percent increase in capital cost w/ capture (%)	58	91	75	44	73	63	13	
LCOE w/o capture (USD/MWh)	61	79	70	64	87	76	-6	-8
LCOE with capture only (USD/MWh)	94	130	113	93	144	119	-6	-5
Increase in LCOE, capture only (USD/MWh)	30	51	43	28	57	43	0	-1
Percent increase in LCOE w/ capture only (%)	46	69	62	42	65	56	5	
Cost of CO ₂ captured (USD/t CO ₂)	36	53	46	33	58	48	-3	-6
Cost of CO ₂ avoided, excl. T&S (USD/t CO ₂)	45	70	63	44	86	67	-4	-6

Capital Cost of SCPC Plants (representative values of cost ranges across studies)




Added Capital Cost for CO₂ Capture (over and above the reference plant cost without capture)



E. J. Kropf, Southwest Energy


Typical Cost Trend of a New Technology



E. J. Kropf, Southwest Energy


LCOE for SCPC Plants

(representative values, excluding transport & storage costs)



Added COE for Capture

(excluding transport & storage costs)



Transport and Storage Costs

(relative to adjusted SRCCS)

Onshore pipelines (250 km):

- Recent U.S. costs are similar to SRCCS: European costs are significantly higher (esp. for 3 MtCO₂/yr)

Geological storage (onshore):

- Low end of cost range is substantially higher: high end of cost range is slightly higher
- EOR credits are substantially higher (~\$15–40/tCO₂)

Total Plant LCOE (2013 \$/MWh)

for CO₂ capture, transport and geological storage

Case	NGCC with post-combustion capture	SCPC with post-combustion capture	IGCC with pre-combustion capture
<i>Without EOR</i>			
SRCCS (adjusted)	56 – 110	94 – 163	92 – 150
Recent Studies	63 – 122	95 – 150	112 – 148
<i>With EOR credits</i>			
SRCCS (adjusted)	48 – 100	76 – 139	77 – 128
Recent Studies	48 – 112	61 – 121	83 – 123

Mitigation costs (\$/tCO₂ avoided) also are roughly similar to adjusted SRCCS costs

Other Conclusions from the Study


- For new SCPC plants oxy-combustion capture shows potential to be cost competitive with post-combustion capture
- Based on current cost estimates for the four CCS pathways analyzed, there are no obvious winners or losers

E.S. Rubin, Carnegie Mellon


*The outlook for
future cost reductions*

E.S. Rubin, Carnegie Mellon

Projected Cost Reductions from "Bottom-Up" Analyses (1)



Projected Cost Reductions from "Bottom-Up" Analyses (2)



Projected Cost Reductions from a “Top-Down” Analysis

(Learning curves plus energy-economic modeling)

(Percent cost reduction, 2001–2050)*

Power Plant System	Reduction in Cost of Electricity (\$/MWh)	Reduction in Mitigation Cost (\$/tCO ₂ avoided)
SCPC –CCS	14% – 44%	19% – 62%
NGCC –CCS	12% – 40%	13% – 60%
IGCC –CCS	22% – 52%	19% – 58%

* Range based on low and high global carbon price scenarios.

Source: van den Broek et al., 2010

© 2010 Global Warming Solutions

What does it take to achieve these cost reductions ?

- Sustained **R&D**
- **Markets** for CCS technology
(created by policy carrots and sticks)
- Learning from **experience**

© 2010 Global Warming Solutions

Thank You

rubin@cmu.edu

© 2000 Andrew A. Chien

Methodology of a Detailed CCS Cost Study




NETL *Driving Innovation ♦ Delivering Results*


Methodology of a Detailed CCS Cost Study
CCS Cost Network Workshop
March 22, 2016

Jeff Hoffmann, Travis Shultz
NETL
Marc Turner, Vincent Chou, Norma Keuhn,
Arun Iyengar, Mark Woods - BAH

 **U.S. DEPARTMENT OF ENERGY** | National Energy Technology Laboratory

Presentation Overview 

- **Systems Engineering & Analysis (SEA)**
 - Emphasis on Energy Process Analysis Team (EPAT)
- **Overview of Techno-economic Analysis (TEA) Approach**
- **NETL Cost and Performance Baseline for Fossil Energy Plants**

 **U.S. DEPARTMENT OF ENERGY** | National Energy Technology Laboratory

2

Systems Engineering and Analysis Overview



- **Multi-disciplined engineering and economic analytical capabilities supporting evaluation of:**
 - Process components and systems of components for conventional and advanced energy technologies
 - Engineering tools and expertise to evaluate research and development progress, assist in identifying and overcoming barriers.
 - Expert capabilities to assess “full-chain” aspects of energy systems
 - Fossil and non-fossil competing assets
 - Energy markets, challenges to new technology adoption
 - Life-cycle environmental aspects at single plant, regional and broad deployment scale
- **Analytical efforts and associated work products inform:**
 - NETL R&D Efforts
 - DOE-FE Program focus and planning
 - Domestic and global energy and environmental decision making



National Energy
Technology Laboratory

Systems Engineering and Analysis Work Products and Tools of Note



NETL Cost and Performance Baseline for Fossil Energy Plants

- Detailed, transparent account of plant information
- Key resource for government, academia and industry



NETL CO₂ Saline Storage Cost Model



NETL Carbon Capture Retrofits Database (CCRD)



NETL CO₂ Capture, Transport, Utilization and Storage - National Energy Modeling System (CTUS-NEMS)

- Adopted by EIA; used in AEO 2014
- Facilitates and encourages EPSA interactions



National Energy
Technology Laboratory

Techno-Economic Analysis (TEA)

Transparent, Consistent Approach



What does a TEA consist of?

1. **Reference case:** state-of-the-art (SOA) power plant should be similar to those found in the Baseline studies
2. **Advanced case(s):** Novel technology replaces SOA technology in reference plant

What to expect from a TEA?

- Defined approach allows for credible comparison within and across similar studies
- The common metric derived and compared is Cost of Electricity (COE) and net power plant efficiency (HHV & LHV)
- Comparison between cases can provide:
 - Representation and quantification of the benefits of the novel technology.
 - Identification and potential quantification of performance and cost goals for the novel technology.
- Sensitivity studies change a parameter in the novel technology and the impact it has on the technology and balance of plant.
 - Identification of critical performance and cost parameters, inform R&D prioritization decisions.

Techno-Economic Analysis (TEA)

Methodology





1. Develop technology analysis plan (TAP) and solicit feedback from stakeholders.
2. Create a performance model based on models from the NETL Baselines.¹⁻³
3. Integrated novel technology based on literature and developer input replacing (where applicable) state-of-the-art technologies
4. Adjusted balance of plant as needed per the new technology demands (steam demands, coal feed rates, etc.)
5. Cost the balance of plant and novel technology using the methodology described in NETL's QGESS documents and used in the Baseline studies.⁴
6. Apply economic assumptions to develop a cost of electricity (COE).⁴
7. Perform sensitivity analyses and provide R&D guidance

1. QGESS: Performing a Techno-economic Analysis for Power Generation Plants, DOE/NETL-2015/1726

2. QGESS: Process Modeling Design Parameters, DOE/NETL-341/042514

3. Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity, DOE/NETL-2010/1397, Revised July 2015

4. QGESS: Cost Estimation Methodology for NETL Assessments of Power Plant Performance, DOE/NETL-2011/1455



Process Performance Modeling *Foundation Aspects*



- **Key Specifications**
 - Site conditions
 - Feedstock and consumable specifications
 - Steam cycle conditions
 - Boiler/gasifier performance
 - Syngas processing
 - Integration with balance-of-plant
- **Performance Basis**
 - Technology supplier/vendor data
 - Laboratory (i.e., R&D) data
 - Theoretical (i.e., thermophysical models, equations of state, etc.)
 - Target (i.e., meeting program goals and objectives)

Process Performance Modeling *Primary Outputs*



- **Material Streams**
 - Composition
 - Flows
 - Physical properties
 - Enthalpies
- **Unit Operations**
 - Material flow rates
 - Energy inputs and outputs
- **Major Equipment**
 - Count
 - Key specifications
 - Critical Design Conditions (flow, pressure, temperature, etc.)

Exhibit 3-3 Case 31A stream table, 100% H₂O without capture

Stream	Flow Rate (kg/hr)	Temp (°C)	Pressure (bar)	Composition (wt %)	Enthalpy (kJ/kg)
1	1000	25	1	H ₂ O	104.8
2	1000	25	1	H ₂ O	104.8
3	1000	25	1	H ₂ O	104.8
4	1000	25	1	H ₂ O	104.8
5	1000	25	1	H ₂ O	104.8
6	1000	25	1	H ₂ O	104.8
7	1000	25	1	H ₂ O	104.8
8	1000	25	1	H ₂ O	104.8
9	1000	25	1	H ₂ O	104.8
10	1000	25	1	H ₂ O	104.8
11	1000	25	1	H ₂ O	104.8
12	1000	25	1	H ₂ O	104.8
13	1000	25	1	H ₂ O	104.8
14	1000	25	1	H ₂ O	104.8
15	1000	25	1	H ₂ O	104.8
16	1000	25	1	H ₂ O	104.8
17	1000	25	1	H ₂ O	104.8
18	1000	25	1	H ₂ O	104.8
19	1000	25	1	H ₂ O	104.8
20	1000	25	1	H ₂ O	104.8
21	1000	25	1	H ₂ O	104.8
22	1000	25	1	H ₂ O	104.8
23	1000	25	1	H ₂ O	104.8
24	1000	25	1	H ₂ O	104.8
25	1000	25	1	H ₂ O	104.8
26	1000	25	1	H ₂ O	104.8
27	1000	25	1	H ₂ O	104.8
28	1000	25	1	H ₂ O	104.8
29	1000	25	1	H ₂ O	104.8
30	1000	25	1	H ₂ O	104.8
31	1000	25	1	H ₂ O	104.8
32	1000	25	1	H ₂ O	104.8
33	1000	25	1	H ₂ O	104.8
34	1000	25	1	H ₂ O	104.8
35	1000	25	1	H ₂ O	104.8
36	1000	25	1	H ₂ O	104.8
37	1000	25	1	H ₂ O	104.8
38	1000	25	1	H ₂ O	104.8
39	1000	25	1	H ₂ O	104.8
40	1000	25	1	H ₂ O	104.8
41	1000	25	1	H ₂ O	104.8
42	1000	25	1	H ₂ O	104.8
43	1000	25	1	H ₂ O	104.8
44	1000	25	1	H ₂ O	104.8
45	1000	25	1	H ₂ O	104.8
46	1000	25	1	H ₂ O	104.8
47	1000	25	1	H ₂ O	104.8
48	1000	25	1	H ₂ O	104.8
49	1000	25	1	H ₂ O	104.8
50	1000	25	1	H ₂ O	104.8
51	1000	25	1	H ₂ O	104.8
52	1000	25	1	H ₂ O	104.8
53	1000	25	1	H ₂ O	104.8
54	1000	25	1	H ₂ O	104.8
55	1000	25	1	H ₂ O	104.8
56	1000	25	1	H ₂ O	104.8
57	1000	25	1	H ₂ O	104.8
58	1000	25	1	H ₂ O	104.8
59	1000	25	1	H ₂ O	104.8
60	1000	25	1	H ₂ O	104.8
61	1000	25	1	H ₂ O	104.8
62	1000	25	1	H ₂ O	104.8
63	1000	25	1	H ₂ O	104.8
64	1000	25	1	H ₂ O	104.8
65	1000	25	1	H ₂ O	104.8
66	1000	25	1	H ₂ O	104.8
67	1000	25	1	H ₂ O	104.8
68	1000	25	1	H ₂ O	104.8
69	1000	25	1	H ₂ O	104.8
70	1000	25	1	H ₂ O	104.8
71	1000	25	1	H ₂ O	104.8
72	1000	25	1	H ₂ O	104.8
73	1000	25	1	H ₂ O	104.8
74	1000	25	1	H ₂ O	104.8
75	1000	25	1	H ₂ O	104.8
76	1000	25	1	H ₂ O	104.8
77	1000	25	1	H ₂ O	104.8
78	1000	25	1	H ₂ O	104.8
79	1000	25	1	H ₂ O	104.8
80	1000	25	1	H ₂ O	104.8
81	1000	25	1	H ₂ O	104.8
82	1000	25	1	H ₂ O	104.8
83	1000	25	1	H ₂ O	104.8
84	1000	25	1	H ₂ O	104.8
85	1000	25	1	H ₂ O	104.8
86	1000	25	1	H ₂ O	104.8
87	1000	25	1	H ₂ O	104.8
88	1000	25	1	H ₂ O	104.8
89	1000	25	1	H ₂ O	104.8
90	1000	25	1	H ₂ O	104.8
91	1000	25	1	H ₂ O	104.8
92	1000	25	1	H ₂ O	104.8
93	1000	25	1	H ₂ O	104.8
94	1000	25	1	H ₂ O	104.8
95	1000	25	1	H ₂ O	104.8
96	1000	25	1	H ₂ O	104.8
97	1000	25	1	H ₂ O	104.8
98	1000	25	1	H ₂ O	104.8
99	1000	25	1	H ₂ O	104.8
100	1000	25	1	H ₂ O	104.8




Case 31A - Access to Gasifier, ATE, and Access to including Low Temperature Heat


Process Economic Modeling Equipment Costing Basis




- **Vendor Quotes**
 - Significant process elements
 - ASU
 - Gasifier
 - Turbine generators
 - AGR (sulfur, CO₂) processes
- **Third-party EPC Databases**
 - Conditioning of vendor quotes
 - Balance-of-plant including:
 - Foundations
 - Piping
 - Instrumentation
 - Ancillary equipment
- **Program Targets**

Process Economic Modeling Process Capital Costing Elements






Process Economic Modeling Cost of Electricity (COE)




- COE the most frequent metric of interest, used to represent the required selling price of electricity generated**
 - Net of other product (for co-production) and byproduct revenues
 - Usually annualized over assumed economic life of facility (~30-35 years)
 - Long-term interest/investor return rolled into a capital charge factor (CCF)
 - Includes fixed and variable operating costs, with variable operating costs calculated based on average annual capacity factor

Fixed Operating Costs	Variable Operating Costs
Annual Operating Labor Cost	Maintenance Material Cost
Maintenance Labor Cost	Fuel
Administrative & Support Labor	Other Consumables
Property Taxes and Insurance	Waste Disposal
	Emission Costs

- Transparent approach allowing for sensitivity analyses of key performance and economic inputs**





14

Quality Guidelines for Energy System Studies

Comprehensive Documentation



Title	Description
Detailed Coal Specifications	Provides detailed specifications for seven coals commonly used with detailed production information
Specifications for Selected Feedstocks	Provides recommended specifications for natural gas and coal that are commonly found in NETL energy system studies.
Process Modeling Design Parameters	Documents the process modeling assumptions most commonly used in systems analysis studies and the basis for those assumptions. The large number of assumptions required for a systems analysis makes it impractical to document the entire set in each report. This document serves as a comprehensive reference for these assumptions as well as their justification.
CO₂ Impurity Design Parameters	Summarizes the impurity limits for CO ₂ stream components for use in carbon steel pipelines, enhanced oil recovery (EOR), saline formation sequestration, and co-sequestration of CO ₂ and H ₂ S in saline formations.
Capital Cost Scaling Methodology	Provides a standard basis for scaling capital costs, with specific emphasis on scaling exponents. This document contains a listing of frequently used pieces of equipment and their corresponding scaling exponent for various plant types, along with their ranges of applicability.
Cost Estimation Methodology	Summarizes the cost estimation methodology employed by NETL in its assessment of power plant performance.
Carbon Dioxide Transport and Storage Costs	Addresses the cost of CO ₂ transport and storage (T&S) in a deep saline formation with respect to plant location and region-specific aquifers.
Fuel Prices for Selected Feedstocks	Provides an estimate of the market price delivered to specific end-use areas of four coals that are commonly used as feedstocks in the energy system studies sponsored by NETL. Also includes the estimated market price for natural gas delivered to three different regions.



U.S. DEPARTMENT OF ENERGY
National Energy Technology Laboratory

15

NETL TEA Reporting

Publicly Available Documents



- **Cost and Performance Baseline for Fossil Energy Plants**
 - A Series of documents that provide Baseline's for comparison
 - <http://www.netl.doe.gov/research/energy-analysis/baseline-studies>
- **Quality Guidelines for Energy System Studies (QGESS) Documents**
 - A series of documents that provide the details to performing TEAs
 - <http://www.netl.doe.gov/research/energy-analysis/quality-guidelines>

<http://www.netl.doe.gov>

<http://www.netl.doe.gov/research/energy-analysis>



U.S. DEPARTMENT OF ENERGY
National Energy Technology Laboratory

16


TEA Use

Evaluate Progress and Inform Decisions



NETL Current and Future Technology Pathway Studies



IGCC, IGFC, Oxy-combustion, Post-Combustion Capture



Evaluate Technology Potential

Set Program Goals

Assess Market Competitiveness




U.S. DEPARTMENT OF ENERGY National Energy Technology Laboratory

17

TEA Use Example:


R&D Trajectories to Meet Program Goals



*State-of-the-Art Coal with Carbon Capture from NETL "Cost and Performance Baseline, Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity" (July 2015). Normalized cost reductions represents reduction in annualized capital and non-fuel O&M cost (on a \$/MMBtu fuel input basis) compared to the Base Plant.


U.S. DEPARTMENT OF ENERGY National Energy Technology Laboratory

18



Case Study


NETL Baseline Study Cases B12A and B12B Bituminous-fired Supercritical Pulverized Coal (SCPC) Plant



ENERGY National Energy Technology Laboratory

NETL Baseline Studies

Overarching Objective




- **Determine cost and performance estimates of near-term commercial offerings for power plants, both with and without current technology for CO₂ capture**
 - Consistent design requirements
 - Up-to-date performance and capital cost estimates
 - Technologies built and deployed in the near-term
- **Provides baseline cost and performance**
 - Compare existing technologies
 - Guide R&D for advancing technologies within the DOE Office of Fossil Energy (FE), NETL Programs

Reports referenced:


U.S. DOE, NETL, July 2015, *Cost and Performance Baseline for Fossil Energy Plants, Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity, Revision 3*, Pittsburgh, PA : Department of Energy, 2015. Report DOE/NETL-2015/1723

U.S. DOE, NETL, June 2015, *Cost and Performance Baseline for Fossil Energy Plants Supplement: Sensitivity to CO₂ capture rate in coal-fired power plants*, Pittsburgh, PA : Department of Energy, 2015. Report DOE/NETL-2015/1720



ENERGY National Energy Technology Laboratory

Supercritical Pulverized Coal Power Plant "Conventional" Coal without CO₂ Capture




Note: Block Flow Diagram is not intended to represent a complete material balance; only major process streams and equipment are shown.

ENERGY National Energy Technology Laboratory

21

Supercritical Pulverized Coal Power Plant Conventional Coal with CO₂ Capture



Note: Block Flow Diagram is not intended to represent a complete material balance; only major process streams and equipment are shown.

ENERGY National Energy Technology Laboratory

22

Supercritical Pulverized Coal Power Plant Environmental Controls



Criteria Pollutants – February 2013 New Source Performance Standards

- **PM**
 - Fabric filter
- **NO_x**
 - Low NO_x burners with over fire air
 - Selective Catalytic Removal (SCR) (83 – 85 % reduction)
- **SO₂**
 - Wet limestone Flue Gas Desulfurization (FGD)
 - 98% removal

Hazardous Air Pollutants - March 2013 Utility Mercury and Air Toxic Standards

- **Mercury, Hydrochloric Acid**
 - Activated carbon injection (ACI) removed in fabric filter with direct sorbent injection (DSI) for SO₂ removal to improve effectiveness of activated carbon injection
 - Co-benefit capture (removal of 90% for bituminous coal) of SCR, fabric filter and wet FGD combination

Polishing systems required in CO₂ capture cases (to meet performance requirements of the capture system) drive model plant emissions even lower




National Energy
Technology Laboratory

23

Supercritical Pulverized Coal Power Plant CO₂ Capture and Compression



- **Pre-treatment**
 - Lowers SO_x to ~ 1 ppmv from ~40 ppmv out of FGD
- **Cansolv CO₂ Capture Process**



National Energy
Technology Laboratory

24

Supercritical Pulverized Coal Power Plant CO₂ Capture and Compression (continued)



- **Cansolv CO₂ Capture Process Details**
 - 90 % CO₂ capture
 - Steam extraction from crossover pipe between IP and LP sections of steam turbine
 - Product CO₂ ~ 30 psia
- **CO₂ Compression System**
 - CO₂ compressed to 2,200 psig
 - 8 stages (2.23 to 1.48 stage pressure ratios)
 - Intercooling in each stage
 - Water knockout in first 3 stages
 - TEG dehydration unit between stages 4 and 5
 - 300 ppmw H₂O in CO₂ product

Supercritical Pulverized Coal Power Plant Summary Performance and Cost Results





Case	B12A	B12B
CO ₂ Capture	0%	90%
Gross Power (MW)	580	642
Auxiliary Power Summary		
Balance of Plant	27	35
Flue Gas Cleanup	3	4
CO ₂ Capture	-	16
CO ₂ Compression	-	36
Total Aux. Power (MW)	30	91
Net Power (MW)	550	550
Heat Rate (Btu/kWh)	8,400	10,500
Efficiency (HHV)	41	33
Energy Penalty ¹	-	8


¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture

²Total Plant Capital Cost (includes contingencies and engineering fees but not owner's costs)

³85% Capacity Factor

Case	B12A	B12B
CO ₂ Capture	0%	90%
Total Plant Cost, in Millions 2011\$²		
Base Plant	947	1,111
Gas Cleanup (SOx/NOx/Hg/HCl/PM)	167	197
CO ₂ Capture	-	484
CO ₂ Compression	-	98
Total	1,114	1,890
Cost of Electricity, \$/MWh (2011\$)		
Capital	39	72
Fixed	10	15
Variable	9	15
Fuel	25	31
CO ₂ T&S	-	10
Total³	82	143
CO₂ Captured (w/o T&S), \$/tonne (2011\$)		
Compared to SCPC or NGCC	-	58





NETL Cost and Performance Studies Important Considerations

Capital Costs:

- Point estimates, consistent with AACE Class 4 (accuracy -15% to +30%)¹
- Intended to represent a "near-term" commercial offering (not Nth plant)
- Designed using a specific design basis

Costs of mature technologies and designs, PC and NGCC Plants without CO₂ Capture

- Estimates reflect nth-of-a-kind
- Costs have comparatively low uncertainty resulting from serial deployments (i.e., "learning from previous efforts") as well as continuing R&D

Costs of emerging technologies and designs, PC and NGCC Plants with CO₂ Capture, all IGCC Plants

- Use same fundamental cost estimating methodology as mature plant designs
- Does not fully account for the unique cost premiums associated with true first-of-a-kind (FOAK) projects ("learning while executing current effort") initial, complex integrations of emerging technologies in a commercial application
- FOAK efforts are near certain to incur costs greater than those reflected in these reports

¹National Energy Technology Laboratory. QGESS: Cost Estimation Methodology for NETL Assessments of Power Plant Performance. Pittsburgh, Pa : U.S. Department of Energy, April 2011. DOE/NETL-2011/145

DOE ENERGY National Energy Technology Laboratory

NETL Cost and Performance Studies

Important Considerations (continued)



Other Factors:


- Actual reported project costs for all of the plant types are also expected to deviate from the cost estimates in this report due to project- and site-specific considerations
 - i.e. contracting strategy, local labor costs, seismic conditions, water quality, etc.
 - Current work is evaluating the impact of site-specific factors



Future Cost Trends:



- Continuing research, development, and demonstration (RD&D) is expected to result in designs that are more advanced than those assessed by this report, leading to costs that are lower than those estimated



NETL Cost and Performance Studies

COE Sensitivity to CCS Parameters










NETL Cost and Performance Baseline Summary Results




- With state-of-the-art technology, adding 90% CO₂ capture and storage (CCS) significantly increases the cost of electricity (COE)
 - 45-65% for NGCC
 - ~75% for pulverized coal (PC)
- Lower capture rates for PC plants decrease the COE penalty, but result in a higher cost of capture
 - e.g. \$87/tonne versus \$58/tonne for 35% and 90% capture, respectively
 - Due in part to diseconomies of scale
- RD&D is needed to reduce the costs of advanced coal power with CCS



Source: NETL Cost and Performance Baseline for Fossil Energy Plants: Volume 1a: Bituminous Coal (PC) and Natural Gas (NGCC) to Electricity (July 2015) & Supplement: Sensitivity to CO₂ Capture Rate in Coal-Fired Power Plants (June 2015)

¹T&S = transport (100 km) and storage in a Midwest saline formation. ²+30%/-15% uncertainty range; different finance structure utilized for non-capture and capture plants. ³Fully-loaded design rates; does not account for start-up, shutdown, performance degradation between maintenance, part-load operation, etc. ⁴Excludes CO₂ T&S; relative to non-capture NGCC and non-capture supercritical PC design for NGCC and PC capture designs, respectively.

NETL Cost and Performance Baseline COE Parity Map



NETL Cost and Performance Baseline

Additional Observations



- **Lower capture rates result in lower COE**
 - Lower capital and operating costs
 - Lower solvent regeneration energy steam use
- **CO₂ capture cost (\$/tonne CO₂) higher at lower capture rates**
 - Economies of scale
 - Less CO₂ available for sale
- **Capture system (capital cost and solvent regeneration energy) and compression capital cost significantly impact CO₂ capture cost**
 - R&D needed to address all
- **Bulk of the cost to capture, transport and store CO₂ is in the CO₂ capture system**


NETL Cost and Performance Baseline


Most Recent Updates






- **Cost and Performance Baseline for Fossil Energy Plants, Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity, Revision 3 (DOE/NETL-2015/1723)**
- **Cost and Performance Baseline for Fossil Energy Plants Supplement: Sensitivity to CO₂ Capture Rate in Coal-Fired Power Plants (DOE/NETL-2015/1720)**
 - Includes PC and IGCC cases
- **Cost and Performance Baseline for Fossil Energy Plants, Volume 1b: Bituminous Coal (IGCC) to Electricity, Revision 2 – Year Dollar Update (DOE/NETL-2015/1727)**


<http://www.netl.doe.gov/research/energy-analysis/energy-baseline-studies>

It's All About a Clean, Affordable Energy Future 



 *For More Information, Contact NETL*
the ENERGY lab
Delivering Yesterday and Preparing for Tomorrow 



 **ENERGY** National Energy Technology Laboratory

43



QUEST PROJECT AND ITS COSTS

IEAGHG /GCCSI 4th CCS cost workshop Boston 23-24/3-2016



Wilfried Maas
General Manager Carbon Capture & Storage

Shell Global Solutions International

DEFINITIONS & CAUTIONARY NOTE

Reserves: Our use of the term "reserves" in this presentation means SEC proved oil and gas reserves.

Resources: Our use of the term "resources" in this presentation includes quantities of oil and gas not yet classified as SEC proved oil and gas reserves. Resources are consistent with the Society of Petroleum Engineers 2P and 2C definitions.

Organic: Our use of the term Organic includes SEC proved oil and gas reserves excluding changes resulting from acquisitions, divestments and year-average pricing impact.

Shales: Our use of the term "shales" refers to tight, shale and coal bed methane oil and gas acreage.

The companies in which Royal Dutch Shell plc directly and indirectly owns investments are separate entities. In this document "Shell", "Shell group" and "Royal Dutch Shell" are sometimes used for convenience where references are made to Royal Dutch Shell plc and its subsidiaries in general. Likewise, the words "we", "us" and "our" are also used to refer to subsidiaries in general or to those who work for them. These expressions are also used where no useful purpose is served by identifying the particular company or companies. "Subsidiaries", "Shell subsidiaries" and "Shell companies" as used in this document refer to companies over which Royal Dutch Shell plc either directly or indirectly has control. Companies over which Shell has joint control are generally referred to as "joint ventures" and companies over which Shell has significant influence but neither control nor joint control are referred to as "associates". The term "Shell interest" is used for convenience to indicate the direct and/or indirect ownership interest held by Shell in a venture, partnership or company, after exclusion of all third-party interest.

This presentation contains forward-looking statements concerning the financial condition, results of operations and businesses of Royal Dutch Shell. All statements other than statements of historical fact are, or may be deemed to be, forward-looking statements. Forward-looking statements are statements of future expectations that are based on management's current expectations and assumptions and involve known and unknown risks and uncertainties that could cause actual results, performance or events to differ materially from those expressed or implied in these statements. Forward-looking statements include, among other things, statements concerning the potential exposure of Royal Dutch Shell to market risks and statements expressing management's expectations, beliefs, estimates, forecasts, projections and assumptions. These forward-looking statements are identified by their use of terms and phrases such as "anticipate", "believe", "could", "estimate", "expect", "intend", "may", "plan", "objectives", "outlook", "probably", "project", "will", "seek", "target", "risk", "goals", "should" and similar terms and phrases. There are a number of factors that could affect the future operations of Royal Dutch Shell and could cause those results to differ materially from those expressed in the forward-looking statements included in this presentation, including (without limitation): (a) price fluctuations in crude oil and natural gas; (b) changes in demand for Shell's products; (c) currency fluctuations; (d) drilling and production results; (e) reserves estimates; (f) loss of market share and industry competition; (g) environmental and physical risks; (h) risks associated with the identification of suitable potential acquisition properties and targets, and successful negotiation and completion of such transactions; (i) the risk of doing business in developing countries and countries subject to international sanctions; (j) legislative, fiscal and regulatory developments including potential litigation and regulatory measures as a result of climate changes; (k) economic and financial market conditions in various countries and regions; (l) political risks, including the risks of expropriation and renegotiation of the terms of contracts with governmental entities, delays or advancements in the approval of projects and delays in the reimbursement for shared costs; and (m) changes in trading conditions. All forward-looking statements contained in this presentation are expressly qualified in their entirety by the cautionary statements contained or referred to in this section. Readers should not place undue reliance on forward-looking statements. Additional factors that may affect future results are contained in Royal Dutch Shell's 2015 Form 20-F for the year ended 31 December, 2015 (available at www.shell.com/investor and www.sec.gov). These factors also should be considered by the reader. Each forward-looking statement speaks only as of the date of this presentation, 23 March, 2015. Neither Royal Dutch Shell nor any of its subsidiaries undertake any obligation to publicly update or revise any forward-looking statement as a result of new information, future events or other information. In light of these risks, results could differ materially from those stated, implied or inferred from the forward-looking statements contained in this presentation. There can be no assurance that dividend payments will match or exceed those set out in this presentation in the future, or that they will be made at all.

We use certain terms in this presentation, such as discovery potential, that the United States Securities and Exchange Commission (SEC) guidelines strictly prohibit us from including in filings with the SEC. U.S. investors are urged to consider closely the disclosure in our Form 20-F, File No. 1-32575, available on the SEC website www.sec.gov. You can also obtain this form from the SEC by calling 1-800-SEC-0330.


Shell
March 2016
2

AGENDA

- Quest Project and Performance
- Funding & Knowledge sharing
- Project Costs


Shell Global Solutions International

March 2016



QUEST CCS

QUEST CCS



WORLD FIRST
Commercial-scale CCS project in the oil sands



IMPACT
Capture and permanently store more than one million tonnes of CO₂ annually – equivalent to 250,000 cars.

CONTEXT
Canadian and Alberta governments support for capital expenses and regulatory framework

TECHNOLOGY
Pre-combustion capture from hydrogen production using Shell's ADIP-X amine

QUEST CCS

SELECT CONCEPT DEFINE PROJECT EXECUTE PROJECT OPERATE ASSET






QUEST "HARDWARE"

- Capture plant in Fort Saskatchewan, approx 50 km N.E. of Edmonton
- Capture at the Scotford Upgrader from 3 Hydrogen Manufacturing Units
- CO₂ transported by 12" pipeline to storage, with 6" laterals
- Pipeline to 65 km north of the Upgrader
- Route selected to meet stakeholder requirements:
 - 28 km follows existing ROW
 - Drilled under North Saskatchewan River
 - 30+ re-routes to accommodate landowner wishes
- Base plan: 3 injection wells and associated monitoring



QUEST STORAGE




Shell Global Solutions International

March 2016

CO₂ STORAGE

- CO₂ stored in porous rock containing natural brine
- Basal Cambrian Sands (BCS) selected
 - 2,300 m, Prairies deepest sandstone
 - Multiple cap rock and salt seal layers, no significant faulting visible from wells or seismic
 - Well below hydrocarbon bearing formations and potable water zones in the region
 - Relatively few wells drilled into the BCS, none within 10km of the proposed storage site
- Wells and Drilling
 - Three injection wells
 - Conventional drilling methods
 - Multiple steel casings for wells, 3 in freshwater zone, all cemented to surface



Shell Global Solutions International

March 2016

TIMELINE

Regulatory Hearing	Mar 2012
▪ Approvals received	Aug 2012
Final Investment Decision (FID)	Sep 2012
Well Program	Q4 2012
▪ 2 additional injection wells	
▪ Associated deep monitoring and groundwater wells	
▪ Baseline	
Capture & Pipeline completed	
▪ Pipeline construction	Q4 2014
▪ Capture construction	Q2 2015
Operations Handover	Q2 2015
▪ Full production	Q3 2015



- Continuous capture and storage since August 2015, exceeding target rate
- Commercial tests complete – 3 months ahead of target

Shell

March 2016


MEASUREMENT, MONITORING AND VERIFICATION PLAN




- Comprehensive : Geosphere to Atmosphere and entire lifecycle
- Risk-based, site-specific
- Independently (DNV) certified MMV and storage plan

Shell Global Solutions International

March 2016



6 MONTHS INJECTION



- We prepared for issues related to start up and responded accordingly
- Successfully injected 500,000 tonnes in less than 6 months!

Shell

15

AGENDA

- Quest Project and Performance
- Funding & Knowledge sharing
- Project Costs

Shell Global Solutions International

March 2016

FUNDING AGREEMENTS & REVENUES

- Government Funding Support – CAN\$865 M
 - CAN\$120 M Canadian Federal Government (Pre FID)
 - CAN\$745 M Alberta Province (Construction, Startup and 10 years operation)
 - Extensive knowledge sharing
 - Stringent monitoring (Measurement, Monitoring & Verification) plan
 - NPV Zero commitment
- Revenues – GHG offsets (credits)
 - Net amount – stored CO₂, less direct and indirect emissions (13-18% of injected)
 - Design Captured & Stored 1.08 mt/a , Avoided 0.94 mt/a
 - Credits to be used first by Shell's Alberta assets for regulatory compliance
 - A second set of credits will be received as early developer

Shell Global Solutions International

March 2016

KNOWLEDGE SHARING

- Extensive knowledge sharing part of the program
- <http://www.energy.alberta.ca/CCS/3845.asp>
 - Facility Design
 - Construction Schedule
 - Geological Formation Selection
 - Facilities Operations :Capture, Transportation, Storage& Monitoring, Maintenance and Repairs
 - Regulatory approvals
 - Public Engagement
 - Cost and Revenues**
 - Timeline
 - General Project Assessment
 - Extensive Detailed reporting
 - Flow Diagram, H&M balance, Plot plan, Work Breakdown,, MMV, Closure Plan , Annual Status Reports, Screening reports etc., P&ID's
- Analogous to Knowledge sharing in the (now cancelled) UK CCS commercialisation program
 - <https://www.gov.uk/government/collections/carbon-capture-and-storage-knowledge-sharing>

Shell Global Solutions International

March 2016

AGENDA

- Quest Project and Performance
- Funding & Knowledge sharing
- Project Costs

Shell Global Solutions International

March 2016

QUEST COSTS

First of a kind facilities cost forecast

- Venture: CAN\$137M
- Tie-in work: CAN\$38M
- Capture: CAN\$446M
- Pipeline: CAN\$128M
- Subsurface: CAN\$40M
- Contingency: CAN \$23M


Total CAN\$812M -> 752 \$/tpa captured

Anticipated Project Operating Costs :

\$44M per annum -> 41 \$/ton captured

Potential savings for future projects

- Reduced venture costs
- Reduced capture costs
- Reduced pipeline/subsurface costs




- Overall Venture Costs
- Tie-in/Brownfield Work
- Capture Facility
- Pipeline (Transport)
- Subsurface (Wells/MMV)
- Total Contingency, Inflation & Market Escalation

Watch the release of the 2015 reports
 - which will show actual performance numbers from startup year
 - Under budget & under schedule

1 CDN = 0.99 USD (2011)


CCS DEMONSTRATION REQUIRES SUPPORT MECHANISMS



- CO₂ emissions penalty generally too low currently to get CCS going
- CCS demo capital grants are too significant to sustain for a long period
- Additional mechanisms will be required to get CCS demonstrated at scale

CCS WILL REQUIRE DEMONSTRATION SUPPORT, EFFECTIVE POLICIES NEEDED

Objective – adequate support is needed to demonstrate CCS and reduce costs from FOAK to NOAK to deliver a competitive and viable technology in a decarbonised world.




FIRST OF A KIND

Nth OF A KIND


DEVELOPMENT	DEMONSTRATION	DEPLOYMENT
Capital grants (support build)		
Opex support (ensure plant operates)		
		Robust CO ₂ price
... plus other temporary measures (e.g. CCS certificates) if the uptake rate continues to be disappointing ...		
Non-financial measures (enabling regulations, liability agreements, etc)		



Insights into Cost of CCS Gained from the Illinois Basin-Decatur Project



Midwest Geological Sequestration Consortium






TRIMERIC CORPORATION



Insights into Costs of CCS Gained from the Illinois Basin – Decatur Project


Sallie E. Greenberg, Ph.D. and the MGSC Project Team
Advanced Energy Technology Initiative
University of Illinois – Illinois State Geological Survey

Ray McKaskle, P.E. and the Trimeric Project Team

22 March 2016 – IEAGHG CCS Cost Network Workshop at the Massachusetts Institute of Technology



MGSC Phase III Team



MGSC Program Goals



Prove Injectivity and Capacity

Demonstrate Security of Injection Zone

Contribute to Best Practices

IBDP Accomplishments

IBDP is the first demonstration-scale (one million tonne) U.S. project to use carbon dioxide (CO₂) from an industrial/biofuel source within the DOE Regional Carbon Sequestration Partnership (RCSP) program

IBDP is a fully integrated demonstration project comprised of compression - dehydration facility, 1.9 km pipeline for delivery of supercritical CO₂ to injection, and observation system on an intensely monitored site

IBDP injection is the result of nine years of Phase III effort from funding to storing CO₂ in the reservoir; includes site characterization, permitting, risk assessment, public engagement, drilling, injection operations, reservoir geology, engineering, and geophysics, and baseline, injection, and post-injection monitoring and analysis



Illinois Basin – Decatur Project Site (on ADM industrial site)

- A Dehydration/ compression facility location
- B Pipeline route (1.9 km)
- C Injection well site
- D Verification/ monitoring well site
- E Geophone well



Operational Injection: 17 November 2011

- IBDP is the first one million tonne carbon capture and storage project from a biofuel facility in the US
- Injection completed November 2014
- Intensive post-injection monitoring under MGSC through 2017



Total Injection
(26 November 2014):
999,215 tonnes

Insights into Costs of CCS Gained from IBDP

• IBDP Scope and Scale Definition:

- Capture of low pressure, water-saturated, high purity CO₂ from biofuels production
- Compression, dehydration, transportation, storage, and MVA represent what is done AFTER post-combustion flue gas capture at a power plant or other industrial facility
- Injection rate of 1,000 tonne / day represents about 50 MW_e of CO₂ or 10% scale of a 550 MW_(net) power plant with 90% capture
- Broader, overall project costs will be presented first, followed by a detailed examination of the capital and operating costs for the compression, dehydration, and transportation facilities

IBDP Overall Project Costs

- Pre-injection
 - Budget Period 3 (12/18/07 to 4/30/10): Cost \$22,226,960
- Injection
 - Budget Period 4 (5/1/10 to 1/15/15): Cost \$66,077,449
- Post-injection
 - Budget Period 5 (1/16/15 to 12/17/17): Cost \$21,659,483
- DOE Share \$ 87,318,798 79%
- Non-DOE Share \$ 22,645,094 21%
- Total Value \$109,963,892


Project Cost Breakdown (in progress)

Wells (11/2013)	Infrastructure (11/2013)	Geophysical (11/2013)	Geologic (11/2013)	MVA (12/2015)
Injection \$8,581,000	Well site Prep & Utilities \$673,000	Two 3D seismic surveys \$6,800,000	Well Logging \$1,650,000	Groundwater wells \$282,000
Verification \$6,377,00	Data Acquisition System \$387,000	Baseline 3D VSP \$280,000	Coring \$202,000	Equipment \$324,000
Geophone \$589,000	Office/training/ Computer Facility \$73,000	Three repeat 3D VSPs \$960,000	Core Analysis \$409,000	Chemical Analyses \$591,000
		Microseismic and surface sensors \$1,277,000	(Above applies to injection and verification wells)	Risk Assessment \$170,000
TOTALS \$15,547,000	\$1,133,000	\$9,217,000	\$2,261,000	\$1,127,000

Compression/Dehydration not included here. Items in Purple based on BP4.
All totals subject to change by end of project

Facility Overview (1 of 2)

Compression, Dehydration, Transmission Facilities



Facility Overview (2 of 2)

Compression, Dehydration, Transmission Facilities



IBDP Capital Costs for Compression, Dehydration, and Transmission Facilities

Cost Categories	Costs, (2009 – 2011 US \$ MM)	Actual % of TDIC	Typical Range* (% of TDIC)
Purchased Equipment	6.1	30	15-40
Purchased-Equipment Installation	1.9	9	6-14
Instrumentation and Controls	1.0	5	2-12
Piping	5.1	25	4-17
Electrical Systems	3.0	15	2-10
Buildings and Yard Improvements	0.9	5	4-23
Total Direct Cost (TDC)	18.0		
Engineering	1.9	9	4-20
Construction Expenses	0.4	2	4-17
Total Indirect Cost (TIC)	2.3		
Total Direct and Indirect Cost (TDIC)	20.3		

*Typical Ranges from Peters and Timmerhaus, 2003

IBDP Capital and Operating Costs / Tonne Injected for Compression, Dehydration, and Transmission Facilities

Cost Categories	Costs, (2009 – 2014) US \$ / tonne
Capital Costs	20.34
Electrical Power	7.76
Operating Labor	1.32
Supervisor Labor	0.20
Maintenance	1.22
Other Operating Costs	0.61
Total	31.45

• Important statements regarding this table:

- Capital costs are amortized over the three-year injection period, amortization period would be much longer on a typical commercial project
- All costs in this table except for capital costs are derived using typical industry values as actual values are either confidential or not available
- Host site provided Plant Overhead functions, which would be an additional estimated \$ 2.01 / tonne at a green-field location
- If scaling costs for future projects, suggest using mid-2010 for capital costs and late-2014 for operating costs

Lessons Learned Regarding Project Costs for Compression, Dehydration, and Transmission Facilities

Capital costs were higher than the initial estimate, but operating costs were lower → Net effect < 5% increase in \$ / tonne injected

- Scope Changes
 - Design capacity increased by 21%
 - Multistage centrifugal pump added
 - Above ground transmission pipeline insulation added
- Items (highest to lowest) with higher than original cost estimates
 - Transmission pipeline and insulation costs
 - Process and cooling water piping
 - Structural
 - Electrical
 - Engineering

Factors That Affected Project Costs for Compression, Dehydration, and Transmission Facilities

- Installation within a major operating industrial facility can increase project costs / complexity
 - Transmission pipeline had to be above ground and had to be insulated
 - Two equipment buildings required instead of one due to underground piping
 - These experiences may be informative with respect to installing a CO₂ capture retrofit within an existing power plant or other industrial facility
- UIC permitting timeline extended the facility construction schedule

Considerations for Costs on Future Projects

- It would help to know or at least to have a firmer estimate of the required injection pressure prior to process design and ordering compression equipment
- Planning for future projects can be informed by timeline required to obtain injection permits on first mover projects
 - We thought compressor 52-week lead time would be critical path, but turned out not to be so in this case
 - Longer project timelines may allow alternate equipment selection and / or more favorable pricing
- Pricing for future projects may be influenced (up or down) by overall economic conditions in general and for the oil and gas industry in particular

Conclusions

- Carbon capture and storage is a major undertaking involving many types of industry, government, and financial professionals, as well as many industry trades
- First mover projects can provide useful benchmarks and lessons learned that will benefit future projects
- Incorporating CCS into existing, operational power plants or other industrial facilities comes with additional, case-specific challenges and costs
- Permitting timelines and general economic conditions may impact costs on future projects in ways that are difficult to predict



MGSC Acknowledgements

- The Midwest Geological Sequestration Consortium is funded by the U.S. Department of Energy through the National Energy Technology Laboratory (NETL) via the Regional Carbon Sequestration Partnership Program (contract number DE-FC26-05NT42588) and by a cost share agreement with the Illinois Department of Commerce and Economic Opportunity, Office of Coal Development through the Illinois Clean Coal Institute.
- The Midwest Geological Sequestration Consortium (MGSC) is a collaboration led by the geological surveys of Illinois, Indiana, and Kentucky.
- Landmark Graphics software via their University Donation Program and cost share plus Petrel software via Schlumberger Carbon Services.



Post-Injection Activities

- 3D Surface Seismic Survey – January 2015
 - Processing nearly complete
- Post-injection VSP, permit interim period – January 2015
 - Working to improve comparisons between repeat VSPs
- Post-injection near surface monitoring
 - Moving from injection monitoring to reduced program
- Knowledge and data sharing best practices
 - Publications
 - National and international research collaborations
 - Collective data sets
 - Teaching data sets

CCS in Decatur, IL USA




Illinois Basin – Decatur Project

- Large-scale demonstration
- Volume: 1 million tonnes
- Injection period: 3 years
- Injection rate: 1,000 tonnes/d
- Compression capacity: 1,100 tonnes/day
- Status: Post-injection monitoring

Illinois Industrial CCS Project

- Industrial-scale
- Volume: 5 million tonnes
- Injection period: 3 years
- Injection rate: 3,000 tons/d
- Compression capacity: 2,200 tonnes/day
- Status: Pre-injection monitoring



Project Costs Power Applications

EPRI | ELECTRIC POWER
RESEARCH INSTITUTE

Session 3: Project Costs Power Applications

George Booras
Principal Technical Leader

CCS Cost Network Workshop
Massachusetts Institute of Technology
March 22, 2016



© 2016 Electric Power Research Institute, Inc. All rights reserved.

Session 3: Overview and Objectives

This session will focus on cost estimates for CCS applications in electric power generation

Objectives

- Learn about the cost of actual projects
- Major capital cost areas
 - CO₂ capture, compression, and pipeline
 - Upgrades to upstream process equipment
 - Balance of plant and owner's costs
- Comparisons of final project cost to initial estimates
 - Scope changes? Construction delays? Equipment/labor cost increases?
- Summary of lessons learned
- Opportunities for future cost reductions



Session 3: Power Projects and Speakers

- 1) Boundary Dam Carbon Capture Project
Max Ball and Peter Versteeg*
SaskPower



- 2) FutureGen 2.0
Ken Humphreys
FutureGen Industrial Alliance



- 3) White Rose CCS Project
Leigh Hackett
GE Power



* via teleconference

3

© 2016 Electric Power Research Institute, Inc. All rights reserved.

EPR | ELECTRIC POWER
RESEARCH INSTITUTE




Together...Shaping the Future of Electricity



4

© 2016 Electric Power Research Institute, Inc. All rights reserved.

EPR | ELECTRIC POWER
RESEARCH INSTITUTE

Factors Impacting Capital Costs at SaskPower's Boundary Dam Integrated CCS Project





Potential for CCS at SASKPOWER

Unit	Initial Investment	Final Investment	In Service
BD 4/5	2017	2019*	2025*
BD 6	2022	2024	2028*
PR 1	2024	2026	2030*
PR 2	2026	2026	2030*
Shand 1	2037	2039	2043*
New Build	New costs more than rebuild today		

* Fixed by Regulation


5

Factors Impacting Capital Costs

- Site Specific Factors
- First of a Kind Factors
- Market Factors
- Design Features

6

Site Specific Factors




7

Market Factors

SteelBenchmarker™ HRB Price

USA, China, Western Europe and World Export
(WSD's PriceTrack data, Jan. 2001 - March 2006; SteelBenchmarker data begins April 2006)





FutureGen™
ALLIANCE

Clean Energy for a Secure Future


FutureGen 2.0



Clean energy for a secure future.



Ken Humphreys
Chief Executive, FutureGen Alliance
MIT Cost Workshop
March 22, 2016

www.FutureGenAlliance.org



FutureGen 2.0

- Repower Meredosia Energy Center with oxy-combustion and CCS technology
 - Repowered gross: 167-Mwe
 - Near-zero emissions
 - CO₂ capture rate: 90%+
 - CO₂ capture volume: 1.1 MMT/yr
 - Pipeline transport: 28 miles
 - Deep geologic storage
 - 60%/40% Illinois/PRB

Design	Construction	Power Production w/CCS	Post-closure monitoring
2010	2014	2018	2038

2088
www.FutureGenAlliance.org

Project Status and Cost Context

- Expiration of federal co-funding terminated the project
 - CAPEX within DOE and ICC-approved budgets
 - Operating costs well below the statutory rate caps
- Project was “well advanced” at the time of termination contributing to an extremely high degree of cost certainty
- Costs must be interpreted within the context of this first of a kind project
 - FutureGen's size and host site well matched to project purpose of proving out the technology
 - Subsequent retrofit applications quite different
 - Newer, larger plants
 - SC or USC
 - EOR or storage hub

3

www.FutureGenAlliance.org

Project Well Advanced

- Power Purchase Agreement signed
- Power Plant Asset Purchase Agreement signed
- Final air, water, pipeline, and storage permits issued
- MISO grid interconnection agreement finalized
- Subsurface storage rights acquired
- CO₂ liability management addressed
- Mega-FEED complete (70 – 90% final design complete)
- Project Labor Agreement signed
- Early construction activities initiated
 - Initial demolition and excavation
 - Geologic characterization well complete
- EPC contract costs known
- Final stage of financing due diligence



4

www.FutureGenAlliance.org

Meredosia Energy Center Host Site




- Recently idled and well maintained in a retrofit-ready condition.
- Unit 4 steam turbine in excellent condition (< 20,000 hrs of operation)
- Coal handling and other selected infrastructure to be utilized
- Existing air permit (modified) provided flexibility beneficial to FOAK retrofit
- Existing MISO transmission infrastructure simplifies interconnection requirements

5

www.FutureGenAlliance.org

Power Plant Repowering



6

www.FutureGenAlliance.org

CO₂ Pipeline




- Approximately 28 miles of 10" pipe
- Standard technology
- Eminent domain for ROW

7

www.FutureGenAlliance.org

CO₂ Storage Site


- High quality storage reservoir
 - Drilled to expected to reservoir depth (~4500 ft) in Mt Simon formation
 - Seismic surveys completed
 - Hydrologic testing completed
 - Core analysis and modeling completed



8

www.FutureGenAlliance.org

CO₂ Storage Site **Main Injection Location**



9

www.FutureGenAlliance.org

CO₂ Storage Site **Land Acquisition**

- Subsurface rights for 20-year, 4000-acre plume secured
- Opportunistically acquiring buffer zone around permitted area
 - Increases flexibility
 - Reduces litigation risk
 - Increases power plant lender comfort



8

www.FutureGenAlliance.org


CO₂ Storage Site Subsurface Monitoring Network



9

www.FutureGenAlliance.org

Power Plant CAPEX - \$1256M



- ASU, & pipeline/storage over-the-fence.
- As-spent based on 2015 construction start.

12

www.FutureGenAlliance.org

Power Plant CAPEX: Owner Costs

Cost Category	Total Cost As-Spent \$millions
Legacy Equipment	\$72.0
Project Development/Management Costs	\$22.4
Capital Spares	\$8.9
O&M Training & Mobilization	\$5.0
Builder's Risk & General Liability	\$8.2
Property Tax	\$2.7
Initial Fuel Pile & Consumables	\$2.5
Interconnection	\$1.5
State Sales Tax	\$0.0
Owner G&A & IWC LOC Fee	\$22.3
Total Owner Costs (excludes island specific start-up costs)	\$146

13

www.FutureGenAlliance.org

Power Plant CAPEX: Financing Cost

- Project financed
- Construction Bank Loan followed by a long-term bond financing

Cost Category	Total Cost As-Spent \$millions
Legal & Consulting Fees	\$6
Upfront Financing Fees	\$13
Origination Fees	\$10
Commitment Fees During Construction	\$5
Interest During Construction	\$31
Bond Placement Fees (Term Financing)	\$9
Initial Debt Service Reserve - LOC Commitment Fees	<\$1
Total Financing Costs	\$74

14

www.FutureGenAlliance.org

Power Plant CAPEX: Start-up Cost


- Start-up costs for legacy equipment and integrated plant testing.
- Island-specific start-up costs are included in equipment island CAPEX budget.

Cost Category	Total Cost As-Spent \$millions
Start-up of Legacy Equipment	\$10
Fuel and other Consumables	\$24
Purchased Power	\$8
Credit for Power Sold	(\$15)
Total Start-up Costs (excludes island specific start-up costs)	\$27

15

www.FutureGenAlliance.org

CO₂ Pipeline & Storage CAPEX - \$423M



- 100% cash financed with no equity return
- Excludes visitor & training center

16

www.FutureGenAlliance.org

CO₂ Storage CAPEX: Owner Cost

- Includes pipeline and storage
- All cash basis with no return on equity

Cost Category	Total Cost As-Spent \$millions
Land Acquisition	\$27.7
Project Development/Management Costs	\$12.1
Builder's Risk & General Liability	\$3.3
Property Tax	\$0.3
CO ₂ Trust Fund	\$51.9
State Sales Tax	\$0.0
Owner G&A, IWC, & Fees	\$21.7
Total Owner Costs	\$117


17

www.FutureGenAlliance.org

FutureGen Alliance Confidential Information

OPEX Cost Drivers


- OPEX is driven by five key costs areas:
 - Oxygen
 - Fuel
 - Purchased power
 - Ash disposal & consumables
 - CO₂ transport & storage
- These cost categories account for 80% of the operating costs



18

www.FutureGenAlliance.org


Levelized Cost of Electricity



19

www.FutureGenAlliance.org

Net Cost to Ratepayers



20

www.FutureGenAlliance.org

Commercial

Informing Nth Plant Costs

- Aggregate costs largely irrelevant
- Component costs very relevant
- Potential for Nth plant economic improvement on retrofits
 - Power
 - Economies of scale (e.g., 500-MWe)
 - Pre-existing, modern environmental controls
 - Supercritical retrofit
 - ASU competition
 - Vendor experience
 - Full wrap
 - Storage
 - Economies of scale

21

www.FutureGenAlliance.org

FutureGen 2.0

Principal Partners



GlencoreXstrata

22

www.FutureGenAlliance.org




DOE Acknowledgment and Disclaimer

"This material is based upon work supported by the Department of Energy under Award Number DE-FE0001882 and DE-FE0005054."

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

White Rose—Oxy-fuel CCS Project



White Rose – Oxy-fuel CCS Project
Dr. Leigh A. Hackett

CCS Cost Network Workshop MIT
March 22-23, 2016

Imagination at work

White Rose project



White Rose - Project summary

- A new modern ultra-supercritical Oxy-Power Plant, up to 448MWe (gross)
- Clean power generated for the equivalent needs of 630,000 homes
- 100% of flue gas treated, 90% CO₂ capture rate → 2 million tonnes CO₂/year
- Potential to co-fire biomass
- Anchor project for National Grid's regional CO₂ transport & offshore storage network
- Yorkshire & Humber CCS cluster covers almost 20% of UK's CO₂ emissions
- Infrastructure planned to be sized for 17 million tonnes CO₂/year to enable future projects
- CO₂ to be permanently stored in a deep saline formation offshore, beneath the North Sea



CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

3

Project key-knowledge reports

- 41 documents to be published by Department of Energy & Climate Change (DECC), UK including:
 - Full-chain FEED summary report
 - Full-chain basis of design
 - Full-chain FEED lessons learnt
 - Full-chain FEED risk report
 - Full-chain project programme
 - Full-chain project cost estimate report
 - Financing feasibility report
 - Financial model
 - Project execution plan
 - Various technical documents




CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

4


Commercial landscape



Capex estimate



White Rose full-chain CCS project



Full Chain Interim Cost Estimate – Basis

- Cost estimate performed through 2015 assuming an NTP late 2015 as part of FEED work.
- Capture Power managed the estimating process (alignment, basis, reviews, etc)
 - OPP - Input from GE, BOC, Drax and owners costs by CPL
 - T&S – Input from NGC
- Market enquiries undertaken for 90% of the project's costs.
- Costs assessed to be equivalent to AACE Level 2 for the majority of items.
- Monte Carlo analyses performed for calculation of uncertainty bands and establishment of P_{50} , P_{10} and P_{90} values.



CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

9

Cost Estimate for dissemination¹

Oxy Power Plant

- Cost estimate adjusted to take out project specifics allowing comparisons with other published data:
 - Site preparation costs removed
 - US Gulf Coast basis
 - Construction through to Mechanical Completion
 - Owners costs (Development costs, Implementation team, Advisors, Site specific costs, insurances, etc.)
 - Hedging costs (exchange rate as of November 2015)
- Transport & Storage network
 - cost estimate corresponds to an oversized network, e.g. 17 MTA capacity pipeline
 - No location adjustments made (i.e. UK basis).

¹ Preview of information yet to be published by the UK DECC through Key Knowledge Deliverable



CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

10

Normalised Capex estimate

#	Cost element	Notes	P ₅₀ (£m)	P ₁₀	P ₉₀	Drivers of uncertainty
1	Externally supplied OPP utilities	Interconnections for coal, limestone, water etc.	49	-3%	+3%	Commodity and labour prices
2	Oxyfuel boiler, Air Separation Unit and Gas Processing Unit	Equipment	455	-2%	+3%	Commodity and labour prices, technology risks
3	Oxy-power plant generation equipment and BoP	Including civils and erection for element 2	471	-3%	+4%	Commodity and labour prices
4	Onshore CO ₂ pipeline	Including multi-junction, pumping station, metering and owner's costs	358	-6%	+6%	Commodity and labour prices
5	Offshore pipeline	Including landfall and owner's costs	225	-11%	+11%	Commodity and labour prices, offshore risks
6	Storage facilities	Including the platform, wells, metering and owner's costs	344	-17%	+21%	Commodity and labour prices, offshore risks, storage risk




¹ Nominal, NTP assumed November 2017
CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

11

Strike price projections for follow-on projects



Strike prices 2012 real terms
CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

12

Lessons learnt

Commercial



White Rose Key Commercial Lessons Learnt

The 4 key commercial lessons learnt that are presented are relevant to projects that have some or all of the following characteristics:

- No liquid, demonstrable and commercially financeable CO₂ transport and storage (T&S) system available.
- No value associated with the CO₂ going to store, e.g. Saline storage or depleted oil and gas without EOR. (Waste disposal business!)
- Lack of liquid market for available CO₂ to the T&S system
- Independent developers for the individual chain links with limited (capped) cross chain liabilities
- Limited recourse project finance approach for one or more chain links, with no cross security over the other assets
- Others



1. Full-chain commercial structuring.

Management of cross-chain risks: **challenges**

- The inter-dependence of individual businesses across the full CCS scope raises cross-chain risk issues.
- Most significant manifestation is the cross chain default risk or "Project on Project risk".
 - Limited appetite of investors and lenders to accept significant cross chain risks outside of their control e.g.
 - Construction delays of another chain link
 - Unavailability of another chain link (performance issues)
 - Insolvency of another chain link
- Commercial projects not readily financeable in absence of resolution of Project on Project risks



1. Full-chain commercial structuring.

Management of cross-chain risks: **considerations**

- Potential solution via decoupling the T&S links from the generation link from a risk perspective, with an entity (State) absorbing cross chain default/performance risk
- T&S infrastructure could be structured as national infrastructure project.
- In the UK a regulated asset based (RAB) model could for example be considered:
 - Regulator licenses the T&S operator who provides the CO₂ T&S storage service.
 - Regulator has powers to enforce obligations and of step-in (Special Administration)
 - Regulated return for the provider of the T&S infrastructure, with KPI incentives
 - Regulator determines amounts to be charged to users
 - Financial support package for non-availability of Users, CCS risks, Others?
- Generation projects could be developed on traditional models, however.
 - Market price support for CCS costs required and,
 - T&S availability protection required e.g. financial compensation



2. Non-EOR CO₂ storage business model

Seeking storage business investment: **challenges**

- Non-EOR related CO₂ storage is a “high” risk and “low” return business, especially for offshore solutions:
 - Potential liabilities in the unlikely event of CO₂ leakage.
 - Likely returns capped by energy markets and regulators (latter in a regulated model).
- Limited market appetite for accepting long-term CO₂ storage risk especially, in absence of insurance solutions.
- Oil & gas investors deem returns as insufficient unless EOR is involved.
- Financial and other investors unable to bring requisite skills.



2. Non-EOR CO₂ storage business model

Seeking storage business investment: **considerations**

- Non-EOR related storage could be structured as national infrastructure projects:
 - e.g. UK RAB model
- Long-term storage risk underwriting
 - State backed support for storage liabilities (time dependent financial support, or insurance of last resort, etc.)
 - Decommissioning support (funding adequacy)
 - Timely hand over of store to State following decommissioning.
- De-risk sufficiently to attract institutional investors willing to accept low-risk lower reward opportunities.
 - Would have benefit of reducing costs of Storage albeit by transferring risk to the state.



3. Oversizing and sharing T&S infrastructure

T&S infrastructure: **challenges**

- Point-to-point minimum necessary T&S infrastructure development, linked to a single generator unlikely to be competitive for most commercial projects.
- Significant economies of scale and value for money are to be realized if T&S infrastructure developed as a "right sized" shared regional network.
- Risk allocation and 3rd party access rights
 - Who takes the risk of developing the right sized infrastructure and who benefits from access rights? (unlikely to be a single generator)
 - Who takes the risk with respect to future demand for CO₂ storage capacity? (dependent upon government policies)
 - Who takes the performance risk of the T&S assets including storage risks? (too big to fail?)
- T&S charging methodology for anchor and follow-on projects.
 - Through users or separate funding approach for T&S infrastructure?
 - Average or incremental pricing approach?



3. Oversizing and sharing T&S infrastructure

T&S infrastructure : **considerations**

- T&S needs to be developed along the lines of regional networks and needs planning to achieve economies of scale and optimum deployment:
 - Regional potential for CO₂ capture clusters including power and industrial emitters
 - Storage locations, capacity and development, including EOR/EGR potential
 - Infrastructure sizing, routing and build-out program.
- High up-front development costs especially for storage
 - Will require some level of financial support, especially with uncertainty over CCS future
- T&S providers will very likely require a degree of risk insulation:
 - Revenue certainty for failure of CCS market to develop or failure/default of user(s)
 - Long term CO₂ storage risks
 - Change in market circumstances, e.g. change in Law
- Up front clarity on 3rd party access, charging methodology, funding approach, etc.



4. Insurance

Potential insurance gaps: **challenges**

- Construction phase:
 - Adequacy of insurance coverage for CCS related risks was not confirmed, e.g. Delayed Start-up (DS) coverage for CCS specific equipment and for offshore risks.
- Operational phase:
 - Insurance coverage was not available for storage risk.
 - Adequacy of insurance coverage for CCS related risks was not confirmed, e.g. Business Interruption (BI) coverage for CCS specific equipment and offshore risks.
 - Longer-term market-appetite for operational insurances could only be assessed after operational feedback from one or more projects available.



CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

21

4. Insurance

Potential insurance gaps: **considerations**

- UK DECC had proposed mechanisms to share costs associated with impact from specific CCS related construction and operational risks .
- Mechanisms were under discussion to address the storage risk and the financial instrument requirements of the EU CCS directive:
 - Establishment of a specific ring-fenced storage risk mitigation fund built over the initial operational years and maintained until handing back of the store.
 - Potential government support backing shortfalls that cannot be covered through the fund.
- Discussions were ongoing with DECC in relation to the concept of “insurer of last resort”, however the need had not been fully established or agreed.
- These mechanisms may be beneficial to support initial CCS projects more widely until an insurance market is adequately developed particularly for “CCS” risks.
- In the UK a regulated utility model for T&S infrastructure could be developed to include cost recovery for certain risks which are not adequately insured.



22

Key Take-aways



Key take-aways

- There were no significant technical impediments to project implementation.
 - Limited benefits from further R&D for oxy-fuel based CCS
- Full-chain aspects were adequately defined and developed:
 - Basis of design
 - Interfaces
 - Metering & monitoring
 - Commissioning
 - Operation & controls etc.
- large-scale commercialization projects the next logical step in the technology development road-map.
- UK Government decision to cancel the UK CCS Competition has stalled commercialization in the UK and Europe and dented confidence in CCS



Key take-aways

- CCS can be competitive with other forms of low-carbon generation including renewables and new nuclear
- Deployment of appropriate commercial structures key to enabling large-scale roll-out of flexible or base-load CCS:
 - De-link generation business models from potential T&S impact and vice versa.
 - Government support desirable for cross chain default and storage risk, at least for the initial projects.
 - Non-EOR storage is a low-return waste disposal business; de-risking the business key for attracting private sector investments.
- To achieve economies of scale and compete with other clean energy technologies T&S infrastructure needs to be right-sized and planned, considering:
 - Regional requirements, clusters and storage locations and capacities
 - Potential CO₂ uses (EOR/EGR)
- Long-term policy certainty and consistency essential for attracting investments.





CCS Cost Network Workshop – MIT White Rose

March 22-23 2016

25



The Value of Flexible, Firm Capacity on a Decarbonised Grid






Key Messages


A zero- or very low- carbon system with weather dependent renewables needs low carbon technologies to provide firm capacity



Policy makers and system operators need to value services that ensure grid stability so new providers feel a market



A holistic approach to system cost would better recognise the importance of firm low carbon technologies and the cost of balancing the system



ERP Modelling

ERP modelling stacked generation to meet demand exploring different mixes of low carbon technologies on the system. It met the following criteria on an hourly basis:

- Energy balancing – nearly all modelling does this, at least on an annual basis
- Sufficient firm capacity – ensures peak demand can be met
- Sufficient flexibility – the model ensures there's sufficient reserve, response and inertia at all times.

Energy Research Partnership




Firm Zero-C Capacity

A zero- or very low- carbon system with weather dependent renewables needs low carbon technologies to provide firm capacity



Policy makers and system operators need to value services that ensure grid stability so new providers feel a market



A holistic approach to system cost would better recognise the importance of firm low carbon technologies and the cost of balancing the system




Energy Research Partnership



The need for firm capacity



With no new nuclear (or any other zero carbon firm capacity), the best that 60 GW of onshore wind can achieve is about 170 g/kWh



Infinite storage or demand side response could improve that to 133 g/kWh



If wind build didn't exceed the National Renewable Energy Action Plan then 23 GW of nuclear would achieve 50 g/kWh

Building 20 GW of nuclear means 50 g/kWh can be achieved with 42 GW of onshore wind






Energy Research Partnership




Load Duration for 80-100% Renewable



Energy Research Partnership



Role for Storage



Scenario: There's sufficient weather dependent renewables to meet demand, PV and Wind balanced to eliminate summer/winter imbalance
 For storage to eliminate fossil (or other firm capacity) would require ~15GW to hold ~8 TWh ready for lulls in output with 1-2 cycles p.a.
 Hence providing security is probably not best role for storage
 But 25 cycles above, or diurnal cycles or reserve, response or inertia may be.

Energy Research Partnership




Valuing Flexibility

A zero- or very low- carbon system with weather dependent renewables needs low carbon technologies to provide firm capacity



Policy makers and system operators need to value services that ensure grid stability so new providers feel a market



A holistic approach to system cost would better recognise the importance of firm low carbon technologies and the cost of balancing the system



Energy Research Partnership



Essential Grid Services



Short Term Operating Reserve (STOR) is available within 5-20 minutes of instruction, although some can be as long as 4 hours. This provides a longer term replacement for the lost generation

Generator loss incident
1000MW is lost at 13:43. Frequency drops to 49.6 Hz before recovery begins. Statutory limit is 49.5 Hz.



Inertia slows the fall in frequency immediately after an incident, buying time for frequency response services to act

Fast Reserve is available to replace plant that was on frequency control and aid recovery by increasing generation within 2 minutes of instruction

Frequency response automatically increases generation or decreases demand to begin recovery. Acts in 10-30s window (primary) or 30s-30m window (secondary)

There are 22* ancillary services NG buy, but these four are key for energy balancing + the need for firm capacity > peak demand

* Others include: voltage control; MaxGen, warming and fast start contracts for fossil; intertrips; transmission constraint agreements; SO to SO (interconnector) services; black start.





The Need for a Holistic Approach

Traditional approach – all that matters is delivery of energy so calculate the levelised cost of energy.

Example using DECC costs

$$\text{LCOE} = \frac{\text{all costs annualised}^*}{\text{annual energy production}^*}$$

* These can be reduced with an annual discount factor

LCOE		£/MWh
1 st	Wind	81
2 nd	Nuclear	87
3 rd	Gas-CCS	91

This is simple and **works well for conventional thermal & hydro** comparisons – When energy is delivered they can all offer other services:

- flexibility (load following, reserve, response)
- inertia
- firm capacity

However this doesn't work for technologies


- that only deliver some of these services
- deliver no energy
- increase the need for some grid services

- Wind
- PV
- Nuclear
- Storage
- Demand Resp.
- Interconnectors



Key Messages



A **holistic approach** to system cost would better recognise the importance of firm low carbon technologies and the cost of balancing the system



Tech.	Additional services provided / increased need			Traditional LCOE (£/MWh)	Holistic: Reduction in system cost	
	Provides Flexibility	Inertia	Firm Cap.		Net Value to pure gas sys. (£/MWh)	Net Value to Sys with 30 GW wind (£/MWh)
Nuclear	doubtful	yes	yes	87	11	8
Wind	demands	very little	very little	81	3	17
Gas-CCS	yes	yes	yes	91	6	4

- Previous 1st choice is different
- Value changes with the system
- Diminishing returns effect

The values here are not important, but it illustrates fact that the holistic approach values CCS firmness and flexibility



Energy Research Partnership



Could UK Have it's Own EnergieWende?


In essence – **yes** – UK needs a strategic narrative:

- Public engagement
- Policy Stability
- Investor Confidence

<http://erpuk.org/project/public-engagement/>




The same as Germany's – **no** – GB & German systems and objectives are chalk & cheese



Energy Research Partnership



Germany





Key Messages

A zero- or very low- carbon system with weather dependent renewables needs companion low carbon technologies to provide firm capacity

- Cannot decarbonise to 50 g/kWh by weather dependent renewables alone
- Storage, demand side & interconnection help
- 15-20GW of new nuclear, biomass or fossil CCS is essential
- Provides clean supply for dark, windless weeks

Policy makers and system operators need to value services that ensure grid stability so new providers feel a market

- Some necessary services (e.g. inertia/frequency response) are free or mandated
- Demand for them is growing
- Traditional providers (fossil) are disappearing
- Weather dependent renewables are not consistent suppliers
- New providers can't develop with no market

A holistic approach to system cost would better recognise the importance of firm low carbon technologies and the cost of balancing the system

- The value of a technology is dependent on
 - the existing generation mix
 - the grid services it provides
- So it cannot be valued by a single number such as levelised cost of energy (LCOE)




2016 MIT CCS Cost Network Workshop Cambridge, MA

Neil Kern, March 22, 2016

Moving toward a lower carbon footprint and increased fuel diversity



Total Company Fuel Diversity (MWh Output)⁽¹⁾



Reduction of US Generation Emissions from
2005-2014³

CO₂ ↓ 19% SO₂ ↓ 85% NO_x ↓ 64%

- Additions of pollution control equipment
- Retirement of higher emitting plants
- Decreased coal generation
- Increased gas generation

Total Company Carbon Intensity⁽⁴⁾

2006 1.27 lbs/kwh ↓ 17% 2014 1.06 lbs/kwh ↓ 6-15% 2020 (Est.) 0.9-1 lbs/kwh

Key Takeaways

- Greater diversification of generation mix by 2020
- Expected 33% decrease in coal between 2014 and 2020
- Expected 27% increase in natural gas/oil between 2014 and 2020


⁽¹⁾ 2020 estimate does not reflect the recently-finalized EPA Clean Power Plan

⁽²⁾ 2006 data does not include Progress Energy

⁽³⁾ The divestment of our non-regulated Midwest coal and natural gas generation in April 2015 further reduces total CO₂ emission to 22%, SO₂ emissions to 86%, and NO_x emissions to 65% from the 2005 to 2014 timeframe


⁽⁴⁾ 2020 carbon intensity range could be impacted by customer demand, generation mix, weather, fuel availability and prices

2




Utility Planning for the Future

- Paradigm shift from how traditional utility planning takes place.




- Distribution planning could significantly influence generation planning in the future.
- Generation must be able to serve the grid and respond quickly to changing grid signals.
- Must maintain the goal of providing reliable electricity to customers at all times.

Flexibility Overview




Value of Firm Capacity of Central Generation



Conclusion

- Currently, there is no standard metric for quantifying the value of flexibility.
- Central generation has a place in the future but its role will be significantly different (i.e. more flexible)
- CCS technology must not hinder flexibility.
- Explore non-traditional markets for central stations (polygen, CHP, desalinization, etc.)
- Technologies must be economically competitive to justify ongoing O&M spend.



7



8

INTERNATIONAL ENERGY AGENCY GREENHOUSE GAS PROGRAMME
CHELTENHAM, UK
www.ieaghg.org

